

November 28, 1983

Docket No. 50-324

Mr. E. E. Utley
Executive Vice President
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602

Dear Mr. Utley:

The Commission has issued the enclosed Amendment No. 83 to Facility Operating License No DPR-62 for the Brunswick Steam Electric Plant, Unit 2. The amendment consists of changes to the Technical Specifications in response to your application of July 29, 1983.

The amendment changes the Unit 2 Technical Specifications to revise control rod scram insertion times, increase certain limiting values of the Minimum Critical Power Ratio and delete references to 7X7 type fuel assemblies.

A copy of the related Safety Evaluation is also enclosed.

Sincerely,

Original signed by/

Marshall Grotenhuis, Project Manager
Operating Reactors Branch #2
Division of Licensing

Enclosures:

- 1. Amendment No. 83 to License No. DPR-62
- 2. Safety Evaluation

cc w/enclosures:
See next page

DISTRIBUTION

Docket File
NRC PDR
Local PDR
ORB#2 Reading
DEisenhut
SNorris
MGrotenhuis
OELD
SECY
LJHarmon

ELJordan
JMTaylor
TBarnhart (4)
WJones
DBrinkman
SSun
ACRS (10)
OPA, CMiles
RDiggs
NSIC

Gray File
Extra - 5
HDenton
WHouston

Don't forget to check with Gove & O'Connell for utilities & compare before response

DL:ORB#2
SNorris:ajs
10/25/83

H
DL:ORB#2
MGrotenhuis
10/1/83

SM
DL:ORB#2
SMackKay
10/31/83

DR
DL:ORB#2
DVassallo
10/1/83

DL:AD-OR
GLainas
10/23/83

DL:AD-OR
WHouston
10/14/83
OZLD
H. Farman
10/9/83
ML

Mr. E. E. Utley
Carolina Power & Light Company
Brunswick Steam Electric Plant, Units 1 and 2

cc:

Richard E. Jones, Esquire
Carolina Power & Light Company
336 Fayetteville Street
Raleigh, North Carolina 27602

George F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. Charles R. Dietz
Plant Manager
Post Office Box 458
Southport, North Carolina 28461

Mr. Franky Thomas, Chairman
Board of Commissioners
Post Office Box 249
Bolivia, North Carolina 28422

Mrs. Chrys Baggett
State Clearinghouse
Budget and Management
116 West Jones Street
Raleigh, North Carolina 27603

U. S. Environmental Protection
Agency
Region IV Office
Regional Radiation Representative
345 Courtland Street, N. W.
Atlanta, Georgia 30308

Resident Inspector
U. S. Nuclear Regulatory Commission
Post Office Box 1057
Southport, North Carolina 28461

James P. O'Reilly
Regional Administrator
Region II Office
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dayne H. Browns, Chief
Radiation Protection Branch
Division of Facility Services
Department of Human Resources
Post Office Box 12200
Raleigh, North Carolina 27605



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

CAROLINA POWER & LIGHT COMPANY

DOCKET NO. 50-324

BRUNSWICK STEAM ELECTRIC PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 83
License No. DPR-62

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Carolina Power & Light Company (the licensee) dated July 29, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-62 is hereby amended to read as follows:

8312090089 831128
PDR ADOCK 05000324
P PDR

2. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 83, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Attachment:
Changes to the
Technical Specifications

Date of Issuance: November 28, 1983

ATTACHMENT TO LICENSE AMENDMENT NO. 83

FACILITY OPERATING LICENSE NO. DPR-62

DOCKET NO. 50-324

Revise the Appendix A Technical Specifications as indicated below. The changed areas are indicated by vertical lines.

Remove

IV

3/4 1-6

3/4 1-7

3/4 2-1 thru 3/4 2-15

B 3/4 2-1

B 3/4 2-2

B 3/4 2-3

B 3/4 2-5

Insert

IV

3/4 1-6

3/4 1-7

3/4 2-1 thru 3/4 2-15

B 3/4 2-1

B 3/4 2-2

B 3/4 2-3

~~B 3/4 2-5~~

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.0 APPLICABILITY</u>	3/4 0-1
<u>3/4.1 REACTIVITY CONTROL SYSTEMS</u>	
3/4.1.1 SHUTDOWN MARGIN.....	3/4 1-1
3/4.1.2 REACTIVITY ANOMALIES.....	3/4 1-2
3/4.1.3 CONTROL RODS	
Control Rod Operability.....	3/4 1-3
Control Rod Maximum Scram Insertion Times.....	3/4 1-5
Control Rod Average Scram Insertion Times.....	3/4 1-6
Four Control Rod Group Insertion Times.....	3/4 1-7
Control Rod Scram Accumulators.....	3/4 1-8
Control Rod Drive Coupling.....	3/4 1-9
Control Rod Position Indication.....	3/4 1-11
Control Rod Drive Housing Support.....	3/4 1-13
3/4.1.4 CONTROL ROD PROGRAM CONTROLS	
Rod Worth Minimizer.....	3/4 1-14
Rod Sequence Control System.....	3/4 1-15
Rod Block Monitor.....	3/4 1-17
3/4.1.5 STANDBY LIQUID CONTROL SYSTEM.....	3/4 1-18
<u>3/4.2 POWER DISTRIBUTION LIMITS</u>	
3/4.2.1 AVERAGE PLANAR LINEAR HEAT GENERATION RATE.....	3/4 2-1
3/4.2.2 APRM SETPOINTS.....	3/4 2-8
3/4.2.3 MINIMUM CRITICAL POWER RATIO.....	3/4 2-9
3/4.2.4 LINEAR HEAT GENERATION RATE.....	3/4 2-15

REACTIVITY CONTROL SYSTEMS

CONTROL ROD AVERAGE SCRAM INSERTION TIMES

LIMITING CONDITIONS FOR OPERATION

3.1.3.3 The average scram insertion time of all OPERABLE control rods from the fully withdrawn position, based on de-energization of the scram pilot valve solenoids as time zero, shall not exceed any of the following:

<u>Position Inserted From Fully Withdrawn</u>	<u>Average Scram Inser- tion Time (Seconds)</u>
46	0.31
36	1.05
26	1.82
6	3.37

APPLICABILITY: OPERATIONAL CONDITIONS 1 and 2.

ACTION:

With the average scram insertion time exceeding any of the above limits, be in at least HOT SHUTDOWN within 12 hours.

SURVEILLANCE REQUIREMENTS

4.1.3.3 All control rods shall be demonstrated OPERABLE by scram time testing from the fully withdrawn position as required by Surveillance Requirement 4.1.3.2.

REACTIVITY CONTROL SYSTEMS

FOUR CONTROL ROD GROUP SCRAM INSERTION TIMES

LIMITING CONDITION FOR OPERATION

3.1.3.4 The average scram insertion time, from the fully withdrawn position, for the three fastest control rods in each group of four control rods arranged in a two-by-two array, based on deenergization of the scram pilot valve solenoids as time zero, shall not exceed any of the following:

<u>Position Inserted From Fully Withdrawn</u>	<u>Average Scram Inser- tion Time (Seconds)</u>
46	0.33
36	1.12
26	1.93
6	3.58

APPLICABILITY: OPERATIONAL CONDITIONS 1 and 2.

ACTION:

With the average scram insertion times of control rods exceeding the above limits, operation may continue and the provisions of Specification 3.0.4 are not applicable provided:

- a. The control rods with the slower than average scram insertion times are declared inoperable,
- b. The requirements of Specification 3.1.3.1 are satisfied, and
- c. The Surveillance Requirements of Specification 4.1.3.2.c are performed at least once per 92 days when operation is continued with three or more control rods with slow scram insertion times.

Otherwise, be in at least HOT SHUTDOWN within the next 12 hours.

SURVEILLANCE REQUIREMENTS

4.1.3.4 All control rods shall be demonstrated OPERABLE by scram time testing from the fully withdrawn position as required by Surveillance Requirement 4.1.3.2.

3/4.2 POWER DISTRIBUTION LIMITS

3/4.2.1 AVERAGE PLANAR LINEAR HEAT GENERATION RATE

LIMITING CONDITION FOR OPERATION

3.2.1 All AVERAGE PLANAR LINEAR HEAT GENERATION RATES (APLHGR's) for each type of fuel as a function of AVERAGE PLANAR EXPOSURE shall not exceed the following limits:

- a. During two recirculation loop operation, the limits are shown in Figures 3.2.1-1, 3.2.1-2, 3.2.1-3, 3.2.1-4, 3.2.1-5, and 3.2.1-6.


APPLICABILITY: OPERATIONAL CONDITION 1, when THERMAL POWER is greater than or equal to 25% of RATED THERMAL POWER.

ACTION: With an APLHGR exceeding the limits of Figures 3.2.1-1, 3.2.1-2, 3.2.1-3, 3.2.1-4, 3.2.1-5, and 3.2.1-6, initiate corrective action within 15 minutes and continue corrective action so that APLHGR is within the limit within 4 hours or reduce THERMAL POWER to less than 25% of RATED THERMAL POWER within the next 4 hours.

SURVEILLANCE REQUIREMENTS


4.2.1 All APLHGR's shall be verified to be equal to or less than the applicable limit determined from Figures 3.2.1-1, 3.2.1-2, 3.2.1-3, 3.2.1-4, 3.2.1-5, and 3.2.1-6:

- a. At least once per 24 hours,
- b. Within 12 hours after completion of a THERMAL POWER increase of at least 15% of RATED THERMAL POWER, and
- c. Initially and at least once per 12 hours when the reactor is operating with a LIMITING CONTROL ROD PATTERN for APLHGR.




FUEL TYPE 8D274L (8X8)
MAXIMUM AVERAGE PLANAR LINEAR HEAT
GENERATION RATE (MAPLHGR)
VERSUS AVERAGE PLANAR EXPOSURE

FIGURE 3.2.1-1




FUEL TYPE 8D274H (8X8)
MAXIMUM AVERAGE PLANAR LINEAR HEAT
GENERATION RATE (MAPLHGR)
VERSUS AVERAGE PLANAR EXPOSURE

FIGURE 3.2.1-2




FUEL TYPE 8DRB265H (8X8R)
MAXIMUM AVERAGE PLANAR LINEAR HEAT
GENERATION RATE (MAPLHGR)
VERSUS AVERAGE PLANAR EXPOSURE

FIGURE 3.2.1-3




FUEL TYPE 8DRB283 (8X8R)
MAXIMUM AVERAGE PLANAR LINEAR HEAT
GENERATION RATE (MAPLHGR)
VERSUS AVERAGE PLANAR EXPOSURE

FIGURE 3.2.1-4



FUEL TYPE P8DRB265H (P8X8R)
MAXIMUM AVERAGE PLANAR LINEAR HEAT
GENERATION RATE (MAPLHGR)
VERSUS PLANAR AVERAGE EXPOSURE

FIGURE 3.2.1-5



FUEL TYPE P8DRB284H (P8X8R)
MAXIMUM AVERAGE PLANAR LINEAR HEAT
GENERATION RATE (MAPLHGR)
VERSUS AVERAGE PLANAR EXPOSURE

FIGURE 3.2.1-6

POWER DISTRIBUTION LIMITS

3/4.2.2 APRM SETPOINTS

LIMITING CONDITION FOR OPERATION

3.2.2 The flow-biased APRM scram trip setpoint (S) and rod block trip setpoint (S_{RB}) shall be established according to the following relationships:

$$S \leq (0.66W + 54\%) T$$

$$S_{RB} \leq (0.66W + 42\%) T$$

where: S and S_{RB} are in percent of RATED THERMAL POWER,
W = Loop recirculation flow in percent of rated flow,
T = Lowest value of the ratio of design TPF divided by the MTPF obtained for any class of fuel in the core ($T \leq 1.0$), and

Design TPF for: P8 X 8R fuel = 2.39
8 X 8R fuel = 2.39
8 X 8 fuel = 2.43

APPLICABILITY: OPERATIONAL CONDITION 1, when THERMAL POWER is greater than or equal to 25% of RATED THERMAL POWER.

ACTION:

With S or S_{RB} exceeding the allowable value, initiate corrective action within 15 minutes and continue corrective action so that S and S_{RB} are within the required limits within 4 hours, or reduce THERMAL POWER to less than 25% of RATED THERMAL POWER within the next 4 hours.

SURVEILLANCE REQUIREMENTS

4.2.2 The MTPF for each class of fuel shall be determined, the value of T calculated, and the flow-biased APRM trip setpoint adjusted, as required:

- a. At least once per 24 hours,
- b. Within 12 hours after completion of a THERMAL POWER increase of at least 15% of RATED THERMAL POWER, and
- c. Initially and at least once per 12 hours when the reactor is operating with a LIMITING CONTROL ROD PATTERN for MTPF.

POWER DISTRIBUTION LIMITS

3/4.2.3 MINIMUM CRITICAL POWER RATIO

LIMITING CONDITION FOR OPERATION

3.2.3.1 The MINIMUM CRITICAL POWER RATIO (MCPR), as a function of core flow, shall be equal to or greater than the MCPR limit times the K_f shown in Figure 3.2.3-1, provided that the end-of-cycle recirculation pump trip system is OPERABLE per specification 3.3.6.2, with:

- a. If ODYN OPTION A analyses are in effect, the MCPR limits are listed below:
 1. MCPR for 8x8 fuel = 1.29
 2. MCPR for 8x8R fuel = 1.27
 3. MCPR for P8x8R fuel = 1.29

- b. If ODYN OPTION B analyses are in effect (refer to Specification 3.2.3.2), the MCPR limits are listed below:
 1. MCPR for 8x8 fuel = 1.29
 2. MCPR for 8x8R fuel = 1.21
 3. MCPR for P8x8R fuel = 1.22

APPLICABILITY: OPERATIONAL CONDITION 1 when THERMAL POWER is greater than or equal to 25% RATED THERMAL POWER

ACTION:

- a. With the end-of-cycle recirculation trip system inoperable per Specification 3.3.6.2, operation may continue and the provisions of Specification 3.0.4 are not applicable with the following MCPR limit adjustments:
 1. Beginning-of-cycle (BOC) to end-of-cycle (EOC) minus 2000 MWD/t, within one hour determine that MCPR, as a function of core flow, is equal to or greater than the MCPR limit times the K_f shown in Figure 3.2.3-1 with:
 - a. If ODYN OPTION A analyses are in effect, the MCPR limits are listed below:
 1. MCPR for 8x8 fuel = 1.29
 2. MCPR for 8x8R fuel = 1.26
 3. MCPR for P8x8R fuel = 1.28

 - b. If ODYN OPTION B analyses are in effect (refer to Specification 3.2.3.2), the MCPR limits are listed below:
 1. MCPR for 8x8 fuel = 1.29
 2. MCPR for 8x8R fuel = 1.25
 3. MCPR for P8x8R fuel = 1.28

POWER DISTRIBUTION LIMITS

LIMITING CONDITION FOR OPERATION (Continued)

ACTION (Continued)

2. EOC minus 2000 MWD/t to EOC, within one hour determine that MCPR, as a function of core flow, is equal to or greater than the MCPR limit times the K_f shown in Figure 3.2.3-1 with:
 - a. If ODYN OPTION A analyses are in effect, the MCPR limits are listed below:
 1. MCPR for 8x8 fuel = 1.37
 2. MCPR for 8x8R fuel = 1.38
 3. MCPR for P8x8R fuel = 1.41
 - b. If ODYN OPTION B analyses are in effect (refer to Specification 3.2.3.2), the MCPR limits are listed below:
 1. MCPR for 8x8 fuel = 1.29
 2. MCPR for 8x8R fuel = 1.26
 3. MCPR for P8x8R fuel = 1.29
- b. With MCPR, as a function of core flow, less than the applicable limit determined from Figure 3.2.3-1 initiate corrective action within 15 minutes and restore MCPR to within the applicable limit within 4 hours or reduce THERMAL POWER to less than 25% of RATED THERMAL POWER within the next 4 hours.

SURVEILLANCE REQUIREMENTS

- 4.2.3.1 MCPR, as a function of core flow, shall be determined to be equal to or greater than the applicable limit determined from Figure 3.2.3-1:
- a. At least once per 24 hours,
 - b. Within 12 hours after completion of a THERMAL POWER increase of at least 15% of RATED THERMAL POWER, and
 - c. Initially and at least once per 12 hours when the reactor is operating in a LIMITING CONTROL ROD PATTERN for MCPR.

POWER DISTRIBUTION LIMITS

3/4.2.3 MINIMUM CRITICAL POWER RATIO (ODYN OPTION B)

LIMITING CONDITION FOR OPERATION

3.2.3.2 For the OPTION B MCPR limits listed in Specification 3.2.3.1 to be used, the cycle average 20% scram time (τ_{ave}) shall be less than or equal to the Option B scram time limit (τ_B), where τ_{ave} and τ_B are determined as follows:

$$\tau_{ave} = \frac{\sum_{i=1}^n N_i \tau_i}{\sum_{i=1}^n N_i}, \text{ where:}$$

- i = Surveillance test number,
- n = Number of surveillance tests performed to date in the cycle (including BOC),
- N_i = Number of rods tested in the i^{th} surveillance test, and
- τ_i = Average scram time to notch 36 for surveillance test i

$$\tau_B = \mu + 1.65 \left(\frac{N_1}{\sum_{i=1}^n N_i} \right)^{1/2} (\sigma), \text{ where:}$$

- i = Surveillance test number
- n = Number of surveillance tests performed to date in the cycle (including BOC),
- N_i = Number of rods tested in the i^{th} surveillance test
- N_1 = Number of rods tested at BOC,
- μ = 0.834 seconds
(mean value for statistical scram time distribution from de-energization of scram pilot valve solenoid to pickup on notch 36),
- σ = 0.059 seconds
(standard deviation of the above statistical distribution).

APPLICABILITY: OPERATIONAL CONDITION 1, when THERMAL POWER is greater than or equal to 25% RATED THERMAL POWER.

POWER DISTRIBUTION LIMITS

LIMITING CONDITION FOR OPERATION (Continued)

ACTION:

Within twelve hours after determining that τ_{ave} greater than τ_B , the operating limit MCPRs shall be either:

- a. Adjusted for each fuel type such that the operating limit MCPR is the maximum of the non-pressurization transient MCPR operating limit (from Table 3.2.3.2-1) or the adjusted pressurization transient MCPR operating limits, where the adjustment is made by:

$$MCPR_{adjusted} = MCPR_{option B} + \frac{\tau_{ave} - \tau_B}{\tau_A - \tau_B} (MCPR_{option A} - MCPR_{option B})$$

where: τ_A = 1.05 seconds, control rod average scram insertion time limit to notch 36 per Specification 3.1.3.3,
MCPR_{option A} = Determined from Table 3.2.3.2-1,
MCPR_{option B} = Determined from Table 3.2.3.2-1, or

- b. The OPTION A MCPR limits listed in Specification 3.2.3.1.

SURVEILLANCE REQUIREMENTS

4.2.3.2 The values of τ_{ave} and τ_B shall be determined and compared each time a scram time test is performed. The requirement for the frequency of scram time testing shall be identical to Specification 4.1.3.2.

TABLE 3.2.3.2-1

TRANSIENT OPERATING LIMIT MCPR VALUES

TRANSIENT	FUEL TYPE					
	8x8		8x8R		P8x8R	
NONPRESSURIZATION TRANSIENTS						
With RPT operable (op.)	1.29		1.21		1.22	
With RPT inoperable (inop.)	1.29		1.25		1.28	
TURBINE TRIP/LOAD REJECT WITHOUT BYPASS						
	MCPR _A	MCPR _B	MCPR _A	MCPR _B	MCPR _A	MCPR _B
RPT (op.)	1.27	1.19	1.27	1.19	1.29	1.21
RPT (inop.) BOC → EOC - 2000	1.25	1.08	1.26	1.08	1.28	1.09
RPT (inop.) EOC - 2000 → EOC	1.37	1.25	1.38	1.26	1.41	1.29
FEEDWATER CONTROL FAILURE						
	MCPR _A	MCPR _B	MCPR _A	MCPR _B	MCPR _A	MCPR _B
RPT (op.)	1.19	1.16	1.19	1.16	1.19	1.16
RPT (inop.) BOC → EOC - 2000	1.18	1.12	1.19	1.13	1.19	1.13
RPT (inop.) EOC - 2000 → EOC	1.18	1.12	1.18	1.12	1.19	1.13

BRUNSWICK-UNIT 2

3/4 2-14

AMENDMENT NO. 83




FIGURE 3.2.3-1

POWER DISTRIBUTION LIMITS

3/4.2.4 LINEAR HEAT GENERATION RATE

LIMITING CONDITION FOR OPERATION

3.2.4 The LINEAR HEAT GENERATION RATE (LHGR) shall not exceed 13.4 kw/ft for 8 X 8, 8 X 8R, and P8 X 8R fuel assemblies.

APPLICABILITY: OPERATIONAL CONDITION 1, when THERMAL POWER is greater than or equal to 25% of RATED THERMAL POWER.

ACTION:

With the LHGR of any fuel rod exceeding the above limits, initiate corrective action within 15 minutes and continue corrective action so that the LHGR is within the limit within 4 hours, or reduce THERMAL POWER to less than 25% of RATED THERMAL POWER within the next 4 hours.

SURVEILLANCE REQUIREMENTS

4.2.4 LHGRs shall be determined to be equal to or less than the applicable above limit:

- a. At least once per 24 hours,
- b. Within 12 hours after completion of a THERMAL POWER increase of at least 15% of RATED THERMAL POWER, and
- c. Initially and at least once per 12 hours when the reactor is operating on a LIMITING CONTROL ROD PATTERN for LHGR.

3/4.2 POWER DISTRIBUTION LIMITS

BASES

The specifications of this section assure that the peak cladding temperature following the postulated design basis loss-of-coolant accident will not exceed the 2200°F limit specified in the Final Acceptance Criteria (FAC) issued in June 1971 considering the postulated effects of fuel pellet densification.

3/4.2.1 AVERAGE PLANAR LINEAR HEAT GENERATION RATE

This specification assures that the peak cladding temperature following the postulated design basis loss-of-coolant accident will not exceed the limit specified in 10 CFR 50, Appendix K.

The peak cladding temperature (PCT) following a postulated loss-of-coolant accident is primarily a function of the average heat generation rate of all the rods of a fuel assembly at any axial location and is dependent only secondarily on the rod-to-rod power distribution within a assembly. The peak cladding temperature is calculated assuming a LHGR for the highest-powered rod which is equal to or less than the design LHGR corrected for densification. This LHGR times 1.02 is used in the heatup code along with the exposure-dependent steady state gap conductance and rod-to-rod local peaking factor. The Technical Specification APHGR is this LHGR of the highest-powered rod divided by its local peaking factor. The limiting value for APLHGR is shown in Figures 3.2.1-1, 3.2.1-2, 3.2.1-3, 3.2.1-4, 3.2.1-5, and 3.2.1-6.

The calculational procedure used to establish the APLHGR shown on Figures 3.2.1-1, 3.2.1-2, 3.2.1-3, 3.2.1-4, 3.2.1-5, and 3.2.1-6 is based on a loss-of-coolant accident analysis. The analysis was performed using General Electric (GE) calculational models which are consistent with the requirements of Appendix K to 10 CFR 50. A complete discussion of each code employed in the analysis is presented in Reference 1. Differences in this analysis compared to previous analyses performed with Reference 1 are (1) The analysis assumes a fuel assembly planar power consistent with 102% of the MAPLHGR shown in Figures 3.2.1-1, 3.2.1-2, 3.2.1-3, 3.2.1-4, 3.2.1-5, and 3.2.1-6; (2) Fission product decay is computed assuming an energy release rate of 200 MeV/Fission; (3) Pool boiling is assumed after nucleate boiling is lost during the flow stagnation period; and (4) The effects of core spray entrainment and countercurrent flow limitation as described in Reference 2, are included in the reflooding calculations.

A list of the significant plant input parameters to the loss-of-coolant accident analysis is presented in Bases Table B 3.2.1-1.

Bases Table B 3.2.1-1
SIGNIFICANT INPUT PARAMETERS TO THE
LOSS-OF-COOLANT ACCIDENT ANALYSIS
FOR BRUNSWICK - UNIT 2

Plant Parameters;

Core Thermal Power	2531 Mwt which corresponds to 105% of rated steam flow
Vessel Steam Output	10.96 x 10 ⁶ Lbm/h which corresponds to 105% of rated steam flow
Vessel Steam Dome Pressure	1055 psia
Recirculation Line Break Area for Large Breaks	
a. Discharge	2.4 ft ² (DBA); 1.9 ft ² (80% DBA)
b. Suction	4.2 ft ²
Number of Drilled Bundles	520

Fuel Parameters:

FUEL TYPES	FUEL BUNDLE GEOMETRY	PEAK TECHNICAL SPECIFICATION LINEAR HEAT GENERATION RATE (kw/ft)	DESIGN AXIAL PEAKING FACTOR	INITIAL MINIMUM CRITICAL POWER** RATIO
Reload Core	8 x 8	13.4	1.4	1.20

A more detailed list of input to each model and its source is presented in Section II of Reference 1.

* This power level meets the Appendix K requirement of 102%.

** To account for the 2% uncertainty in bundle power required by Appendix K, the SCAT calculation is performed with an MCPR of 1.18 (i.e., 1.2 divided by 1.02) for a bundle with an initial MCPR of 1.20.

POWER DISTRIBUTION LIMITS

BASES

3/4.2.2 APRM SETPOINTS

The fuel cladding integrity Safety Limits of Specification 2.1 were based on a TOTAL PEAKING FACTOR of 2.43 for 8 x 8 fuel, 2.39 for 8 x 8R fuel and 2.39 for P8 x 8R fuel. The scram setting and rod block functions of the APRM instruments must be adjusted to ensure that the MCPR does not become less than 1.0 in the degraded situation. The scram settings and rod block settings are adjusted in accordance with the formula in this specification when the combination of THERMAL POWER and peak flux indicates a TOTAL PEAKING FACTOR greater than 2.43 for 8 x 8 fuel, 2.39 for 8 x 8R and 2.39 for P8 x 8R fuel. This adjustment may be accomplished by increasing the APRM gain and thus reducing the slope and intercept point of the flow referenced APRM high flux scram curve by the reciprocal of the APRM gain change. The method used to determine the design TPF shall be consistent with the method used to determine the MTPF.

3/4.2.3 MINIMUM CRITICAL POWER RATIO

The required operating limit MCPRs at steady state operating conditions as specified in Specification 3.2.3 are derived from the established fuel cladding integrity Safety Limit MCPR of 1.07, and an analysis of abnormal operational transients.⁽¹⁾ For any abnormal operating transient analysis evaluation with the initial condition of the reactor being at the steady state operating limit, it is required that the resulting MCPR does not decrease below the Safety Limit MCPR at any time during the transient, assuming an instrument trip setting as given in Specification 2.2.1.

To assure that the fuel cladding integrity Safety Limit is not exceeded during any anticipated abnormal operational transient, the most limiting transients have been analyzed to determine which result in the largest reduction in CRITICAL POWER RATIO (CPR). The type of transients evaluated were loss of flow, increase in pressure and power, positive reactivity insertion, and coolant temperature decrease.

The limiting transient which determines the required steady state MCPR limit is the turbine trip with failure of the turbine bypass. This transient yields the largest Δ MCPR. When added to the Safety Limit MCPR of 1.07 the required minimum operating limit MCPR of Specification 3.2.3 is obtained. Prior to the analysis of abnormal operational transients an initial fuel bundle MCPR was determined. This parameter is based on the bundle flow calculated by a GE multichannel steady state flow distribution model as described in Section 4.4 of NEDO-20360⁽⁴⁾ and on core parameters shown in Reference 3, response to Items 2 and 9.

POWER DISTRIBUTION LIMITS

BASES

MINIMUM CRITICAL POWER RATIO (Continued)

For operation in the automatic flow control mode, the same procedure was employed except the initial power distribution was established such that the MCPR was equal to the operating limit MCPR at rated power and flow.

The K_f factors shown in Figure 3.2.3-1 are conservative for the General Electric Plant operation with 8 x 8 and 8 x 8R fuel assemblies because the operating limit MCPRs of Specification 3.2.3 are greater than the original 1.20 operating limit MCPR used for the generic derivation of K_f .

At core thermal power levels less than or equal to 25%, the reactor will be operating at minimum recirculation pump speed and the moderator void content will be very small. For all designated control rod patterns which may be employed at this point, operating plant experience indicated that the resulting MCPR value is in excess of requirements by a considerable margin. With this low void content, any inadvertent core flow increase would only place operation in a more conservative mode relative to MCPR. During initial start-up testing of the plant, a MCPR evaluation will be made at 25% thermal power level with minimum recirculation pump speed. The MCPR margin will thus be demonstrated such that future MCPR evaluation below this power level will be shown to be unnecessary. The daily requirement for calculating MCPR above 25% rated thermal power is sufficient since power distribution shifts are very slow when there have not been significant power or control rod changes. The requirement for calculating MCPR when a limiting control rod pattern is approached ensures that MCPR will be known following a change in power or power shape, regardless of magnitude that could place operation at a thermal limit.

3.2.4 LINEAR HEAT GENERATION RATE

The LHGR specification assures that the linear heat generation rate in any rod is less than the design linear heat generation even if fuel pellet densification is postulated. The power spike penalty specified is based on the analysis presented in Section 3.2.1 of the GE topical report NEDM-10735 Supplement 6, and assumes a linearly increasing variation in axial gaps between core bottom and top, and assures with a 95% confidence that no more than one fuel rod exceeds the design linear heat generation rate due to power spiking.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

SUPPORTING AMENDMENT NO. 83 TO FACILITY LICENSE NO. DPR-62

CAROLINA POWER & LIGHT COMPANY

BRUNSWICK STEAM ELECTRIC PLANT, UNIT 2

DOCKET NO. 50-324

1.0 Introduction

By letter dated July 29, 1983, the Carolina Power & Light Company (the licensee) submitted proposed changes to the technical specifications that would provide more conservative values of the Operating Limit Minimum Critical Power Ratio (OLMCPR), correct errors in control rod insertion times, and delete references to 7X7 fuel assemblies.

2.0 Discussion and Evaluation

The licensee has requested changes to the Technical Specifications to correct an error detected in the reload analysis which was used to determine the OLMCPR for Cycle 5 operation. In support of its proposed changes to the Technical Specifications, the licensee has submitted MCPR data based on the approved General Electric reload methods (Ref. 1). The limiting Cycle 5 pressurization transient (the load rejection without bypass transient) was reanalyzed using the approved and corrected OLYN code. The analytical results show that the operating limit MCPR should be increased by 0.02 for Option A. The OLMCPR should be larger than 1.20, 1.29, 1.26 and 1.28 for 7X7, 8X8, 8X8R and P8X8R types of fuel, respectively. The licensee also indicates that the rod withdrawal error MCPR should be increased by 0.03 for the 8X8R and the P8X8R fuel types to reflect the higher initial MCPR values. The exposure dependent OLMCPRs for both Option A and Option B are indicated in Technical Specification 3.2.3 of the proposed Technical Specification.

The staff has reviewed the Technical Specification changes requested by the licensee. We find that for the determination of the OLMCPR credit is assumed for operation of the highwater level (L8) trip and turbine bypass system. In this regard, we have concluded that this subject should be treated as a generic issue, and we plan to handle it in accordance with our internal procedures for dealing with such issues. We have also determined, based on preliminary analysis, that the risk of operating Brunswick Unit 2 without Technical Specifications concerning surveillance of the highwater level turbine trip or turbine bypass systems until the generic issue is resolved is small. Accordingly, we find that the results of analyses are consistent with the proposed OLMCPRs and safety limit MCPR and conclude that the proposed OLMCPRs are acceptable for operation during the remainder of Cycle 5.

The proposed changes to the Technical Specifications would also revise the control rod scram insertion time requirements listed in Specifications 3.1.3.3. and 3.1.3.4. These time requirements were correct in the original Brunswick custom Technical Specifications where they were listed in terms of rod notch position. Since the rod notch position did not correspond precisely to percent of rod insertion, an offset of some of the scram time limits was erroneously introduced. The change to the scram insertion time specification has been made to reflect the change from notch position to percent of insertion and is acceptable.

The licensee has also requested changes to the technical specifications that would delete references to 7X7 type fuel assemblies since this type of fuel is no longer used in the Brunswick Steam Electric Plant, Unit 2. The proposed deletions involve technical specifications for power distribution limits on average planar heat generation rates and average power range monitor set points. We have examined the proposed specifications and have found that no changes have been made to power distribution limits or set points and that references to 7X7 type fuel have been deleted. The proposed specifications are therefore acceptable.

3.0 Environmental Considerations

We have determined that the amendment does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and pursuant to 10 CFR 51.5(d)(4), that an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

4.0 Conclusions

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

5.0 Reference

1. General Electric Standard Application for Reactor Fuel, NEDO-24011-A-4, January, 1982.

Principal Contributor: Summer Sun

Dated: November 28, 1983