

Initial Lead Test Results at Maine Schools

Test results for lead in school drinking water are measured in parts-per-billion (ppb). Water fixtures with results over 4ppb are recommended for mitigation/remediation. For more information about lead testing and the health effects of lead, please visit our website at:

<http://www.medwp.com/schools.html>

School Name	Sample Location	Lead Test Result
Abraham Lincoln School	Bottle Fill Station - Boiler Entrance	2 ppb
Abraham Lincoln School	Bottle Fill Station - Cafeteria	0 ppb
Abraham Lincoln School	Drinking Water Tap - Outside Room 16	7.9 ppb
Abraham Lincoln School	Drinking Water Tap - Outside Room 7	5 ppb
Abraham Lincoln School	Drinking Water Tap - Room 13	5.1 ppb
Abraham Lincoln School	Drinking Water Tap - Room 16	10.1 ppb
Abraham Lincoln School	Drinking Water Tap - Room 3	11.1 ppb
Abraham Lincoln School	Drinking Water Tap - Room 6	5.5 ppb
Abraham Lincoln School	Drinking Water Tap - Room 8	15.9 ppb
Abraham Lincoln School	Drinking Water Tap -room 15	7.8 ppb
Abraham Lincoln School	Faucet - Teacher's Lounge	167 ppb
Abraham Lincoln School	Kitchen - Food Prep Faucet	2.7 ppb
Academy Hill School	Bottle Fill Ground Floor	14.2 ppb
Academy Hill School	Bottle Fill Outside Office	6.4 ppb
Academy Hill School	Bottle Fill Upstairs	0 ppb
Academy Hill School	Kitchen Dish Prep Sink	5.7 ppb
Academy Hill School	Kitchen Food Prep Sink	6.1 ppb
Academy Hill School	Kitchen Kettle #1	22.2 ppb
Academy Hill School	Kitchen Kettle #2	8.6 ppb
Academy Hill School	Nurse's Room Sink	16.9 ppb
Academy Hill School	Sink Room 211	83.3 ppb
Acadia Academy School	Bottle Filling Station(near Boys)	0 ppb
Acadia Academy School	Bottle Filling Station(near Girls)	0 ppb
Acadia Academy School	Boys - Handwash Sink Left	1.3 ppb
Acadia Academy School	Boys - Handwash Sink Right	1.5 ppb
Acadia Academy School	Cafe - Handwash Sink	0 ppb
Acadia Academy School	Custodial Office Laundry Sink	0 ppb
Acadia Academy School	Girls - Handwash Sink Left	1.1 ppb
Acadia Academy School	Girls - Handwash Sink Right	1.3 ppb
Acadia Academy School	Nurses Office Ice Maker	0 ppb
Acadia Academy School	Nurses Sink	0 ppb
Acadia Academy School	Pre K Bathroom - Handwash Sink L	0 ppb
Acadia Academy School	Pre K Bathroom - Handwash Sink R	0 ppb
Acadia Academy School	Pre K Room 5 Handwash Sink	1.5 ppb
Acadia Academy School	Pre K Room 6 Handwash Sink	1.6 ppb
Acadia Academy School	Pre K Room 7 Handwash Sink	0 ppb
Acadia Academy School	Staff Bathroom R1 Handwash Sink	1 ppb
Acadia Academy School	Staff Bathroom R2 Handwash Sink	0 ppb
Acadia Academy School	Staff Bathroom R5 Handwash Sink	1 ppb
Acadia Academy School	Staff Bathroom R6 Handwash Sink	0 ppb
Acadia Academy School	Water Cooler Nurses Office	0 ppb

School Name	Sample Location	Lead Test Result
Acton Elementary School	2 Kitchen Food Prep	0 ppb
Acton Elementary School	Kitchen Food Prep	0 ppb
Acton Elementary School	Teacher Breakroom Jr	0 ppb
Acton Elementary School	Water Bottle Fill 3	0 ppb
Acton Elementary School	Water Bottle Fill Gym	0 ppb
Acton Elementary School	Water Bottle Fill K	0 ppb
Acton Elementary School	Water Bottle Fill Lobby	0 ppb
Acton Elementary School	Water Bottle Fill Ms	0 ppb
Adams School	2nd And 3rd Grade Room	0 ppb
Adams School	Bottle Fill Fountain	0 ppb
Adams School	Kitchen - 1 Bay Sink	1.3 ppb
Adams School	Kitchen - 3 Bay Sink	1.4 ppb
Adams School	Teacher's Room	1.1 ppb
Agnes Gray School	Cafeteria Basement	3.3 ppb
Agnes Gray School	Kitchen Sinks X4	6.1 ppb
Agnes Gray School	Main Lobby Hallway	0 ppb
Agnes Gray School	Outdoor Spigot And Faucet	0 ppb
Agnes Gray School	Upstairs Hallway	1.6 ppb
Airline Community School	Gymnasium Drinking Fountain	0 ppb
Airline Community School	Hallway Drinking Fountain	1.4 ppb
Airline Community School	Kitchen Food Prep Faucet	1.2 ppb
Airline Community School	Staff Breakroom Sink	2 ppb
Albert S Hall School	101 Teachers North Break Room Sink	0 ppb
Albert S Hall School	3rd Flr Boys Bathroom Left Sink	4.1 ppb
Albert S Hall School	3rd Flr Boys Bathroom Right Sink	0 ppb
Albert S Hall School	3rd Flr Girls Bathroom Left Sink	0 ppb
Albert S Hall School	3rd Flr Girls Bathroom Right Sink	0 ppb
Albert S Hall School	3rd Flr Teachers Bathroom	2.6 ppb
Albert S Hall School	3rd Flr Teachers Breakroom	2 ppb
Albert S Hall School	3rd Flr Water Fountain South	0 ppb
Albert S Hall School	Basement Boys Bathroom Left Sink	0 ppb
Albert S Hall School	Basement Boys Bathroom Right Sink	0 ppb
Albert S Hall School	Basement Girls Bathroom Left Sink	1.6 ppb
Albert S Hall School	Basement Girls Bathroom Right Sink	2.3 ppb
Albert S Hall School	Basement Teachers South Break Rm Sink	3.9 ppb
Albert S Hall School	Basement Water Fountain	0 ppb
Albert S Hall School	Main Flr Boys Bathroom Left Sink	0 ppb
Albert S Hall School	Main Flr Boys Bathroom Right Sink	0.99 ppb
Albert S Hall School	Main Flr Girls Bathroom Left Sink	0 ppb
Albert S Hall School	Main Flr Girls Bathroom Right Sink	0 ppb
Albert S Hall School	Main Flr Kitchen Double Sink	5.3 ppb
Albert S Hall School	Main Flr Kitchen Small Sink	1.1 ppb
Albert S Hall School	Main Flr Nurses Office	1.5 ppb
Albert S Hall School	Main Flr Teachers Room Sink	1.8 ppb
Albert S Hall School	Main Flr Water Fountain North	1.2 ppb
Albert S Hall School	Main Flr Water Fountain South	0 ppb
Albion Elementary School	Boys Bathroom Faucet Near Back Of Gym	8.5 ppb

School Name	Sample Location	Lead Test Result
Albion Elementary School	Boys Bathroom Main Hallway Sink #1	7.2 ppb
Albion Elementary School	Boys Bathroom Main Hallway Sink #2	5.5 ppb
Albion Elementary School	Boys Bathroom Old Wing Sink #1	4.4 ppb
Albion Elementary School	Boys Bathroom Old Wing Sink #2	5 ppb
Albion Elementary School	Drinking Fountain Near Main Office	0 ppb
Albion Elementary School	Drinking Fountain Old Wing Hallway	0 ppb
Albion Elementary School	Girls Bathroom Faucet Near Back Of Gym	7.2 ppb
Albion Elementary School	Girls Bathroom Main Hallway Sink #1	1.4 ppb
Albion Elementary School	Girls Bathroom Main Hallway Sink #2	6.6 ppb
Albion Elementary School	Girls Bathroom Old Wing Sink #1	3.3 ppb
Albion Elementary School	Girls Bathroom Old Wing Sink #2	6.1 ppb
Albion Elementary School	Gym Drinking Fountain	0 ppb
Albion Elementary School	Kitchen Faucet #1	3.5 ppb
Albion Elementary School	Kitchen Faucet #2	3.8 ppb
Albion Elementary School	Kitchen Faucet #3	7.2 ppb
Albion Elementary School	Kitchen Faucet #4	5.1 ppb
Albion Elementary School	Kitchen Handwashing Sink	10.3 ppb
Albion Elementary School	Nurses Room Sink	6.3 ppb
Albion Elementary School	Room #1 Sink	3.3 ppb
Albion Elementary School	Room #13 Bathroom Sink #1	10 ppb
Albion Elementary School	Room #13 Bathroom Sink #2	2.6 ppb
Albion Elementary School	Room #2 Sink	6.8 ppb
Albion Elementary School	Room #3 Sink	3 ppb
Albion Elementary School	Room #5 Sink	5.7 ppb
Albion Elementary School	Room #6 Sink	4.5 ppb
Albion Elementary School	Teachers Room Water Cooler	0 ppb
Alexander Elementary	Kitchen - Triple Sink	0 ppb
Alexander Elementary	Main Office Sink	0 ppb
Alexander Elementary	Mr. Morris's Room # 6	1.2 ppb
Alexander Elementary	Water Filling Station - Hallway	0 ppb
Alfred Elementary School	1st Floor Hallway-drinking Fountain	2.4 ppb
Alfred Elementary School	2nd Floor Hallway-drinking Fountain	5.2 ppb
Alfred Elementary School	Drinking Fountain-gym (high)	11 ppb
Alfred Elementary School	Drinking Fountain-gym (low)	13.2 ppb
Alfred Elementary School	Kitchen-3 Bay Sink (l)	3.9 ppb
Alfred Elementary School	Kitchen-3 Bay Sink (r)	4.7 ppb
Alfred Elementary School	Kitchen-kettle	187 ppb
Alfred Elementary School	Kitchen-vegetable Sink	6.1 ppb
Alfred Elementary School	Nurse's Office-sink	6.2 ppb
Alfred Elementary School	Room 129-drinking Fountain	11.5 ppb
Alfred Elementary School	Room 129-sink	9.8 ppb
Alfred Elementary School	Room 134-drinking Fountain	9.1 ppb
Alfred Elementary School	Room 134-sink	4.8 ppb
Alfred Elementary School	Room 135-drinking Fountain	12.9 ppb
Alfred Elementary School	Room 135-sink	4.3 ppb
Alfred Elementary School	Room 137-drinking Fountain	10.7 ppb
Alfred Elementary School	Room 137-sink	8.5 ppb

School Name	Sample Location	Lead Test Result
Alfred Elementary School	Room 145-drinking Fountain	10.4 ppb
Alfred Elementary School	Room 145-sink	11.9 ppb
Alfred Elementary School	Room 146-drinking Fountain	14.1 ppb
Alfred Elementary School	Room 146-sink	10.1 ppb
Alfred Elementary School	Room 147-drinking Fountain	12.8 ppb
Alfred Elementary School	Room 147-sink	5.4 ppb
Alfred Elementary School	Room 152-drinking Fountain	11.8 ppb
Alfred Elementary School	Room 152-sink	7.6 ppb
Alfred Elementary School	Room 210-drinking Fountain	10.1 ppb
Alfred Elementary School	Room 210-sink	14.3 ppb
Alfred Elementary School	Room 211-drinking Fountain	46.4 ppb
Alfred Elementary School	Room 211-sink	7.8 ppb
Alfred Elementary School	Room 212-drinking Fountain	24 ppb
Alfred Elementary School	Room 212-sink	5.2 ppb
Alfred Elementary School	Room 214 Drinking Fountain	56.6 ppb
Alfred Elementary School	Room 214-sink	16 ppb
Alfred Elementary School	Room 216-drinking Fountain	10 ppb
Alfred Elementary School	Room 216-sink	13.2 ppb
Alfred Elementary School	Room 219-drinking Fountain	17.9 ppb
Alfred Elementary School	Room 219-sink	4.6 ppb
Alfred Elementary School	Teacher's Room-sink	8.2 ppb
All Saints Catholic School	Sjc Bottle Fill Station 1st Floor Hall	0 ppb
All Saints Catholic School	Sjc Bottle Fill Station 2nd Floor Hall	0 ppb
All Saints Catholic School	Sjc Drinking Fountain 1st Floor	7.7 ppb
All Saints Catholic School	Sjc Drinking Fountain 2nd Floor	16.7 ppb
All Saints Catholic School	Sjc Kitchen Sink Basement	1.5 ppb
All Saints Catholic School	Smc Bottle Fill 2nd Floor By Lounge	0 ppb
All Saints Catholic School	Smc Bottle Fill 2nd Floor By Rm 206	0 ppb
All Saints Catholic School	Smc Bottle Fill Station 1st Floor Hall	0 ppb
All Saints Catholic School	Smc Kitchen Sink Double In Kitchen	0 ppb
All Saints Catholic School	Smc Kitchen Sink Single In Kitchen	0 ppb
All Saints Catholic School	Smc Kitchen Sink Single In Pre-k	0 ppb
All Saints Catholic School	Smc Kitchen Sink Single In Room 109	0 ppb
All Saints Catholic School	Smc Kitchen Sink Single In Room 110	3.1 ppb
Alternative Adult Education	Kitchen Sink #1	0 ppb
Alternative Adult Education	Kitchen Sink #2	1.9 ppb
Alternative Adult Education	Kitchen Sink #3 A.e.	0 ppb
Alternative Adult Education	Kitchen Sink #4 A.e.	0 ppb
Alternative Education MSAD 75	6 Kitchen Faucet	3.4 ppb
Alternative Education MSAD 75	7 Water Cooler	0 ppb
Alternative Pathways Center	Snk Kitchen	0 ppb
Amanda C Rowe School	111	2.4 ppb
Amanda C Rowe School	112	0 ppb
Amanda C Rowe School	113	0 ppb
Amanda C Rowe School	114	3 ppb
Amanda C Rowe School	115	0 ppb
Amanda C Rowe School	116	0 ppb

School Name	Sample Location	Lead Test Result
Amanda C Rowe School	119	14 ppb
Amanda C Rowe School	120	0 ppb
Amanda C Rowe School	122	8.1 ppb
Amanda C Rowe School	123	0 ppb
Amanda C Rowe School	124	1.4 ppb
Amanda C Rowe School	126	0 ppb
Amanda C Rowe School	127	1.4 ppb
Amanda C Rowe School	128	4.8 ppb
Amanda C Rowe School	129	2.3 ppb
Amanda C Rowe School	130	1.9 ppb
Amanda C Rowe School	131	1.1 ppb
Amanda C Rowe School	135	1.6 ppb
Amanda C Rowe School	201	8.7 ppb
Amanda C Rowe School	203	11.7 ppb
Amanda C Rowe School	208	2.7 ppb
Amanda C Rowe School	210	3.5 ppb
Amanda C Rowe School	213	1.2 ppb
Amanda C Rowe School	214	6 ppb
Amanda C Rowe School	215	1.6 ppb
Amanda C Rowe School	216	1.9 ppb
Amanda C Rowe School	217	0 ppb
Amanda C Rowe School	220	1.5 ppb
Amanda C Rowe School	221	5.1 ppb
Amanda C Rowe School	Art Room	1.6 ppb
Amanda C Rowe School	Fls Room	1.2 ppb
Amanda C Rowe School	Hall 1st Floor By Gang Bathroom	0 ppb
Amanda C Rowe School	Hall By 212	0 ppb
Amanda C Rowe School	Hall By Office	0 ppb
Amanda C Rowe School	Kitchen Sink	0 ppb
Amanda C Rowe School	Kitchen Sink 2	0 ppb
Amanda C Rowe School	Library Office	7 ppb
Amanda C Rowe School	Maker Space	9 ppb
Amanda C Rowe School	Maker Space - Classroom Sink	0 ppb
Amanda C Rowe School	Maker Space - Large Basin	4.3 ppb
Amanda C Rowe School	Staff Kitchen By 220	0 ppb
Amanda C Rowe School	Teacher Room 1st Floor	0 ppb
Amanda C Rowe School	Work Space By 123	5.4 ppb
Amanda C Rowe School	Work Space By 212	1.6 ppb
Ames Elementary School	Kitchen By Back Exit Door	0 ppb
Ames Elementary School	Kitchen Left Of Dishwasher	0 ppb
Ames Elementary School	Kitchen Right Of Dishwasher	0 ppb
Ames Elementary School	Main Hallway Near Bathrooms	0 ppb
Ames Elementary School	Staff Kitchen	0 ppb
Andover Elementary School	Bottle Fill Station By Girls Bathroom	1.9 ppb
Andover Elementary School	Kitchen Food Prep Sink	85 ppb
Andover Elementary School	Kitchen Ice Machine	1.4 ppb
Androscoggin Learning & Transition	Art Sink 1 Main Bldg Upstairs	1.1 ppb

School Name	Sample Location	Lead Test Result
Androscoggin Learning & Transition	Bathroom Sink 1 Main Bldg Upstairs	1.7 ppb
Androscoggin Learning & Transition	Bathroom Sink 2 Main Bldg Upstairs	0 ppb
Androscoggin Learning & Transition	Bathroom Sink 3 Main Bldg Upstairs	0 ppb
Androscoggin Learning & Transition	Bathroom Sink 4 Main Bldg Downstairs	0 ppb
Androscoggin Learning & Transition	Bathroom Sink 5 Main Bldg Downstairs	0 ppb
Androscoggin Learning & Transition	Bathroom Sink 6 Main Bldg Downstairs	0 ppb
Androscoggin Learning & Transition	Bathroom Sink 7 Gym	1.4 ppb
Androscoggin Learning & Transition	Bathroom Sink 8 Gym	0 ppb
Androscoggin Learning & Transition	Bathroom Sink 9 Gym	0 ppb
Androscoggin Learning & Transition	Handwash Sink 1 Kitchen	0 ppb
Androscoggin Learning & Transition	Handwash Sink 2 Kitchen	30.2 ppb
Androscoggin Learning & Transition	Kitchen Faucet 1 Kitchen	9.7 ppb
Androscoggin Learning & Transition	Kitchen Faucet 2 Kitchen	3.3 ppb
Androscoggin Learning & Transition	Science Sink Gym	6.9 ppb
Appleton Village School	8th Grade Water Bottle Fill	0 ppb
Appleton Village School	Gym- Water Bottle Fill	1 ppb
Appleton Village School	Kitchen- Handwashing Sink	13.4 ppb
Appleton Village School	Kitchen- Sink	5.1 ppb
Appleton Village School	Room 101 Kindergarten Faucet	4.5 ppb
Appleton Village School	Room 101 Kindergarten Fountain	7.4 ppb
Appleton Village School	Room 109- 3rd Grade Faucet	2.3 ppb
Appleton Village School	Room 109- 3rd Grade Fountain	5.5 ppb
Appleton Village School	Room 113- Special Ed	2.2 ppb
Appleton Village School	Room 201-4th Grade Faucet	5.7 ppb
Appleton Village School	Room 201-4th Grade Fountain	5.9 ppb
Appleton Village School	Room 202- 5th Grade Faucet	7.3 ppb
Appleton Village School	Room 202- 5th Grade Fountain	13.4 ppb
Appleton Village School	Room 205- Art And Music Sink 1	2.3 ppb
Appleton Village School	Room 205- Art And Music Sink 2	2.4 ppb
Appleton Village School	Teachers Lounge	0 ppb
Arthur R Gould School LCYDC	Art Classroom	0 ppb
Arthur R Gould School LCYDC	Culinary / 3 Bay Sink	0 ppb
Arthur R Gould School LCYDC	Culinary / 2 Bay Sink	0 ppb
Arthur R Gould School LCYDC	Gymnasium	0 ppb
Arthur R Gould School LCYDC	Main Kitchen / 3 Bay Sink / Center	0 ppb
Arthur R Gould School LCYDC	Main Kitchen / 3 Bay Sink / Left	1.5 ppb
Arthur R Gould School LCYDC	Main Kitchen / 3 Bay Sink/ Right	1.4 ppb
Arthur R Gould School LCYDC	Main Kitchen Blodget Tilt Skillet	0 ppb
Arthur R Gould School LCYDC	Main Kitchen Legon Tilt Skillet	9.1 ppb
Arthur R Gould School LCYDC	Main Kitchen Sink By Cook Line	0 ppb
Arthur R Gould School LCYDC	Main Kitchen Sink By Serving Line	0 ppb
Arthur R Gould School LCYDC	Main Kitchen Steam Jacket	0 ppb
Asa C Adams School	2nd Fountain In Gym	0 ppb
Asa C Adams School	Across From A-4	0 ppb
Asa C Adams School	Classroom 1	0 ppb
Asa C Adams School	Classroom 10	6.2 ppb
Asa C Adams School	Classroom 12	1.6 ppb

School Name	Sample Location	Lead Test Result
Asa C Adams School	Classroom 14	1.4 ppb
Asa C Adams School	Classroom 15	1.5 ppb
Asa C Adams School	Classroom 17	4.1 ppb
Asa C Adams School	Classroom 19	4 ppb
Asa C Adams School	Classroom 2	0 ppb
Asa C Adams School	Classroom 20	4.9 ppb
Asa C Adams School	Classroom 29	29.8 ppb
Asa C Adams School	Classroom 3	0 ppb
Asa C Adams School	Classroom 30	7.2 ppb
Asa C Adams School	Classroom 31	8.9 ppb
Asa C Adams School	Classroom 32	6.9 ppb
Asa C Adams School	Classroom 33	24.1 ppb
Asa C Adams School	Classroom 34	26.2 ppb
Asa C Adams School	Classroom 35	6.1 ppb
Asa C Adams School	Classroom 36	2.8 ppb
Asa C Adams School	Classroom 39	4.3 ppb
Asa C Adams School	Classroom 40	3.8 ppb
Asa C Adams School	Classroom 41	7.4 ppb
Asa C Adams School	Classroom 42	12.2 ppb
Asa C Adams School	Classroom 8	7.7 ppb
Asa C Adams School	Fountain By Library	0 ppb
Asa C Adams School	Fountain In Gym	0 ppb
Asa C Adams School	Kitchen 3 Bay Sink	0 ppb
Asa C Adams School	Kitchen Vegetable Wash	0 ppb
Asa C Adams School	Nurses Room	0 ppb
Ash Point Community School	Art Room Drinking Fountain	0 ppb
Ash Point Community School	Art Room Sink	0 ppb
Ash Point Community School	Band Room Sink	0 ppb
Ash Point Community School	Bottle Fill Staion Outside Student Bathroom	0 ppb
Ash Point Community School	Bottle Fill Station	0 ppb
Ash Point Community School	Bottle Fill Station Left Side	0 ppb
Ash Point Community School	Bottle Fill Station Right Side	0 ppb
Ash Point Community School	Boys Bathroom Sink Left	1 ppb
Ash Point Community School	Boys Bathroom Sink Near Gym Left	1 ppb
Ash Point Community School	Boys Bathroom Sink Near Gym Right	4 ppb
Ash Point Community School	Boys Bathroom Sink Right	1 ppb
Ash Point Community School	Drinking Faucet At Bfs Left Side	0 ppb
Ash Point Community School	Drinking Faucet At Bfs Right Side	0 ppb
Ash Point Community School	Drinking Fountain At Bfs Left Side	0 ppb
Ash Point Community School	Drinking Fountain At Bfs Right Side	0 ppb
Ash Point Community School	Girls Bathroom Sink Left	0 ppb
Ash Point Community School	Girls Bathroom Sink Near Gym Left	3 ppb
Ash Point Community School	Girls Bathroom Sink Near Gym Right	3 ppb
Ash Point Community School	Girls Bathroom Sink Right	2 ppb
Ash Point Community School	Girls Bathroon Sink Left Near Bfs	3 ppb
Ash Point Community School	Girls Bathroon Sink Right Near Bfs	2 ppb

School Name	Sample Location	Lead Test Result
Ash Point Community School	Kitchen Dish Washer	0 ppb
Ash Point Community School	Kitchen Hand Washing Sink Near Dish Washer	4 ppb
Ash Point Community School	Kitchen Hand Washing Sink Near Freezer	8 ppb
Ash Point Community School	Kitchen Sink Opposite Wash Sink	0 ppb
Ash Point Community School	Kitchen Sink Right Of Dish Washer	3 ppb
Ash Point Community School	Kitchen Triple Sink Faucet Left	1 ppb
Ash Point Community School	Kitchen Triple Sink Faucet Right	7 ppb
Ash Point Community School	Nurses Office Sink	0 ppb
Ash Point Community School	Outside Spigot Left Of Kitchen Entrance	0 ppb
Ash Point Community School	Outside Spigot Left Of Main Entrance	1 ppb
Ash Point Community School	Outside Spigot Right Of Kitchen Entrance	0 ppb
Ash Point Community School	Outside Spigot Right Of Main Entrance	0 ppb
Ash Point Community School	Room 206 Classroom Sink	0 ppb
Ash Point Community School	Room 209 Classroom Sink	0 ppb
Ash Point Community School	Room 211 Classroom Sink	0 ppb
Ash Point Community School	Room 212 Classroom Sink	0 ppb
Ash Point Community School	Room 130 Classroom Fountain	0 ppb
Ash Point Community School	Room 130 Classroom Sink	0 ppb
Ash Point Community School	Room 132 Classroom Fountain	1 ppb
Ash Point Community School	Room 132 Classroom Sink	0 ppb
Ash Point Community School	Room 134 Bathroom Sink	0 ppb
Ash Point Community School	Room 134 Classroom Fountain	3 ppb
Ash Point Community School	Room 134 Classroom Sink	0 ppb
Ash Point Community School	Room 137 Bathroom Sink	0 ppb
Ash Point Community School	Room 137 Water Fountain	1 ppb
Ash Point Community School	Room 138	0 ppb
Ash Point Community School	Room 138 Sink	0 ppb
Ash Point Community School	Room 138 Water Fountain	0 ppb
Ash Point Community School	Room 141 Classroom Fountain	1 ppb
Ash Point Community School	Room 141 Classroom Sink	0 ppb
Ash Point Community School	Room 143 Classroom Fountain	0 ppb
Ash Point Community School	Room 143 Classroom Sink	0 ppb
Ash Point Community School	Room 145 Classroom Fountain	1 ppb
Ash Point Community School	Room 145 Classroom Sink	0 ppb
Ash Point Community School	Room 201 Classroom Drinking Fountain	0 ppb
Ash Point Community School	Room 201 Classroom Sink	0 ppb
Ash Point Community School	Room 206 Classroom Fountain	1 ppb
Ash Point Community School	Room 209 Classroom Fountain	1 ppb
Ash Point Community School	Room 211 Classroom Fountain	1 ppb
Ash Point Community School	Room 212 Classroom Fountain	1 ppb
Ash Point Community School	Room 214 Classroom Drinking Fountain	0 ppb
Ash Point Community School	Room 214 Classroom Sink	0 ppb
Ash Point Community School	Sink Room 137	1 ppb
Ash Point Community School	Staff Bathroom Sink	0 ppb
Ash Point Community School	Teachers Lounge Sink	5 ppb
Ashland District School	Fitness Center	0 ppb

School Name	Sample Location	Lead Test Result
Ashland District School	Gym Elementary Side	0 ppb
Ashland District School	Gym High School Side	0 ppb
Ashland District School	Gym Ice Maker	1.5 ppb
Ashland District School	Hall By Super Office	0 ppb
Ashland District School	Hs Hall Wing	1.9 ppb
Ashland District School	Hs Teacher Work Rm	1.2 ppb
Ashland District School	Kitchen 3 Bay Sink	0 ppb
Ashland District School	Kitchen Ice Maker	0 ppb
Ashland District School	Kitchen Tilt Skillet Faucet	1.3 ppb
Ashland District School	Kitchen Vegetable Sink	0 ppb
Ashland District School	Music Rm	0 ppb
Ashland District School	Nurse's Office Sink	0 ppb
Ashland District School	Nurse's Personal Office Sink	0 ppb
Ashland District School	Prek-2 Wing Teacher Rm	1.5 ppb
Ashland District School	Rm 203	0 ppb
Ashland District School	Rm 210	0 ppb
Ashland District School	Rm 211	0 ppb
Ashland District School	Rm 212	0 ppb
Ashland District School	Rm 217	0 ppb
Ashland District School	Rm 218	1.9 ppb
Ashland District School	Rm 249	0 ppb
Ashland District School	Room 104	0 ppb
Ashland District School	Room 107	0 ppb
Ashland District School	Room 113	0 ppb
Ashland District School	Room 114	0 ppb
Ashland District School	Room 116	0 ppb
Ashland District School	Room 121	0 ppb
Ashland District School	Room 137	0 ppb
Ashland District School	Room 142	0 ppb
Ashland District School	Room 143	0 ppb
Ashland District School	Room 144	28.8 ppb
Ashland District School	Room 145	0 ppb
Ashland District School	Room 146	1.3 ppb
Ashley Bryan School	Bathroom	4.1 ppb
Ashley Bryan School	Grades 3-8	50.3 ppb
Ashley Bryan School	Grades K-2	14.2 ppb
Ashwood Waldorf School	Early Childhood Appleblossom Room	0 ppb
Ashwood Waldorf School	Early Childhood Buttercup Room	0 ppb
Ashwood Waldorf School	Early Childhood Sunflower Room	0 ppb
Ashwood Waldorf School	Grade School Classroom #1	0 ppb
Ashwood Waldorf School	Grade School Classroom #2	0 ppb
Ashwood Waldorf School	Grade School Classroom #3	0 ppb
Ashwood Waldorf School	Grade School Classroom #4	0 ppb
Ashwood Waldorf School	Grade School Classroom #5	0 ppb
Ashwood Waldorf School	Grade School Classroom #6	0 ppb
Ashwood Waldorf School	Green Building Bathroom -end Of Hall	1.1 ppb
Ashwood Waldorf School	Green Building Bathroom -left Side	1.8 ppb

School Name	Sample Location	Lead Test Result
Athens Community School	"1st """"	2.5 ppb
Athens Community School	"2nd """"	2.2 ppb
Athens Community School	"4th """"	1.2 ppb
Athens Community School	"5th """"	5.2 ppb
Athens Community School	"8th """"	7.6 ppb
Athens Community School	"sp Ed """"	3 ppb
Athens Community School	3rd Grade	1.6 ppb
Athens Community School	Fountain By Bathrooms	0 ppb
Athens Community School	Kindergarten	0 ppb
Athens Community School	Kitchen Hand Wash Sink	4 ppb
Athens Community School	Kitchen Prep Sink	0 ppb
Athens Community School	Main Hall Fountain	0 ppb
Athens Community School	Nurse's Office	8.4 ppb
Athens Community School	Teachers Rm Bathroom Sink	3.3 ppb
Athens Community School	Teachers Rm Sink	3.3 ppb
Atlantic Academy	Back Classroom	0 ppb
Atlantic Academy	Kitchen	0 ppb
Auburn Middle School	514 Office By Stairs	7.5 ppb
Auburn Middle School	Boys Room After 221 Left Faucet	0 ppb
Auburn Middle School	Boys Room After 221 Right Faucet	1.6 ppb
Auburn Middle School	Boys Room By Room 106 L Faucet	1.8 ppb
Auburn Middle School	Boys Room By Room 106 R Faucet	1.4 ppb
Auburn Middle School	Boys Room By Room 206 L Faucet	1.1 ppb
Auburn Middle School	Boys Room By Room 206 R Faucet	1.6 ppb
Auburn Middle School	Bubbler Between Restrooms	0 ppb
Auburn Middle School	Bubbler By Room 124	0 ppb
Auburn Middle School	Bubbler By Room 206	0 ppb
Auburn Middle School	Bubbler By Room 221	0 ppb
Auburn Middle School	Cafeteria Bubbler	0 ppb
Auburn Middle School	Cafeteria Water Bottle Filler	0 ppb
Auburn Middle School	Classroom By Wash/dry Faucet	3 ppb
Auburn Middle School	Exam Room Faucet	11.7 ppb
Auburn Middle School	Girls Room After 221 Left Faucet	1.2 ppb
Auburn Middle School	Girls Room After 221 Right Faucet	1.1 ppb
Auburn Middle School	Girls Room By Room 106 L Faucet	0 ppb
Auburn Middle School	Girls Room By Room 106 R Faucet	1.7 ppb
Auburn Middle School	Girlsroom By Room 206 L Faucet	2.3 ppb
Auburn Middle School	Girlsroom By Room 206 R Faucet	1.4 ppb
Auburn Middle School	Gym Bubbler	1.2 ppb
Auburn Middle School	Gym Mens Locker Room Center Faucet	1.1 ppb
Auburn Middle School	Gym Mens Locker Room Left Faucet	3.7 ppb
Auburn Middle School	Gym Mens Locker Room Right Faucet	11800 ppb
Auburn Middle School	Gym Mens Office Sink Faucet	9.6 ppb
Auburn Middle School	Gym Water Bottle Filler	0 ppb
Auburn Middle School	Gym Womens Locker Room Center Faucet	1.2 ppb
Auburn Middle School	Gym Womens Locker Room Left Faucet	1.4 ppb
Auburn Middle School	Gym Womens Locker Room Right Faucet	6.5 ppb

School Name	Sample Location	Lead Test Result
Auburn Middle School	Gym Womens Office Sink Faucet	6.1 ppb
Auburn Middle School	Hall Bathroom By Room 117 Faucet	0 ppb
Auburn Middle School	Hall Bathroom By Teachers Room Faucet	1.6 ppb
Auburn Middle School	Hall Restroom Across From Room 122 Faucet	1.1 ppb
Auburn Middle School	Hall Restrooms Outside Gym Mens Faucet	1.2 ppb
Auburn Middle School	Hall Restrooms Outside Gym Womens Faucet	0 ppb
Auburn Middle School	Hand Wash Sink By Food Line	1.4 ppb
Auburn Middle School	Hand Wash Sink On Back Wall Kitchen Faucet	2 ppb
Auburn Middle School	Home Ec Area Blue Counter Faucet	81.5 ppb
Auburn Middle School	Home Ec Area Green Counter Faucet	25.8 ppb
Auburn Middle School	Home Ec Area Spec Blue Counter Faucet	2.5 ppb
Auburn Middle School	Home Ec Area Spec Green Counter Faucet	18.2 ppb
Auburn Middle School	Kitchen Bathroom Faucet	7.7 ppb
Auburn Middle School	Kitchen Ice Maker	4.1 ppb
Auburn Middle School	Kitchen Sink Food Wash Faucet	2.1 ppb
Auburn Middle School	Left Kettle Faucet Kitchen	5.6 ppb
Auburn Middle School	Music Room Bubbler	0 ppb
Auburn Middle School	Nurses Office Faucet	1.3 ppb
Auburn Middle School	Right Kettle Faucet Kitchen	3.6 ppb
Auburn Middle School	Room 105 Center Faucet	0 ppb
Auburn Middle School	Room 105 Left Faucet	0 ppb
Auburn Middle School	Room 105 Right Faucet	0 ppb
Auburn Middle School	Room 111 Center Faucet	2.5 ppb
Auburn Middle School	Room 111 Left Faucet	2.5 ppb
Auburn Middle School	Room 111 Right Faucet	0 ppb
Auburn Middle School	Room 114 Restroom Faucet	4.4 ppb
Auburn Middle School	Room 120 Center Of Room W/eyewash Faucet	0 ppb
Auburn Middle School	Room 120 Center Of Room W/o Eyewash Faucet	0 ppb
Auburn Middle School	Room 120 Corner Sink Faucet	1.7 ppb
Auburn Middle School	Room 205 Center Faucet	0 ppb
Auburn Middle School	Room 205 Left Faucet	0 ppb
Auburn Middle School	Room 205 Right Faucet	0 ppb
Auburn Middle School	Room 211 Center Faucet	2.7 ppb
Auburn Middle School	Room 211 Left Faucet	1.1 ppb
Auburn Middle School	Room 211 Right Faucet	0 ppb
Auburn Middle School	Room 213 Small Office Bathroom Faucet	1 ppb
Auburn Middle School	Room 221 Center Faucet	1.1 ppb
Auburn Middle School	Room 221 Left Faucet	0 ppb
Auburn Middle School	Room 221 Right Faucet	1.4 ppb
Auburn Middle School	Room 226 Center Faucet	0 ppb
Auburn Middle School	Room 226 Left Faucet	0 ppb
Auburn Middle School	Room 226 Right Faucet	2.8 ppb

School Name	Sample Location	Lead Test Result
Auburn Middle School	Sink On Front Side Of Bld Faucet	4.3 ppb
Auburn Middle School	Sink On Office Side Of Bld Faucet	2.1 ppb
Auburn Middle School	Sink On Orchard Side Of Bld Faucet	6.9 ppb
Auburn Middle School	Sink On Rear Side Of Bld Faucet	1.4 ppb
Auburn Middle School	Special Ed Room Faucet	1.5 ppb
Auburn Middle School	Teachers Room Bathroom Faucet	0 ppb
Auburn Middle School	Teachers Room Sink Faucet	0 ppb
Auburn Middle School	Teachers Storage Area Sink Faucet	2850 ppb
Auburn Middle School	Water Bottle Filler Between Restrooms	0 ppb
Auburn Middle School	Water Bottle Filler By Room 124	0 ppb
Auburn Middle School	Water Bottle Filler By Room 206	0 ppb
Auburn Middle School	Water Bottle Filler By Room 221	0 ppb
Aucocisco School	Boys Bathroom Faucet	0 ppb
Aucocisco School	Girls Bathroom Faucet	0 ppb
Aucocisco School	Kitchen Faucet	0 ppb
Aucocisco School	Science Lab Sink Faucet	1.5 ppb
Aucocisco School	Staff Bathroom Faucet	1 ppb
Bangor Christian Schools	1st Grade Sink Room #7 Elementary	17 ppb
Bangor Christian Schools	Boys Bathroom Sink K-5 End Left Sink	11.6 ppb
Bangor Christian Schools	Boys Bathroom Sink K-5 End Right Sink	5.4 ppb
Bangor Christian Schools	Boys Bathroom Sink Locker End Left	15.1 ppb
Bangor Christian Schools	Boys Bathroom Sink Locker End Right	24.1 ppb
Bangor Christian Schools	Boys Bathroom Sink. Left. High School	1.4 ppb
Bangor Christian Schools	Boys Bathroom Sink. Left. Middle School	5.2 ppb
Bangor Christian Schools	Boys Bathroom Sink. Right. High School	0 ppb
Bangor Christian Schools	Boys Bathroom Sink. Right. Middle School	8.1 ppb
Bangor Christian Schools	Boys Bathroom. Up Street	1.7 ppb
Bangor Christian Schools	Boys Lockerroom Sink Elementary Left	162 ppb
Bangor Christian Schools	Boys Lockerroom Sink Elementary Right	17.7 ppb
Bangor Christian Schools	Cafe Ice Maker	0 ppb
Bangor Christian Schools	Cafe Sink	0 ppb
Bangor Christian Schools	Cafeteria Hand Sink.	4.2 ppb
Bangor Christian Schools	Cafeteria Triple Kitchen Sink. Left	3.9 ppb
Bangor Christian Schools	Cafeteria Triple Kitchen Sink. Middle	9.1 ppb
Bangor Christian Schools	Cafeteria Triple Kitchen Sink. Right	2.4 ppb
Bangor Christian Schools	Drinking Water Fountain K-5 End Left	2.1 ppb
Bangor Christian Schools	Drinking Water Fountain K-5 End Right	1.8 ppb
Bangor Christian Schools	Drinking Water Fountain. Left. High School	0 ppb
Bangor Christian Schools	Drinking Water Fountain. Middle School	17.1 ppb
Bangor Christian Schools	Drinking Water Fountain. Right. High School	0 ppb
Bangor Christian Schools	Foyer Bathroom. Maine Church Floor	0 ppb
Bangor Christian Schools	Gilrs Lockerroom Sink Locker End Right	48.3 ppb
Bangor Christian Schools	Girls Bathroom Sink K-5 End Left Sink	8.1 ppb
Bangor Christian Schools	Girls Bathroom Sink K-5 End Right Sink	3.7 ppb
Bangor Christian Schools	Girls Bathroom Sink Locker End Left	104 ppb
Bangor Christian Schools	Girls Bathroom Sink Locker End Right	60 ppb

School Name	Sample Location	Lead Test Result
Bangor Christian Schools	Girls Bathroom Sink. Left. High School	0 ppb
Bangor Christian Schools	Girls Bathroom Sink. Left. Middle School	5.6 ppb
Bangor Christian Schools	Girls Bathroom Sink. Right. High School	0 ppb
Bangor Christian Schools	Girls Bathroom Sink. Right. Middle School	7.7 ppb
Bangor Christian Schools	Girls Bathroom. Up Street	2.1 ppb
Bangor Christian Schools	Girls Lockerroom Sink Locker End Left	311 ppb
Bangor Christian Schools	Girls Lockerroom Sink Locker End Middle	59.7 ppb
Bangor Christian Schools	K-4 Sink Room #6 Elementary	17.7 ppb
Bangor Christian Schools	Kitchen Sink. Middle School	10.5 ppb
Bangor Christian Schools	Late Duty Staff Bathroom. Middle School	539 ppb
Bangor Christian Schools	Science Closet Sink. Middle School	94.1 ppb
Bangor Christian Schools	Science Lab Sink. Left. Middle School	11.9 ppb
Bangor Christian Schools	Science Lab Sink. Right. Middle School	14.2 ppb
Bangor Christian Schools	Staff Bathroom Sink. Middle School	3.1 ppb
Bangor Christian Schools	Thrive Boys Bathroom Sink. Left	3.5 ppb
Bangor Christian Schools	Thrive Boys Bathroom Sink. Right	2.4 ppb
Bangor Christian Schools	Thrive Girls Bathroom Sink. Left	2.9 ppb
Bangor Christian Schools	Thrive Girls Bathroom Sink. Right	2.8 ppb
Bangor Christian Schools	Thrive Water Fountain Boys Side	0 ppb
Bangor Christian Schools	Thrive Water Fountain Girls Side	1.1 ppb
Bangor Christian Schools	Water Spigot Front Of Church. By Sign	3.5 ppb
Bangor Christian Schools	Water Spigot. Brick Building Side	3.2 ppb
Bangor Christian Schools	Water Spigot. High School End	3.8 ppb
Bangor High School	Bottle Fill Station - Admin Wing	0 ppb
Bangor High School	Bottle Fill Station - B Lobby	0 ppb
Bangor High School	Bottle Fill Station - D Wing	1.4 ppb
Bangor High School	Bottle Fill Station - Lower A North	0 ppb
Bangor High School	Bottle Fill Station - Lower B	0 ppb
Bangor High School	Bottle Fill Station - Maintenance	4.1 ppb
Bangor High School	Bottle Fill Station - Peakes	3.6 ppb
Bangor High School	Bottle Fill Station - Upper A North	0 ppb
Bangor High School	Bottle Fill Station - Upper A South	0 ppb
Bangor High School	Bottle Fill Station - Upper B Lobby	1.1 ppb
Bangor High School	Bottle Fill Station - Upper B North	0 ppb
Bangor High School	Bottle Fill Station - Upper B South	0 ppb
Bangor High School	Cafeteria - A-la-cart Left	4.7 ppb
Bangor High School	Cafeteria - A-la-cart Right	2.4 ppb
Bangor High School	Cafeteria - Main Prep Left	5.7 ppb
Bangor High School	Cafeteria - Main Prep Right	8.5 ppb
Bangor High School	Faucet - Mh Room	6 ppb
Bangor High School	Kitchen - Kettle	1.4 ppb
Bangor High School	Project Transition - Dw Sink Faucet	2.2 ppb
Bangor High School	Project Transition - Pt Sink Faucet	1.1 ppb
Bangor Regional Program	Bottle Fill Station - Dto Hallway	0 ppb
Bangor Regional Program	Bottle Fill Station - Elementary Build.	0 ppb
Bangor Regional Program	Bottle Fill Station - Office Hallway	7 ppb
Bangor Regional Program	Kitchen - Food Prep Faucet	23 ppb

School Name	Sample Location	Lead Test Result
Bath Middle School	Dwf 100 Wing By Rm 106	17.2 ppb
Bath Middle School	Dwf 100 Wing By Rm 111	20.4 ppb
Bath Middle School	Dwf 300 Wing	31.2 ppb
Bath Middle School	Dwf 6/7 Grade Boy Lr	1.3 ppb
Bath Middle School	Dwf 6/7 Grade Girls Lr	2.1 ppb
Bath Middle School	Dwf 8th Grade Boys Lr	1.4 ppb
Bath Middle School	Dwf 8th Grade Girls Lr	1.2 ppb
Bath Middle School	Dwf Gym Lobby	3.2 ppb
Bath Middle School	Dwf Outside Of Cafe	3.4 ppb
Bath Middle School	Prep Sink Kitchen	7.1 ppb
Bath Middle School	Sink 100 Wing Staff Rm	33.5 ppb
Bath Middle School	Sink Clinic 603a	2.5 ppb
Bath Middle School	Sink Clinic 603b	3.2 ppb
Bath Middle School	Sink Concession Stand	5.7 ppb
Bath Middle School	Sink Rm 101	2.1 ppb
Bath Middle School	Water Fountain/bottle Fill Station	0 ppb
Baxter Academy for Tech & Sciences	Downstairs Fountain - Br Hall - Dwf 02	0 ppb
Baxter Academy for Tech & Sciences	Downstairs Fountain - Br Hall - Dwf 03	0 ppb
Baxter Academy for Tech & Sciences	Downstairs Fountain - Office - Dwf 01	0 ppb
Baxter Academy for Tech & Sciences	Great Room Sink - Kf 01	0 ppb
Baxter Academy for Tech & Sciences	Hospitality Kitchen - Kf 02	8.3 ppb
Baxter Academy for Tech & Sciences	Room 110 - Lab Sink	2 ppb
Baxter Academy for Tech & Sciences	Room 111 - Lab Sink	13.2 ppb
Baxter Academy for Tech & Sciences	Room 133 - Lab Sink	0 ppb
Baxter Academy for Tech & Sciences	Teachers Room Sink - Kf 03	0 ppb
Baxter Academy for Tech & Sciences	Upstairs Fountain - Dwf 04	0 ppb
Bay Ridge Elementary	Food Prep Sink Kitchen	1.2 ppb
Bay Ridge Elementary	Gym Drinking Fountain	0 ppb
Bay Ridge Elementary	Pre-k Sink	1.4 ppb
Bay Ridge Elementary	Teachers Room	1.6 ppb
Bay Ridge Elementary	West Side Hall Drinking Fountain	0 ppb
Bay School	Emlen Hall Art Rm. Sink Tap	3.4 ppb
Bay School	Emlen Hall Custodial Sink Tap	0 ppb
Bay School	Emlen Hall Water Bottle Retrofit Fill Station	1.7 ppb
Bay School	N. C. Early Childhood Kitchen Sink Tap	0 ppb
Bay School	Rousseau Building Custodial Sink Tap	1.6 ppb
Bay School	Rousseau Building Kitchen Sink Tap	0 ppb
Bay School	Rousseau Building Rm. A Sink Tap	0 ppb
Bay School	Rousseau Building Rm. B Sink Tap	0 ppb
Bay School	Rousseau Building Rm. C Sink Tap	0 ppb
Bay School	Rousseau Building Rm. D Sink Tap	0 ppb
Bay School	Rousseau Building Rm. E Sink Tap	0 ppb
Bay School	Rousseau Building Water Bottle Fill Station	0 ppb
Beals Elementary School	Kindergarten Sink	0 ppb
Beals Elementary School	Kitchen 3 Bay Sink	7 ppb

School Name	Sample Location	Lead Test Result
Beals Elementary School	Pre-k Sink	4.3 ppb
Beals Elementary School	Special Education Sink	10 ppb
Beatrice Rafferty School	No Samples Yet Taken	
Beech Hill School	Bubbler Gym	2.4 ppb
Beech Hill School	Elkay Water Bottle Station	0 ppb
Beech Hill School	K/1 Fountain	1.1 ppb
Beech Hill School	Kitchen Sink	7.5 ppb
Beech Hill School	Nurses Office Sink	1.1 ppb
Beech Hill School	Pk Fountain	0 ppb
Beech Hill School	Water Fountain - Art Room	2.8 ppb
Beech Hill School	Water Fountain - Book Room	0 ppb
Beech Hill School	Water Fountain - Grade 2/3 Room	2.6 ppb
Beech Hill School	Water Fountain - Grade 4/5 Room	0 ppb
Beech Hill School	Water Fountain - Grade 6 Room	2.2 ppb
Beech Hill School	Water Fountain - Grade 7 Room	4.7 ppb
Beech Hill School	Water Fountain - Resource Room	158 ppb
Beech Hill School	Water Fountain - Study	5.5 ppb
Belfast Area High School	1 Band Room	1.9 ppb
Belfast Area High School	10 Kitchen	0 ppb
Belfast Area High School	11 Kitchen	1.1 ppb
Belfast Area High School	12 Kitchen	0 ppb
Belfast Area High School	13 Kitchen By Ice Box	0 ppb
Belfast Area High School	14 Room 334 Trainer	2.7 ppb
Belfast Area High School	15 Pool	0 ppb
Belfast Area High School	16 Room 101	0 ppb
Belfast Area High School	17 Room 101	3 ppb
Belfast Area High School	18 Room 101	0 ppb
Belfast Area High School	19 Room 101	0 ppb
Belfast Area High School	2 Hallway 1st Fl	0 ppb
Belfast Area High School	20 Room 113	0 ppb
Belfast Area High School	21 Central Office	2.4 ppb
Belfast Area High School	22 Adult Ed	0 ppb
Belfast Area High School	23 Adult Ed	1.5 ppb
Belfast Area High School	24 Hallway Bathroom 2nd Fl	0 ppb
Belfast Area High School	25 Hallway By 216 2nd Fl	2.7 ppb
Belfast Area High School	26 Hallway By 224 2nd Fl	0 ppb
Belfast Area High School	27 Room 211	1.3 ppb
Belfast Area High School	3 Hallway 1st Fl	0 ppb
Belfast Area High School	4 Room 106 Nurse	1 ppb
Belfast Area High School	5 Room 105	2.1 ppb
Belfast Area High School	6 Staff Break Room	0 ppb
Belfast Area High School	7 Hallway 1st Fl	1.1 ppb
Belfast Area High School	8 Main Lobby	4.6 ppb
Belfast Area High School	9 Kitchen	0 ppb
Belfast Area High School	Bcope Hallway Between Bathrooms	0 ppb
Belfast Area High School	Bcope Kitchen	0 ppb
Belgrade Central School	Across From Gym Bottle Fill Station	0 ppb

School Name	Sample Location	Lead Test Result
Belgrade Central School	Across From Gym Boys Bathroom Sink	0 ppb
Belgrade Central School	Across From Gym D W F	0 ppb
Belgrade Central School	Across From Gym Girls Bathroom Sink	0 ppb
Belgrade Central School	Boys Bathroom -sink A	0 ppb
Belgrade Central School	Boys Bathroom -sink B	0 ppb
Belgrade Central School	Boys Ganag Bathroom Sink A	0 ppb
Belgrade Central School	Boys Ganag Bathroom Sink B	0 ppb
Belgrade Central School	Boys Ganag Bathroom Sink C	0 ppb
Belgrade Central School	Boys Ganag Bathroom Sink D	0 ppb
Belgrade Central School	By The 3rd Floor Elev. Bottle Fill Station	0 ppb
Belgrade Central School	By The 3rd Floor Elev. D W F	0 ppb
Belgrade Central School	Girls Gang Bathroom Sink A	0 ppb
Belgrade Central School	Girls Gang Bathroom -sink A	0 ppb
Belgrade Central School	Girls Gang Bathroom Sink B	0 ppb
Belgrade Central School	Girls Gang Bathroom -sink B	0 ppb
Belgrade Central School	Girls Gang Bathroom -sink C	0 ppb
Belgrade Central School	Girls Gang Bathroom -sink D	1.1 ppb
Belgrade Central School	Kitchen 3 Bay Sink B	0 ppb
Belgrade Central School	Kitchen - 3 Bay Sink A	0 ppb
Belgrade Central School	Kitchen - Hand Wash Sink	9.2 ppb
Belgrade Central School	Kitchen- Kettle - Hose Bib	3.8 ppb
Belgrade Central School	Kitchen- Steamer- Hose Bib	1.5 ppb
Belgrade Central School	Kitchen- Vegetable Wash-sink	2.2 ppb
Belgrade Central School	Library -sink	33.4 ppb
Belgrade Central School	N/ To Girls Gang Bath- Bot Fill Station	0 ppb
Belgrade Central School	N/to Girls Gang Bathroom #1 Dwf	0 ppb
Belgrade Central School	N/to Girls Gang Bathroom #2 Dwf	0 ppb
Belgrade Central School	Next To Boys Bathroom Bot Fill Station	0 ppb
Belgrade Central School	Next To Boys Bathroom Dwf	0 ppb
Belgrade Central School	Next To Boys Gang Bathroom -dwf	0 ppb
Belgrade Central School	Ot/pt -bathroom-sink	0 ppb
Belgrade Central School	Outside Office Bottle Fill Station	0 ppb
Belgrade Central School	Outside Office Drinking Water Fountain	0 ppb
Belgrade Central School	Room 102-sink A	1.5 ppb
Belgrade Central School	Room 102-sink B	0 ppb
Belgrade Central School	Room 104 (office Conf. Room) Sink	6.7 ppb
Belgrade Central School	Room 105-sink	2.9 ppb
Belgrade Central School	Room 106-sink	10.4 ppb
Belgrade Central School	Room 108 Sink	3.5 ppb
Belgrade Central School	Room 110- Sink	4.4 ppb
Belgrade Central School	Room 111- Sink	2.3 ppb
Belgrade Central School	Room 128 - Bathroom - Sink	0 ppb
Belgrade Central School	Room 128 (nurse) - Sink	2.1 ppb
Belgrade Central School	Room 130- Bathroom - Sink	0 ppb
Belgrade Central School	Room 131 -bathroom - Sink	0 ppb
Belgrade Central School	Room 134-bathroom -sink	0 ppb
Belgrade Central School	Room 212 Science Lab-sink-a	12.8 ppb

School Name	Sample Location	Lead Test Result
Belgrade Central School	Room 212 Science Lab-sink-b	13.8 ppb
Belgrade Central School	Room 212 Science Lab-sink-c	10.9 ppb
Belgrade Central School	Room 212 Science Lab-sink-d	4.5 ppb
Belgrade Central School	Staff Bathroom-sink	0 ppb
Belgrade Central School	Staff Restroom -sink	0 ppb
Benton Elementary School	1st Floor East Pod Fountain #1	0 ppb
Benton Elementary School	1st Floor East Pod Fountain #2	0 ppb
Benton Elementary School	1st Floor Teachers Room Sink Near 128	0 ppb
Benton Elementary School	1st Floor Teachers Room Sink Near Gym	0 ppb
Benton Elementary School	2nd Floor East Pod Boys Bathroom Sink	0 ppb
Benton Elementary School	2nd Floor East Pod Fountain #1	0 ppb
Benton Elementary School	2nd Floor East Pod Fountain #2	0 ppb
Benton Elementary School	2nd Floor East Pod Girls Bathroom Sink	0 ppb
Benton Elementary School	2nd Floor North Pod Boys Bathroom Sink	0 ppb
Benton Elementary School	2nd Floor North Pod Fountain #1	0 ppb
Benton Elementary School	2nd Floor North Pod Fountain #2	0 ppb
Benton Elementary School	2nd Floor North Pod Girls Bathroom Sink	0 ppb
Benton Elementary School	2nd Floor West Pod Boys Bathroom Sink	0 ppb
Benton Elementary School	2nd Floor West Pod Fountain #1	0 ppb
Benton Elementary School	2nd Floor West Pod Fountain #2	0 ppb
Benton Elementary School	2nd Floor West Pod Girls Bathroom Sink	0 ppb
Benton Elementary School	Art Room Sink #1	0 ppb
Benton Elementary School	Art Room Sink #2	20.7 ppb
Benton Elementary School	Band Room Sink #1	2.5 ppb
Benton Elementary School	Band Room Sink #2	1.6 ppb
Benton Elementary School	Drinking Fountain Near Gym #1	0 ppb
Benton Elementary School	Drinking Fountain Near Gym #2	0 ppb
Benton Elementary School	Gym Boys Bathroom Sink #3	0 ppb
Benton Elementary School	Gym Boys Room Sink #1	0 ppb
Benton Elementary School	Gym Boys Room Sink #2	0 ppb
Benton Elementary School	Gym Girls Room Sink #1	0 ppb
Benton Elementary School	Gym Girls Room Sink #2	0 ppb
Benton Elementary School	Gym Girls Room Sink #3	0 ppb
Benton Elementary School	Gym Water Cooler	0 ppb
Benton Elementary School	Kitchen Faucet Prep Sink	0 ppb
Benton Elementary School	Kitchen Hand Washing Sink #1	0 ppb
Benton Elementary School	Kitchen Hand Washing Sink #2	4.4 ppb
Benton Elementary School	Kitchen Ice Maker	0 ppb
Benton Elementary School	Kitchen Prep/dishwashing Sink #3	0 ppb
Benton Elementary School	Kitchen Prep/dishwashing Sink#1	0 ppb
Benton Elementary School	Kitchen Prep/dishwashingsink#2	0 ppb
Benton Elementary School	Library Office Sink	27.2 ppb
Benton Elementary School	Main Office Sink	0 ppb
Benton Elementary School	North Pod Fountain #1	0 ppb
Benton Elementary School	North Pod Fountain #2	0 ppb
Benton Elementary School	Nurses Office Sink	3.2 ppb
Benton Elementary School	Room 101 Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Benton Elementary School	Room 102 Fountain	0 ppb
Benton Elementary School	Room 103 Fountain	0 ppb
Benton Elementary School	Room 104 Fountain	0 ppb
Benton Elementary School	Room 105 Fountain	0 ppb
Benton Elementary School	Room 106 Fountain	0 ppb
Benton Elementary School	Room 107 Fountain	0 ppb
Benton Elementary School	Room 108 Fountain	0 ppb
Benton Elementary School	Room 109 Fountain	1.2 ppb
Benton Elementary School	Room 110 Fountain	0 ppb
Benton Elementary School	Room 111 Fountain	0 ppb
Benton Elementary School	Room 112 Fountain	0 ppb
Benton Elementary School	Room 113 Fountain	0 ppb
Benton Elementary School	Room 114 Fountain	1.3 ppb
Benton Elementary School	Room 115 Fountain	0 ppb
Benton Elementary School	Room 116 Fountain	0 ppb
Benton Elementary School	Room 117 Fountain	0 ppb
Benton Elementary School	Room 118 Fountain	1 ppb
Benton Elementary School	Room 119 Fountain	0 ppb
Benton Elementary School	Room 120 Fountain	3.1 ppb
Benton Elementary School	Room 121 Fountain	0 ppb
Benton Elementary School	Room 122 Fountain	1.2 ppb
Benton Elementary School	Room 123 Fountain	2 ppb
Benton Elementary School	Room 124 Fountain	1.2 ppb
Benton Elementary School	Room 128 Kitchen Sink	0 ppb
Benton Elementary School	Room 201 Fountain	3.6 ppb
Benton Elementary School	Room 202 Fountain	0 ppb
Benton Elementary School	Room 203 Fountain	2.5 ppb
Benton Elementary School	Room 204 Fountain	0 ppb
Benton Elementary School	Room 205 Fountain	1.5 ppb
Benton Elementary School	Room 206 Fountain	0 ppb
Benton Elementary School	Room 207 Fountain	1.8 ppb
Benton Elementary School	Room 208 Fountain	3 ppb
Benton Elementary School	Room 209 Fountain	5.6 ppb
Benton Elementary School	Room 210 Fountain	1.4 ppb
Benton Elementary School	Room 211 Fountain	4.8 ppb
Benton Elementary School	Room 212 Fountain	1.1 ppb
Benton Elementary School	Room 213 Fountain	1.4 ppb
Benton Elementary School	Room 214 Fountain	1.4 ppb
Benton Elementary School	Room 215 Fountain	7.6 ppb
Benton Elementary School	Room 216 Fountain	1.3 ppb
Benton Elementary School	Room 217 Fountain	0 ppb
Benton Elementary School	Room 218 Fountain	0 ppb
Benton Elementary School	Room 219 Fountain	0 ppb
Benton Elementary School	Room 220 Fountain	1 ppb
Benton Elementary School	Room 221 Fountain	1.1 ppb
Benton Elementary School	Room 222 Fountain	3.1 ppb
Benton Elementary School	Room 223 Fountain	2.5 ppb

School Name	Sample Location	Lead Test Result
Benton Elementary School	Room 224 Fountain	1.8 ppb
Benton Elementary School	Room 229 Bathroom Sink	2.1 ppb
Benton Elementary School	Room 229 Kitchen Sink	0 ppb
Benton Elementary School	West Pod Fountain #1	0 ppb
Benton Elementary School	West Pod Fountain #2	0 ppb
Berwick Academy	1 Ls Classroom 1st Floor	3 ppb
Berwick Academy	1 Ls Water Cooler 1st Floor	1.3 ppb
Berwick Academy	1 Ls Water Cooler 2nd Floor	1.3 ppb
Berwick Academy	1 Ms Boys Restroom Sink 1st Floor	2.4 ppb
Berwick Academy	1 Ms Boys Restroom Sink 2nd Floor	2.8 ppb
Berwick Academy	1 Ms Girls Restroom Sink 1st Floor	1.5 ppb
Berwick Academy	1 Ms Girls Restroom Sink 2nd Floor	2 ppb
Berwick Academy	1 Ms Water Cooler 1st Floor	0 ppb
Berwick Academy	1 Ms Water Cooler 2nd Floor	0 ppb
Berwick Academy	1791 Building All Restroom 1st Floor	3 ppb
Berwick Academy	1791 Building All Restroom 2nd Floor	4 ppb
Berwick Academy	1commons Bldg Mens Room 1st Floor Sink	0 ppb
Berwick Academy	1commons Bldg Poterey Room 1st Floor Sink	1.9 ppb
Berwick Academy	1commons Bldg Womens Room 1st Floor Sink	0 ppb
Berwick Academy	2 Ls Classroom 1st Floor	2.9 ppb
Berwick Academy	2 Ms Boys Restroom Sink 1st Floor	3.9 ppb
Berwick Academy	2 Ms Boys Restroom Sink 2nd Floor	6.9 ppb
Berwick Academy	2 Ms Girls Restroom Sink 1st Floor	10.6 ppb
Berwick Academy	2 Ms Girls Restroom Sink 2nd Floor	2.5 ppb
Berwick Academy	2commons Bldg Mens Room 1st Floor Sink	0 ppb
Berwick Academy	2commons Bldg Poterey Room 1st Floor Sink	1.5 ppb
Berwick Academy	2commons Bldg Womens Room 1st Floor Sink	0 ppb
Berwick Academy	3 Ls Classroom 1st Floor	5.9 ppb
Berwick Academy	3 Ms Boys Restroom Sink 1st Floor	1.6 ppb
Berwick Academy	3 Ms Boys Restroom Sink 2nd Floor	1.9 ppb
Berwick Academy	3 Ms Girls Restroom Sink 1st Floor	1.3 ppb
Berwick Academy	3 Ms Girls Restroom Sink 2nd Floor	1.9 ppb
Berwick Academy	3commons Bldg Mens Room 1st Floor Sink	0 ppb
Berwick Academy	3commons Bldg Womens Room 1st Floor Sink	1.5 ppb
Berwick Academy	4 Ls Classroom 1st Floor	1.5 ppb
Berwick Academy	4 Ms Boys Restroom Sink 1st Floor	1.9 ppb
Berwick Academy	4 Ms Boys Restroom Sink 2nd Floor	0 ppb
Berwick Academy	4 Ms Girls Restroom Sink 1st Floor	2.1 ppb
Berwick Academy	4 Ms Girls Restroom Sink 2nd Floor	2.3 ppb
Berwick Academy	5 Ls Classroom 1st Floor	2.5 ppb
Berwick Academy	Arts Center All Gender Restroom 1	1.9 ppb
Berwick Academy	Arts Center All Gender Restroom 2	2.2 ppb

School Name	Sample Location	Lead Test Result
Berwick Academy	Arts Center Boys Restroom 2nd Floor 1	13.7 ppb
Berwick Academy	Arts Center Boys Restroom 2nd Floor 2	24.9 ppb
Berwick Academy	Arts Center Boys Restroom 2nd Floor 3	18.3 ppb
Berwick Academy	Arts Center Clay Room	2.1 ppb
Berwick Academy	Arts Center Girls Restroom 2nd Floor 1	3.4 ppb
Berwick Academy	Arts Center Girls Restroom 2nd Floor 2	10.1 ppb
Berwick Academy	Arts Center Girls Restroom 2nd Floor 3	7.1 ppb
Berwick Academy	Arts Center Lower School Studio	7.7 ppb
Berwick Academy	Arts Center Middle School Studio	9.6 ppb
Berwick Academy	Arts Center Upper School Studio	8.3 ppb
Berwick Academy	Arts Center Water Cooler 1st Floor	0 ppb
Berwick Academy	Arts Center Water Cooler 2nd Floor	0 ppb
Berwick Academy	Burleigh Davidson All Restroom	3.4 ppb
Berwick Academy	Burleigh Davidson All Restroom 1st Floor 2	2.8 ppb
Berwick Academy	Burleigh Davidson All Restroom 2nd Floor	3.5 ppb
Berwick Academy	Burleigh Davidson All Restroom 3rd Floor	2.7 ppb
Berwick Academy	Burleigh Davidson Kitchen 3rd Floor	3.6 ppb
Berwick Academy	Commons All Gender Room	0 ppb
Berwick Academy	Commons Drinking Fountain	0 ppb
Berwick Academy	Fogg All Gender Restroom 1st Floor	2.4 ppb
Berwick Academy	Fogg Boys Restroom 4th Floor 1	0 ppb
Berwick Academy	Fogg Boys Restroom 4th Floor 2	0 ppb
Berwick Academy	Fogg Girls Restroom 3rd Floor 1	0 ppb
Berwick Academy	Fogg Girls Restroom 3rd Floor 2	0 ppb
Berwick Academy	Fogg Staff Bathroom 2nd Floor	0 ppb
Berwick Academy	Fogg Water Cooler 1st Floor	0 ppb
Berwick Academy	Fogg Water Cooler 3rd Floor	0 ppb
Berwick Academy	Gym All Gender Restroom	1.5 ppb
Berwick Academy	Gym Boys Restroom 1	0 ppb
Berwick Academy	Gym Boys Restroom 2	0 ppb
Berwick Academy	Gym Equipment Room 1st Floor	0 ppb
Berwick Academy	Gym Girls Restroom 1	2.2 ppb
Berwick Academy	Gym Girls Restroom 2	3.1 ppb
Berwick Academy	Gym Home Locker Room (boys) 1	1.1 ppb
Berwick Academy	Gym Home Locker Room (boys) 2	3.5 ppb
Berwick Academy	Gym Home Locker Room (boys) 3	1.4 ppb
Berwick Academy	Gym Home Locker Room (girls) 1	2.2 ppb
Berwick Academy	Gym Home Locker Room (girls) 2	2.4 ppb
Berwick Academy	Gym Home Locker Room (girls) 3	4.7 ppb
Berwick Academy	Gym Trainers Room Sink	3.1 ppb
Berwick Academy	Gym Visitors Locker Room (boys) 1	3.4 ppb
Berwick Academy	Gym Visitors Locker Room (boys) 2	4.4 ppb
Berwick Academy	Gym Visitors Locker Room (girls) 1	1.8 ppb
Berwick Academy	Gym Visitors Locker Room (girls) 2	1.3 ppb
Berwick Academy	Gym Water Cooler 1st Floor	0 ppb
Berwick Academy	Jepp All Gender Restroom 1st Floor	0 ppb
Berwick Academy	Jepp Boys Restroom 1st Floor 1	0 ppb

School Name	Sample Location	Lead Test Result
Berwick Academy	Jepp Boys Restroom 1st Floor 2	0 ppb
Berwick Academy	Jepp Boys Restroom 3rd Floor 1	0 ppb
Berwick Academy	Jepp Boys Restroom 3rd Floor 2	0 ppb
Berwick Academy	Jepp Girls Restroom 1st Floor 1	0 ppb
Berwick Academy	Jepp Girls Restroom 1st Floor 2	5.2 ppb
Berwick Academy	Jepp Girls Restroom 3rd Floor 1	93.9 ppb
Berwick Academy	Jepp Girls Restroom 3rd Floor 2	0 ppb
Berwick Academy	Jepp Rm 102 Sink	4.1 ppb
Berwick Academy	Jepp Rm 103 Sink1	4.6 ppb
Berwick Academy	Jepp Rm 103 Sink2	8.4 ppb
Berwick Academy	Jepp Rm 103 Sink3	22.7 ppb
Berwick Academy	Jepp Rm 104 Sink1	20.1 ppb
Berwick Academy	Jepp Rm 105 Sink1	21.1 ppb
Berwick Academy	Jepp Rm 105 Sink2	11.9 ppb
Berwick Academy	Jepp Rm 105 Sink3	22.5 ppb
Berwick Academy	Jepp Rm 105 Sink4	16.1 ppb
Berwick Academy	Jepp Rm 115 Sink1	6.4 ppb
Berwick Academy	Jepp Rm 115 Sink2	6.9 ppb
Berwick Academy	Jepp Rm 201 Sink 1	25.8 ppb
Berwick Academy	Jepp Rm 201 Sink 2	12.3 ppb
Berwick Academy	Jepp Rm 201 Sink 3	17.2 ppb
Berwick Academy	Jepp Rm 201 Sink 4	36.4 ppb
Berwick Academy	Jepp Rm 202 Sink 1	1.9 ppb
Berwick Academy	Jepp Rm 203 Sink 1	11.2 ppb
Berwick Academy	Jepp Rm 203 Sink 2	7.2 ppb
Berwick Academy	Jepp Rm 207 Sink 1	1.6 ppb
Berwick Academy	Jepp Rm 301 Sink 1	7.4 ppb
Berwick Academy	Jepp Rm 301 Sink 2	3.5 ppb
Berwick Academy	Jepp Rm 301 Sink 3	4.1 ppb
Berwick Academy	Jepp Rm 301 Sink 4	7.4 ppb
Berwick Academy	Jepp Rm 302 Sink 1	9.1 ppb
Berwick Academy	Jepp Rm 303 Sink 1	21.4 ppb
Berwick Academy	Jepp Rm 303 Sink 2	10.4 ppb
Berwick Academy	Jepp Rm 303 Sink 3	5.3 ppb
Berwick Academy	Jepp Rm 303 Sink 4	6.5 ppb
Berwick Academy	Jepp Water Cooler 1st Floor	0 ppb
Berwick Academy	Jepp Water Cooler 3rd Floor	0 ppb
Berwick Academy	Library All Gender Bathroom 2nd Floor	1.1 ppb
Berwick Academy	Library Boys Restroom 1st Floor 1	17.8 ppb
Berwick Academy	Library Boys Restroom 1st Floor 2	1.7 ppb
Berwick Academy	Library Boys Restroom 2nd Floor 1	2.3 ppb
Berwick Academy	Library Boys Restroom 2nd Floor 2	1.3 ppb
Berwick Academy	Library Girls Restroom 1st Floor 1	1.2 ppb
Berwick Academy	Library Girls Restroom 1st Floor 2	4.8 ppb
Berwick Academy	Library Girls Restroom 2nd Floor 1	6 ppb
Berwick Academy	Library Girls Restroom 2nd Floor 2	2.6 ppb
Berwick Academy	Library Water Cooler 1st Floor	0 ppb

School Name	Sample Location	Lead Test Result
Berwick Academy	Library Water Cooler 2nd Floor	0 ppb
Berwick Academy	Lower School Boys Room 2nd Floor	2.7 ppb
Berwick Academy	Lower School Classroom 1 2nd Floor	4 ppb
Berwick Academy	Lower School Classroom 2 2nd Floor	3 ppb
Berwick Academy	Lower School Classroom 3 2nd Floor	2.7 ppb
Berwick Academy	Lower School Classroom 4 2nd Floor	3.5 ppb
Berwick Academy	Lower School Girls Room 2nd Floor	3.9 ppb
Berwick Academy	Lower School Great Room 2nd Floor	2.2 ppb
Berwick Academy	Lower School Teachers Restroom 2nd Floor	3.6 ppb
Berwick Academy	Lower School Teachers Room 2nd Floor	3.3 ppb
Berwick Academy	Ls Boys Room 1st Floor	2.8 ppb
Berwick Academy	Ls Girls Room 1st Floor	2.6 ppb
Berwick Academy	Ls Mr Summers Bathroom 1st Floor	4.3 ppb
Berwick Academy	Ls Pre-k Room 1 1st Floor	5.3 ppb
Berwick Academy	Ls Pre-k Room 2 1st Floor	3.4 ppb
Berwick Academy	Ls Pre-k Room 3 1st Floor	2.9 ppb
Berwick Academy	Ls Pre-k Room 4 1st Floor	2.7 ppb
Berwick Academy	Ls Pre-k Room 5 1st Floor	5.7 ppb
Berwick Academy	Middle School All Gender Restroom 2nd Floor	1.2 ppb
Berwick Academy	Middle School Rm 7 2nd Floor	2 ppb
Berwick Academy	Ms All Gender Restroom 1st Floor	0 ppb
Berwick Academy	Ms Art Room 1st Floor	2.3 ppb
Berwick Academy	Ms Rm 12 1st Floor Sink	3.2 ppb
Berwick Academy	Ms Think Tank Room 1st Floor	35.1 ppb
Berwick Academy	Wellness Cente (oaks)mothers Room Sink	2.1 ppb
Berwick Academy	Wellness Center(jewett)restroom 1st Floor	0 ppb
Berwick Academy	Wellness Center(jewett)restroom 2nd Floor	0 ppb
Berwick Academy	Wellness Center(jewett)test Kitchen 1st Floor	1.1 ppb
Berwick Academy	Wellness Center(jewett)water Cooler 2nd	0 ppb
Berwick Academy	Wellness Center(oaks)bathroom 1st Floor	0 ppb
Berwick Academy	Wellness Center(oaks)bathroom 2st Floor	0 ppb
Berwick Academy	Wellness Center(oaks)nurse Station Sink 1st	1.3 ppb
Biddeford High School	Concessions 3-basin Sink	1.9 ppb
Biddeford High School	Concessions Sink	0 ppb
Biddeford High School	Dwf Band Rm B113	1.8 ppb
Biddeford High School	Dwf Band Rm B114	1 ppb
Biddeford High School	Dwf Gym Ent A	0 ppb
Biddeford High School	Dwf Gym Ent B	0 ppb
Biddeford High School	Dwf Obr B021 A	0 ppb
Biddeford High School	Dwf Obr B021 B	0 ppb
Biddeford High School	Dwf Ocaf A	0 ppb

School Name	Sample Location	Lead Test Result
Biddeford High School	Dwf Ocaf B	0 ppb
Biddeford High School	Dwf Odineenrm A	0 ppb
Biddeford High School	Dwf Odineenrm B	0 ppb
Biddeford High School	Dwf Orm A003 A	0 ppb
Biddeford High School	Dwf Orm A003 B	0 ppb
Biddeford High School	Dwf Orm A032	0 ppb
Biddeford High School	Dwf Orm A034	0 ppb
Biddeford High School	Dwf Orm A147 A	0 ppb
Biddeford High School	Dwf Orm A147 B	0 ppb
Biddeford High School	Dwf Orm A202 A	0 ppb
Biddeford High School	Dwf Orm A202 B	0 ppb
Biddeford High School	Dwf Orm A209 A	0 ppb
Biddeford High School	Dwf Orm A209 B	0 ppb
Biddeford High School	Dwf Orm A318a A	0 ppb
Biddeford High School	Dwf Orm A318a B	0 ppb
Biddeford High School	Dwf Orm B006 A	0 ppb
Biddeford High School	Dwf Orm B006 B	0 ppb
Biddeford High School	Dwf Orm B059	1.4 ppb
Biddeford High School	Dwf Orm B330 A	0 ppb
Biddeford High School	Dwf Orm B330 B	0 ppb
Biddeford High School	Ice Machine	0 ppb
Biddeford High School	Im Ath Rm	0 ppb
Biddeford High School	Im Fridge Rm B059	0 ppb
Biddeford High School	Sink Rm A003 B	0 ppb
Biddeford High School	Sink Rm A003 C	6.1 ppb
Biddeford High School	Snk Ath Rm	0 ppb
Biddeford High School	Snk Band Rm B113	0 ppb
Biddeford High School	Snk Band Rm B114	0 ppb
Biddeford High School	Snk Conc Rm	2 ppb
Biddeford High School	Snk Kitchen A	0 ppb
Biddeford High School	Snk Kitchen B	1 ppb
Biddeford High School	Snk Kitchen C	1.8 ppb
Biddeford High School	Snk Kitchen D	0 ppb
Biddeford High School	Snk Lib Fac Rm	0 ppb
Biddeford High School	Snk Nurse Rm 126	0 ppb
Biddeford High School	Snk Rm A003 A	5.2 ppb
Biddeford High School	Snk Rm A004	2.6 ppb
Biddeford High School	Snk Rm A117	0 ppb
Biddeford High School	Snk Rm A143	0 ppb
Biddeford High School	Snk Rm A325	0 ppb
Biddeford High School	Snk Rm A333	1.1 ppb
Biddeford High School	Snk Rm B009	0 ppb
Biddeford High School	Snk Rm B059	0 ppb
Biddeford High School	Snk Rm B102	0 ppb
Biddeford High School	Snk Rm B302	0 ppb
Biddeford High School	Snk Rm B314	0 ppb
Biddeford High School	Spig Ath Rm L	10.1 ppb

School Name	Sample Location	Lead Test Result
Biddeford High School	Spig Ath Rm R	87 ppb
Biddeford Intermediate School	Dwf Obandrm	68.7 ppb
Biddeford Intermediate School	Dwf Orm 108	0 ppb
Biddeford Intermediate School	Dwf Orm 208	0 ppb
Biddeford Intermediate School	Dwf Orm 303a	0 ppb
Biddeford Intermediate School	Snk Bbr 1a	0 ppb
Biddeford Intermediate School	Snk Bbr 1b	0 ppb
Biddeford Intermediate School	Snk Bbr 2a	1.6 ppb
Biddeford Intermediate School	Snk Bbr 2b	0 ppb
Biddeford Intermediate School	Snk Bbr 2c	0 ppb
Biddeford Intermediate School	Snk Bbr 3a	1.7 ppb
Biddeford Intermediate School	Snk Bbr 3b	1.3 ppb
Biddeford Intermediate School	Snk Bk Bdg	0 ppb
Biddeford Intermediate School	Snk Bk Bdg Br A	0 ppb
Biddeford Intermediate School	Snk Bk Bdg Br B	0 ppb
Biddeford Intermediate School	Snk Bk Bdg Br C	0 ppb
Biddeford Intermediate School	Snk Bk Bdg Br D	0 ppb
Biddeford Intermediate School	Snk Gbr 1a	0 ppb
Biddeford Intermediate School	Snk Gbr 1b	0 ppb
Biddeford Intermediate School	Snk Gbr 2a	1.7 ppb
Biddeford Intermediate School	Snk Gbr 2b	1.1 ppb
Biddeford Intermediate School	Snk Gbr 2c	1.1 ppb
Biddeford Intermediate School	Snk Gbr 3a	1.6 ppb
Biddeford Intermediate School	Snk Gbr 3b	1.5 ppb
Biddeford Intermediate School	Snk Gbr 3c	0 ppb
Biddeford Intermediate School	Snk Kitchen A	0 ppb
Biddeford Intermediate School	Snk Kitchen B	0 ppb
Biddeford Intermediate School	Snk Kitchen C	1.7 ppb
Biddeford Intermediate School	Snk Nurse Rm	0 ppb
Biddeford Intermediate School	Snk Rm 308 A	0 ppb
Biddeford Intermediate School	Snk Rm 308 B	0 ppb
Biddeford Middle School	Dwf Oelevator	0 ppb
Biddeford Middle School	Dwf Orm A037 A	0 ppb
Biddeford Middle School	Dwf Orm A037 B	0 ppb
Biddeford Middle School	Dwf Orm A140 A	1.3 ppb
Biddeford Middle School	Dwf Orm A140 B	0 ppb
Biddeford Middle School	Dwf Orm A140 C	0 ppb
Biddeford Middle School	Dwf Orm A140 D	0 ppb
Biddeford Middle School	Dwf Orm A237 A	0 ppb
Biddeford Middle School	Dwf Orm A237 B	0 ppb
Biddeford Middle School	Dwf Orm A237 C	0 ppb
Biddeford Middle School	Dwf Orm B1333 A	0 ppb
Biddeford Middle School	Dwf Orm B1333 B	0 ppb
Biddeford Middle School	Dwf Orm C145 A	0 ppb
Biddeford Middle School	Dwf Orm C145 B	0 ppb
Biddeford Middle School	Im Kitchen	0 ppb
Biddeford Middle School	Snk Kitchen A	1.6 ppb

School Name	Sample Location	Lead Test Result
Biddeford Middle School	Snk Kitchen B	5.4 ppb
Biddeford Middle School	Snk Kitchen C	1.5 ppb
Biddeford Middle School	Snk Orm A125	0 ppb
Biddeford Middle School	Snk Orm A140	0 ppb
Biddeford Middle School	Snk Orm B169	0 ppb
Biddeford Middle School	Snk Rm A006	0 ppb
Biddeford Middle School	Snk Rm A207	0 ppb
Biddeford Middle School	Snk Rm B133	1.1 ppb
Biddeford Middle School	Snk Rm B146	1.2 ppb
Biddeford Middle School	Snk Rm B148	1.2 ppb
Biddeford Middle School	Snk Rm C102 A	1.8 ppb
Biddeford Middle School	Snk Rm C102 B	1.1 ppb
Biddeford Middle School	Snk Rm C102 C	2.2 ppb
Biddeford Middle School	Snk Rm C107 A	0 ppb
Biddeford Middle School	Snk Rm C107 B	0 ppb
Biddeford Middle School	Snk Rm C107 C	0 ppb
Biddeford Middle School	Snk Rm C107 D	0 ppb
Biddeford Middle School	Snk Rm C118 A	1.6 ppb
Biddeford Middle School	Snk Rm C118 B	0 ppb
Biddeford Middle School	Snk Rm C118 C	1.2 ppb
Biddeford Middle School	Snk Rm C118 D	0 ppb
Biddeford Middle School	Snk Rm C118 E	0 ppb
Biddeford Middle School	Snk Rm C145	14.9 ppb
Biddeford Primary School	Dwf Ocaf A	0 ppb
Biddeford Primary School	Dwf Ocaf B	1.2 ppb
Biddeford Primary School	Dwf Ogym	0 ppb
Biddeford Primary School	Im Kitchen	0 ppb
Biddeford Primary School	Snk Kit Tcenter	1.5 ppb
Biddeford Primary School	Snk Kitchen A	1 ppb
Biddeford Primary School	Snk Kitchen B	2.1 ppb
Biddeford Primary School	Snk Kitchen C	1.1 ppb
Biddeford Primary School	Snk Kitchen D	4.3 ppb
Biddeford Primary School	Snk Kitchen E	2.1 ppb
Biddeford Primary School	Snk Nurse Rm A	0 ppb
Biddeford Primary School	Snk Nurse Rm B	0 ppb
Biddeford Primary School	Snk Rm 18	0 ppb
Biddeford Primary School	Snk Rm 29	0 ppb
Biddeford Primary School	Snk Staff Br A	0 ppb
Biddeford Primary School	Snk Staff Br B	0 ppb
Biddeford Primary School	Snk Staff Br C	0 ppb
Biddeford Primary School	Snk Staff Br D	0 ppb
Biddeford Regional Ctr of Tech	Dwf 1fl	3.9 ppb
Biddeford Regional Ctr of Tech	Dwf Orm T-208	88.8 ppb
Biddeford Regional Ctr of Tech	Sink Room 105	5 ppb
Biddeford Regional Ctr of Tech	Snk 2fl Fac Rm	0 ppb
Bloomfield Elementary School	107 Custodian Sink	0 ppb
Bloomfield Elementary School	121 Nurse Station Eye Wash	6.2 ppb

School Name	Sample Location	Lead Test Result
Bloomfield Elementary School	121 Nurse Station Restroom Sink	4.1 ppb
Bloomfield Elementary School	2nd Floor Custodian Sink	1.1 ppb
Bloomfield Elementary School	Boys Restroom Left Sink	5.3 ppb
Bloomfield Elementary School	Boys Restroom Right Sink	3.8 ppb
Bloomfield Elementary School	Farrington Sink	2.3 ppb
Bloomfield Elementary School	Girls Restroom Left Sink	3.6 ppb
Bloomfield Elementary School	Girls Restroom Right Sink	4.3 ppb
Bloomfield Elementary School	Gym Bottle Fill Station By Kitchen	0 ppb
Bloomfield Elementary School	Hall By Room 128 Bottle Fill Station	0 ppb
Bloomfield Elementary School	Hall By Room 213 Bottle Fill Station	0 ppb
Bloomfield Elementary School	Kitchen Sink 2nd On Right	7 ppb
Bloomfield Elementary School	Kitchen Sink 3rd On Right	2.8 ppb
Bloomfield Elementary School	Kitchen Sink 4th On Right	2.1 ppb
Bloomfield Elementary School	Kitchen Sink On Right	19 ppb
Bloomfield Elementary School	Kitchen Steamer	9.5 ppb
Bloomfield Elementary School	Ot/ Pt Sink	1.2 ppb
Bloomfield Elementary School	Outdoor Spicket 2nd On Right	186 ppb
Bloomfield Elementary School	Outdoor Spicket 3rd On Right	75.1 ppb
Bloomfield Elementary School	Outdoor Spicket 4th On Right	0 ppb
Bloomfield Elementary School	Outdoor Spicket 5th On Right	48.1 ppb
Bloomfield Elementary School	Restroom By 216	11.6 ppb
Bloomfield Elementary School	Room 100 Restroom Sink	0 ppb
Bloomfield Elementary School	Room 100 Wash Sink	0 ppb
Bloomfield Elementary School	Room 101 Custodian Sink	0 ppb
Bloomfield Elementary School	Room 102 Fountain	4.4 ppb
Bloomfield Elementary School	Room 102 Restroom Sink	4.8 ppb
Bloomfield Elementary School	Room 102 Wash Sink	5.3 ppb
Bloomfield Elementary School	Room 103 Fountain	8.4 ppb
Bloomfield Elementary School	Room 103 Restroom Sink	16.2 ppb
Bloomfield Elementary School	Room 103 Wash Sink	3.5 ppb
Bloomfield Elementary School	Room 104 Fountain	2 ppb
Bloomfield Elementary School	Room 104 Restroom Sink	6.9 ppb
Bloomfield Elementary School	Room 104 Wash Sink	3.1 ppb
Bloomfield Elementary School	Room 105 Restroom Sink	2.8 ppb
Bloomfield Elementary School	Room 105 Wash Sink	2.7 ppb
Bloomfield Elementary School	Room 124 Restroom Sink	2.8 ppb
Bloomfield Elementary School	Room 124 Wash Sink	3.2 ppb
Bloomfield Elementary School	Room 126 Fountain	1.7 ppb
Bloomfield Elementary School	Room 126 Restroom Sink	1.7 ppb
Bloomfield Elementary School	Room 126 Wash Sink	1.1 ppb
Bloomfield Elementary School	Room 128 Fountain	2.6 ppb
Bloomfield Elementary School	Room 128 Restroom Sink	1.9 ppb
Bloomfield Elementary School	Room 128 Wash Sink	1.3 ppb
Bloomfield Elementary School	Room 129 Wash Sink	2.7 ppb
Bloomfield Elementary School	Room 201 Fountain	1.8 ppb
Bloomfield Elementary School	Room 201 Library	23.3 ppb
Bloomfield Elementary School	Room 201 Wash Sink	4.5 ppb

School Name	Sample Location	Lead Test Result
Bloomfield Elementary School	Room 202 Fountain	6.6 ppb
Bloomfield Elementary School	Room 202 Wash Sink	2.6 ppb
Bloomfield Elementary School	Room 203 Fountain	3.7 ppb
Bloomfield Elementary School	Room 203 Wash Sink	7.4 ppb
Bloomfield Elementary School	Room 204 Fountain	1.2 ppb
Bloomfield Elementary School	Room 204 Wash Sink	2 ppb
Bloomfield Elementary School	Room 206 Restroom	11.6 ppb
Bloomfield Elementary School	Room 212 Fountain	10.6 ppb
Bloomfield Elementary School	Room 212 Wash Sink	2.5 ppb
Bloomfield Elementary School	Room 213 Fountain	5 ppb
Bloomfield Elementary School	Room 213 Wash Sink	1.2 ppb
Bloomfield Elementary School	Room 215 Wash Sink	4.2 ppb
Bloomfield Elementary School	Room 216 Wash Sink	43.1 ppb
Bloomfield Elementary School	Room 301 Fountain	1.9 ppb
Bloomfield Elementary School	Room 301 Wash Sink	1.8 ppb
Bloomfield Elementary School	Room 302 Fountain	0 ppb
Bloomfield Elementary School	Room 302 Wash Sink	0 ppb
Bloomfield Elementary School	Room 303 Fountain	2.8 ppb
Bloomfield Elementary School	Room 303 Wash Sink	1.3 ppb
Bloomfield Elementary School	Room 304 Fountain	0 ppb
Bloomfield Elementary School	Room 304 Wash Sink	0 ppb
Bloomfield Elementary School	Room 305 Fountain	0 ppb
Bloomfield Elementary School	Room 305 Wash Sink	0 ppb
Bloomfield Elementary School	Staff Restroom	3.3 ppb
Bloomfield Elementary School	Staff Room Sink	77.2 ppb
Blue Hill Consolidated School	5th Grade Wing Outside Spigot	32.3 ppb
Blue Hill Consolidated School	8th Hall Bubbler	5 ppb
Blue Hill Consolidated School	Cafeteria Bottle Fill	1.1 ppb
Blue Hill Consolidated School	Greenhouse Outside Spigot	21.9 ppb
Blue Hill Consolidated School	Gym Bubbler/bottle Fill	0 ppb
Blue Hill Consolidated School	Kitchen 3 Bay Sink Left	15 ppb
Blue Hill Consolidated School	Kitchen 3 Bay Sink Right	12.7 ppb
Blue Hill Consolidated School	Kitchen Hand Sink	9.5 ppb
Blue Hill Consolidated School	Kitchen Pot Filler On Stove	266 ppb
Blue Hill Consolidated School	Kitchen Prep Sink	868 ppb
Blue Hill Consolidated School	Lobby Bubbler/bottle Fill	0 ppb
Blue Hill Consolidated School	Nurses Office	17.6 ppb
Blue Hill Consolidated School	Pre-k Kitchen Sink	4.8 ppb
Blue Hill Consolidated School	Teachers Room	7.7 ppb
Blue Hill Consolidated School	Tech Lab Outside Spigot	22.4 ppb
Blue Hill Harbor School	No Samples Yet Taken	
Blue Point School	Clinic Fountain	14.4 ppb
Blue Point School	Clinic Sink	4.5 ppb
Blue Point School	Gym Bottle Filler	0 ppb
Blue Point School	Gym Fountain	0 ppb
Blue Point School	Kitchen 3-bay Sink	1.8 ppb
Blue Point School	Library Sink	18.1 ppb

School Name	Sample Location	Lead Test Result
Blue Point School	Mid Hall Bottle Filler	0 ppb
Blue Point School	Mid Hall Fountain	0 ppb
Blue Point School	Room 1 Fountain	5.3 ppb
Blue Point School	Room 1 Sink	5.7 ppb
Blue Point School	Room 13 Fountain	7.7 ppb
Blue Point School	Room 13 Sink	23.8 ppb
Blue Point School	Room 14 Fountain	1.9 ppb
Blue Point School	Room 14 Sink	2.8 ppb
Blue Point School	Room 15 Fountain	1.2 ppb
Blue Point School	Room 15 Sink	1.3 ppb
Blue Point School	Room 16 Fountain	7.1 ppb
Blue Point School	Room 16 Sink	1.3 ppb
Blue Point School	Room 17 Fountain	1.4 ppb
Blue Point School	Room 17 Sink	2.5 ppb
Blue Point School	Room 18 Fountain	0 ppb
Blue Point School	Room 18 Sink	2.3 ppb
Blue Point School	Room 19 Fountain	30.4 ppb
Blue Point School	Room 19 Sink	2.2 ppb
Blue Point School	Room 2 Fountain	6.5 ppb
Blue Point School	Room 2 Sink	1.2 ppb
Blue Point School	Room 20 Fountain	1.6 ppb
Blue Point School	Room 20 Sink	0 ppb
Blue Point School	Room 21 Fountain	1.5 ppb
Blue Point School	Room 21 Sink	1.7 ppb
Blue Point School	Room 22 Bath Sink	0 ppb
Blue Point School	Room 23 Bath Sink	0 ppb
Blue Point School	Room 24 Bath Sink	31.7 ppb
Blue Point School	Room 25 Bath Sink	0 ppb
Blue Point School	Room 3 Fountain	6.8 ppb
Blue Point School	Room 3 Sink	3.4 ppb
Blue Point School	Room 4 Fountain	3.1 ppb
Blue Point School	Room 4 Sink	2.5 ppb
Blue Point School	Room 5 Fountain	3.5 ppb
Blue Point School	Room 5 Sink	3.2 ppb
Blue Point School	Room 6 Fountain	10 ppb
Blue Point School	Room 6 Sink	5.7 ppb
Blue Point School	Teacher Break Room Sink	0 ppb
Bonny Eagle High School	Athletic Training Room	4.8 ppb
Bonny Eagle High School	Bottle Fill Across From Room # 105	0 ppb
Bonny Eagle High School	Bottle Fill Across From Room # 122	0 ppb
Bonny Eagle High School	Clinic	2.9 ppb
Bonny Eagle High School	Fountain Across From Library	4.2 ppb
Bonny Eagle High School	Fountain Across From Romm # 223	0 ppb
Bonny Eagle High School	Fountain Across From Room # 105	0 ppb
Bonny Eagle High School	Fountain Across From Room # 122	0 ppb
Bonny Eagle High School	Fountain Across From Room # 127	1.2 ppb
Bonny Eagle High School	Fountain Across From Room # 205	0 ppb

School Name	Sample Location	Lead Test Result
Bonny Eagle High School	Fountain Across From Room # 212	1.6 ppb
Bonny Eagle High School	Fountain Across From Room # 305	0 ppb
Bonny Eagle High School	Fountain Across From Room # 311	1.4 ppb
Bonny Eagle High School	Fountain By Music Room	1 ppb
Bonny Eagle High School	Ice Room	0 ppb
Bonny Eagle High School	Kitchen Prep Sink A	3.5 ppb
Bonny Eagle High School	Kitchen Prep Sink B	27.5 ppb
Bonny Eagle High School	Portable 12	59.7 ppb
Bonny Eagle High School	Room # 102 Faucet A	7.6 ppb
Bonny Eagle High School	Room # 102 Faucet C	5.1 ppb
Bonny Eagle High School	Room # 102 Faucet D	6.7 ppb
Bonny Eagle High School	Room # 102 Faucet E	6.4 ppb
Bonny Eagle High School	Room # 232 Staff	13.2 ppb
Bonny Eagle High School	Room #102 Faucet B	5.2 ppb
Bonny Eagle High School	Staff Room Behind Clinic	2.9 ppb
Bonny Eagle Middle School	Bottle Fill By Room # 109	1.7 ppb
Bonny Eagle Middle School	Bottle Fill By Room # 131	1 ppb
Bonny Eagle Middle School	Bottle Fill By Room # 156	0 ppb
Bonny Eagle Middle School	Bottle Fill By Room # 211	0 ppb
Bonny Eagle Middle School	Faucet A In Room # 116	2.8 ppb
Bonny Eagle Middle School	Faucet A In Room # 127	12.5 ppb
Bonny Eagle Middle School	Faucet B In Room # 116	2 ppb
Bonny Eagle Middle School	Faucet B In Room # 127	19.6 ppb
Bonny Eagle Middle School	Faucet C In Room # 116	3.4 ppb
Bonny Eagle Middle School	Faucet C In Room # 127	10.5 ppb
Bonny Eagle Middle School	Faucet D In Room # 116	3 ppb
Bonny Eagle Middle School	Faucet E In Room # 116	4.6 ppb
Bonny Eagle Middle School	Faucet F In Room # 116	2.1 ppb
Bonny Eagle Middle School	Faucet In Room # 112 (Clinic)	2.3 ppb
Bonny Eagle Middle School	Faucet In Room # 115 B	1.2 ppb
Bonny Eagle Middle School	Faucet In Room # 149 B	1.1 ppb
Bonny Eagle Middle School	Faucet In Room # 150	2.2 ppb
Bonny Eagle Middle School	Faucet In Room # 152	9.1 ppb
Bonny Eagle Middle School	Faucet In Room # 154	1.6 ppb
Bonny Eagle Middle School	Faucet In Room # 156	2.7 ppb
Bonny Eagle Middle School	Faucet In Room # 158	8.3 ppb
Bonny Eagle Middle School	Faucet In Room # 180	2.2 ppb
Bonny Eagle Middle School	Faucet In Room # 209	2.1 ppb
Bonny Eagle Middle School	Faucet In Room # 213	1.5 ppb
Bonny Eagle Middle School	Faucet In Room # 214	13.5 ppb
Bonny Eagle Middle School	Faucet In Room# 211	2.3 ppb
Bonny Eagle Middle School	Fountain By Room # 109	1.5 ppb
Bonny Eagle Middle School	Fountain By Room # 116	6.5 ppb
Bonny Eagle Middle School	Fountain By Room # 131	0 ppb
Bonny Eagle Middle School	Fountain By Room # 156	0 ppb
Bonny Eagle Middle School	Fountain By Room # 204	1.2 ppb
Bonny Eagle Middle School	Fountain By Room # 211	0 ppb

School Name	Sample Location	Lead Test Result
Bonny Eagle Middle School	Fountain By Room # 223	3.9 ppb
Bonny Eagle Middle School	Fountain In Room # 190	8.7 ppb
Bonny Eagle Middle School	Fountain In The Gym Lobby	21.9 ppb
Bonny Eagle Middle School	Kitchen Perp Sink Faucet B	0 ppb
Bonny Eagle Middle School	Kitchen Prep Sink Faucet A	2.4 ppb
Boothbay Region Elem School	Central Office Kitchen Sink Faucet	0 ppb
Boothbay Region Elem School	Drinking Water Fountain By Kitchen Door	0 ppb
Boothbay Region Elem School	Drinking Water Fountain By Room #113	0 ppb
Boothbay Region Elem School	Drinking Water Fountain By Room #119	0 ppb
Boothbay Region Elem School	Drinking Water Fountain By Room #216	0 ppb
Boothbay Region Elem School	Drinking Water Fountain By Room #225	0 ppb
Boothbay Region Elem School	Drinking Water Fountain By Room 232	0 ppb
Boothbay Region Elem School	Drinking Water Fountain Gym West Side	0 ppb
Boothbay Region Elem School	Kitchen Sink #1 Prep Sink	8 ppb
Boothbay Region Elem School	Kitchen Sink #2 Kettle Pot	10.8 ppb
Boothbay Region Elem School	Kitchen Sink #3 Kitchen Left Faucet 3 Bay	2.9 ppb
Boothbay Region Elem School	Kitchen Sink #4 Kitchen Right Faucet 3 Bay	10.1 ppb
Boothbay Region Elem School	Nurses Office Kitchen Faucet	9.8 ppb
Boothbay Region Elem School	Room #101 Kitchen Faucet	1.2 ppb
Boothbay Region Elem School	Room #102 Kitchen Faucet	1.1 ppb
Boothbay Region Elem School	Room #103 Kitchen Faucet	1.6 ppb
Boothbay Region Elem School	Room #104 Kitchen Faucet	1 ppb
Boothbay Region Elem School	Room #105 Kitchen Faucet	1.3 ppb
Boothbay Region Elem School	Room #106 Kitchen Faucet	2.8 ppb
Boothbay Region Elem School	Room #107 Kitchen Faucet	1.3 ppb
Boothbay Region Elem School	Room #108 Kitchen Faucet	2.2 ppb
Boothbay Region Elem School	Room #109 Kitchen Faucet	1.8 ppb
Boothbay Region Elem School	Room #110 Kitchen Faucet	1.7 ppb
Boothbay Region Elem School	Room #112 Sink #1 Home Ec	3.2 ppb
Boothbay Region Elem School	Room #112 Sink #2 Home Ec	2.2 ppb
Boothbay Region Elem School	Room #112 Sink #3 Home Ec	2.9 ppb
Boothbay Region Elem School	Room #112 Sink #4 Home Ec	1.5 ppb
Boothbay Region Elem School	Room #112 Sink #5 Home Ec	1.9 ppb
Boothbay Region Elem School	Room #112 Sink #6 Home Ec	1.9 ppb
Boothbay Region Elem School	Room #225 Kitchen Faucet	7.1 ppb
Boothbay Region Elem School	Room #228 Kitchen Faucet	9.6 ppb
Boothbay Region Elem School	Room #234 Kitchen Faucet	26.3 ppb
Boothbay Region High School	Drinking Water Fountain By Art Room	0 ppb
Boothbay Region High School	Drinking Water Fountain By Main Office	0 ppb
Boothbay Region High School	Drinking Water Fountain By Room #104	0 ppb
Boothbay Region High School	Drinking Water Fountain By Room #203	0 ppb
Boothbay Region High School	Kitchen Sink # 1 Faucet	4.5 ppb
Boothbay Region High School	Kitchen Sink #2 Faucet	3.9 ppb
Boothbay Region High School	Room #107 Kitchen Faucet	2.1 ppb
Boothbay Region High School	Room #112 Kitchen Faucet	5.3 ppb
Boothbay Region High School	Room #117 Teachers Room Kitchen Faucet	1.8 ppb
Bowdoin Central School	1 Sink Nurses Office	0 ppb

School Name	Sample Location	Lead Test Result
Bowdoin Central School	11 Room 120 Faucet	0 ppb
Bowdoin Central School	12 Room 120 Water Fountain	0 ppb
Bowdoin Central School	13 Room 119 Faucet	0 ppb
Bowdoin Central School	14 Room 119 Water Fountain	0 ppb
Bowdoin Central School	15 Room 118 Facuet	0 ppb
Bowdoin Central School	16 Room 118 Water Fountain	0 ppb
Bowdoin Central School	17 Room 117 Faucet	0 ppb
Bowdoin Central School	18 Room 117 Water Fountain	0 ppb
Bowdoin Central School	19 Room 116 Faucet	0 ppb
Bowdoin Central School	20 Room 116 Water Fountain	0 ppb
Bowdoin Central School	21 Water Fountain	0 ppb
Bowdoin Central School	25 Room 112 Faucet	0 ppb
Bowdoin Central School	26 Room 112 Water Fountain	0 ppb
Bowdoin Central School	27 Room 111 Faucet	0 ppb
Bowdoin Central School	28 Room 111 Water Fountain	0 ppb
Bowdoin Central School	29 Room 165 Kitchen Faucet	3 ppb
Bowdoin Central School	3 Staff Room Kitchen Faucet	0 ppb
Bowdoin Central School	31 Room 163 Kitchen Faucet	0 ppb
Bowdoin Central School	32 Room 163 Kitchen Faucet	0 ppb
Bowdoin Central School	33 Room 110 Faucet	0 ppb
Bowdoin Central School	34 Room 110 Water Fountain	0 ppb
Bowdoin Central School	35 Room 109 Faucet	0 ppb
Bowdoin Central School	36 Room 109 Water Fountain	0 ppb
Bowdoin Central School	37 Room 108 Faucet	31.9 ppb
Bowdoin Central School	38 Room 108 Water Fountain	227 ppb
Bowdoin Central School	39 Room 107 Faucet	0 ppb
Bowdoin Central School	4 Water Fountain Hall	0 ppb
Bowdoin Central School	40 Room 107 Water Fountain	0 ppb
Bowdoin Central School	42 Water Fountain	0 ppb
Bowdoin Central School	44 Room 105 Faucet	0 ppb
Bowdoin Central School	45 Room 105 Water Fountain	0 ppb
Bowdoin Central School	47 Room 104 Faucet	0 ppb
Bowdoin Central School	48 Room 104 Water Fountain	0 ppb
Bowdoin Central School	5 Room 121 Faucet	0 ppb
Bowdoin Central School	50 Room 101 Faucet	0 ppb
Bowdoin Central School	51 Room 152 Faucet	2 ppb
Bowdoin Central School	52 Room 157 Faucet	1.6 ppb
Bowdoin Central School	55 Gym Water Fountain	0 ppb
Bowdoin Central School	56 Gym Water Fountain	0 ppb
Bowdoin Central School	6 Room 121 Water Fountain	0 ppb
Bowdoin Central School	61 Main Hall Water Fountain	0 ppb
Bowdoin Central School	62 Main Hall Water Fountain	0 ppb
Bowdoin Central School	63 Kitchen Sink	11 ppb
Bowdoin Central School	64 Dishwasher Sprayer	1.3 ppb
Bowdoin Central School	65 Kitchen Sink	1.2 ppb
Bowdoin Central School	66 Steamer	0 ppb
Bowdoin Central School	68 Hand Wash Sink	1.2 ppb

School Name	Sample Location	Lead Test Result
Bowdoinham Community School	1 Room 1 Kitchen Faucet	9.4 ppb
Bowdoinham Community School	10 Room 4 Kitchen Faucet	4.9 ppb
Bowdoinham Community School	11 Room 4 Water Fountain	2.1 ppb
Bowdoinham Community School	12 Room 8 Kitchen Faucet	8 ppb
Bowdoinham Community School	13 Room 8 Water Fountain	2 ppb
Bowdoinham Community School	14 Room 9 Kitchen Faucet	9.6 ppb
Bowdoinham Community School	15 Room 9 Water Fountain	1.6 ppb
Bowdoinham Community School	16 Room 10 Kitchen Faucet	12.5 ppb
Bowdoinham Community School	17 Room 10 Water Fountain	2.8 ppb
Bowdoinham Community School	2 Room 1 Water Fountain	2.7 ppb
Bowdoinham Community School	21 Room 28 Kitchen Faucet	16 ppb
Bowdoinham Community School	22 Nurse Office Sink	1.9 ppb
Bowdoinham Community School	27 Water Fountain	0 ppb
Bowdoinham Community School	28 Room 15 Kitchen Faucet	13.1 ppb
Bowdoinham Community School	29 Room 16 Kitchen Faucet	7.8 ppb
Bowdoinham Community School	30 Room 16 Kitchen Faucet	3.8 ppb
Bowdoinham Community School	36 Kitchen Faucet	5.2 ppb
Bowdoinham Community School	37 Kitchen Faucet	27.2 ppb
Bowdoinham Community School	38 Kitchen Faucet	14 ppb
Bowdoinham Community School	39 Spigot	1.7 ppb
Bowdoinham Community School	41 Spigot	0 ppb
Bowdoinham Community School	5 Room 2 Kitchen Faucet	4 ppb
Bowdoinham Community School	6 Room 2 Water Fountain	1.7 ppb
Bowdoinham Community School	7 Room 3 Kitchen Faucet	13 ppb
Bowdoinham Community School	8 Room 3 Water Fountain	2.9 ppb
Brewer Community School	Bootle Filler 1st Floor Outside Gym	0 ppb
Brewer Community School	Boottle Filler In Cafe	0 ppb
Brewer Community School	Bottle Filler 1st Floor Main Hallway	0 ppb
Brewer Community School	Bottle Filler 2nd Floor (Tower)	0 ppb
Brewer Community School	Concessions For Pac	12.1 ppb
Brewer Community School	Fountain Outside Chorus Room	0 ppb
Brewer Community School	Ice Machine Beside Gym	0 ppb
Brewer Community School	Kitchen Sink	1.7 ppb
Brewer Community School	Life Skills Room C204	2.6 ppb
Brewer Community School	Nurses Office	3.8 ppb
Brewer Community School	Staff Breakroom - Brick	2.8 ppb
Brewer Community School	Staff Breakroom - Library	4.1 ppb
Brewer Community School	Staff Breakroom In Main Office	2.7 ppb
Brewer Community School	Staff Breakroom River Wing	1.5 ppb
Brewer High School	300 Win Fountain	0 ppb
Brewer High School	Band Room	1.2 ppb
Brewer High School	C.o. Bottle Filler Gym	8.1 ppb
Brewer High School	C.o. Ice Machine Locker Room	0 ppb
Brewer High School	C.o. Kitchen Sink #2 Next To Alpha Room	2.2 ppb
Brewer High School	C.o. Kitchen Sink Next To Alpha Room	8.3 ppb
Brewer High School	C.o. Staff Breakroom	10.4 ppb
Brewer High School	Cafe Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Brewer High School	Gym Fountain	5 ppb
Brewer High School	Gym Ice Machine	2.4 ppb
Brewer High School	Kitchen Sink	0 ppb
Brewer High School	Kitchen Sink #2	0 ppb
Brewer High School	Lobby Fountain	0 ppb
Brewer High School	Maintenance Room	84.4 ppb
Brewer High School	Maintenance Room2	13 ppb
Brewer High School	Room 101	0 ppb
Brewer High School	Room 110	1.2 ppb
Brewer High School	Room 205-206	220 ppb
Brewer High School	Room 206-207	3.4 ppb
Brewer High School	Room 313	0 ppb
Brewer High School	Room 316	31.4 ppb
Brewer High School	Staff Breakroom #2	1.3 ppb
Bridge Crossing Academy	Kitchen Sink	0 ppb
Bridge Crossing Academy	Utility Sink In Hallway	0 ppb
Bridge Crossing Academy	Water Cooler In Hallway	0 ppb
Bridgton Academy	No Samples Yet Taken	
Bristol Consolidated School	Boys Bathroom Middle Class Double Hand Wash Sinka	3 ppb
Bristol Consolidated School	Boys Bathroom Middle Class Double Hand Wash Sinkb	4 ppb
Bristol Consolidated School	Boys Locker Room Hand Washing Sink	5.2 ppb
Bristol Consolidated School	Drinking Water Fountain (west)	3.6 ppb
Bristol Consolidated School	Drinking Water Fountain And Bottle Fill Gym	0 ppb
Bristol Consolidated School	Drinking Water Fountain South And Bottle Fill	0 ppb
Bristol Consolidated School	Girl Bathroom Middle Class Double Hand Wash Sinka	2.8 ppb
Bristol Consolidated School	Girl Bathroom Middle Class Double Hand Wash Sinkb	5.2 ppb
Bristol Consolidated School	Girls Locker Room Hand Washing Sink	17.1 ppb
Bristol Consolidated School	Hand Wash Sink Outside Of Rm#8	2.4 ppb
Bristol Consolidated School	Kitchen Bathroom Hand Wash Basin Sink	0 ppb
Bristol Consolidated School	Kitchen Dish Wash Sink	3.2 ppb
Bristol Consolidated School	Kitchen Hand Wash Sink	2.1 ppb
Bristol Consolidated School	Kitchen Three By Sink- Faucet	5 ppb
Bristol Consolidated School	Kitchen Three By Sink- Sprayer	1.4 ppb
Bristol Consolidated School	N. Drinking Water Fountain & Bottle Fill Station	0 ppb
Bristol Consolidated School	Nurse's Office Sink	16.9 ppb
Bristol Consolidated School	Rm# 17 Hand Wash Sink	2.4 ppb
Bristol Consolidated School	Rm#12 Boys Restroom Hand Wash Sink- A	2.2 ppb
Bristol Consolidated School	Rm#12 Boys Restroom Hand Wash Sink- B	2.9 ppb
Bristol Consolidated School	Rm#13 Hand Wash Sink	4.1 ppb
Bristol Consolidated School	Rm#14 Hand Wash Sink	1.1 ppb

School Name	Sample Location	Lead Test Result
Bristol Consolidated School	Rm#28 Single Basin Sink- A	24 ppb
Bristol Consolidated School	Rm#28 Single Basin Sink- B	386 ppb
Bristol Consolidated School	Rm#28 Single Basin Sink Eye Wash	5.9 ppb
Bristol Consolidated School	Rm#30 Single Basin Sink- A	9.2 ppb
Bristol Consolidated School	Rm#32 Single Basin Sink- A	5.4 ppb
Bristol Consolidated School	Rm#32 Single Basin Sink- B	13.9 ppb
Bristol Consolidated School	Rm#33 Single Basin Sink- A	16.5 ppb
Bristol Consolidated School	Rm#33 Single Basin Sink- B	6.6 ppb
Bristol Consolidated School	Rm#40 Single Basin Sink- A	3.4 ppb
Bristol Consolidated School	Rm#40 Single Basin Sink- B	2.6 ppb
Bristol Consolidated School	Rm#40 Single Basin Sink- C	3.5 ppb
Bristol Consolidated School	Rm#44 Single Basin Sink- A	12.7 ppb
Bristol Consolidated School	Rm#44 Single Basin Sink- B	14.3 ppb
Bristol Consolidated School	Rm#7 Girls Restroom Hand Wash Sink- A	2.1 ppb
Bristol Consolidated School	Rm#7 Girls Restroom Hand Wash Sink- B	7.8 ppb
Bristol Consolidated School	Rm#8 Hand Wash Sink	1.3 ppb
Bristol Consolidated School	Snack Shack Sink	42.3 ppb
Bristol Consolidated School	Staff Bathroom Sink Across Mine Office	1.8 ppb
Bristol Consolidated School	Steam Sink-kitchen	649 ppb
Brixham Montessori Friends School	Art Studio Counter Sink	1.8 ppb
Brixham Montessori Friends School	Elementary Classroom Counter Sink	3.5 ppb
Brixham Montessori Friends School	Elementary Loft Counter Sink (upstairs)	1.8 ppb
Brixham Montessori Friends School	Kitchenette Sink	13.9 ppb
Brixham Montessori Friends School	Main Hall Bathroom (downstairs)	0 ppb
Brixham Montessori Friends School	Outdoor Spigot	2.9 ppb
Brixham Montessori Friends School	Primary 1 Counter Sink	1.3 ppb
Brixham Montessori Friends School	Primary 2 Counter Sink	0 ppb
Brixham Montessori Friends School	Primary 3 Counter Sink	0 ppb
Brixham Montessori Friends School	Toddler Classroom Counter Sink	0 ppb
Brooklin School	Annie Porter Room (6)	2.2 ppb
Brooklin School	Becky Courtot Room (25)	1.1 ppb
Brooklin School	Boys Locker Rm (1)	2.5 ppb
Brooklin School	Boys Restroom (a) Left (13)	19.9 ppb
Brooklin School	Boys Restroom (b) Right (14)	4 ppb
Brooklin School	Cafeteria (a) Left (11)	1.4 ppb
Brooklin School	Cafeteria (b) Right (12)	1.6 ppb
Brooklin School	Emily Newell (life Skills) (20)	1.6 ppb
Brooklin School	Girls Locker Rm (3)	9 ppb
Brooklin School	Girls Locker Shower (4)	73.1 ppb
Brooklin School	Girls Restroom (a) Left (16)	0 ppb
Brooklin School	Girls Restroom (b) Right (17)	2.1 ppb
Brooklin School	Gym Drinking Fountain (2)	1.1 ppb
Brooklin School	Hallway Drinking Fountain (15)	0 ppb
Brooklin School	Hand Wash Sink/kitchen	9.1 ppb
Brooklin School	Julia Baird Room (grades 1&2) (19)	0 ppb
Brooklin School	Julie Wilson Room (pre K And K) (21)	3.2 ppb
Brooklin School	Kitchen (a) Left (7)	0 ppb

School Name	Sample Location	Lead Test Result
Brooklin School	Kitchen ~ Right (9)	2.2 ppb
Brooklin School	Kitchen Dishwasher Sprayer (10)	2.7 ppb
Brooklin School	Kitchen Sprayer (b) Middle (8)	0 ppb
Brooklin School	Neal Kennerk Room (art) (22)	0 ppb
Brooklin School	Nurse Office (24)	4.4 ppb
Brooklin School	Office Restroom (23)	0 ppb
Brooklin School	Staff Lounge (18)	9.4 ppb
Brooklin School	Staff Restroom (5)	2 ppb
Brooksville Elementary School	Big Kids Drinking Fountain Lobby (right)	0 ppb
Brooksville Elementary School	Gym Drinking Fountain	0 ppb
Brooksville Elementary School	Kitchen Food Prep Sink	0 ppb
Brooksville Elementary School	Little Child Drinking Fountain Lobby (left)	3.5 ppb
Brooksville Elementary School	Pre-k Sink	0 ppb
Brownville Elementary School	Composite Room	3.4 ppb
Brownville Elementary School	Room 103	1.3 ppb
Brownville Elementary School	Room 106	5.1 ppb
Brownville Elementary School	Room 107	1.4 ppb
Brownville Elementary School	Room 110	1.4 ppb
Brownville Elementary School	Room 112	1.4 ppb
Brownville Elementary School	Room 115	1.8 ppb
Brownville Elementary School	Room 116	1.3 ppb
Brownville Elementary School	Room 119	2 ppb
Brownville Elementary School	Teachers Break Room	2.6 ppb
Bruce M Whittier Middle School	Adult F114 Sink 17 R	0 ppb
Bruce M Whittier Middle School	Adult F115 Sink 16 L	0 ppb
Bruce M Whittier Middle School	Art Room C116 Sink 43 R	0 ppb
Bruce M Whittier Middle School	Art Room C116 Sink 44 L	0 ppb
Bruce M Whittier Middle School	Art Room C116 Sink 45 L	0 ppb
Bruce M Whittier Middle School	Boy's C134 Sink 30 L	0 ppb
Bruce M Whittier Middle School	Boy's C134 Sink 31 R	1.7 ppb
Bruce M Whittier Middle School	Boy's C134 Sink 32 R	1.5 ppb
Bruce M Whittier Middle School	Boy's F116 Sink 14 R	1.1 ppb
Bruce M Whittier Middle School	Boy's F116 Sink 15 L	0 ppb
Bruce M Whittier Middle School	Boy's L. C110 Sink 48 R	2 ppb
Bruce M Whittier Middle School	Boy's L. C110 Sink 49 L	3.5 ppb
Bruce M Whittier Middle School	Classroom C123 Sink 38 R	0 ppb
Bruce M Whittier Middle School	Classroom C138 Sink 39 L	0 ppb
Bruce M Whittier Middle School	Classroom C140 Sink 40 R	0 ppb
Bruce M Whittier Middle School	Classroom C141 Sink 41 L	1.1 ppb
Bruce M Whittier Middle School	Corr. C151 Sink 47 L	24.2 ppb
Bruce M Whittier Middle School	Corr. F100 Dwf 10	0 ppb
Bruce M Whittier Middle School	Corr. F100 Dwf 11	0 ppb
Bruce M Whittier Middle School	Girl's C133 Sink 35 R	0 ppb
Bruce M Whittier Middle School	Girl's C133 Sink 36 R	0 ppb
Bruce M Whittier Middle School	Girl's C133 Sink 37 R	1.4 ppb
Bruce M Whittier Middle School	Girl's F113 Sink 12 R	1.3 ppb
Bruce M Whittier Middle School	Girl's F113 Sink 13 L	0 ppb

School Name	Sample Location	Lead Test Result
Bruce M Whittier Middle School	Girl's L. C109 Sink 50 R	0 ppb
Bruce M Whittier Middle School	Girl's L. C109 Sink 51 L	0 ppb
Bruce M Whittier Middle School	Jan. C114 Sink 46	0 ppb
Bruce M Whittier Middle School	Janitor C135 Sink 26 R	1.6 ppb
Bruce M Whittier Middle School	Janitor C135 Sink 27 L	2.3 ppb
Bruce M Whittier Middle School	Kitchen A148 Sink 50 L	0 ppb
Bruce M Whittier Middle School	Men's C132 Sink 33 L	0 ppb
Bruce M Whittier Middle School	Ms Gym C112 Dwf 52 L	0 ppb
Bruce M Whittier Middle School	Near Ms Gym O. Faucet 147	772 ppb
Bruce M Whittier Middle School	Nurse A134 Sink 49 L	2.6 ppb
Bruce M Whittier Middle School	Science F101 Sink 1 R	0 ppb
Bruce M Whittier Middle School	Science F101 Sink 2 L	0 ppb
Bruce M Whittier Middle School	Science F101 Sink 3 L	0 ppb
Bruce M Whittier Middle School	Science F101 Sink 4 L	0 ppb
Bruce M Whittier Middle School	Science F102 Sink 5 L	0 ppb
Bruce M Whittier Middle School	Science F102 Sink 6 L	0 ppb
Bruce M Whittier Middle School	Science F102 Sink 7 L	1.2 ppb
Bruce M Whittier Middle School	Science F102 Sink 8 L	0 ppb
Bruce M Whittier Middle School	Science F119 Sink 18 L	1.7 ppb
Bruce M Whittier Middle School	Science F119 Sink 19 R	2.4 ppb
Bruce M Whittier Middle School	Science F119 Sink 20 L	1.2 ppb
Bruce M Whittier Middle School	Science F119 Sink 21 R	0 ppb
Bruce M Whittier Middle School	Science F120 Sink 22 L	0 ppb
Bruce M Whittier Middle School	Science F120 Sink 23 R	2.8 ppb
Bruce M Whittier Middle School	Science F120 Sink 24 R	0 ppb
Bruce M Whittier Middle School	Science F120 Sink 25 L	8.8 ppb
Bruce M Whittier Middle School	Sp. Ed C136 Sink 28 R	0 ppb
Bruce M Whittier Middle School	Sp. Ed C136 Sink 29 L	0 ppb
Bruce M Whittier Middle School	Teacher F107 Sink 9 L	0 ppb
Bruce M Whittier Middle School	Tech Ed. C113 Sink 42 L	0 ppb
Bruce M Whittier Middle School	Toilet A146 Sink 52 L	1 ppb
Bruce M Whittier Middle School	Toilet A147 Sink 51 L	2.8 ppb
Bruce M Whittier Middle School	Women's C131 Sink 34 R	0 ppb
Brunswick High School	*field Men's Bathroom Sink	0 ppb
Brunswick High School	*field Outside Spigot	2.8 ppb
Brunswick High School	*field Outside Water Fountain	0 ppb
Brunswick High School	*field Women's Bathroom Sink	2.9 ppb
Brunswick High School	1/alumni Sink (kitchen)	0 ppb
Brunswick High School	1/bat Cave Boy's Bath (dressing Room Sink)	6.2 ppb
Brunswick High School	1/bat Cave Girl's Bath (dressing Room Sink)	3.6 ppb
Brunswick High School	1/bat Cave Sink Between Dressing Rooms	0 ppb
Brunswick High School	1/boy's B/r First Floor Bottle Station #2	0 ppb
Brunswick High School	1/boy's Gang B/r Sink	0 ppb
Brunswick High School	1/boy's Locker Room Sink	0 ppb
Brunswick High School	1/breakroom Sink	0 ppb

School Name	Sample Location	Lead Test Result
Brunswick High School	1/crooker Concession Sink	6.7 ppb
Brunswick High School	1/darkroom Sink	4.8 ppb
Brunswick High School	1/faculty Lounge Sink	1.5 ppb
Brunswick High School	1/floor Faculty B/r Sink (left)	3.1 ppb
Brunswick High School	1/floor Faculty B/r Sink (right)	3.6 ppb
Brunswick High School	1/girl's B/r First Floor Bottle Station (bottle)	0 ppb
Brunswick High School	1/girl's Gang B/r Sink	0 ppb
Brunswick High School	1/girl's Locker Room Sink	0 ppb
Brunswick High School	1/ice Room Ice Maker Connected To Faucet	1.9 ppb
Brunswick High School	1/kitchen Bathroom Handwash Sink	2.5 ppb
Brunswick High School	1/kitchen Ice Maker (by Door)	0 ppb
Brunswick High School	1/kitchen Sanitize Station (dish Room)	3.6 ppb
Brunswick High School	1/kitchen Sink Across From Warming Station	0 ppb
Brunswick High School	1/kitchen Sink By Dry Rack (und Soap/dish Room)	0 ppb
Brunswick High School	1/kitchen Sink By Office	0 ppb
Brunswick High School	1/kitchen Sink In Counter (across From Cooler)	2 ppb
Brunswick High School	1/kitchen Sink In Counter (under Fire Blanket)	2.9 ppb
Brunswick High School	1/kitchen Sink Udr Towel Disp (next To Ice Mach)	2.3 ppb
Brunswick High School	1/kitchen Spray Nozzle Sink (dish Room)	5 ppb
Brunswick High School	1/kitchen Steamer Faucet	20.8 ppb
Brunswick High School	1/library Office Sink	0 ppb
Brunswick High School	1/lockerroom Ext Drinking Fountain	0 ppb
Brunswick High School	1/main Office Sink (left)	1.1 ppb
Brunswick High School	1/main Office Sink (right)	2.4 ppb
Brunswick High School	1/metalshop Handwash Station Sink	5.9 ppb
Brunswick High School	1/n.courtyard Boy's Br Sink	1.9 ppb
Brunswick High School	1/nadeau B/r Sink	4.6 ppb
Brunswick High School	1/ne Corner Water Fountain	1.1 ppb
Brunswick High School	1/nurse B/r Sink	0 ppb
Brunswick High School	1/room 106/near Water Fountain	183 ppb
Brunswick High School	1/room 110 B/r Sink	2.6 ppb
Brunswick High School	1/room 112 B/r Sink	0 ppb
Brunswick High School	1/room 112 Sink (kitchen)	0 ppb
Brunswick High School	1/room 112 Sink (laundry)	1.6 ppb
Brunswick High School	1/room 114 Sink	0 ppb
Brunswick High School	1/room 116 Sink	2 ppb
Brunswick High School	1/room 119 Sink	4.4 ppb
Brunswick High School	1/room 121 Sink	1.1 ppb
Brunswick High School	1/room 123 B/r Sink	0 ppb
Brunswick High School	1/room 123 Sink (near Door)	1.2 ppb

School Name	Sample Location	Lead Test Result
Brunswick High School	1/room 125 Sink	2.3 ppb
Brunswick High School	1/room 127 Sink	10.6 ppb
Brunswick High School	1/room 129 Sink	2.7 ppb
Brunswick High School	1/room 131 Sink	0 ppb
Brunswick High School	1/s.courtyard Girl's B/r Sink	17.6 ppb
Brunswick High School	1/tech 1 Sink	10.9 ppb
Brunswick High School	1/tuttles Bathroom Sink	4.5 ppb
Brunswick High School	1/voc Hall Boy's Bath Sink (near Door)	13.1 ppb
Brunswick High School	1/voc Hall Drinking Fountain (left Side)	21.1 ppb
Brunswick High School	1/voc Hall Girl's Bath Sink (near Door)	4.6 ppb
Brunswick High School	1/woodshop Handwash Station Sink	4.2 ppb
Brunswick High School	2/boy's B/r Sink	6.6 ppb
Brunswick High School	2/boy's Fill Station	0 ppb
Brunswick High School	2/boy's Gang Br Sink	2.1 ppb
Brunswick High School	2/faculty Lounge Sink	0 ppb
Brunswick High School	2/faculty Men B/r Sink	2.9 ppb
Brunswick High School	2/faculty Women B/r Sink	1.4 ppb
Brunswick High School	2/girl's B/r Sink	8 ppb
Brunswick High School	2/girl's Gang Br Sink	4 ppb
Brunswick High School	2/n.east Corner Water Fountain	8.7 ppb
Brunswick High School	2/room 221 Eyewash Station	3.4 ppb
Brunswick High School	2/room 221 Sink (island)	16.8 ppb
Brunswick High School	2/room 221 Sink (wall)	2 ppb
Brunswick High School	2/room 223 Eyewash Station	12.2 ppb
Brunswick High School	2/room 223 Sink (island)	125 ppb
Brunswick High School	2/room 223 Sink (wall Nearest Door)	4.1 ppb
Brunswick High School	2/room 226 Eyewash Station	11.7 ppb
Brunswick High School	2/room 226 Sink (wall)	3 ppb
Brunswick High School	2/room 227 Closet Sink	2.9 ppb
Brunswick High School	2/room 227 Sink (island)	1.7 ppb
Brunswick High School	2/room 227 Sink (wall)	8.3 ppb
Brunswick High School	2/room 228 Closet Sink	4.6 ppb
Brunswick High School	2/room 229 Eyewash Station	3 ppb
Brunswick High School	2/room 229 Sink (wall Nearest Door)	6.7 ppb
Brunswick High School	2/room 230 Eyewash Station	1.6 ppb
Brunswick High School	2/room 230 Sink (island)	237 ppb
Brunswick High School	2/room 230 Sink (wall)	3.2 ppb
Brunswick High School	2/room 231 Closet Sink	17.5 ppb
Brunswick High School	2/room 231 Eyewash Station	4.2 ppb
Brunswick High School	2/room 231 Sink (island)	12.8 ppb
Brunswick High School	2/room 231 Sink (wall Nearest Door)	49.7 ppb
Brunswick High School	2/room 232 Eyewash Station	2.8 ppb
Brunswick High School	2/room 232 Sink (island)	12.2 ppb
Brunswick High School	2/room 232 Sink (wall)	10 ppb
Brunswick High School	2/room 234 Closet Sink	13.6 ppb
Brunswick High School	2/room 235 Eyewash Station	3.9 ppb
Brunswick High School	2/room 235 Sink (island)	77.6 ppb

School Name	Sample Location	Lead Test Result
Brunswick High School	2/room 235 Sink (wall Nearest Door)	1.9 ppb
Brunswick High School	2/room 236 Eyewash Station	6.3 ppb
Brunswick High School	2/room 236 Sink (wall)	4.9 ppb
Brunswick High School	2/s.east Fill Station	0 ppb
Brunswick High School	2/terrarium Sink	4.9 ppb
Brunswick Jr High School	100 Wing Boy's Bathroom Sink (left)	1.2 ppb
Brunswick Jr High School	100 Wing Boy's Bathroom Sink (right)	1.5 ppb
Brunswick Jr High School	100 Wing Girl's Bathroom Sink (left)	3.9 ppb
Brunswick Jr High School	100 Wing Girl's Bathroom Sink (right)	3.4 ppb
Brunswick Jr High School	100 Wing Water Fountain (near Guidance)	0 ppb
Brunswick Jr High School	200 Wing Boy's Bathroom Sink (center)	0 ppb
Brunswick Jr High School	200 Wing Boy's Bathroom Sink (left)	0 ppb
Brunswick Jr High School	200 Wing Boy's Bathroom Sink (right)	1 ppb
Brunswick Jr High School	200 Wing Custodial Closet	2 ppb
Brunswick Jr High School	200 Wing Girl's Bathroom Sink (center)	0 ppb
Brunswick Jr High School	200 Wing Girl's Bathroom Sink (left)	0 ppb
Brunswick Jr High School	200 Wing Girl's Bathroom Sink (right)	0 ppb
Brunswick Jr High School	200 Wing Water Fountain (near Faculty Brk Rm)	0 ppb
Brunswick Jr High School	300 Wing Bathroom Handwash Sink (back)	0 ppb
Brunswick Jr High School	300 Wing Bathroom Handwash Sink (front)	0 ppb
Brunswick Jr High School	300 Wing Bathroom Handwash Sink (middle)	0 ppb
Brunswick Jr High School	300 Wing Bathroom Near Room 318 (student)	1.7 ppb
Brunswick Jr High School	300 Wing Bathroom Near Room 318 (teacher)	1.6 ppb
Brunswick Jr High School	300 Wing Custodial Closet	6.8 ppb
Brunswick Jr High School	300 Wing Water Fountain	10 ppb
Brunswick Jr High School	Admin Ast. Principal's Bathroom Sink	1.5 ppb
Brunswick Jr High School	Admin Ast. Principal's Dish Sink	1.7 ppb
Brunswick Jr High School	Bottle Fill Staion/bottle (outside Cust Off.)	0 ppb
Brunswick Jr High School	Bottle Fill Staion/drink (outside Cust Off.)	0 ppb
Brunswick Jr High School	Bottle Fill Station/bottle (200 Wing Landing)	0 ppb
Brunswick Jr High School	Bottle Fill Station/drink (200 Wing Landing)	0 ppb
Brunswick Jr High School	Cafeteria Custodial Closet	1.8 ppb
Brunswick Jr High School	Gym Boy's Locker Room #1	1.3 ppb
Brunswick Jr High School	Gym Boy's Locker Room #2	1.7 ppb
Brunswick Jr High School	Gym Girl's Locker Room Sink #1	4.9 ppb
Brunswick Jr High School	Gym Lobby Boy's Bathroom Sink	3.7 ppb
Brunswick Jr High School	Gym Lobby Custodial Closet	10.7 ppb
Brunswick Jr High School	Gym Lobby Girl's Bathroom Sink	4.3 ppb
Brunswick Jr High School	Gym Lobby Water Fountain	45.7 ppb
Brunswick Jr High School	Gym/room 405a Instructors Office	14.3 ppb
Brunswick Jr High School	Kitchen Bathroom Sink	1.1 ppb

School Name	Sample Location	Lead Test Result
Brunswick Jr High School	Kitchen Sink #1	0 ppb
Brunswick Jr High School	Kitchen Sink #2	0 ppb
Brunswick Jr High School	Kitchen Sink #3	3.1 ppb
Brunswick Jr High School	Main Lobby Boy's Bathroom (below Stairs)(center)	0 ppb
Brunswick Jr High School	Main Lobby Boy's Bathroom (below Stairs)(left)	1.3 ppb
Brunswick Jr High School	Main Lobby Boy's Bathroom (below Stairs)(right)	0 ppb
Brunswick Jr High School	Main Lobby Custodial Closet (below Stairs)	1.1 ppb
Brunswick Jr High School	Main Lobby Girl's Bathroom (below Stairs)(ctr)	0 ppb
Brunswick Jr High School	Main Lobby Girl's Bathroom (below Stairs)(left)	0 ppb
Brunswick Jr High School	Main Lobby Girl's Bathroom (below Stairs)(right)	0 ppb
Brunswick Jr High School	Main Lobby Water Fountain (near Office)	36.3 ppb
Brunswick Jr High School	Room 101/fls Bathroom Shower	2.5 ppb
Brunswick Jr High School	Room 101/fls Excersize Area Sink	1.1 ppb
Brunswick Jr High School	Room 101/fls Kitchen Sink	27.3 ppb
Brunswick Jr High School	Room 102/science Sink (ring)	7.6 ppb
Brunswick Jr High School	Room 103/science Sink	19.3 ppb
Brunswick Jr High School	Room 103a/sub Room Sink	7.9 ppb
Brunswick Jr High School	Room 105 Sink	3.3 ppb
Brunswick Jr High School	Room 108 Sink	8.4 ppb
Brunswick Jr High School	Room 111/guidance Sink	8.2 ppb
Brunswick Jr High School	Room 201d/library Office Sink	5.5 ppb
Brunswick Jr High School	Room 201f/tech Sink	6.3 ppb
Brunswick Jr High School	Room 206a Faculty Bathroom Sink	1.7 ppb
Brunswick Jr High School	Room 206a Faculty Breakroom Sink	3.1 ppb
Brunswick Jr High School	Room 208 Closet Sink	1130 ppb
Brunswick Jr High School	Room 208/science Sink	15.6 ppb
Brunswick Jr High School	Room 300/sicence Closet Sink	0 ppb
Brunswick Jr High School	Room 307b/reading Sink	1.5 ppb
Brunswick Jr High School	Room 310 Classroom Sink	3.2 ppb
Brunswick Jr High School	Room 318 First Class Sink	0 ppb
Brunswick Jr High School	Room 318/homeec Kitchen Sink (#1)	3.1 ppb
Brunswick Jr High School	Room 318/homeec Kitchen Sink (#2)	0 ppb
Brunswick Jr High School	Room 318/homeec Kitchen Sink (#3)	0 ppb
Brunswick Jr High School	Room 318/homeec Kitchen Sink (#4)	2.5 ppb
Brunswick Jr High School	Room 319 Art Hallway Sink (w/eyewash)	2.5 ppb
Brunswick Jr High School	Room 319 Waterfountain (near Art)	0 ppb
Brunswick Jr High School	Room 319a/art Sink (#1)	0 ppb
Brunswick Jr High School	Room 319a/art Sink (#2)	0 ppb
Brunswick Jr High School	Room 319a/art Sink (#3)	3.3 ppb
Brunswick Jr High School	Room 319a/art Sink (#4)	0 ppb
Brunswick Jr High School	Room 319b/art Sink (#1)	0 ppb

School Name	Sample Location	Lead Test Result
Brunswick Jr High School	Room 319b/art Sink (#2)	0 ppb
Brunswick Jr High School	Room 319b/art Sink (#3)	0 ppb
Brunswick Jr High School	Room 319b/art Sink (#4)	1.1 ppb
Brunswick Jr High School	Room 402a Admin Secretary Bathroom Sink	2.7 ppb
Brunswick Jr High School	Room 403 Sink	1.5 ppb
Brunswick Jr High School	Room 406 Bathroom Sink	3 ppb
Brunswick Jr High School	Room 408 Nurse Office Sink	0 ppb
Buckfield Jr-Sr High School	106a- Classroom Sink	3 ppb
Buckfield Jr-Sr High School	106b- Bathroom Sink	1.7 ppb
Buckfield Jr-Sr High School	110a Sink- Art Room	61.4 ppb
Buckfield Jr-Sr High School	110b Sink- Art Room	57.4 ppb
Buckfield Jr-Sr High School	115a- Kitchen Sink	2.3 ppb
Buckfield Jr-Sr High School	115b- Kitchen Sink	4.1 ppb
Buckfield Jr-Sr High School	115c- Kitchen Sink	1.7 ppb
Buckfield Jr-Sr High School	115d- Kitchen Sink	14.6 ppb
Buckfield Jr-Sr High School	115e- Bathroom Sink	1.4 ppb
Buckfield Jr-Sr High School	128a- Sink	0 ppb
Buckfield Jr-Sr High School	210a Sink- High School Biology	77.1 ppb
Buckfield Jr-Sr High School	210b Sink- High School Biology	4.4 ppb
Buckfield Jr-Sr High School	210c Sink- High School Biology	59.2 ppb
Buckfield Jr-Sr High School	210e Sink- High School Biology	113 ppb
Buckfield Jr-Sr High School	210f Sink- High School Biology	10.8 ppb
Buckfield Jr-Sr High School	210g Sink- High School Biology	35.7 ppb
Buckfield Jr-Sr High School	210h Sink- Closet	417 ppb
Buckfield Jr-Sr High School	216b Sink- Middle School Science	27.4 ppb
Buckfield Jr-Sr High School	216c Sink- Middle School Science	217 ppb
Buckfield Jr-Sr High School	216d Sink- Middle School Science	29 ppb
Buckfield Jr-Sr High School	218a Sink- High School Science	9.6 ppb
Buckfield Jr-Sr High School	308a- Kitchen	1.1 ppb
Buckfield Jr-Sr High School	308b- Kitchen	4.2 ppb
Buckfield Jr-Sr High School	308c- Kitchen	2.2 ppb
Buckfield Jr-Sr High School	308d- Kitchen	1.3 ppb
Buckfield Jr-Sr High School	308e- Kitchen	16.5 ppb
Buckfield Jr-Sr High School	308f- Kitchen	11.6 ppb
Buckfield Jr-Sr High School	309a- P.e Office	24.6 ppb
Buckfield Jr-Sr High School	309b- Trainers Office	4.6 ppb
Buckfield Jr-Sr High School	310a- Nurse Office	3.1 ppb
Buckfield Jr-Sr High School	310b- Nurse Bathroom	0 ppb
Buckfield Jr-Sr High School	Drinking Fountain Downstairs Hs Wing (df1)	0 ppb
Buckfield Jr-Sr High School	Drinking Fountain In Gym (df2)	0 ppb
Buckfield Jr-Sr High School	Drinking Fountain In High School (df4)	0 ppb
Buckfield Jr-Sr High School	Drinking Fountain- Middle School (df3)	0 ppb
Buckfield Jr-Sr High School	High School Boys Bathroom (hsbb1)	3.9 ppb
Buckfield Jr-Sr High School	High School Boys Bathroom (hsbb2)	1.9 ppb
Buckfield Jr-Sr High School	High School Girls Bathroom (hsgb1)	1.4 ppb

School Name	Sample Location	Lead Test Result
Buckfield Jr-Sr High School	High School Girls Bathroom (hsgb2)	1.6 ppb
Buckfield Jr-Sr High School	High School Girls Bathroom (hsgb3)	3.2 ppb
Buckfield Jr-Sr High School	Mens Locker Room (mlr1)	4 ppb
Buckfield Jr-Sr High School	Mens Locker Room (mlr2)	3.2 ppb
Buckfield Jr-Sr High School	Middle School Boys Bathroom (msbb2)	4.3 ppb
Buckfield Jr-Sr High School	Middle School Girls Bathroom (msgb1)	0 ppb
Buckfield Jr-Sr High School	Middle School Girls Bathroom (msgb2)	2.7 ppb
Buckfield Jr-Sr High School	Office Bathroom In Office (ob1)	1.1 ppb
Buckfield Jr-Sr High School	Staff Bathroom By Kitchen (sb1)	0 ppb
Buckfield Jr-Sr High School	Staff Bathroom In High School Wing (sb5)	2.7 ppb
Buckfield Jr-Sr High School	Staff Bathroom In Teachers Room (sb2)	2.2 ppb
Buckfield Jr-Sr High School	Staff Bathroom In Teachers Room (sb3)	1.3 ppb
Buckfield Jr-Sr High School	Staff Bathroom- Middle School Wing (sb4)	0 ppb
Buckfield Jr-Sr High School	Student Lobby- Boys Bathroom (bb1)	1.3 ppb
Buckfield Jr-Sr High School	Student Lobby- Boys Bathroom (bb2)	3.1 ppb
Buckfield Jr-Sr High School	Student Lobby- Girls Bathroom (gb1)	1.4 ppb
Buckfield Jr-Sr High School	Student Lobby- Girls Bathroom (gb2)	1.4 ppb
Buckfield Jr-Sr High School	Womens Locker Room (wlr1)	1.2 ppb
Buckfield Jr-Sr High School	Womens Locker Room (wlr2)	2.1 ppb
Bucksport High School	1st Floor By Entrance	0 ppb
Bucksport High School	2nd Floor Hallway Main Stairs	0 ppb
Bucksport High School	Gym - Boys Side	0 ppb
Bucksport High School	Gym - Girls Side	0 ppb
Bucksport High School	Kitchen Sink Center	1.6 ppb
Bucksport High School	Kitchen Sink Left	2.1 ppb
Bucksport High School	Kitchen Sink North Left Side	1.7 ppb
Bucksport High School	Kitchen Sink North Right Side	5.9 ppb
Bucksport High School	Kitchen Sink Right	4.6 ppb
Bucksport High School	Kitchen Steamer	1.5 ppb
Bucksport High School	Science Wing	0 ppb
Bucksport Middle School	Blue Wing Hall	0 ppb
Bucksport Middle School	Fountain Closest To Computer Room	0 ppb
Bucksport Middle School	Fountain Closest To Wood Shop	0 ppb
Bucksport Middle School	Green Wing Hall	0 ppb
Bucksport Middle School	Kitchen	0 ppb
Bucksport Middle School	Kitchen Kettle	7.4 ppb
Bucksport Middle School	Kitchen Steamer	1.2 ppb
Bucksport Middle School	Music Room Room Behind Stage	5 ppb
Bucksport Middle School	Red Wing Hall	0 ppb
Bucksport Middle School	Yellow Wing Hall	0 ppb
Burchard A Dunn School	Class Sink Rm # 1007	0 ppb
Burchard A Dunn School	Class Sink Rm # 19	2.8 ppb
Burchard A Dunn School	Class Sink Rm # 23a/b	0 ppb
Burchard A Dunn School	Class Sink Rm #17	1.4 ppb
Burchard A Dunn School	Class Sink Rm #22	0 ppb
Burchard A Dunn School	Class Sink Rm #24	0 ppb
Burchard A Dunn School	Class Sink Rm #25	0 ppb

School Name	Sample Location	Lead Test Result
Burchard A Dunn School	Class Sink Rm #26	0 ppb
Burchard A Dunn School	Class Sink Rm #27	1.1 ppb
Burchard A Dunn School	Class Sink Rm #29	0 ppb
Burchard A Dunn School	Class Sink Rm #37	0 ppb
Burchard A Dunn School	Class Sink Rm #38	0 ppb
Burchard A Dunn School	Class Sink Rm #41	0 ppb
Burchard A Dunn School	Class Sink Rm #44	0 ppb
Burchard A Dunn School	Class Sink Rm #45	1.6 ppb
Burchard A Dunn School	Class Sink Rm #46	0 ppb
Burchard A Dunn School	Class Sink Rm #47	0 ppb
Burchard A Dunn School	Class Sink Rm #48	0 ppb
Burchard A Dunn School	Class Sink Rm #51	0 ppb
Burchard A Dunn School	Class Sink Rm #53	0 ppb
Burchard A Dunn School	Class Sink Rm #60	0 ppb
Burchard A Dunn School	Class Sink Rm #61	0 ppb
Burchard A Dunn School	Class Sink Rm #62	0 ppb
Burchard A Dunn School	Hall Bottle Fill	0 ppb
Burchard A Dunn School	Hall Water Bottle Filler #1	0 ppb
Burchard A Dunn School	Hall Water Bottle Filler #2	0 ppb
Burchard A Dunn School	Kitchen 3 Bay	4 ppb
Burchard A Dunn School	Kitchen Food Prep	0 ppb
Burchard A Dunn School	Nurse Station Sink Rm #12	0 ppb
Burchard A Dunn School	Sink Bubbler Rm #35	0 ppb
Burchard A Dunn School	Staff Lounge Sink Rm #31	0 ppb
Buxton Center Elementary School	By A 171 Lower Fountain	0 ppb
Buxton Center Elementary School	By A 171 Upper Fountain	0 ppb
Buxton Center Elementary School	By A156 Upper Fountain	0 ppb
Buxton Center Elementary School	By C 227 Lower Fountain	0 ppb
Buxton Center Elementary School	By C 227 Upper Fountain	0 ppb
Buxton Center Elementary School	Office Staff Room Faucet	0 ppb
Buxton Center Elementary School	Room # A132 Kitchen Prep Faucet A	1.5 ppb
Buxton Center Elementary School	Room # A132 Kitchen Prep Faucet B	0 ppb
Buxton Center Elementary School	Room # A145 Faucet	0 ppb
Buxton Center Elementary School	Room # A165 Fountain	0 ppb
Buxton Center Elementary School	Room # A170 Fountain	0 ppb
Buxton Center Elementary School	Room A 116 Faucet	0 ppb
Buxton Center Elementary School	Room A 117 Faucet	1.1 ppb
Buxton Center Elementary School	Room A 122 Faucet	1.2 ppb
Buxton Center Elementary School	Room A 175 Faucet A	0 ppb
Buxton Center Elementary School	Room A 175 Faucet B	0 ppb
Buxton Center Elementary School	Room A 175 Faucet C	0 ppb
Buxton Center Elementary School	Room A 179 Faucet A	0 ppb
Buxton Center Elementary School	Room A 179 Faucet B	1 ppb
Buxton Center Elementary School	Room A 179 Faucet C	0 ppb
Buxton Center Elementary School	Room B 110 Faucet	55.5 ppb
Buxton Center Elementary School	Room B 111 Faucet	0 ppb
Buxton Center Elementary School	Room B 111 Fountain	1.3 ppb

School Name	Sample Location	Lead Test Result
Buxton Center Elementary School	Room B 114 Faucet	0 ppb
Buxton Center Elementary School	Room B 114 Fountain	1.6 ppb
Buxton Center Elementary School	Room B 118 Faucet	0 ppb
Buxton Center Elementary School	Room B 118 Fountain	2.8 ppb
Buxton Center Elementary School	Room B 121 Faucet	0 ppb
Buxton Center Elementary School	Room B 121 Fountain	2 ppb
Buxton Center Elementary School	Room B 123 Faucet	0 ppb
Buxton Center Elementary School	Room B 123 Fountain	1.6 ppb
Buxton Center Elementary School	Room B 125 Faucet	0 ppb
Buxton Center Elementary School	Room B 128 Faucet	0 ppb
Buxton Center Elementary School	Room B 135 Faucet	0 ppb
Buxton Center Elementary School	Room B 205 Faucet	0 ppb
Buxton Center Elementary School	Room B 208 Faucet	0 ppb
Buxton Center Elementary School	Room B 208 Fountain	1.6 ppb
Buxton Center Elementary School	Room B 209 Faucet	0 ppb
Buxton Center Elementary School	Room B 209 Fountain	2.3 ppb
Buxton Center Elementary School	Room B 212 Faucet	0 ppb
Buxton Center Elementary School	Room B 212 Fountain	1.9 ppb
Buxton Center Elementary School	Room B 217 Faucet	0 ppb
Buxton Center Elementary School	Room B 217 Fountain	1.4 ppb
Buxton Center Elementary School	Room B 220 Faucet	0 ppb
Buxton Center Elementary School	Room B 220 Fountain	1.6 ppb
Buxton Center Elementary School	Room B 221 Faucet	0 ppb
Buxton Center Elementary School	Room B 221 Fountain	1.8 ppb
Buxton Center Elementary School	Room B 231 Faucet	0 ppb
Buxton Center Elementary School	Room B125 Fountain	1.6 ppb
Buxton Center Elementary School	Room C 111 Faucet	0 ppb
Buxton Center Elementary School	Room C 111 Fountain	3.6 ppb
Buxton Center Elementary School	Room C 114 Faucet	0 ppb
Buxton Center Elementary School	Room C 114 Fountain	3.1 ppb
Buxton Center Elementary School	Room C 116 Faucet	0 ppb
Buxton Center Elementary School	Room C 116 Fountain	1.8 ppb
Buxton Center Elementary School	Room C 118 Faucet	0 ppb
Buxton Center Elementary School	Room C 118 Fountain	1.5 ppb
Buxton Center Elementary School	Room C 121 Faucet	0 ppb
Buxton Center Elementary School	Room C 121 Fountain	2 ppb
Buxton Center Elementary School	Room C 125 Faucet	0 ppb
Buxton Center Elementary School	Room C 125 Fountain	2.4 ppb
Buxton Center Elementary School	Room C 128 Faucet	0 ppb
Buxton Center Elementary School	Room C 128 Fountain	1.5 ppb
Buxton Center Elementary School	Room C 129 Faucet	0 ppb
Buxton Center Elementary School	Room C 129 Fountain	2.2 ppb
Buxton Center Elementary School	Room C 203 Faucet	0 ppb
Buxton Center Elementary School	Room C 203 Fountain	3.2 ppb
Buxton Center Elementary School	Room C 206 Faucet	0 ppb
Buxton Center Elementary School	Room C 206 Fountain	2.1 ppb
Buxton Center Elementary School	Room C 207 Faucet	0 ppb

School Name	Sample Location	Lead Test Result
Buxton Center Elementary School	Room C 207 Fountain	2.1 ppb
Buxton Center Elementary School	Room C 210 Faucet	0 ppb
Buxton Center Elementary School	Room C 210 Fountain	2.9 ppb
Buxton Center Elementary School	Room C 215 Faucet	0 ppb
Buxton Center Elementary School	Room C 215 Fountain	2.9 ppb
Buxton Center Elementary School	Room C 218 Faucet	0 ppb
Buxton Center Elementary School	Room C 218 Fountain	3.1 ppb
Buxton Center Elementary School	Room C 219 Faucet	0 ppb
Buxton Center Elementary School	Room C 219 Fountain	1.9 ppb
Buxton Center Elementary School	Room C109 Faucet	0 ppb
Buxton Center Elementary School	Room C109 Fountain	2.9 ppb
Buxton Center Elementary School	Room D 111 Faucet	0 ppb
Buxton Center Elementary School	Room D 111 Fountain	1.8 ppb
Buxton Center Elementary School	Room D 114 Faucet	0 ppb
Buxton Center Elementary School	Room D 114 Fountain	2.3 ppb
Buxton Center Elementary School	Room D 118 Fountain	1.5 ppb
Buxton Center Elementary School	Room D 120 Faucet	0 ppb
Buxton Center Elementary School	Room D 120 Fountain	1.5 ppb
Buxton Center Elementary School	Room D 123 Faucet	0 ppb
Buxton Center Elementary School	Room D 123 Fountain	1.3 ppb
Buxton Center Elementary School	Room D 125 Faucet	0 ppb
Buxton Center Elementary School	Room D 125 Fountain	0 ppb
Buxton Center Elementary School	Room D 128 Faucet	0 ppb
Buxton Center Elementary School	Room D 128 Fountain	2.1 ppb
Buxton Center Elementary School	Room D 129 Faucet	0 ppb
Buxton Center Elementary School	Room D 129 Fountain	1.2 ppb
Buxton Center Elementary School	Room D 132 Faucet	1.2 ppb
Buxton Center Elementary School	Room D 133 Faucet	1 ppb
Buxton Center Elementary School	Room D 210 Faucet	0 ppb
Buxton Center Elementary School	Room D 210 Fountain	2.4 ppb
Buxton Center Elementary School	Room D 211 Faucet	1.9 ppb
Buxton Center Elementary School	Room D 211 Fountain	2.8 ppb
Buxton Center Elementary School	Room D 214 Faucet	0 ppb
Buxton Center Elementary School	Room D 214 Fountain	2.6 ppb
Buxton Center Elementary School	Room D 219 Faucet	0 ppb
Buxton Center Elementary School	Room D 219 Fountain	1.7 ppb
Buxton Center Elementary School	Room D 222 Fauvet	0 ppb
Buxton Center Elementary School	Room D 222 Fountain	1.3 ppb
Buxton Center Elementary School	Room D 223 Faucet	0 ppb
Buxton Center Elementary School	Room D 223 Fountain	2.6 ppb
Buxton Center Elementary School	Room D 226 Faucet	0 ppb
Buxton Center Elementary School	Room D 226 Fountain	2.4 ppb
Buxton Center Elementary School	Roomd 118 Faucet	0 ppb
C K Burns School	Drinking Water Fountain Bubbler Outside Fac. Room	1.6 ppb
C K Burns School	Drinking Water Fountain Bubbler Outside Room 16	1.6 ppb

School Name	Sample Location	Lead Test Result
C K Burns School	Drinking Water Fountain Bubbler Outside Room 21	3.1 ppb
C K Burns School	Drinking Water Fountain Bubbler Outside Room 21 B	0 ppb
C K Burns School	Drinking Water Fountain Bubbler Outside Room 6 A	0 ppb
C K Burns School	Drinking Water Fountain Bubbler Outside Room 6 B	0 ppb
C K Burns School	Dwf Gym	0 ppb
C K Burns School	Dwf Obr 1fl	0 ppb
C K Burns School	Dwf Ofac Rm	0 ppb
C K Burns School	Dwf Orm 16	0 ppb
C K Burns School	Dwf Orm21 2fl	0 ppb
C K Burns School	Dwf Orm27	2.2 ppb
C K Burns School	Dwf Orm6 A	0 ppb
C K Burns School	Dwf Orm64	0 ppb
C K Burns School	Snk 1fl Fac Rm	0 ppb
C K Burns School	Snk 2fl Fac Rm	2.2 ppb
C K Burns School	Snk Kitchen A	16.5 ppb
C K Burns School	Snk Kitchen B	2.6 ppb
Calais Alternative School	Bottle Fill Station	0 ppb
Calais Alternative School	Teachers Lounge	0 ppb
Calais Alternative School	Water Fountain	0 ppb
Calais Elementary School	Bottle Fill Station (Cafeteria)	1.2 ppb
Calais Elementary School	Bottle Fill Station (Gym)	0 ppb
Calais Elementary School	Bottle Fill Station (5&6 Grade Wing)	0 ppb
Calais Elementary School	Bottle Fill Station (1&2 Grade Wing)	0 ppb
Calais Elementary School	Drinking Fountain (5&6 Grade Wing) Lower	0 ppb
Calais Elementary School	Drinking Fountain (5&6 Grade Wing) Upper	0 ppb
Calais Elementary School	Drinking Fountain (1&2 Grade Wing) Lower	0 ppb
Calais Elementary School	Drinking Fountain (1&2 Grade Wing) Upper	0 ppb
Calais Elementary School	Drinking Water Fountain (Cafeteria)	1.3 ppb
Calais Elementary School	Drinking Water Fountain (Gym) Lower	0 ppb
Calais Elementary School	Kitchen Kettle (Left)	72.6 ppb
Calais Elementary School	Kitchen Kettle (Right)	7.8 ppb
Calais Elementary School	Kitchen Single Bay Sink	3.3 ppb
Calais Elementary School	Kitchen Three Bay Sink	7.3 ppb
Calais Elementary School	Teachers Lounge Sink	2 ppb
Calais Middle/High School	Business Wing Bottle Fill Station	0 ppb
Calais Middle/High School	Business Wing Drinking Fountain Lower	0 ppb
Calais Middle/High School	Business Wing Drinking Fountain Upper	0 ppb
Calais Middle/High School	Gym Drinking Fountain	7.1 ppb
Calais Middle/High School	High School Bottle Fill Station	0 ppb
Calais Middle/High School	High School Drinking Fountain Lower	0 ppb
Calais Middle/High School	High School Drinking Fountain Upper	0 ppb

School Name	Sample Location	Lead Test Result
Calais Middle/High School	Kitchen Ice Machine	0 ppb
Calais Middle/High School	Kitchen Kettle	14.3 ppb
Calais Middle/High School	Kitchen Single Bay Sink (Back Wall)	4.8 ppb
Calais Middle/High School	Kitchen Three Bay Sink (Back Wall)	3 ppb
Calais Middle/High School	Middle School Bottle Fill Station	0 ppb
Calais Middle/High School	Middle School Drinking Fountain Lower	0 ppb
Calais Middle/High School	Middle School Drinking Fountain Upper	0 ppb
Calais Middle/High School	Teacher's Lounge	2 ppb
Camden Hills Regional H S	A Ground Bottle Fill/water Fountain	0 ppb
Camden Hills Regional H S	A Ground Water Fountain	0 ppb
Camden Hills Regional H S	Blackbox Dressing Room #1 Sink	1.3 ppb
Camden Hills Regional H S	Blackbox Dressing Room #2 Sink	10.3 ppb
Camden Hills Regional H S	Bottle Fill By Rm 227	0 ppb
Camden Hills Regional H S	Bottle Fill/fountain By Rm 327	0 ppb
Camden Hills Regional H S	Bottle Fill/fountain By Rm 425	0 ppb
Camden Hills Regional H S	Bottle Fill/fountain By School Store	0 ppb
Camden Hills Regional H S	Boys Pe Locker Room Large Sink Left	0 ppb
Camden Hills Regional H S	Boys Pe Locker Room Large Sink Right	0 ppb
Camden Hills Regional H S	Boys Pe Locker Room Small Sink Left	2.9 ppb
Camden Hills Regional H S	Boys Pe Locker Room Small Sink Right	0 ppb
Camden Hills Regional H S	Boys Restroom By 223 Sink Left	0 ppb
Camden Hills Regional H S	Boys Restroom By 223 Sink Middle	1.3 ppb
Camden Hills Regional H S	Boys Restroom By 223 Sink Right	1.3 ppb
Camden Hills Regional H S	Boys Restroom By 323 Sink Left	0 ppb
Camden Hills Regional H S	Boys Restroom By Cafe Sink Left	0 ppb
Camden Hills Regional H S	Boys Restroom By Cafe Sink Middle	0 ppb
Camden Hills Regional H S	Boys Restroom By Cafe Sink Right	0 ppb
Camden Hills Regional H S	Boys Restroom By Rm 123 Sink Left	0 ppb
Camden Hills Regional H S	Boys Restroom By Rm 123 Sink Middle	2.4 ppb
Camden Hills Regional H S	Boys Restroom By Rm 123 Sink Right	0 ppb
Camden Hills Regional H S	Boys Restroom By Rm 323 Sink Middle	0 ppb
Camden Hills Regional H S	Boys Restroom By Rm 323 Sink Right	1 ppb
Camden Hills Regional H S	Chorus Rm Sink	0 ppb
Camden Hills Regional H S	D Wing Boys Restroom Sink	1.7 ppb
Camden Hills Regional H S	D Wing Girls Restroom Sink	3.3 ppb
Camden Hills Regional H S	D Wing Water Fountain Left	0 ppb
Camden Hills Regional H S	D Wing Water Fountain Right	0 ppb
Camden Hills Regional H S	Exterior Spigot By Gym Entrance	216 ppb
Camden Hills Regional H S	Exterior Spigot Maintenance Building	1 ppb
Camden Hills Regional H S	Girls Pe Locker Room Large Sink Left	0 ppb
Camden Hills Regional H S	Girls Pe Locker Room Large Sink Right	1.5 ppb
Camden Hills Regional H S	Girls Pe Locker Room Small Sink Left	1.5 ppb
Camden Hills Regional H S	Girls Pe Locker Room Small Sink Right	2.6 ppb
Camden Hills Regional H S	Girls Restroom By Cafe Sink 2nd From Left	0 ppb
Camden Hills Regional H S	Girls Restroom By Cafe Sink 2nd From Right	0 ppb
Camden Hills Regional H S	Girls Restroom By Cafe Sink Left	0 ppb

School Name	Sample Location	Lead Test Result
Camden Hills Regional H S	Girls Restroom By Cafe Sink Right	0 ppb
Camden Hills Regional H S	Girls Restroom By Rm 123 Sink Left	2.5 ppb
Camden Hills Regional H S	Girls Restroom By Rm 123 Sink Middle	0 ppb
Camden Hills Regional H S	Girls Restroom By Rm 123 Sink Right	0 ppb
Camden Hills Regional H S	Girls Restroom By Rm 223 Sink Left	1.6 ppb
Camden Hills Regional H S	Girls Restroom By Rm 223 Sink Middle	6.1 ppb
Camden Hills Regional H S	Girls Restroom By Rm 223 Sink Right	0 ppb
Camden Hills Regional H S	Girls Restroom By Rm 323 Sink Left	2.3 ppb
Camden Hills Regional H S	Girls Restroom By Rm 323 Sink Middle	0 ppb
Camden Hills Regional H S	Girls Restroom By Rm 323 Sink Right	1.5 ppb
Camden Hills Regional H S	Guidance Office Restroom Sink	0 ppb
Camden Hills Regional H S	Kitchen 1 Bay Sink	5 ppb
Camden Hills Regional H S	Kitchen 2 Bay Sink	8 ppb
Camden Hills Regional H S	Kitchen 3 Bay Sink	2 ppb
Camden Hills Regional H S	Kitchen Coffee Maker	166 ppb
Camden Hills Regional H S	Kitchen Dishwasher Spray Sink	1.6 ppb
Camden Hills Regional H S	Kitchen Icemaker	0 ppb
Camden Hills Regional H S	Kitchen Kettle	0 ppb
Camden Hills Regional H S	Kitchen Large Sink By Sub Line	18.3 ppb
Camden Hills Regional H S	Kitchen Large Sink By Grill	8.8 ppb
Camden Hills Regional H S	Kitchen Sink By Icemaker	1 ppb
Camden Hills Regional H S	Kitchen Small Sink By Grill	1 ppb
Camden Hills Regional H S	Kitchen Small Sink By Sub Line	10.4 ppb
Camden Hills Regional H S	Kitchen Steamer Left Bottom	3.8 ppb
Camden Hills Regional H S	Kitchen Steamer Left Top	2.2 ppb
Camden Hills Regional H S	Kitchen Steamer Right Bottom	21 ppb
Camden Hills Regional H S	Kitchen Steamer Right Top	1.5 ppb
Camden Hills Regional H S	Kitchen Tilt Skillet	19 ppb
Camden Hills Regional H S	Main Office Restroom Sink	1.3 ppb
Camden Hills Regional H S	Maint Building Restroom Athletic Side	0 ppb
Camden Hills Regional H S	Maintenance Building Restroom Maint Side	0 ppb
Camden Hills Regional H S	Nurse Office Exam Rm Sink	1.2 ppb
Camden Hills Regional H S	Nurse Office Restroom Sink	0 ppb
Camden Hills Regional H S	Restroom By Rm 231 Sink	0 ppb
Camden Hills Regional H S	Restroom By Rm 333 Sink	0 ppb
Camden Hills Regional H S	Rm 111 Prep Room Sink	0 ppb
Camden Hills Regional H S	Rm 231 Fcs Kitchen Sink #1	0 ppb
Camden Hills Regional H S	Rm 231 Fcs Kitchen Sink #2	0 ppb
Camden Hills Regional H S	Rm 231 Fcs Kitchen Sink #3	0 ppb
Camden Hills Regional H S	Rm 231 Fcs Kitchen Sink #4	0 ppb
Camden Hills Regional H S	Staff Lounge Sink	0 ppb
Camden Hills Regional H S	Stagecraft Sink	0 ppb
Camden Hills Regional H S	Training Room Ice Maker	0 ppb
Camden Hills Regional H S	Training Room Sink	0 ppb
Camden Hills Regional H S	Water Fountain By Rm 227	0 ppb
Camden Hills Regional H S	Water Fountain By Rm 228 Left	99.2 ppb

School Name	Sample Location	Lead Test Result
Camden Hills Regional H S	Water Fountain By Rm 228 Right	4.2 ppb
Camden Hills Regional H S	Water Fountain By Rm 327	0 ppb
Camden Hills Regional H S	Water Fountain By Rm 328 Left	1.7 ppb
Camden Hills Regional H S	Water Fountain By Rm 328 Right	3.5 ppb
Camden Hills Regional H S	Water Fountain By Rm 425	0 ppb
Camden Hills Regional H S	Water Fountain By School Store	0 ppb
Camden Hills Regional H S	Water Fountain By Senior Lounge Left	0 ppb
Camden Hills Regional H S	Water Fountain By Senior Lounge Right	2 ppb
Camden Hills Regional H S	Water Fountain Pe Corridor Left	0 ppb
Camden Hills Regional H S	Water Fountain Pe Corridor Right	0 ppb
Camden-Rockport Elementary School	Adult Lav Sink By Room 227	0 ppb
Camden-Rockport Elementary School	Art Room Sink Center	0 ppb
Camden-Rockport Elementary School	Art Room Sink Left	1.7 ppb
Camden-Rockport Elementary School	Art Room Sink Right	1.3 ppb
Camden-Rockport Elementary School	Bottle Fill Fountain By Room 345	0 ppb
Camden-Rockport Elementary School	Bottle Fill Fountain By Staff Workroom	0 ppb
Camden-Rockport Elementary School	Boys Lav (by Room 157) Left	0 ppb
Camden-Rockport Elementary School	Boys Lav (by Room 157) Right	0 ppb
Camden-Rockport Elementary School	Boys Lav By Gym Office Left Center Sink	0 ppb
Camden-Rockport Elementary School	Boys Lav By Gym Office Left Sink	8 ppb
Camden-Rockport Elementary School	Boys Lav By Gym Office Right Center Sink	48.8 ppb
Camden-Rockport Elementary School	Boys Lav By Gym Office Right Sink	0 ppb
Camden-Rockport Elementary School	By Room 225 Bottle Fill And Drink	0 ppb
Camden-Rockport Elementary School	Cafeteria Bottle Fill And Drink	0 ppb
Camden-Rockport Elementary School	Cafeteria Drink Fountain	41 ppb
Camden-Rockport Elementary School	Girls Lav (by Room 151) Left	1.1 ppb
Camden-Rockport Elementary School	Girls Lav (by Room 151) Right	0 ppb
Camden-Rockport Elementary School	Girls Lav By Gym Office Left Center Sink	80.6 ppb
Camden-Rockport Elementary School	Girls Lav By Gym Office Left Sink	1.1 ppb
Camden-Rockport Elementary School	Girls Lav By Gym Office Right Center Sink	0 ppb
Camden-Rockport Elementary School	Girls Lav By Gym Office Right Sink	53.9 ppb
Camden-Rockport Elementary School	Kitchen Ice Maching	0 ppb
Camden-Rockport Elementary School	Kitchen North Wall Sink	2 ppb
Camden-Rockport Elementary School	Kitchen South Wall Triple Sink Left	0 ppb
Camden-Rockport Elementary School	Kitchen South Wall Triple Sink Right	1.2 ppb
Camden-Rockport Elementary School	Lav By Room 251 Left Sink	1.6 ppb
Camden-Rockport Elementary School	Lav By Room 251 Right Sink	1 ppb
Camden-Rockport Elementary School	Lav By Room 257 Sink	1.3 ppb
Camden-Rockport Elementary School	Lav By Room 351 Left Sink	1.8 ppb
Camden-Rockport Elementary School	Lav By Room 351 Right Sink	1.3 ppb
Camden-Rockport Elementary School	Lav By Room 357 Sink	2 ppb
Camden-Rockport Elementary School	Library Drink Fountain	3.5 ppb
Camden-Rockport Elementary School	Lower Level Bottle Fill And Drink	0 ppb
Camden-Rockport Elementary School	Lower Level Water Fountain By Elevator	2.5 ppb
Camden-Rockport Elementary School	Mag Area Student Lav Left Sink	0 ppb
Camden-Rockport Elementary School	Mag Area Student Lav Right Sink	0 ppb
Camden-Rockport Elementary School	Mag Hall Bottle Fill And Drink	0 ppb

School Name	Sample Location	Lead Test Result
Camden-Rockport Elementary School	Mag Hall Drink Fountain	5.2 ppb
Camden-Rockport Elementary School	Mens Lav By Gym Office	1.3 ppb
Camden-Rockport Elementary School	Mid Level East Room 287 Sink	29.9 ppb
Camden-Rockport Elementary School	Nurses Lavatory Sink	0 ppb
Camden-Rockport Elementary School	Nurses Office Sink	0 ppb
Camden-Rockport Elementary School	Room 149 Drink Fountain	0 ppb
Camden-Rockport Elementary School	Room 151 Drink Fountain	2.6 ppb
Camden-Rockport Elementary School	Room 157 Drink Fountain	0 ppb
Camden-Rockport Elementary School	Room 159 Drink Fountain	0 ppb
Camden-Rockport Elementary School	Room 161 Drink Fountain	2.2 ppb
Camden-Rockport Elementary School	Room 167 Drink Fountain	7 ppb
Camden-Rockport Elementary School	Room 169 Drink Fountain	3.1 ppb
Camden-Rockport Elementary School	Room 172 Drink Fountain	2 ppb
Camden-Rockport Elementary School	Room 215 Lav Sink	0 ppb
Camden-Rockport Elementary School	Room 215 Wash Sink	0 ppb
Camden-Rockport Elementary School	Room 217 Lav Sink	0 ppb
Camden-Rockport Elementary School	Room 217 Wash Sink	2.3 ppb
Camden-Rockport Elementary School	Room 223 Drink Fountain	0 ppb
Camden-Rockport Elementary School	Room 225 Drink Fountain	1.2 ppb
Camden-Rockport Elementary School	Room 233 Handwash Sink	0 ppb
Camden-Rockport Elementary School	Room 233 Lav Sink	0 ppb
Camden-Rockport Elementary School	Room 237 Handwash Sink	0 ppb
Camden-Rockport Elementary School	Room 239 Handwash Sink	0 ppb
Camden-Rockport Elementary School	Room 249 Sink	0 ppb
Camden-Rockport Elementary School	Room 251 Sink	0 ppb
Camden-Rockport Elementary School	Room 257 Sink	0 ppb
Camden-Rockport Elementary School	Room 259 Sink	1.6 ppb
Camden-Rockport Elementary School	Room 261 Sink	10.4 ppb
Camden-Rockport Elementary School	Room 283 Sink	9.6 ppb
Camden-Rockport Elementary School	Room 285 Sink	2.2 ppb
Camden-Rockport Elementary School	Room 307 Handwash Sink	1.3 ppb
Camden-Rockport Elementary School	Room 309 Handwash Sink	0 ppb
Camden-Rockport Elementary School	Room 349 Sink	1.6 ppb
Camden-Rockport Elementary School	Room 351 Sink	1.4 ppb
Camden-Rockport Elementary School	Room 357 Sink	1 ppb
Camden-Rockport Elementary School	Room 359 Sink	3.1 ppb
Camden-Rockport Elementary School	Room 361 Sink	8.6 ppb
Camden-Rockport Elementary School	Staff Breakroom Sink Room 243	0 ppb
Camden-Rockport Elementary School	Staff Restroom By 345 Sink	0 ppb
Camden-Rockport Elementary School	Staff Restroom Of Room 247	0 ppb
Camden-Rockport Elementary School	Student Lav Sink By Room 225 Left	0 ppb
Camden-Rockport Elementary School	Student Lav Sink By Room 225 Right	0 ppb
Camden-Rockport Elementary School	Student Rest Room By Elevator LI	2 ppb
Camden-Rockport Elementary School	Water Fountain By Gym Office Left	11.1 ppb
Camden-Rockport Elementary School	Water Fountain By Gym Office Right	5.7 ppb
Camden-Rockport Elementary School	Water Fountain By Room 345	7 ppb
Camden-Rockport Elementary School	Water Fountain By Staff Workroom	5.3 ppb

School Name	Sample Location	Lead Test Result
Camden-Rockport Elementary School	West Area Kitchen Sink	0 ppb
Camden-Rockport Elementary School	West Area Staff Lavatory Sink	0 ppb
Camden-Rockport Elementary School	West Room 227 Drink Fountain	0 ppb
Camden-Rockport Elementary School	West Upper Bottle Fill And Drink	0 ppb
Camden-Rockport Elementary School	West Upper Boys Lav Wash Sink	0 ppb
Camden-Rockport Elementary School	West Upper Girls Lav Wash Sink	0 ppb
Camden-Rockport Elementary School	West Upper Room 301 Handwash Sink	0 ppb
Camden-Rockport Elementary School	West Upper Staff Lav Sink	1.1 ppb
Camden-Rockport Elementary School	Womens Lav By Gym Office	0 ppb
Camden-Rockport Middle School	Bb Boys Restroom Sink Left	0 ppb
Camden-Rockport Middle School	Bb Boys Restroom Sink Right	0 ppb
Camden-Rockport Middle School	Bb Corridor Bottle Fill Water Fountain	0 ppb
Camden-Rockport Middle School	Bb Girls Restroom Sink Left	0 ppb
Camden-Rockport Middle School	Bb Girls Restroom Sink Right	0 ppb
Camden-Rockport Middle School	Bb Rm 17 Kitchen Sink	1.8 ppb
Camden-Rockport Middle School	Bb Room 24 Sink	1.4 ppb
Camden-Rockport Middle School	Bb Room 25 Bathroom Sink	3.6 ppb
Camden-Rockport Middle School	Bottle Fill/water Fountain By Rm 009	0 ppb
Camden-Rockport Middle School	Bottle Fill/water Fountain By Rm 114	0 ppb
Camden-Rockport Middle School	Bottle Fill/water Fountain By Rm 167	0 ppb
Camden-Rockport Middle School	Bottle Fill/water Fountain By Rm 255	0 ppb
Camden-Rockport Middle School	Bottle Fill/water Fountain Cafeteria	0 ppb
Camden-Rockport Middle School	Concessions Sink	0 ppb
Camden-Rockport Middle School	Kitchen 3 Bay Sink	0 ppb
Camden-Rockport Middle School	Kitchen Dishwasher Sprayer	1.4 ppb
Camden-Rockport Middle School	Kitchen Double Bowl Sink	0 ppb
Camden-Rockport Middle School	Kitchen Hand Wash Sink North End	0 ppb
Camden-Rockport Middle School	Kitchen Hand Wash Sink Theatre End	0 ppb
Camden-Rockport Middle School	Kitchen Ice Maker	0 ppb
Camden-Rockport Middle School	Kitchen Steamer	2.1 ppb
Camden-Rockport Middle School	Main Office Workroom Sink	0 ppb
Camden-Rockport Middle School	Nurses Office 108b Sink	2 ppb
Camden-Rockport Middle School	Nurses Office 108c Sink	0 ppb
Camden-Rockport Middle School	Nurses Office Room 108 Ice Machine	0 ppb
Camden-Rockport Middle School	Nurses Office Room 108 Sink	1.5 ppb
Camden-Rockport Middle School	Rm 003 Girls Restroom - Sink Left	0 ppb
Camden-Rockport Middle School	Rm 003 Girls Restroom - Sink Middle	1.2 ppb
Camden-Rockport Middle School	Rm 003 Girls Restroom - Sink Right	0 ppb
Camden-Rockport Middle School	Rm 007 Boys Restroom - Sink Left	0 ppb
Camden-Rockport Middle School	Rm 007 Boys Restroom - Sink Middle	0 ppb
Camden-Rockport Middle School	Rm 007 Boys Restroom - Sink Right	0 ppb
Camden-Rockport Middle School	Rm 009 Restroom - Sink	0 ppb
Camden-Rockport Middle School	Rm 014 Girls Locker - Sink Left	0 ppb
Camden-Rockport Middle School	Rm 014 Girls Locker - Sink Right	0 ppb
Camden-Rockport Middle School	Rm 015 Boys Locker - Sink Left	0 ppb
Camden-Rockport Middle School	Rm 015 Boys Locker - Sink Right	0 ppb
Camden-Rockport Middle School	Rm 044 Sink	2 ppb

School Name	Sample Location	Lead Test Result
Camden-Rockport Middle School	Rm 045 Kitchen Sink	0 ppb
Camden-Rockport Middle School	Rm 045a Restroom Sink	0 ppb
Camden-Rockport Middle School	Rm 047 Workroom Sink	0 ppb
Camden-Rockport Middle School	Rm 050 Restroom Sink	0 ppb
Camden-Rockport Middle School	Rm 059 Restroom Sink	0 ppb
Camden-Rockport Middle School	Rm 061 Restroom Sink	0 ppb
Camden-Rockport Middle School	Rm 063 Classroom Sink	0 ppb
Camden-Rockport Middle School	Rm 065 Classroom Sink	1.1 ppb
Camden-Rockport Middle School	Rm 066 Classroom Sink	0 ppb
Camden-Rockport Middle School	Rm 067 Classroom Sink	0 ppb
Camden-Rockport Middle School	Rm 068 Classroom Sink	1.4 ppb
Camden-Rockport Middle School	Rm 109 Restroom Sink	1.2 ppb
Camden-Rockport Middle School	Rm 113 - Gym Storage - Ice Machine	0 ppb
Camden-Rockport Middle School	Rm 114 Girls Restroom Sink Left	2.5 ppb
Camden-Rockport Middle School	Rm 114 Girls Restroom Sink Right	0 ppb
Camden-Rockport Middle School	Rm 117 Boys Restroom Sink Left	0 ppb
Camden-Rockport Middle School	Rm 117 Boys Restroom Sink Right	1.4 ppb
Camden-Rockport Middle School	Rm 119 Restroom Sink	0 ppb
Camden-Rockport Middle School	Rm 126 Restroom Sink	0 ppb
Camden-Rockport Middle School	Rm 127 Boys Restroom Sink Left	0 ppb
Camden-Rockport Middle School	Rm 127 Boys Restroom Sink Right	0 ppb
Camden-Rockport Middle School	Rm 128 Girls Restroom Sink Left	0 ppb
Camden-Rockport Middle School	Rm 128 Girls Restroom Sink Middle	0 ppb
Camden-Rockport Middle School	Rm 128 Girls Restroom Sink Right	0 ppb
Camden-Rockport Middle School	Rm 12b - Locker Rm - Sink	0 ppb
Camden-Rockport Middle School	Rm 133 Staff Sink	0 ppb
Camden-Rockport Middle School	Rm 134 Band Room Sink	0 ppb
Camden-Rockport Middle School	Rm 152 Restroom Sink	0 ppb
Camden-Rockport Middle School	Rm 153 Fcs Kitchen Sink Blue Area	0 ppb
Camden-Rockport Middle School	Rm 153 Fcs Kitchen Sink Green Area	0 ppb
Camden-Rockport Middle School	Rm 153 Fcs Kitchen Sink Orange Area	0 ppb
Camden-Rockport Middle School	Rm 153 Fcs Kitchen Sink Purple Area	6.5 ppb
Camden-Rockport Middle School	Rm 153 Fcs Kitchen Sink Red Area	0 ppb
Camden-Rockport Middle School	Rm 153 Fcs Kitchen Sink Yellow Area	0 ppb
Camden-Rockport Middle School	Rm 165 Classroom Sink	0 ppb
Camden-Rockport Middle School	Rm 166 Classroom Sink	0 ppb
Camden-Rockport Middle School	Rm 167 Classroom Sink	1 ppb
Camden-Rockport Middle School	Rm 245 Restroom Sink	0 ppb
Camden-Rockport Middle School	Rm 247 Restroom Sink	0 ppb
Camden-Rockport Middle School	Rm 249 Girls Restroom Sink Left	0 ppb
Camden-Rockport Middle School	Rm 249 Girls Restroom Sink Right	0 ppb
Camden-Rockport Middle School	Rm 251 Boys Restroom Sink Left	0 ppb
Camden-Rockport Middle School	Rm 251 Boys Restroom Sink Right	0 ppb
Camden-Rockport Middle School	Rm 253 Restroom Sink	0 ppb
Camden-Rockport Middle School	Rm 257 Classroom Sink	0 ppb
Camden-Rockport Middle School	Rm 258 Workroom Sink	1.3 ppb
Camden-Rockport Middle School	Rm 259 Classroom Sink	0 ppb

School Name	Sample Location	Lead Test Result
Camden-Rockport Middle School	Rm 260 Classroom Sink	0 ppb
Camden-Rockport Middle School	Rm 262 Classroom Sink	0 ppb
Camden-Rockport Middle School	Rm 263 Classroom Sink	2.5 ppb
Camden-Rockport Middle School	Rm 265 Classroom Sink	0 ppb
Camden-Rockport Middle School	Rm 266 Classroom Sink	0 ppb
Camden-Rockport Middle School	Rm 267 Classroom Sink	0 ppb
Camden-Rockport Middle School	Water Fount/bottle Fill Gym	0 ppb
Camden-Rockport Middle School	Water Fountain By Rm 009	0 ppb
Camden-Rockport Middle School	Water Fountain By Rm 255	0 ppb
Camden-Rockport Middle School	Water Fountain By Room 114	0 ppb
Canaan Elementary School	Boys Restroom Wash Sink Far Left	0 ppb
Canaan Elementary School	Boys Restroom Wash Sink Right	0 ppb
Canaan Elementary School	Closet 1 Sink	8.9 ppb
Canaan Elementary School	Girls Restroom Wash Sink Far Right	0 ppb
Canaan Elementary School	Girls Restroom Wash Sink Left	0 ppb
Canaan Elementary School	Hall By Girls Restroom Bottle Fill	0 ppb
Canaan Elementary School	Hall By Room 15 Bottle Fill Station	0 ppb
Canaan Elementary School	Hall By Room 21 Bottle Fill Station	0 ppb
Canaan Elementary School	Hall By Wing Girls Restroom Bottle Fill	0 ppb
Canaan Elementary School	Kitchen 1 Basin Sink Left Of Dishwasher	23.9 ppb
Canaan Elementary School	Kitchen 3 Basin Sink By Freezer	0 ppb
Canaan Elementary School	Kitchen Dishwasher	0 ppb
Canaan Elementary School	Kitchen Steamer	0 ppb
Canaan Elementary School	Kitchen Wash Sink Right Of Dishwasher	0 ppb
Canaan Elementary School	Outside Spicket By Room 4	0 ppb
Canaan Elementary School	Room 1 Fountain	10.4 ppb
Canaan Elementary School	Room 1 Wash Sink	0 ppb
Canaan Elementary School	Room 14 Fountain	4.7 ppb
Canaan Elementary School	Room 15 Wash Sink	0 ppb
Canaan Elementary School	Room 16 Fountain	10.9 ppb
Canaan Elementary School	Room 16 Wash Sink	0 ppb
Canaan Elementary School	Room 17 Fountain	3.2 ppb
Canaan Elementary School	Room 17 Wash Sink	0 ppb
Canaan Elementary School	Room 18 Fountain	3.5 ppb
Canaan Elementary School	Room 18 Wash Sink	0 ppb
Canaan Elementary School	Room 19 Fountain	3.5 ppb
Canaan Elementary School	Room 19 Wash Sink	0 ppb
Canaan Elementary School	Room 2 Wash Sink	2.1 ppb
Canaan Elementary School	Room 20 Fountain	5.3 ppb
Canaan Elementary School	Room 20 Wash Sink	0 ppb
Canaan Elementary School	Room 21 Fountain	0 ppb
Canaan Elementary School	Room 21 Wash Sink	0 ppb
Canaan Elementary School	Room 3 Wash Sink	5.5 ppb
Canaan Elementary School	Room 4 Fountain	0 ppb
Canaan Elementary School	Room 4 Wash Sink	5 ppb
Canaan Elementary School	Teachers Restroom Wash Sink	0 ppb
Canaan Elementary School	Teachers Room Wash Sink	0 ppb

School Name	Sample Location	Lead Test Result
Canaan Elementary School	Wing Boys Restroom Sink 2nd From Right	0 ppb
Canaan Elementary School	Wing Boys Restroom Sink 3rd From Right	0 ppb
Canaan Elementary School	Wing Boys Restroom Sink 4th From Right	0 ppb
Canaan Elementary School	Wing Boys Restroom Sink Far Right	0 ppb
Canaan Elementary School	Wing Closet Wash Sink	3.5 ppb
Canaan Elementary School	Wing Girls Restroom Sink 2nd From Right	0 ppb
Canaan Elementary School	Wing Girls Restroom Sink 3rd From Right	0 ppb
Canaan Elementary School	Wing Girls Restroom Sink 4th From Right	0 ppb
Canaan Elementary School	Wing Girls Restroom Sink Far Right	0 ppb
Canaan Elementary School	Wing Teachers Wash Sink	0 ppb
Cape Cod Hill Elem School	Bottle Fill Outside Elevator	0 ppb
Cape Cod Hill Elem School	Kitchen Kettle	8.7 ppb
Cape Cod Hill Elem School	Kitchen Sink #1	2.1 ppb
Cape Cod Hill Elem School	Kitchen Sink #2	0 ppb
Cape Cod Hill Elem School	Sink #1 Art Room	0 ppb
Cape Cod Hill Elem School	Sink #1 Outside Elevator Upstairs	0 ppb
Cape Cod Hill Elem School	Sink #2 Art Room	0 ppb
Cape Cod Hill Elem School	Sink #2 Outside Elevator Upstairs	0 ppb
Cape Cod Hill Elem School	Sink Nurse's Room	6 ppb
Cape Cod Hill Elem School	Sink Room 101	0 ppb
Cape Cod Hill Elem School	Sink Room 102	3.2 ppb
Cape Cod Hill Elem School	Sink Room 103	6.7 ppb
Cape Cod Hill Elem School	Sink Room 104	5.4 ppb
Cape Cod Hill Elem School	Sink Room 105	3.2 ppb
Cape Cod Hill Elem School	Sink Room 106	5.2 ppb
Cape Cod Hill Elem School	Sink Room 202	7.8 ppb
Cape Cod Hill Elem School	Sink Room 203	13.8 ppb
Cape Cod Hill Elem School	Sink Room 204	13.9 ppb
Cape Cod Hill Elem School	Sink Room 205	15.8 ppb
Cape Cod Hill Elem School	Sink Room 206	11.3 ppb
Cape Cod Hill Elem School	Sink Teachers Room	1.6 ppb
Cape Elizabeth High School	1st Floor Facilities Mens Restroom L	3.5 ppb
Cape Elizabeth High School	1st Floor Facilities Mens Restroom R	2.9 ppb
Cape Elizabeth High School	1st Floor Facilities Womens Restroom L	2.4 ppb
Cape Elizabeth High School	1st Floor Facilities Womens Restroom R	1.7 ppb
Cape Elizabeth High School	1st Floor Mens Restroom Left	1.1 ppb
Cape Elizabeth High School	1st Floor Mens Restroom Right	1.5 ppb
Cape Elizabeth High School	1st Floor Womens Restroom Left	0 ppb
Cape Elizabeth High School	1st Floor Womens Restroom Right	1.4 ppb
Cape Elizabeth High School	2nd Floor Mens Restroom L	2.7 ppb
Cape Elizabeth High School	2nd Floor Mens Restroom M	0 ppb
Cape Elizabeth High School	2nd Floor Mens Restroom R	0 ppb
Cape Elizabeth High School	2nd Floor Staff Restroom Men	6.5 ppb
Cape Elizabeth High School	2nd Floor Staff Restroom Women	1.1 ppb
Cape Elizabeth High School	2nd Floor Womens Restroom L	0 ppb
Cape Elizabeth High School	2nd Floor Womens Restroom M	1.2 ppb
Cape Elizabeth High School	2nd Floor Womens Restroom R	1.7 ppb

School Name	Sample Location	Lead Test Result
Cape Elizabeth High School	314 Left	16 ppb
Cape Elizabeth High School	314 Right	5.2 ppb
Cape Elizabeth High School	315 Back	1.8 ppb
Cape Elizabeth High School	315 Front	0 ppb
Cape Elizabeth High School	316 Left	37 ppb
Cape Elizabeth High School	316 Right	2.5 ppb
Cape Elizabeth High School	318 Left	0 ppb
Cape Elizabeth High School	318 Right	4.2 ppb
Cape Elizabeth High School	319 Left	1.2 ppb
Cape Elizabeth High School	319 Right	0 ppb
Cape Elizabeth High School	320 Left	3.8 ppb
Cape Elizabeth High School	320 Right	6 ppb
Cape Elizabeth High School	3rd Floor Boys Restroom Front	0 ppb
Cape Elizabeth High School	3rd Floor Girls Restroom Front	1 ppb
Cape Elizabeth High School	3rd Floor Staff Restroom Left	0 ppb
Cape Elizabeth High School	3rd Floor Staff Restroom Right	1.6 ppb
Cape Elizabeth High School	3th Floor Boys Restroom Back	2.1 ppb
Cape Elizabeth High School	3th Floor Boys Restroom Center	0 ppb
Cape Elizabeth High School	3th Floor Girls Restroom Back	1.4 ppb
Cape Elizabeth High School	3th Floor Girls Restroom Center	1.5 ppb
Cape Elizabeth High School	Art Room 1	0 ppb
Cape Elizabeth High School	Art Room 2	1 ppb
Cape Elizabeth High School	Art Room 3	1.2 ppb
Cape Elizabeth High School	Back Stage Work Area Sink	2.4 ppb
Cape Elizabeth High School	Boys Locker Room Fountain	0 ppb
Cape Elizabeth High School	Cafe Hallway L	0 ppb
Cape Elizabeth High School	Cafe Hallway R	0 ppb
Cape Elizabeth High School	Clay Room	6.7 ppb
Cape Elizabeth High School	Clay Room 123 Deep Sink	6.5 ppb
Cape Elizabeth High School	Fitness Center Mens Restroom	0 ppb
Cape Elizabeth High School	Fitness Center Womens Restroom	1.2 ppb
Cape Elizabeth High School	Fountain - 2nd Floor	0 ppb
Cape Elizabeth High School	Fountain - 3rd Floor	0 ppb
Cape Elizabeth High School	Fountain - Between Gym/cafe	0 ppb
Cape Elizabeth High School	Fountain - Gym	0 ppb
Cape Elizabeth High School	Fountain - Mens Locker Room	0 ppb
Cape Elizabeth High School	Fountain - Pool Hallway	0 ppb
Cape Elizabeth High School	Fountain - Pool Main	0 ppb
Cape Elizabeth High School	Green Room	0 ppb
Cape Elizabeth High School	Gym Fountain	0 ppb
Cape Elizabeth High School	Ice Machine - Kitchen	0 ppb
Cape Elizabeth High School	Ice Machine - Trainers Office	0 ppb
Cape Elizabeth High School	Kitchen Deep Sink	2.1 ppb
Cape Elizabeth High School	Kitchen Dishwasher Sink	1.1 ppb
Cape Elizabeth High School	Kitchen Handwash Sink	1.1 ppb
Cape Elizabeth High School	Large Visitors Locker Room Right	0 ppb
Cape Elizabeth High School	Library Office	0 ppb

School Name	Sample Location	Lead Test Result
Cape Elizabeth High School	Life Skills	3.4 ppb
Cape Elizabeth High School	Life Skills Restroom	2.5 ppb
Cape Elizabeth High School	M Coaches Locker Room	0 ppb
Cape Elizabeth High School	Mens Locker Room Left	0 ppb
Cape Elizabeth High School	Mens Locker Room Right	0 ppb
Cape Elizabeth High School	Photography Room L	0 ppb
Cape Elizabeth High School	Photography Room R	2.4 ppb
Cape Elizabeth High School	Pool Center Restroom	1.1 ppb
Cape Elizabeth High School	Pool Mens Locker Room Left	1.5 ppb
Cape Elizabeth High School	Pool Mens Locker Room Right	0 ppb
Cape Elizabeth High School	Pool Womens Locker Room Left	2.6 ppb
Cape Elizabeth High School	Pool Womens Locker Room Right	0 ppb
Cape Elizabeth High School	Pool Womens Locker Room Single	0 ppb
Cape Elizabeth High School	Small Visitors Locker Room	2.9 ppb
Cape Elizabeth High School	Staff Lounge	383 ppb
Cape Elizabeth High School	Trainers Office	1.3 ppb
Cape Elizabeth High School	Transportation Office	0 ppb
Cape Elizabeth High School	W Coaches Locker Room	1.1 ppb
Cape Elizabeth High School	Womens Locker Room Left	1.2 ppb
Cape Elizabeth High School	Womens Locker Room Right	0 ppb
Cape Elizabeth High School	Wood Technology	0 ppb
Cape Elizabeth Middle School	1930s Basement Sink	0 ppb
Cape Elizabeth Middle School	1930s Fountain	0 ppb
Cape Elizabeth Middle School	1930's Restroom Left	1.4 ppb
Cape Elizabeth Middle School	1930's Restroom Right	0 ppb
Cape Elizabeth Middle School	6th Grade Boys L	0 ppb
Cape Elizabeth Middle School	6th Grade Boys R	0 ppb
Cape Elizabeth Middle School	6th Grade Girls L	0 ppb
Cape Elizabeth Middle School	6th Grade Girls R	0 ppb
Cape Elizabeth Middle School	7th Grade Boys L	1.3 ppb
Cape Elizabeth Middle School	7th Grade Boys R	0 ppb
Cape Elizabeth Middle School	7th Grade Girls L	0 ppb
Cape Elizabeth Middle School	7th Grade Girls R	0 ppb
Cape Elizabeth Middle School	7th Grade Hallway	0 ppb
Cape Elizabeth Middle School	8th Grade Boys R	0 ppb
Cape Elizabeth Middle School	8th Grade Girls L	0 ppb
Cape Elizabeth Middle School	8th Grade Girls R	0 ppb
Cape Elizabeth Middle School	Admin Hallway	0 ppb
Cape Elizabeth Middle School	Art Room L	0 ppb
Cape Elizabeth Middle School	Art Room R	2.1 ppb
Cape Elizabeth Middle School	Band Hallway	0 ppb
Cape Elizabeth Middle School	Band Hallway Restroom	0 ppb
Cape Elizabeth Middle School	Boys Locker Room	0 ppb
Cape Elizabeth Middle School	Connors Office	7.5 ppb
Cape Elizabeth Middle School	E102	1.2 ppb
Cape Elizabeth Middle School	E103	2.4 ppb
Cape Elizabeth Middle School	E104	4.1 ppb

School Name	Sample Location	Lead Test Result
Cape Elizabeth Middle School	E105	4.1 ppb
Cape Elizabeth Middle School	E106	1.9 ppb
Cape Elizabeth Middle School	E107	5 ppb
Cape Elizabeth Middle School	E108	3.7 ppb
Cape Elizabeth Middle School	E120	1.4 ppb
Cape Elizabeth Middle School	E134	5.2 ppb
Cape Elizabeth Middle School	E145	0 ppb
Cape Elizabeth Middle School	E166	0 ppb
Cape Elizabeth Middle School	F107	2.7 ppb
Cape Elizabeth Middle School	Fountain - 8th Grade	0 ppb
Cape Elizabeth Middle School	Fountain - Cafeteria	0 ppb
Cape Elizabeth Middle School	Fountain - Gym Hallway	0 ppb
Cape Elizabeth Middle School	Fountain - Outside Cafeteria	0 ppb
Cape Elizabeth Middle School	G004	22.7 ppb
Cape Elizabeth Middle School	G004 Restroom	15.4 ppb
Cape Elizabeth Middle School	G010	11.6 ppb
Cape Elizabeth Middle School	G111 L	7.3 ppb
Cape Elizabeth Middle School	G111 R	3.6 ppb
Cape Elizabeth Middle School	G115 L	2 ppb
Cape Elizabeth Middle School	G115 R	2.1 ppb
Cape Elizabeth Middle School	G121	1.9 ppb
Cape Elizabeth Middle School	G122	4.7 ppb
Cape Elizabeth Middle School	G123	7.7 ppb
Cape Elizabeth Middle School	G127	4.2 ppb
Cape Elizabeth Middle School	G131	6.7 ppb
Cape Elizabeth Middle School	G132	3.6 ppb
Cape Elizabeth Middle School	G134	2.7 ppb
Cape Elizabeth Middle School	G135	4.7 ppb
Cape Elizabeth Middle School	G211 L	1.6 ppb
Cape Elizabeth Middle School	G211 R	1.3 ppb
Cape Elizabeth Middle School	G215 L	1.9 ppb
Cape Elizabeth Middle School	G215 R	2.2 ppb
Cape Elizabeth Middle School	G301	2.5 ppb
Cape Elizabeth Middle School	G302	12.9 ppb
Cape Elizabeth Middle School	G303	6.1 ppb
Cape Elizabeth Middle School	G304	2.8 ppb
Cape Elizabeth Middle School	Girls Locker Room	3.1 ppb
Cape Elizabeth Middle School	Gym Boys L	0 ppb
Cape Elizabeth Middle School	Gym Boys R	0 ppb
Cape Elizabeth Middle School	Gym Girls L	0 ppb
Cape Elizabeth Middle School	Gym Girls M	0 ppb
Cape Elizabeth Middle School	Gym Girls R	0 ppb
Cape Elizabeth Middle School	Kitchen Fountain	3.9 ppb
Cape Elizabeth Middle School	Kitchen Ice Machine	0 ppb
Cape Elizabeth Middle School	Kitchen Sink End	2.1 ppb
Cape Elizabeth Middle School	Kitchen Sink L	2 ppb
Cape Elizabeth Middle School	Kitchen Sink M	1.2 ppb

School Name	Sample Location	Lead Test Result
Cape Elizabeth Middle School	Kitchen Sink R	3.4 ppb
Cape Elizabeth Middle School	Library Staff M	0 ppb
Cape Elizabeth Middle School	Library Staff W	0 ppb
Cape Elizabeth Middle School	Mens Staff Restroom L	6.6 ppb
Cape Elizabeth Middle School	Mens Staff Restroom M	4.8 ppb
Cape Elizabeth Middle School	Mens Staff Restroom R	0 ppb
Cape Elizabeth Middle School	Room G008 Sink	0 ppb
Cape Elizabeth Middle School	Top Of 1930s	0 ppb
Cape Elizabeth Middle School	Womens Staff Restroom L	0 ppb
Cape Elizabeth Middle School	Womens Staff Restroom M	0 ppb
Cape Elizabeth Middle School	Womens Staff Restroom R	0 ppb
Capital Area Technical Center	3 Bay Sink Kitchen	6.5 ppb
Capital Area Technical Center	Bottle Fill Station 1st Floor	0 ppb
Capital Area Technical Center	Bottle Fill Station 2nd Floor	0 ppb
Capital Area Technical Center	Bottle Fill Station Plumbing Shop	0 ppb
Capital Area Technical Center	Bubbler Auto Tech Shop	5.2 ppb
Capital Area Technical Center	Childcare Kitchen Sink	0 ppb
Capital Area Technical Center	Ice Machine Kitchen	0 ppb
Capital Area Technical Center	Small Sink Kitchen	2.9 ppb
Capital Area Technical Center	Staff Lounge Sink 1st Floor	0 ppb
Capital Area Technical Center	Staff Lounge Sink 2nd Floor	6.9 ppb
Capital Area Technical Center	Tilt Skillet Kitchen	4.1 ppb
Capital Area Technical Center	Water Fountain Metal Shop	0 ppb
Captain Albert W. Stevens School	2nd Floor Custodian Closet	0 ppb
Captain Albert W. Stevens School	Blue Wing Bathroom	0 ppb
Captain Albert W. Stevens School	Classroom 118	6.3 ppb
Captain Albert W. Stevens School	Classroom 124	0 ppb
Captain Albert W. Stevens School	Classroom 125	1.1 ppb
Captain Albert W. Stevens School	Classroom 126	1.3 ppb
Captain Albert W. Stevens School	Classroom 130	0 ppb
Captain Albert W. Stevens School	Classroom 131	1.2 ppb
Captain Albert W. Stevens School	Classroom 132	0 ppb
Captain Albert W. Stevens School	Classroom 134	1 ppb
Captain Albert W. Stevens School	Classroom 135	0 ppb
Captain Albert W. Stevens School	Classroom 206	0 ppb
Captain Albert W. Stevens School	Classroom 207	1 ppb
Captain Albert W. Stevens School	Classroom 208	0 ppb
Captain Albert W. Stevens School	Classroom 210	1.1 ppb
Captain Albert W. Stevens School	Classroom 211	1.1 ppb
Captain Albert W. Stevens School	Classroom 212	1.1 ppb
Captain Albert W. Stevens School	Classroom 214	2 ppb
Captain Albert W. Stevens School	Classroom 217	1.1 ppb
Captain Albert W. Stevens School	Classroom 218	1 ppb
Captain Albert W. Stevens School	Classroom 219	1 ppb
Captain Albert W. Stevens School	Classroom 221	1.2 ppb
Captain Albert W. Stevens School	Classroom 222	0 ppb
Captain Albert W. Stevens School	Classroom 223	0 ppb

School Name	Sample Location	Lead Test Result
Captain Albert W. Stevens School	Gym	0 ppb
Captain Albert W. Stevens School	Kitchen 1	1.6 ppb
Captain Albert W. Stevens School	Kitchen 2	1.4 ppb
Captain Albert W. Stevens School	Kitchen 3	0 ppb
Captain Albert W. Stevens School	Kitchen 4	0 ppb
Captain Albert W. Stevens School	Library	1.2 ppb
Captain Albert W. Stevens School	Nurses Office	0 ppb
Captain Albert W. Stevens School	Ocean Wing Bathroom	1.2 ppb
Captain Albert W. Stevens School	Purple Wing Bathroom	0 ppb
Captain Albert W. Stevens School	Teachers Room	0 ppb
Caravel Middle School	Admin Wing	0 ppb
Caravel Middle School	Connecting Hall	0 ppb
Caravel Middle School	Kitchen 3 Bay	3 ppb
Caravel Middle School	Kitchen Prep	4.5 ppb
Caravel Middle School	Near Locker Room	1.9 ppb
Caravel Middle School	Near Room 13	0 ppb
Caravel Middle School	Near Room 18	1.6 ppb
Caravel Middle School	Room 21	5.9 ppb
Caravel Middle School	Room 23	11.3 ppb
Caribou Community School	Cafe Fountain	0 ppb
Caribou Community School	Cafe Island One Bay Sink	2.4 ppb
Caribou Community School	Cafe Three Bay Sink	1 ppb
Caribou Community School	Cafe Two Bay Sink	0 ppb
Caribou Community School	Fountain Next To Rm D109 A	0 ppb
Caribou Community School	Fountain In Carp. Bld	2.9 ppb
Caribou Community School	Fountain Next To E211 A	0 ppb
Caribou Community School	Fountain Next To Rm A101 A	0 ppb
Caribou Community School	Fountain Next To Rm A101 B	0 ppb
Caribou Community School	Fountain Next To Rm A114	0 ppb
Caribou Community School	Fountain Next To Rm A117	0 ppb
Caribou Community School	Fountain Next To Rm B101 B	0 ppb
Caribou Community School	Fountain Next To Rm D209 A	0 ppb
Caribou Community School	Fountain Next To Rm E109 A	0 ppb
Caribou Community School	Ice Machine Next To Rm 114	0 ppb
Caribou Community School	Officie B100c Sink	0 ppb
Caribou Community School	Rm E201 Sink Teachers Rm	0 ppb
Caribou Community School	Sink In Carp. Bld	0 ppb
Caribou Community School	Sink Rm B115	0 ppb
Caribou Community School	Sink Rm E101 Teachers Rm	0 ppb
Caribou Community School	Supers Office Kitchen Sink	0 ppb
Caribou High School	Cafe Three Bay Sink	0 ppb
Caribou High School	Cafe Two Bay Sink	0 ppb
Caribou High School	First Floor Fountain	0 ppb
Caribou High School	Fountain In Hallway By Welding	0 ppb
Caribou High School	Hs Teachers Room	5.1 ppb
Caribou High School	Lc Main Hallway	0 ppb
Caribou High School	Lc Room 11	0 ppb

School Name	Sample Location	Lead Test Result
Caribou High School	Lc Room 5	0 ppb
Caribou High School	Main Gym Lobby	0 ppb
Caribou High School	Main Lobby Fountain	0 ppb
Caribou High School	Nurses Office Sink (main Counter)	1.7 ppb
Caribou High School	Rm 156 Ice Machine	0 ppb
Caribou High School	Rm 156 Sink	0 ppb
Caribou High School	Rm 157 Sink By Dish Washer	16 ppb
Caribou High School	Rm 157 Sink By Fridge	0 ppb
Caribou High School	Rm 213 Sink (other Side Of Room)	4.2 ppb
Caribou High School	Rm 213 Sink (Corner Sink)	2.4 ppb
Caribou High School	Rm 213 Sink (by Door)	3.5 ppb
Caribou High School	Rm 214 Sink	5.3 ppb
Caribou High School	Second Floor Fountain	0 ppb
Caribou High School	Ski Building Fountain	0 ppb
Caribou High School	Ski Building Sink By Freezer	51.2 ppb
Caribou High School	Ski Building Sink In Corner	2.2 ppb
Caribou High School	Training Rm Ice Machine	1.3 ppb
Caribou High School	Voc Main Hall	0 ppb
Caribou High School	Voc Teachers Room	24.3 ppb
Carl J Lamb School	By Rm 202 Hallway	0 ppb
Carl J Lamb School	Cafe	44.5 ppb
Carl J Lamb School	Main Lobby	0 ppb
Carl J Lamb School	Rm 114 Gym	3.9 ppb
Carl J Lamb School	Rm 118	4.5 ppb
Carl J Lamb School	Rm 119	7.2 ppb
Carl J Lamb School	Rm 120	9.3 ppb
Carl J Lamb School	Rm 121	9.6 ppb
Carl J Lamb School	Rm 122	7.8 ppb
Carl J Lamb School	Rm 123	4.1 ppb
Carl J Lamb School	Rm 124	6.2 ppb
Carl J Lamb School	Rm 125	217 ppb
Carl J Lamb School	Rm 128 Nurse	1.6 ppb
Carl J Lamb School	Rm 129	2 ppb
Carl J Lamb School	Rm 130	1.9 ppb
Carl J Lamb School	Rm 131	2.2 ppb
Carl J Lamb School	Rm 133 (1)	4.2 ppb
Carl J Lamb School	Rm 133 (2)	3.2 ppb
Carl J Lamb School	Rm 136	22.9 ppb
Carl J Lamb School	Rm 137	148 ppb
Carl J Lamb School	Rm 138	17.8 ppb
Carl J Lamb School	Rm 144	12.8 ppb
Carl J Lamb School	Rm 145	59.3 ppb
Carl J Lamb School	Rm 146	8.3 ppb
Carl J Lamb School	Rm 150 Staff Break Room	1.1 ppb
Carl J Lamb School	Rm 153 Kettle	44.2 ppb
Carl J Lamb School	Rm 153 Kitchen Dish Machine	6.3 ppb
Carl J Lamb School	Rm 153 Prep Sink	0 ppb

School Name	Sample Location	Lead Test Result
Carl J Lamb School	Rm 153 Sink By Window	10.7 ppb
Carl J Lamb School	Rm 153 Sink Under Clock	1.4 ppb
Carl J Lamb School	Rm 206	6.7 ppb
Carl J Lamb School	Rm 207	32.7 ppb
Carl J Lamb School	Rm 208	22.8 ppb
Carl J Lamb School	Rm 217 - Staff Kitchen	1.9 ppb
Carl J Lamb School	Rm 218	6 ppb
Carl J Lamb School	Rm 219	14.8 ppb
Carl J Lamb School	Rm 220	9.5 ppb
Carl J Lamb School	Rm 223	48.6 ppb
Carl J Lamb School	Rm 224	0 ppb
Carl J Lamb School	Rm 225	20.2 ppb
Carl J Lamb School	Rm 233	16 ppb
Carl J Lamb School	Rm 234	6.6 ppb
Carl J Lamb School	Rm 235	6.4 ppb
Carleton Project - Houlton	Bathroom 1 - Red	1.1 ppb
Carleton Project - Houlton	Bathroom 2 - Blue	2.8 ppb
Carleton Project - Houlton	Kitchen Sink Faucet	0 ppb
Carmel Elementary School	Gym	1.3 ppb
Carmel Elementary School	Kitchen 3 Bay	1.4 ppb
Carmel Elementary School	Kitchen Prep	0 ppb
Carmel Elementary School	Main Entry Hallway	0 ppb
Carmel Elementary School	North Hallway	0 ppb
Carmel Elementary School	Teachers Room	2.8 ppb
Carrabassett Valley Academy	1st Floor Atrium Bathroom Sink	4.8 ppb
Carrabassett Valley Academy	1st Floor Atrium Sink	2 ppb
Carrabassett Valley Academy	1st Floor Bathroom Sink	6 ppb
Carrabassett Valley Academy	1st Floor Boys Bathroom Sink A	3.1 ppb
Carrabassett Valley Academy	1st Floor Boys Bathroom Sink B	2 ppb
Carrabassett Valley Academy	1st Floor Dorm Bathromm West Sink D	8.6 ppb
Carrabassett Valley Academy	1st Floor Dorm Bathroom East Shower A	124 ppb
Carrabassett Valley Academy	1st Floor Dorm Bathroom East Shower B	17.5 ppb
Carrabassett Valley Academy	1st Floor Dorm Bathroom East Sink A	12.3 ppb
Carrabassett Valley Academy	1st Floor Dorm Bathroom East Sink D	4.6 ppb
Carrabassett Valley Academy	1st Floor Dorm Bathroom Shower C	95 ppb
Carrabassett Valley Academy	1st Floor Dorm Bathroom West Shower A	121 ppb
Carrabassett Valley Academy	1st Floor Dorm Bathroom West Shower B	17.1 ppb
Carrabassett Valley Academy	1st Floor Dorm Bathroom West Shower C	2.7 ppb
Carrabassett Valley Academy	1st Floor Dorm Bathroom West Sink A	3.5 ppb
Carrabassett Valley Academy	1st Floor Dorm Bathroom West Sink B	13.9 ppb
Carrabassett Valley Academy	1st Floor Dorm Bathroom Wets Sink C	8.3 ppb
Carrabassett Valley Academy	1st Floor Drinking Fountain	0 ppb
Carrabassett Valley Academy	1st Floor Drinking Fountain B	0 ppb
Carrabassett Valley Academy	1st Floor Girls Bathroom Sink A	2.5 ppb
Carrabassett Valley Academy	1st Floor Girs Bathroom Sink B	4 ppb
Carrabassett Valley Academy	1st Floor Staff Bathroom Sink	2.2 ppb
Carrabassett Valley Academy	1st Flor Dorm Bathroom East Sink C	14.2 ppb

School Name	Sample Location	Lead Test Result
Carrabassett Valley Academy	2nd Floor Custodian Room Mop Sink	33.5 ppb
Carrabassett Valley Academy	2nd Floor Boys Bathroom Sink A	0 ppb
Carrabassett Valley Academy	2nd Floor Boys Bathroom Sink B	3.6 ppb
Carrabassett Valley Academy	2nd Floor Dorm Bathroom East Shower A	53.4 ppb
Carrabassett Valley Academy	2nd Floor Dorm Bathroom East Shower B	15.1 ppb
Carrabassett Valley Academy	2nd Floor Dorm Bathroom East Shower C	8.7 ppb
Carrabassett Valley Academy	2nd Floor Dorm Bathroom East Sink A	9.8 ppb
Carrabassett Valley Academy	2nd Floor Dorm Bathroom East Sink B	11.1 ppb
Carrabassett Valley Academy	2nd Floor Dorm Bathroom West Shower A	504 ppb
Carrabassett Valley Academy	2nd Floor Dorm Bathroom West Shower B	4.7 ppb
Carrabassett Valley Academy	2nd Floor Dorm Bathroom West Shower C	32.1 ppb
Carrabassett Valley Academy	2nd Floor Dorm Bathroom West Sink A	8.6 ppb
Carrabassett Valley Academy	2nd Floor Dorm Bathroom West Sink B	13.9 ppb
Carrabassett Valley Academy	2nd Floor Dorm Bathroom West Sink C	11.8 ppb
Carrabassett Valley Academy	2nd Floor Dorm Bathroom West Sink D	8.9 ppb
Carrabassett Valley Academy	2nd Floor Drinking Fountain A	0 ppb
Carrabassett Valley Academy	2nd Floor Drinking Fountain B	0 ppb
Carrabassett Valley Academy	2nd Floor Drinking Fountain C	0 ppb
Carrabassett Valley Academy	2nd Floor Girls Bathroom Sink B	4.1 ppb
Carrabassett Valley Academy	2nd Floor Girls Bathroom Sink A	3.5 ppb
Carrabassett Valley Academy	2nd Floor Staff Bathroom Sink	2.4 ppb
Carrabassett Valley Academy	2nd Floor Staff Teachers Lounge Sink	6.2 ppb
Carrabassett Valley Academy	3rd Floor Dorm Bathroom East Sink C	8.1 ppb
Carrabassett Valley Academy	3rd Floor Dorm Bathroom East Shower A	29.6 ppb
Carrabassett Valley Academy	3rd Floor Dorm Bathroom East Shower B	9.2 ppb
Carrabassett Valley Academy	3rd Floor Dorm Bathroom East Shower C	5.8 ppb
Carrabassett Valley Academy	3rd Floor Dorm Bathroom East Sink A	3.1 ppb
Carrabassett Valley Academy	3rd Floor Dorm Bathroom East Sink B	6 ppb
Carrabassett Valley Academy	3rd Floor Dorm Bathroom West Shower A	19.4 ppb
Carrabassett Valley Academy	3rd Floor Dorm Bathroom West Shower B	26.4 ppb
Carrabassett Valley Academy	3rd Floor Dorm Bathroom West Shower C	5.5 ppb
Carrabassett Valley Academy	3rd Floor Dorm Bathroom West Sink A	7.2 ppb
Carrabassett Valley Academy	3rd Floor Dorm Bathroom West Sink C	9.6 ppb
Carrabassett Valley Academy	3rd Floor Dorm Bathroom West Sink D	9.8 ppb
Carrabassett Valley Academy	3rd Floor Lounge Drinking Fountain	0 ppb
Carrabassett Valley Academy	Art Room Sink	2.7 ppb
Carrabassett Valley Academy	Basement All Gender Bathroom Sink	25.4 ppb
Carrabassett Valley Academy	Basement Boys Bathroom Shower	10100 ppb
Carrabassett Valley Academy	Basement Boys Bathroom Sink	12.4 ppb
Carrabassett Valley Academy	Basement Girls Bathroom Sink	3.3 ppb
Carrabassett Valley Academy	Ice Machine	0 ppb
Carrabassett Valley Academy	Ice Machine Capricorn	0 ppb
Carrabassett Valley Academy	Juice Dispenser	2 ppb
Carrabassett Valley Academy	Juice Dispenser Capricorn	3.5 ppb
Carrabassett Valley Academy	Kitchen Hand Wash Sink A	4.9 ppb
Carrabassett Valley Academy	Kitchen Hand Wash Sink B	2.7 ppb
Carrabassett Valley Academy	Kitchen Mop Station	5 ppb

School Name	Sample Location	Lead Test Result
Carrabassett Valley Academy	Kitchen Pot Wash Sink	0 ppb
Carrabassett Valley Academy	Kitchen Prep Sink	2.3 ppb
Carrabassett Valley Academy	Kitchen Spray Sink	2.2 ppb
Carrabec Community School	6-8 Hall Water Fountain	0 ppb
Carrabec Community School	Admin Sink	0 ppb
Carrabec Community School	Gym Water Fountain	0 ppb
Carrabec Community School	Kitchen By Oven Sink	0 ppb
Carrabec Community School	Room # 104 Water Faucet	0 ppb
Carrabec Community School	Room # 106 Water Faucet	0 ppb
Carrabec Community School	Room # 107 Water Faucet	0 ppb
Carrabec Community School	Room # 109 Water Faucet	0 ppb
Carrabec Community School	Room # 200 Water Faucet	0 ppb
Carrabec Community School	Room # 204 Water Faucet	0 ppb
Carrabec Community School	Sink Staff Use Room # 198	0 ppb
Carrabec Community School	Title I Water Faucet	0 ppb
Carrabec High School	Cafeteria #1	5.4 ppb
Carrabec High School	Cafeteria #2	0 ppb
Carrabec High School	Gym By Elevator	1.1 ppb
Carrabec High School	Kitchen Sink For Cooking	4.1 ppb
Carrabec High School	Life Skills Water Fountain	1.6 ppb
Carrabec High School	Main Hall	0 ppb
Carrabec High School	Teachers Room	0 ppb
Carrabec High School	Ticket Office	18.4 ppb
Carrie Ricker School	Art Rm 105- Sink A	1.1 ppb
Carrie Ricker School	Art Rm 105- Sink B	0 ppb
Carrie Ricker School	Art Rm 105- Sink C	0 ppb
Carrie Ricker School	Av Room/ Tech Office- Sink	4.1 ppb
Carrie Ricker School	Boys Bathroom Lower Level- Sink A	0 ppb
Carrie Ricker School	Boys Bathroom Lower Level- Sink B	0 ppb
Carrie Ricker School	Boys Bathroom- Sink A	0 ppb
Carrie Ricker School	Boys Bathroom- Sink B	0 ppb
Carrie Ricker School	Drinking Fountain- Lower Level	0 ppb
Carrie Ricker School	Girls Bathroom Lower Level- Sink A	0 ppb
Carrie Ricker School	Girls Bathroom Lower Level- Sink B	0 ppb
Carrie Ricker School	Girls Bathroom- Sink A	0 ppb
Carrie Ricker School	Girls Bathroom- Sink B	0 ppb
Carrie Ricker School	Green House Rm 102- Faucet	203 ppb
Carrie Ricker School	Gym Boys Locker Room- Shower A	59.9 ppb
Carrie Ricker School	Gym Boys Locker Room- Shower B	47.5 ppb
Carrie Ricker School	Gym Boys Locker Room- Shower C	41.6 ppb
Carrie Ricker School	Gym Boys Locker Room- Sink A	3.1 ppb
Carrie Ricker School	Gym Boys Locker Room- Sink B	9.3 ppb
Carrie Ricker School	Gym Girls Locker Room- Shower A	61.7 ppb
Carrie Ricker School	Gym Girls Locker Room- Shower B	35.3 ppb
Carrie Ricker School	Gym Girls Locker Room- Shower C	33.8 ppb
Carrie Ricker School	Gym Girls Locker Room- Sink A	1.5 ppb
Carrie Ricker School	Gym Girls Locker Room- Sink B	2 ppb

School Name	Sample Location	Lead Test Result
Carrie Ricker School	Gym Office- Shower	51.5 ppb
Carrie Ricker School	Gym Office- Sink	23.8 ppb
Carrie Ricker School	Hall Bathrooms By Custodial Office- Sink A	0 ppb
Carrie Ricker School	Hall Bathrooms By Custodial Office- Sink B	0 ppb
Carrie Ricker School	Hall Bathrooms Outside Office- Sink A	0 ppb
Carrie Ricker School	Hall Bathrooms Outside Office- Sink B	0 ppb
Carrie Ricker School	Kitchen Bathroom- Sink	0 ppb
Carrie Ricker School	Kitchen- Sink A	0 ppb
Carrie Ricker School	Kitchen- Sink B	1.9 ppb
Carrie Ricker School	Kitchen- Sink C	3.5 ppb
Carrie Ricker School	Kitchen- Sink D	9 ppb
Carrie Ricker School	Kitchen- Sink E	1.6 ppb
Carrie Ricker School	Kitchen- Sink F	3.2 ppb
Carrie Ricker School	Nurse Bathroom- Sink	0 ppb
Carrie Ricker School	Nurse Rm 300- Ice Maker	0 ppb
Carrie Ricker School	Nurse Rm 300- Sink	0 ppb
Carrie Ricker School	Office Bathroom- Sink	0 ppb
Carrie Ricker School	Rm 102- Sink A	0 ppb
Carrie Ricker School	Rm 102- Sink B	2.3 ppb
Carrie Ricker School	Rm 102- Sink C	2.2 ppb
Carrie Ricker School	Rm 104- Sink	1.3 ppb
Carrie Ricker School	Rm 106- Sink	0 ppb
Carrie Ricker School	Rm 107- Bathroom Sink	0 ppb
Carrie Ricker School	Rm 107- Sink	0 ppb
Carrie Ricker School	Rm 108- Sink	0 ppb
Carrie Ricker School	Rm 109- Sink	0 ppb
Carrie Ricker School	Rm 110- Sink	0 ppb
Carrie Ricker School	Rm 112- Sink	0 ppb
Carrie Ricker School	Rm 114- Sink	1.3 ppb
Carrie Ricker School	Rm 121- Sink	0 ppb
Carrie Ricker School	Rm 125- Sink A	0 ppb
Carrie Ricker School	Rm 125- Sink B	1.9 ppb
Carrie Ricker School	Rm 202- Sink	1 ppb
Carrie Ricker School	Rm 204- Sink A	0 ppb
Carrie Ricker School	Rm 204- Sink C	2.4 ppb
Carrie Ricker School	Rm 205- Sink	2.5 ppb
Carrie Ricker School	Rm 206- Sink	4.2 ppb
Carrie Ricker School	Rm 207- Sink	0 ppb
Carrie Ricker School	Rm 208- Sink	2.3 ppb
Carrie Ricker School	Rm 209- Sink	0 ppb
Carrie Ricker School	Rm 210- Sink	1.1 ppb
Carrie Ricker School	Rm 211- Sink	1.3 ppb
Carrie Ricker School	Rm 212- Sink	0 ppb
Carrie Ricker School	Rm 214- Sink	1.1 ppb
Carrie Ricker School	Rm 216- Sink	0 ppb
Carrie Ricker School	Teacher Work Rm 301- Ice Maker	0 ppb
Carrie Ricker School	Teacher Work Rm 301- Sink	0 ppb

School Name	Sample Location	Lead Test Result
Carrie Ricker School	Teachers Bathroom Lower Level- Sink	0 ppb
Carrie Ricker School	Teachers Bathroom- Sink	0 ppb
Carrie Ricker School	Water Fountain By Custodial Office	0 ppb
Carrie Ricker School	Water Fountain By Main Office	0 ppb
Carrie Ricker School	Water Fountain Upstairs	0 ppb
Cascade Brook School	Bottle Fill Outside Room 137	2.1 ppb
Cascade Brook School	Bottle Fill Outside Room 255	2.2 ppb
Cascade Brook School	Kitchen 3-bay Sink	29.3 ppb
Cascade Brook School	Kitchen Hand Sink	174 ppb
Cascade Brook School	Kitchen Kettle	25.6 ppb
Cascade Brook School	Kitchen Sink	11.3 ppb
Cascade Brook School	Sink Room 112	4.2 ppb
Cascade Brook School	Sink Room 117	9.3 ppb
Cascade Brook School	Sink Room 122	3.1 ppb
Cascade Brook School	Sink Room 204	15.4 ppb
Cascade Brook School	Sink Room 240	10.4 ppb
Cascade Brook School	Sink Room 244	13.4 ppb
Cascade Brook School	Sink Room 245	14.7 ppb
Cascade Brook School	Sink Room 250	15.2 ppb
Cascade Brook School	Sink Room 253	12.6 ppb
Cascade Brook School	Sink Room 254	6 ppb
Cascade Brook School	Sink Room 255	14.9 ppb
Cascade Brook School	Sink Room 260	19.4 ppb
Cascade Brook School	Sink Room 261	12.1 ppb
Cascade Brook School	Sink Room 264	17.6 ppb
Cascade Brook School	Sink Room 265	17.1 ppb
Cave Hill School	Bottle Fill Station Upstairs Hall	0 ppb
Cave Hill School	Bottle Fill Station-front Entryway Downstairs	0 ppb
Cave Hill School	Kitchen /3 Bay Sink #107	4 ppb
Cave Hill School	Kitchen Vegetable Sink # 107	12.7 ppb
Cave Hill School	Nurses Stationsink Room # 103	13.2 ppb
Cave Hill School	Teachers Lounge Sink #102	3.4 ppb
Center Drive School	3/4 Wing Drinking Fountain	0 ppb
Center Drive School	5-8 Wing Drinking Fountain	0 ppb
Center Drive School	Baseball Field Faucet	3.5 ppb
Center Drive School	Cafeteria Drinking Fountain	0 ppb
Center Drive School	Gymnasium Drinking Fountain	0 ppb
Center Drive School	K-2 Wing Drinking Fountain	0 ppb
Center Drive School	Kitchen Food Prep Sink	0 ppb
Center Drive School	Life Skills Sink	0 ppb
Center Drive School	Music Room Drinking Fountain	0 ppb
Center Drive School	Snack Shack Sink	0 ppb
Center Drive School	Soccer Field Faucet	0 ppb
Center Drive School	Teachers Room Sink	0 ppb
Center For Teaching & Learning	Adult Bathroom - Top Floor	2.3 ppb
Center For Teaching & Learning	Art Room Bathroom	4.1 ppb

School Name	Sample Location	Lead Test Result
Center For Teaching & Learning	Art Room Sink	6.4 ppb
Center For Teaching & Learning	Back Outdoor Spigot	1.9 ppb
Center For Teaching & Learning	Front Outdoor Spigot Left	71.6 ppb
Center For Teaching & Learning	Front Outdoor Spigot Right	12 ppb
Center For Teaching & Learning	Kindergarten Bathroom	1.1 ppb
Center For Teaching & Learning	Kindergarten Sink	1.5 ppb
Center For Teaching & Learning	Kitchen Sink	0 ppb
Center For Teaching & Learning	Lab Bathroom	0 ppb
Center For Teaching & Learning	Lab Sink	0 ppb
Center For Teaching & Learning	M/s Bathroom	1.3 ppb
Center For Teaching & Learning	M/s Sink	1.8 ppb
Center For Teaching & Learning	Primary Reading Room Bathroom	2.7 ppb
Center For Teaching & Learning	Writing Room Bathroom	0 ppb
Central Aroostook Jr-Sr H S	Back Hall	1.5 ppb
Central Aroostook Jr-Sr H S	Break Room	16.3 ppb
Central Aroostook Jr-Sr H S	Girls Locker Room	25.6 ppb
Central Aroostook Jr-Sr H S	Kitchen Sink On North Wall	2.8 ppb
Central Aroostook Jr-Sr H S	Kitchen Sink On West Wall	15.6 ppb
Central Aroostook Jr-Sr H S	Kitchen Sink/island Near Serving Area	16.5 ppb
Central Aroostook Jr-Sr H S	Lobby	0 ppb
Central Aroostook Jr-Sr H S	Shop	22.7 ppb
Central Aroostook Jr-Sr H S	Staff Room	8.6 ppb
Central Community Elementary School	A006 Administration Workroom Sink	0 ppb
Central Community Elementary School	A012 Booster Workroom Sink	0 ppb
Central Community Elementary School	A017 Nurse Exam Room Sink	0 ppb
Central Community Elementary School	A032 District Workroom Sink	0 ppb
Central Community Elementary School	A035 District Lounge Sink	0 ppb
Central Community Elementary School	A100c Water Cooler	0 ppb
Central Community Elementary School	A101 Sink Fountain	0 ppb
Central Community Elementary School	A102 Sink Fountain	0 ppb
Central Community Elementary School	A103 Sink Fountain	0 ppb
Central Community Elementary School	A112 Staff Lounge Sink	0 ppb
Central Community Elementary School	A114 Music Sink	0 ppb
Central Community Elementary School	A128 Water Cooler	0 ppb
Central Community Elementary School	A143 Kitchen 2 Bay Sink	0 ppb
Central Community Elementary School	A143 Kitchen Mixer Filler	0 ppb
Central Community Elementary School	A143 Kitchen Pot Filler	10 ppb
Central Community Elementary School	B101 Sink Fountain	0 ppb
Central Community Elementary School	B102 Sink Fountain	0 ppb
Central Community Elementary School	B103 Sink Fountain	0 ppb
Central Community Elementary School	B104 Sink Fountain	0 ppb
Central Community Elementary School	B105 Sink Fountain	0 ppb
Central Community Elementary School	B106 Sink Fountain	0 ppb
Central Community Elementary School	B107 Sink Fountain	0 ppb
Central Community Elementary School	B108 Sink Fountain	0 ppb
Central Community Elementary School	B109 Sink Fountain	0 ppb
Central Community Elementary School	B110 Sink Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Central Community Elementary School	B111 Work Room Sink	0 ppb
Central Community Elementary School	B112c Water Cooler	0 ppb
Central Community Elementary School	B114 Project East Wall Left	0 ppb
Central Community Elementary School	B114 Project East Wall Right	0 ppb
Central Community Elementary School	B116 Art Sink East Wall Left	0 ppb
Central Community Elementary School	B116 Art Sink East Wall Right	0 ppb
Central Community Elementary School	B116 Art Sink South Wall	0 ppb
Central Community Elementary School	B117 Life Skills Sink	0 ppb
Central Community Elementary School	B211 Workroom Sink	0 ppb
Central Community Elementary School	B212c Water Cooler	0 ppb
Central Community Elementary School	C101 Sink Fountain	0 ppb
Central Community Elementary School	C102 Sink Fountain	0 ppb
Central Community Elementary School	C103 Sink Fountain	0 ppb
Central Community Elementary School	C104 Sink Fountain	0 ppb
Central Community Elementary School	C105 Sink Fountain	0 ppb
Central Community Elementary School	C107 Sink Fountain	0 ppb
Central Community Elementary School	C208 Sink Fountain	0 ppb
Central High School	A12 East Wall Center Sink	26.3 ppb
Central High School	A12 East Wall Left Sink	18.2 ppb
Central High School	A12 East Wall Right Sink	19.9 ppb
Central High School	A12 North Wall Sink	6.7 ppb
Central High School	A12 Water Cooler	6.7 ppb
Central High School	A12 West Wall Sink	24.3 ppb
Central High School	B-wing Water Cooler	6.7 ppb
Central High School	C-wing Water Cooler	5.8 ppb
Central High School	Kitchen Dishwasher Sink	8.4 ppb
Central High School	Kitchen Prep Sink	7.6 ppb
Central High School	Library Staff Lounge Sink	47.8 ppb
Central High School	Staff Lounge Sink	7.6 ppb
Central Maine Learning Center	Bathroom Sink 1 Main Bldg	0 ppb
Central Maine Learning Center	Bathroom Sink 2 Main Bldg	0 ppb
Central Maine Learning Center	Bathroom Sink 3 Main Bldg	0 ppb
Central Maine Learning Center	Bathroom Sink 4 Coach House	1.3 ppb
Central Maine Learning Center	Kitchen Faucet 1 Main Bldg	13.2 ppb
Central Maine Learning Center	Kitchen Faucet 2 Main Bldg	19.3 ppb
Central Maine Learning Center	Kitchen Handwash Sink Main Bldg	3.1 ppb
Central Maine Learning Center	Science Sink 1 Science	5.4 ppb
Central Maine Learning Center	Science Sink 2 Science	3.1 ppb
Central Maine Learning Center	Staff Office Sink Main Bldg	0 ppb
Central ME Christian Acad	Boys Bathroom Left Sink	2.7 ppb
Central ME Christian Acad	Boys Bathroom Right Sink	1.1 ppb
Central ME Christian Acad	Girls Bathroom Left Sink	0 ppb
Central ME Christian Acad	Girls Bathroom Right Sink	4.8 ppb
Central ME Christian Acad	Gym Sink	1.2 ppb
Central ME Christian Acad	Teachers Lounge Sink	6.1 ppb
Central ME Christian Acad	Teachers Bathroom Sink (level 2)	2 ppb
Central ME Christian Acad	Teachers Lounge Bathroom	2.1 ppb

School Name	Sample Location	Lead Test Result
Central ME Christian Acad	Upstairs Hallway Sink	1.8 ppb
Central Middle School	1st Floor Lobby/corridor Water Cooler	0 ppb
Central Middle School	2nd Floor Corridor Water Cooler	3.8 ppb
Central Middle School	Cafeteria Water Fountain	7.6 ppb
Central Middle School	Hose Bib Near Front Entrance	10 ppb
Central Middle School	Kitchen Ice Maker	5.3 ppb
Central Middle School	Kitchen Pot Sink	11.6 ppb
Central Middle School	Kitchen Prep Sink	1.2 ppb
Central Middle School	Library Sink	9.2 ppb
Central Middle School	Nurses Sink	6.1 ppb
Central Middle School	Staff Lounge Sink	27.8 ppb
Central School	1st Floor Hallway Across From Rm. #129	0 ppb
Central School	1st Floor Hallway Next To Gymnasium	0 ppb
Central School	2nd Floor Hallway Next To Rm. #105	7.3 ppb
Central School	3rd Floor Hallway Next To Rm. #206	0 ppb
Central School	Basement Hallway Next To 001 & Kitchen	0 ppb
Central School	In Rm. #1 (rm. #109)	0 ppb
Central School	Kitchen 1st Sink To Left Next To Dishwasher	0 ppb
Central School	Main Office	0 ppb
Central School	Nurse Office Rm. #123	0 ppb
Charlotte Elementary School	Drinking Fountain In Room 2-4	6 ppb
Charlotte Elementary School	Drinking Fountain In Room 5-8	4.4 ppb
Charlotte Elementary School	Drinking Fountain In Room Pk-1	21.5 ppb
Charlotte Elementary School	Drinking Fountain In The Gym	8.2 ppb
Charlotte Elementary School	Kitchen Handwash Sink	3.8 ppb
Charlotte Elementary School	Supply Line In The Boiler Room	1.3 ppb
Charlotte Elementary School	Wash Sink In The Kitchen	2.7 ppb
Chebeague Island School	Hallway Drinking Water Fountain	0 ppb
Chebeague Island School	Handwash Sink	0 ppb
Chebeague Island School	One Bay Sink	0 ppb
Chebeague Island School	Two Bay Sink - Left Faucet	0 ppb
Chebeague Island School	Two Bay Sink - Right Faucet	0 ppb
Chelsea Elementary School	1st Fl Gym Entrance Bottle Fill Near Boys Br	0 ppb
Chelsea Elementary School	2nd Floor Bottle Fill Across Rm #207	0 ppb
Chelsea Elementary School	2nd Floor Bottle Fill Beside Boys Restroom	0 ppb
Chelsea Elementary School	2nd Floor Rm #200 Sink	0 ppb
Chelsea Elementary School	2nd Floor Rm #206 Sink	0 ppb
Chelsea Elementary School	2nd Floor Science Rm #205 Sink #1	0 ppb
Chelsea Elementary School	2nd Floor Science Rm #205 Sink #2	0 ppb
Chelsea Elementary School	2nd Floor Science Rm #205 Sink #3	0 ppb
Chelsea Elementary School	2nd Floor Science Rm #205 Sink #4	0 ppb
Chelsea Elementary School	2nd Floor Teachers Rm Sink	0 ppb
Chelsea Elementary School	Cafeteria Entrance Sink #1	0 ppb
Chelsea Elementary School	Cafeteria Entrance Sink #1 Left Of Entrance	0 ppb
Chelsea Elementary School	Cafeteria Entrance Sink #2	0 ppb

School Name	Sample Location	Lead Test Result
Chelsea Elementary School	Cafeteria Entrance Sink #2 Left Of Entrance	0 ppb
Chelsea Elementary School	Cafeteria Entrance Sink #3	0 ppb
Chelsea Elementary School	Cafeteria Entrance Sink #3 Left Of Entrance	0 ppb
Chelsea Elementary School	First Floor Art Rm Sink #1	0 ppb
Chelsea Elementary School	First Floor Art Rm Sink #2	1.1 ppb
Chelsea Elementary School	First Floor Art Rm Sink #3	1.4 ppb
Chelsea Elementary School	First Floor Bottle Fill Across From Rm #103	0 ppb
Chelsea Elementary School	First Floor Cafeteria Entrance Bottle Fill	0 ppb
Chelsea Elementary School	First Floor File Rm In The Main Office Sink	0 ppb
Chelsea Elementary School	First Floor Library Sink	0 ppb
Chelsea Elementary School	First Floor Nurses Office In The Main Office Sink	0 ppb
Chelsea Elementary School	First Floor Rm #106	0 ppb
Chelsea Elementary School	First Floor Rm #108	0 ppb
Chelsea Elementary School	First Floor Rm #109	0 ppb
Chelsea Elementary School	First Floor Rm #110	0 ppb
Chelsea Elementary School	First Floor Rm #111	0 ppb
Chelsea Elementary School	First Floor Rm #112	0 ppb
Chelsea Elementary School	First Floor Rm #113	0 ppb
Chelsea Elementary School	First Floor Rm #114	0 ppb
Chelsea Elementary School	First Floor Rm #121	0 ppb
Chelsea Elementary School	First Floor Teachers Work Rm	0 ppb
Chelsea Elementary School	Kitchen Steamer	43.9 ppb
Chelsea Elementary School	Kitchen Two Bay Sink	0 ppb
Chelsea Elementary School	Music Rm Sink	0 ppb
Cherryfield Elementary	Drinking Water Fountain Hallway	3.4 ppb
Cherryfield Elementary	Kindergarden Sink	2.4 ppb
Cherryfield Elementary	Kitchen Food Prep Sink	5.5 ppb
Cherryfield Elementary	Pre-k Sink	0 ppb
Cheverus High School	Cheverus Hall Althetics Fill	2.1 ppb
Cheverus High School	Cheverus Hall Althetics Training Room	0 ppb
Cheverus High School	Cheverus Hall Kitchen Sink # 1	0 ppb
Cheverus High School	Cheverus Hall Kitchen Sink # 2	3.3 ppb
Cheverus High School	Cheverus Hall Kitchen Sink # 3	0 ppb
Cheverus High School	Drinking Water Fountain Ch 1st Flr Atrium	0 ppb
Cheverus High School	Drinking Water Fountain Ch 1st Flr Lib	0 ppb
Cheverus High School	Drinking Water Fountain Ch Ground	0 ppb
Cheverus High School	Drinking Water Fountain Indoor Track 1m	0 ppb
Cheverus High School	Drinking Water Fountain Indoor Track 2w	0 ppb
Cheverus High School	Drinking Water Fountain Loyola 1st Flr Ent	0 ppb
Cheverus High School	Drinking Water Fountain Loyola 1st Flr Spa	0 ppb
Cheverus High School	Drinking Water Fountain Loyola 2nd Floor	0 ppb
Cheverus High School	Drinking Water Fountain Loyola Ground	5.8 ppb
Cheverus High School	Loyola Hall Admissions Office Sink	2.2 ppb
Cheverus High School	Loyola Hall Kitchen Sink #1	0 ppb
Cheverus High School	Loyola Hall Kitchen Sink #2	83 ppb
Cheverus High School	Loyola Hall Kitchen Sink #3	0 ppb

School Name	Sample Location	Lead Test Result
Cheverus High School	Loyola Hall Teacher's Lounge	1.1 ppb
Chewonki Elementary and Middle School	Cee- Apartment Bathroom Sink	0 ppb
Chewonki Elementary and Middle School	Cee- Apartment Kitchen Sink	0 ppb
Chewonki Elementary and Middle School	Cee- Bathroom 1 Next To Utility Closet	0 ppb
Chewonki Elementary and Middle School	Cee- Bathroom 2	0 ppb
Chewonki Elementary and Middle School	Cee- Bathroom 3	0 ppb
Chewonki Elementary and Middle School	Cee- Bathroom 4 With Shower	0 ppb
Chewonki Elementary and Middle School	Cee- Bathroom 5- 2 Access Doors	0 ppb
Chewonki Elementary and Middle School	Cee- Bathroom 6	0 ppb
Chewonki Elementary and Middle School	Cee- Bathroom 7	0 ppb
Chewonki Elementary and Middle School	Cee- Classroom North Sink	2.1 ppb
Chewonki Elementary and Middle School	Cee- Classroom South Sink	0 ppb
Chewonki Elementary and Middle School	Cee- Indoor Classroom Sink	2 ppb
Chewonki Elementary and Middle School	Cee- Kitchen Coffee Maker	2.3 ppb
Chewonki Elementary and Middle School	Cee- Kitchen Hand Sink	0 ppb
Chewonki Elementary and Middle School	Cee- Kitchen Prep-sink	0 ppb
Chewonki Elementary and Middle School	Cee- Lobby Sink Faucet Left	0 ppb
Chewonki Elementary and Middle School	Cee- Lobby Sink Faucet Right	0 ppb
Chewonki Elementary and Middle School	Cee- Lobby Water Bottle Filler	0 ppb
Chewonki Elementary and Middle School	Cee- Upstairs Classroom Sink	2.1 ppb
Chewonki Elementary and Middle School	East Side Staff House Bathroom Sink	0 ppb
Chewonki Elementary and Middle School	East Side Wash House Bottle Filler Left	0 ppb
Chewonki Elementary and Middle School	East Side Wash House Bottle Filler Right	0 ppb
Chewonki Elementary and Middle School	Eastside Wash House Sink 1	5.7 ppb

School Name	Sample Location	Lead Test Result
Chewonki Elementary and Middle School	Eastside Wash House Sink 2	3.4 ppb
Chewonki Elementary and Middle School	Eastside Wash House Sink 3	2.3 ppb
Chewonki Elementary and Middle School	Eastside Wash House Sink 4	2 ppb
Chewonki Elementary and Middle School	Tree House Boys Bathroom Sink	0 ppb
Chewonki Elementary and Middle School	Tree House Girls Bathroom Faucet Left	3.1 ppb
Chewonki Elementary and Middle School	Tree House Girls Bathroom Faucet Right	6.3 ppb
Chewonki Elementary and Middle School	Tree House Outdoor Faucet Left	1.2 ppb
Chewonki Elementary and Middle School	Tree House Outdoor Faucet Right	0 ppb
Children's Center-Early Intervention and Family Support	Admin Bathroom Sink	0 ppb
Children's Center-Early Intervention and Family Support	Bursting Blossoms Bathroom Sink	0 ppb
Children's Center-Early Intervention and Family Support	Bursting Blossoms Classroom Sink	0 ppb
Children's Center-Early Intervention and Family Support	Growing Sprouts Adult Sink	0 ppb
Children's Center-Early Intervention and Family Support	Growing Sprouts Bathroom Sink	0 ppb
Children's Center-Early Intervention and Family Support	Growing Sprouts Children's Sink	0 ppb
Children's Center-Early Intervention and Family Support	Hallway Adult Bathroom Sink	0 ppb
Children's Center-Early Intervention and Family Support	Hallway Children's Bathroom Sink	0 ppb
Children's Center-Early Intervention and Family Support	Hallway Water Cooler	0 ppb
Children's Center-Early Intervention and Family Support	Hummingbirds Adult Sink	0 ppb
Children's Center-Early Intervention and Family Support	Hummingbirds Children's Sink	0 ppb
Children's Center-Early Intervention and Family Support	Kitchen Small Sink	3.8 ppb
Children's Center-Early Intervention and Family Support	Kitchen-3 Basin Sink	0 ppb
Children's Center-Early Intervention and Family Support	Special Purpose Private School Sink	0 ppb
Children's Center-Early Intervention and Family Support	Stepping Stones li Bathroom Sink	0 ppb

School Name	Sample Location	Lead Test Result
Children's Center-Early Intervention and Family Support	Stepping Stones li Classroom Sink	0 ppb
Children's Center-Early Intervention and Family Support	Stepping Stones lii Adult Sink	0 ppb
Children's Center-Early Intervention and Family Support	Stepping Stones lii Bathroom Sink	1.1 ppb
China Middle School	5th Grd Hall - Bottle Fill Station	0 ppb
China Middle School	5th Grd Hall - Dwf	0 ppb
China Middle School	8 Grd - Bottle Fill Station	0 ppb
China Middle School	8 Grd - Dwf	0 ppb
China Middle School	8 Grd Boy Gang B.room - Sink A	5.4 ppb
China Middle School	8 Grd Boy Gang B.room - Sink B	3 ppb
China Middle School	8 Grd Girl Gang B.room - Sink A	6.6 ppb
China Middle School	8 Grd Girl Gang B.room - Sink B	4.5 ppb
China Middle School	8th Grd Printer/staff B.rm - Sink	5.1 ppb
China Middle School	Across Frm M. Office - Dwf	0 ppb
China Middle School	After-treatment - Hose Bib	10.9 ppb
China Middle School	Boys Gang B.rm - Sink A	4.6 ppb
China Middle School	Boys Gang B.rm - Sink B	4.4 ppb
China Middle School	Front Rd Side - Hose Bib	10 ppb
China Middle School	Girls Gang B.rm - Sink A	4.9 ppb
China Middle School	Girls Gang B.rm - Sink B	4.4 ppb
China Middle School	Gym Bathroom A - Sink	9.6 ppb
China Middle School	Gym Bathroom B - Sink	8 ppb
China Middle School	Kitchen - Dishwash Station	2.5 ppb
China Middle School	Kitchen Handwash - Sink	8.2 ppb
China Middle School	Kitchen Rinse - Sink	4 ppb
China Middle School	Kitchen Veggie Wash - Sink	3.8 ppb
China Middle School	Kitchen Wash - Sink	4.7 ppb
China Middle School	Men 5th Grd B.rm - Sink B	4.6 ppb
China Middle School	Men's R.rm Across Frm M. Office - Sink	6.6 ppb
China Middle School	Next To Gym - Bottle Fill Station	0 ppb
China Middle School	Next To Gym - Dwf	0 ppb
China Middle School	Nurse Station - Sink	2 ppb
China Middle School	Outside Faucet C3 - Hose Bib	39.8 ppb
China Middle School	Pre-treatment - Hose Bib	164 ppb
China Middle School	Rm 10 A - Sink	8.3 ppb
China Middle School	Rm 13 - Sink	7.1 ppb
China Middle School	Rm 14 - Sink	6.5 ppb
China Middle School	Rm 15 - Sink	8.2 ppb
China Middle School	Rm 16 - Sink	5.1 ppb
China Middle School	Rm 20 - Sink	4 ppb
China Middle School	Rm 20 - Sink #1	10.7 ppb
China Middle School	Rm 20 - Sink #2	4.4 ppb
China Middle School	Rm 21 - Sink	6.9 ppb
China Middle School	Rm 23 - Sink A	8.4 ppb
China Middle School	Rm 24 - Sink	7 ppb

School Name	Sample Location	Lead Test Result
China Middle School	Rm 4 Teacher Lounge - Sink	5.3 ppb
China Middle School	Rm 7 - Sink	4.7 ppb
China Middle School	Rm 9 - Sink	17.6 ppb
China Middle School	Staff/printer Rm 5th Grd - Sink	13.5 ppb
China Middle School	Women 5th Grd B.rm - Sink A	7.6 ppb
China Middle School	Women 5th Grd B.rm - Sink B	4 ppb
China Middle School	Women 5th Grd B.rm - Sink C	4.7 ppb
China Middle School	Women's R.rm Across Frm M. Office Sink	3.9 ppb
China Primary School	Across Frm 31 - Bottle Fill Station	0 ppb
China Primary School	Across Frm 31 - Dwf	0 ppb
China Primary School	Across Frm 31 Staff Bathroom - Sink	1.6 ppb
China Primary School	Across Frm 33 Girl B. Rm - Sink A	1.8 ppb
China Primary School	Across Frm 33 Girl B. Rm - Sink B	2.7 ppb
China Primary School	Across Frm 33 Girl B. Rm - Sink C	1.9 ppb
China Primary School	Across Frm Rm 12 Staff Rstrm - Sink	1.5 ppb
China Primary School	Across From 31 Boys Bathrm Sink A	1.9 ppb
China Primary School	Across From 31 Boys Bathrm Sink B	2.4 ppb
China Primary School	Across From 31 Boys Bathrm Sink C	1.4 ppb
China Primary School	Cafeteria - Bottle Fill Station	0 ppb
China Primary School	Cafeteria - Dwf	0 ppb
China Primary School	Cafeteria Handwash A - Sink	1.7 ppb
China Primary School	Cafeteria Handwash B - Sink	2.7 ppb
China Primary School	Custodian Office - Sink	9.9 ppb
China Primary School	Guidance - Sink	18.8 ppb
China Primary School	Gym - Bottle Fill Station	0 ppb
China Primary School	Gym - Dwf	0 ppb
China Primary School	Gym Boys Bathroom - Sink	2.6 ppb
China Primary School	Gym Girl Bathroom - Sink	2.6 ppb
China Primary School	Kitchen Bathroom - Sink	2.9 ppb
China Primary School	Kitchen Dishwash - Sink	9.8 ppb
China Primary School	Kitchen Handwash - Sink Hot Side	3.5 ppb
China Primary School	Kitchen Sanatize Station A - Sink	17.2 ppb
China Primary School	Kitchen Sanatize Station B - Sink	3.9 ppb
China Primary School	Kitchen Veggie Wash - Sink	8 ppb
China Primary School	Library Workroom - Sink	2.6 ppb
China Primary School	Main Office Work - Sink	4.6 ppb
China Primary School	Next To Rm 17 - Bottle Fill Station	0 ppb
China Primary School	Next To Rm 17 - Dwf	0 ppb
China Primary School	Nurse Station - Sink	2 ppb
China Primary School	Nurse Station B. Room - Sink	2.5 ppb
China Primary School	Outside Near Boiler Playground - Hosebib	19.8 ppb
China Primary School	Restroom Across From Staff Lounge - Sink	1.1 ppb
China Primary School	Rm 12 - Sink	9.5 ppb
China Primary School	Rm 13 - Sink	6 ppb
China Primary School	Rm 14 - Sink	11 ppb
China Primary School	Rm 15 - Dwf/sink Combo	8.7 ppb
China Primary School	Rm 15 - Sink	10.1 ppb

School Name	Sample Location	Lead Test Result
China Primary School	Rm 16 - Dwf/sink Combo	10.4 ppb
China Primary School	Rm 16 - Sink	9.5 ppb
China Primary School	Rm 17 - Sink	11.3 ppb
China Primary School	Rm 18 - Sink	7.6 ppb
China Primary School	Rm 21 - Sink	11 ppb
China Primary School	Rm 21 Bathroom - Sink	1.5 ppb
China Primary School	Rm 22 - Sink	13.2 ppb
China Primary School	Rm 23 - Dwf/sink Combo	16.8 ppb
China Primary School	Rm 23 - Sink	7.8 ppb
China Primary School	Rm 23 Bathroom - Sink	9.9 ppb
China Primary School	Rm 28 - Sink	8.5 ppb
China Primary School	Rm 29 - Sink	10.6 ppb
China Primary School	Rm 30 - Dwf/sink Combo	9.8 ppb
China Primary School	Rm 30 - Sink	14.8 ppb
China Primary School	Rm 31 - Sink	21.3 ppb
China Primary School	Rm 32 - Sink	15 ppb
China Primary School	Rm 33 - Sink	15.7 ppb
China Primary School	Rm 34 - Sink	13.2 ppb
China Primary School	Rm 35- Sink	11.5 ppb
China Primary School	Rm 36 - Sink	13.4 ppb
China Primary School	Rm 37 - Sink	10.7 ppb
China Primary School	Staff Lounge - Dwf/sink Combo	31.8 ppb
China Primary School	Staff Lounge - Sink	11.6 ppb
Cliff Island School	Sink	3.3 ppb
Clinton Elementary School	Gym Boys Bathroom Sink	5.5 ppb
Clinton Elementary School	Gym Drinking Fountain	0 ppb
Clinton Elementary School	Gym Girls Bathroom Sink	8.3 ppb
Clinton Elementary School	Kitchen Food Prep Sink #1	1.8 ppb
Clinton Elementary School	Kitchen Food Prep Sink #2	0 ppb
Clinton Elementary School	Kitchen Food Prep Sink #3	4.8 ppb
Clinton Elementary School	Kitchen Hand Washing Sink #1	23.4 ppb
Clinton Elementary School	Kitchen Hand Washing Sink #2	1 ppb
Clinton Elementary School	Lower Wing Boys Bathroom Sink #1	2.7 ppb
Clinton Elementary School	Lower Wing Boys Bathroom Sink #2	3.1 ppb
Clinton Elementary School	Lower Wing Boys Bathroom Sink #3	3.6 ppb
Clinton Elementary School	Lower Wing Girls Bathroom Sink #1	1.3 ppb
Clinton Elementary School	Lower Wing Girls Bathroom Sink #2	2.1 ppb
Clinton Elementary School	Lower Wing Girls Bathroom Sink #3	1.8 ppb
Clinton Elementary School	Lower Wing Hall Drinking Fountain #1	146 ppb
Clinton Elementary School	Lower Wing Hall Drinking Fountain #2	55.3 ppb
Clinton Elementary School	Lower Wing Teachers Room Sink	2.3 ppb
Clinton Elementary School	Nurses Office Sink	3.1 ppb
Clinton Elementary School	Room #126 Sink	3.8 ppb
Clinton Elementary School	Room #127 Sink	1.9 ppb
Clinton Elementary School	Room #128 Sink	6.6 ppb
Clinton Elementary School	Room #131 Bathroom Sink	10.4 ppb
Clinton Elementary School	Room #131 Hand Washing Sink	11.2 ppb

School Name	Sample Location	Lead Test Result
Clinton Elementary School	Room #131 Water Bubbler	0 ppb
Clinton Elementary School	Upper Wing Boys Bathroom Sink #1	2.1 ppb
Clinton Elementary School	Upper Wing Boys Bathroom Sink #2	4.3 ppb
Clinton Elementary School	Upper Wing Girls Bathroom Sink #1	3.9 ppb
Clinton Elementary School	Upper Wing Girls Bathroom Sink #2	3.6 ppb
Clinton Elementary School	Upper Wing Hallway Drinking Fountain	0 ppb
Coastal Christian School	Boys Bathroom Hs Left Sink Downstairs	0 ppb
Coastal Christian School	Boys Bathroom Jr High Left Sink Upstairs	0 ppb
Coastal Christian School	Boys El Bathroom Sink	0 ppb
Coastal Christian School	Girls Bathroom Hs Left Sink Downstairs	0 ppb
Coastal Christian School	Girls Bathroom Jrh Left Sink Downstairs	1 ppb
Coastal Christian School	Girls El Bathroom Sink	1.3 ppb
Coastal Christian School	Gym Boys Bathroom	1.6 ppb
Coastal Christian School	Gym Girls Bathroom	1.1 ppb
Coastal Christian School	Gym Lobby Concession Kitchen	0 ppb
Coastal Christian School	Gym Water Fountain	0 ppb
Coastal Christian School	Kitchen Sink El	0 ppb
Coastal Ridge Elementary	1st Floor Custodial Closet 3rd Grade Hall	3.3 ppb
Coastal Ridge Elementary	2nd Floor Custodial Closet	5.6 ppb
Coastal Ridge Elementary	2nd Floor Hall Restroom Faucet	1.6 ppb
Coastal Ridge Elementary	2nd Grade Hall Sink Faucet	0 ppb
Coastal Ridge Elementary	Artroom Center Sink	0 ppb
Coastal Ridge Elementary	Artroom Left Sink	3.2 ppb
Coastal Ridge Elementary	Artroom Right Sink	1.6 ppb
Coastal Ridge Elementary	Boy Locker Room Sink Left	0 ppb
Coastal Ridge Elementary	Boy Locker Room Sink Right	1.2 ppb
Coastal Ridge Elementary	Cafe Hall Restroom Faucet	0 ppb
Coastal Ridge Elementary	Cafe Sink Faucet	0 ppb
Coastal Ridge Elementary	Cottage Restroom Sink	0 ppb
Coastal Ridge Elementary	Cottage Steam Sink	0 ppb
Coastal Ridge Elementary	Custodial Closet 2nd Grade Hall	5 ppb
Coastal Ridge Elementary	Girl Locker Room Sink Left	1.2 ppb
Coastal Ridge Elementary	Girl Locker Room Sink Right	0 ppb
Coastal Ridge Elementary	Gym Bubbler	0 ppb
Coastal Ridge Elementary	Gym Office Sink	3.9 ppb
Coastal Ridge Elementary	Kitchen 2 Bay Sink	4.5 ppb
Coastal Ridge Elementary	Kitchen Custodial Sink	4 ppb
Coastal Ridge Elementary	Kitchen Dishwasher Sink	10.2 ppb
Coastal Ridge Elementary	Kitchen Handwash Sink	0 ppb
Coastal Ridge Elementary	Kitchen Restroom Sink	0 ppb
Coastal Ridge Elementary	Library Faucet	0 ppb
Coastal Ridge Elementary	Music Room Faucet	5.6 ppb
Coastal Ridge Elementary	Nurse Clinic Restroom Faucet	0 ppb
Coastal Ridge Elementary	Nurse Clinic Sink Faucet	1.2 ppb
Coastal Ridge Elementary	Outside Behind Dumpster Hose	84.5 ppb
Coastal Ridge Elementary	Outside Nurse Office Hose	40.3 ppb
Coastal Ridge Elementary	Outside Rm 131 Hose	253 ppb

School Name	Sample Location	Lead Test Result
Coastal Ridge Elementary	Restroom 1st Floor 3rd Grade Hall Faucet	1.4 ppb
Coastal Ridge Elementary	Restroom Between 103&101 Faucet	1.7 ppb
Coastal Ridge Elementary	Restroom Between 104&102 Faucet	0 ppb
Coastal Ridge Elementary	Restroom Between 111&109 Faucet	0 ppb
Coastal Ridge Elementary	Restroom Between 112&110 Faucet	0 ppb
Coastal Ridge Elementary	Restroom Between 133&135 Faucet	0 ppb
Coastal Ridge Elementary	Restroom Between 134&136 Faucet	0 ppb
Coastal Ridge Elementary	Restroom Between 203&201 Faucet	1 ppb
Coastal Ridge Elementary	Restroom Between 211&209 Faucet	0 ppb
Coastal Ridge Elementary	Rm 101 Bubbler	0 ppb
Coastal Ridge Elementary	Rm 101 Faucet	2.4 ppb
Coastal Ridge Elementary	Rm 102 Bubbler	5.9 ppb
Coastal Ridge Elementary	Rm 102 Faucet	3.2 ppb
Coastal Ridge Elementary	Rm 103 Bubbler	0 ppb
Coastal Ridge Elementary	Rm 103 Faucet	2.5 ppb
Coastal Ridge Elementary	Rm 104 Bubbler	255 ppb
Coastal Ridge Elementary	Rm 104 Faucet	2.4 ppb
Coastal Ridge Elementary	Rm 109 Bubbler	0 ppb
Coastal Ridge Elementary	Rm 109 Faucet	4 ppb
Coastal Ridge Elementary	Rm 110 Bubbler	31.8 ppb
Coastal Ridge Elementary	Rm 110 Faucet	3.2 ppb
Coastal Ridge Elementary	Rm 111 Bubbler	67.9 ppb
Coastal Ridge Elementary	Rm 111 Faucet	0 ppb
Coastal Ridge Elementary	Rm 112 Bubbler	18.6 ppb
Coastal Ridge Elementary	Rm 112 Faucet	1.9 ppb
Coastal Ridge Elementary	Rm 114 Faucet	1.2 ppb
Coastal Ridge Elementary	Rm 130 Restroom Faucet	0 ppb
Coastal Ridge Elementary	Rm 133 Bubbler	3.7 ppb
Coastal Ridge Elementary	Rm 133 Faucet	4.6 ppb
Coastal Ridge Elementary	Rm 134 Bubbler	5.4 ppb
Coastal Ridge Elementary	Rm 134 Faucet	1.9 ppb
Coastal Ridge Elementary	Rm 135 Bubbler	4.2 ppb
Coastal Ridge Elementary	Rm 135 Faucet	4.5 ppb
Coastal Ridge Elementary	Rm 136 Bubbler	4 ppb
Coastal Ridge Elementary	Rm 136 Faucet	3.8 ppb
Coastal Ridge Elementary	Rm 201 Bubbler	1.6 ppb
Coastal Ridge Elementary	Rm 201 Faucet	2.1 ppb
Coastal Ridge Elementary	Rm 202 Bubbler	94.8 ppb
Coastal Ridge Elementary	Rm 202 Faucet	3 ppb
Coastal Ridge Elementary	Rm 202 Restroom Faucet	0 ppb
Coastal Ridge Elementary	Rm 203 Bubbler	38 ppb
Coastal Ridge Elementary	Rm 203 Faucet	4 ppb
Coastal Ridge Elementary	Rm 204 Bubbler	1.6 ppb
Coastal Ridge Elementary	Rm 204 Faucet	0 ppb
Coastal Ridge Elementary	Rm 204 Restroom Faucet	0 ppb
Coastal Ridge Elementary	Rm 209 Bubbler	23.5 ppb
Coastal Ridge Elementary	Rm 209 Faucet	0 ppb

School Name	Sample Location	Lead Test Result
Coastal Ridge Elementary	Rm 210 Bubbler	12.9 ppb
Coastal Ridge Elementary	Rm 210 Faucet	0 ppb
Coastal Ridge Elementary	Rm 210 Restroom Faucet	1.5 ppb
Coastal Ridge Elementary	Rm 211 Bubbler	165 ppb
Coastal Ridge Elementary	Rm 211 Faucet	3.9 ppb
Coastal Ridge Elementary	Rm 212 Bubbler	58.9 ppb
Coastal Ridge Elementary	Rm 212 Faucet	2.1 ppb
Coastal Ridge Elementary	Rm 212 Restroom Faucet	0 ppb
Coastal Ridge Elementary	Teacher Breakroom Faucet	0 ppb
Coastal Ridge Elementary	Teacher Breakroom Restroom Faucet	0 ppb
Coastal Wash Cty Inst of Tech	Early Education Kitchen Sink	0 ppb
Coastal Wash Cty Inst of Tech	Hall Drinking Fountain	0 ppb
Coffin School	Back Concourse Water Fountain (adjacent Rm 16)	1.2 ppb
Coffin School	Kitchen Bathroom Handwash Sink	3 ppb
Coffin School	Kitchen Double Basin Sink (prep Area)	0 ppb
Coffin School	Kitchen Handwash Station Sink (dish Station)	4.6 ppb
Coffin School	Kitchen Handwash Station Sink (prep Side)	1.5 ppb
Coffin School	Kitchen Pre Rinse Sink (dish Washer)	1.2 ppb
Coffin School	Kitchen Tilt Skillet Fill	2.3 ppb
Coffin School	Main Lobby Water Fountain (bottle)	0 ppb
Coffin School	Main Lobby Water Fountain (left Drink)	0 ppb
Coffin School	Main Lobby Water Fountain (right Drink)	0 ppb
Coffin School	Rm 10-16 Teacher's Bathroom Sink	0 ppb
Coffin School	Rm 10-16/bathroom Boy's Sink	1.4 ppb
Coffin School	Rm 10-16/bathroom Girl's Sink	2.6 ppb
Coffin School	Rm 1-4/bathroom Boy's Sink	1.2 ppb
Coffin School	Rm 1-4/bathroom Girl's Sink	1.7 ppb
Coffin School	Rm 17-21/bathroom Boy's Sink	4 ppb
Coffin School	Rm 17-21/bathroom Girl's Sink	5.4 ppb
Coffin School	Rm 5-9/bathroom Boy's Sink	1.3 ppb
Coffin School	Rm 5-9/bathroom Girl's Sink	0 ppb
Coffin School	Room 1 Fountain	464 ppb
Coffin School	Room 1 Sink	0 ppb
Coffin School	Room 10 Fountain	42.7 ppb
Coffin School	Room 10 Sink	6.6 ppb
Coffin School	Room 11 Fountain	2.2 ppb
Coffin School	Room 11 Sink	115 ppb
Coffin School	Room 12 Fountain	1.9 ppb
Coffin School	Room 12 Sink	8.1 ppb
Coffin School	Room 13 Fountain	55.3 ppb
Coffin School	Room 13 Sink	207 ppb
Coffin School	Room 14 Fountain	4.4 ppb
Coffin School	Room 14 Sink	319 ppb
Coffin School	Room 15 Fountain	257 ppb
Coffin School	Room 15 Sink	4.7 ppb

School Name	Sample Location	Lead Test Result
Coffin School	Room 16 Sink	6.6 ppb
Coffin School	Room 17 Fountain	4 ppb
Coffin School	Room 17 Sink	7.4 ppb
Coffin School	Room 18 Fountain	2 ppb
Coffin School	Room 18 Sink	2.7 ppb
Coffin School	Room 19 Fountain	2.9 ppb
Coffin School	Room 19 Sink	8.2 ppb
Coffin School	Room 2 Bathroom Handwash Sink	1.8 ppb
Coffin School	Room 2 Fountain	264 ppb
Coffin School	Room 2 Sink	0 ppb
Coffin School	Room 20 Fountain	2.1 ppb
Coffin School	Room 20 Sink	2.2 ppb
Coffin School	Room 21 Fountain	10.5 ppb
Coffin School	Room 21 Sink	3.4 ppb
Coffin School	Room 27 Teacher Break/bathroom Sink	0 ppb
Coffin School	Room 3 Fountain	4410 ppb
Coffin School	Room 3 Sink	8.9 ppb
Coffin School	Room 32 Bathroom Handwash Sink	2.7 ppb
Coffin School	Room 36/gym Bathroom Handwash Sink	2.3 ppb
Coffin School	Room 36/gym Handicap Bathroom Handwash Sink	1.6 ppb
Coffin School	Room 36/gym Water Fountain	148 ppb
Coffin School	Room 4 Fountain	198 ppb
Coffin School	Room 4 Sink	65 ppb
Coffin School	Room 41 Teacher Prep/bathroom Sink	1.3 ppb
Coffin School	Room 5 Fountain	1.4 ppb
Coffin School	Room 5 Sink	9 ppb
Coffin School	Room 50/cafe Water Fountain	7.7 ppb
Coffin School	Room 50/hall Water Tap (plant Area)	1.9 ppb
Coffin School	Room 6 Fountain	45.9 ppb
Coffin School	Room 6 Sink	3.8 ppb
Coffin School	Room 7 Fountain	1.7 ppb
Coffin School	Room 7 Sink	49.2 ppb
Coffin School	Room 8 Fountain	1.3 ppb
Coffin School	Room 8 Sink	7.4 ppb
Coffin School	Room 9 Fountain	1.5 ppb
Coffin School	Room 9 Sink	3.4 ppb
Community Downtown Campus	No Samples Yet Taken	
Community Early Childhood Campus	No Samples Yet Taken	
Congin School	Cafe Drinking Fountain	0 ppb
Congin School	Gym Drinking Fountain	0 ppb
Congin School	Kitchen Prep Sink	1 ppb
Congin School	Nurse Sink 1	0 ppb
Congin School	Nurse Sink 2	0 ppb
Congin School	Room 1 Fountain	0 ppb
Congin School	Room 10 Fountain	0 ppb
Congin School	Room 15 Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Congin School	Room 16 Fountain	0 ppb
Congin School	Room 19 Fountain	0 ppb
Congin School	Room 2 Fountain	0 ppb
Congin School	Room 20 Fountain	0 ppb
Congin School	Room 21 Fountain	0 ppb
Congin School	Room 22 Fountain	0 ppb
Congin School	Room 23 Fountain	0 ppb
Congin School	Room 24 Fountain	0 ppb
Congin School	Room 3 Fountain	0 ppb
Congin School	Room 4 Fountain	0 ppb
Congin School	Room 5 Fountain	0 ppb
Congin School	Room 6 Fountain	0 ppb
Congin School	Room 7 Fountain	0 ppb
Congin School	Room 8 Fountain	0 ppb
Congin School	Room 9 Fountain	0 ppb
Connors-Emerson School	1st Grade Drink Fountain	0 ppb
Connors-Emerson School	2nd Grade Drink Fountain	0 ppb
Connors-Emerson School	3/4 Drink Fountain	0 ppb
Connors-Emerson School	5/6 Bath Drink Fountain	0 ppb
Connors-Emerson School	5/6 Grade Fountain	1.4 ppb
Connors-Emerson School	7/8 Drink Fountain	0 ppb
Connors-Emerson School	Griddle Water Tap	2.6 ppb
Connors-Emerson School	Gym Drink Fountain	0 ppb
Connors-Emerson School	Kindergarten Drink Fountain	0 ppb
Connors-Emerson School	Kitchen Water Supply Sink (three Bay)	2.2 ppb
Connor Consolidated School	Art Room Hand Washing	29.2 ppb
Connor Consolidated School	Boy Restroom & Sinks Handwashing	4.8 ppb
Connor Consolidated School	Boys Gym Locker Room Hand Wash	2.6 ppb
Connor Consolidated School	Custodian Closet Bucket Filling Handwash	2.2 ppb
Connor Consolidated School	Drinking Fountains Near Gym Entrance	0 ppb
Connor Consolidated School	Girl Restroom & Sinks Handwashing	6.1 ppb
Connor Consolidated School	Girls Gym Locker Room Hand Wash	3 ppb
Connor Consolidated School	Grade 45 Room Hand Washing	13.5 ppb
Connor Consolidated School	Grades 123 Hand Washing	6.2 ppb
Connor Consolidated School	Janitors Closet In Main Hall Bucket& Hand	19 ppb
Connor Consolidated School	Kitchen Ice Machine	0 ppb
Connor Consolidated School	Kitchen Left Fixture & Small Sink Hand Wash	17.1 ppb
Connor Consolidated School	Kitchen Right Fixture For Drinking & Cooking	1.1 ppb
Connor Consolidated School	Main Hallway Drinking Next To Kitchen	0 ppb
Connor Consolidated School	Outside Water Spigot Back Wall East Side	35.8 ppb
Connor Consolidated School	Pre K & K Hand Washing	22.4 ppb
Connor Consolidated School	Resource Room Hand Washing	9.8 ppb
Connor Consolidated School	Staff Restroom & Handwashing	5.8 ppb
Cony Middle/High School	Admin Office Sink	0 ppb
Cony Middle/High School	Art Wing Teachers Lounge	0 ppb

School Name	Sample Location	Lead Test Result
Cony Middle/High School	Bottle Fill Station 1st Fl By Mens Rm	0 ppb
Cony Middle/High School	Bottle Fill Station 1st Fl By Womens Rm	0 ppb
Cony Middle/High School	Bottle Fill Station 2nd Fl By Mens Rm	0 ppb
Cony Middle/High School	Bottle Fill Station 2nd Fl By Womens Rm	0 ppb
Cony Middle/High School	Bottle Fill Station Art Hallway	0 ppb
Cony Middle/High School	Bottle Fill Station Band Room	0 ppb
Cony Middle/High School	Bottle Fill Station Food Court	0 ppb
Cony Middle/High School	Bottle Fill Station Great Hall	0 ppb
Cony Middle/High School	Bottle Fill Station Locker Room	0 ppb
Cony Middle/High School	Classroom 301 Sink #1	0 ppb
Cony Middle/High School	Classroom 301 Sink #2	0 ppb
Cony Middle/High School	Classroom 301 Sink #3	0 ppb
Cony Middle/High School	Classroom 301 Sink #4	0 ppb
Cony Middle/High School	Classroom 301 Sink #5	0 ppb
Cony Middle/High School	Concession Stand Sink	0 ppb
Cony Middle/High School	Ice Machine Trainers Room	0 ppb
Cony Middle/High School	Kettle #1 Kitchen	1.3 ppb
Cony Middle/High School	Kettle #2 Kitchen	0 ppb
Cony Middle/High School	Small Sink By Kitchen Stockroom	1.6 ppb
Cony Middle/High School	Small Sink By Tilt Skillet	3.3 ppb
Cony Middle/High School	Teacher Lounge	0 ppb
Cony Middle/High School	Tilt Skillet Kitchen	0 ppb
Cranberry Isles School	Grades 3-8	1.2 ppb
Cranberry Isles School	Kitchen	0 ppb
Cranberry Isles School	Student Bathroom	2.9 ppb
Cranberry Isles School	Teacher Bathroom	1.5 ppb
Creative Children's Academy	Bear Classroom	0 ppb
Creative Children's Academy	Conference Room Sink	0 ppb
Creative Children's Academy	Kitchen Sink	5.6 ppb
Creative Children's Academy	Moose Classroom	0 ppb
Creative Children's Academy	Special Ed Office	3.7 ppb
Crescent Park School	1 Sink Back Wall Kitchen	1.3 ppb
Crescent Park School	1 Sink By Eye Station	0 ppb
Crescent Park School	3 Yr Old Classroom Sink	0 ppb
Crescent Park School	3 Yrs Old Room Bathroom Sink	0 ppb
Crescent Park School	4-5 Boys Bathroom Sink #1	0 ppb
Crescent Park School	4-5 Boys Bathroom Sink #2	0 ppb
Crescent Park School	4-5 Boys Bathroom Sink #3	2.5 ppb
Crescent Park School	4-5 Boys Bathroom Sink #4	1.9 ppb
Crescent Park School	4-5 Girls Bathroom Sink #1	1.8 ppb
Crescent Park School	4-5 Girls Bathroom Sink #2	0 ppb
Crescent Park School	4-5 Girls Bathroom Sink #3	0 ppb
Crescent Park School	4-5 Girls Bathroom Sink #4	0 ppb
Crescent Park School	Across From Clock Sink Kitchen	1.3 ppb
Crescent Park School	Art Room Back Sink	0 ppb
Crescent Park School	Art Room Front Sink	0 ppb
Crescent Park School	Bottle Station By Cust Closet	0 ppb

School Name	Sample Location	Lead Test Result
Crescent Park School	Bottle Station By Music Rm B-g Bath	0 ppb
Crescent Park School	Bottle Station Tech Lab Left	0 ppb
Crescent Park School	Bottle Station Tech Lab Right	0 ppb
Crescent Park School	Bullen Hallway Bathroom Sink	0 ppb
Crescent Park School	Bullen Room Sink	8.7 ppb
Crescent Park School	By Cafe Bottle Station	0 ppb
Crescent Park School	Card Room Sink	0 ppb
Crescent Park School	Chiasson Room Sink	0 ppb
Crescent Park School	Conference Room Sink	5.5 ppb
Crescent Park School	Copy Room Sink	15.7 ppb
Crescent Park School	Crockett Room Sink	0 ppb
Crescent Park School	Cust 4-5 Wing Sink	8.8 ppb
Crescent Park School	Cust Main Floor Sink	1.1 ppb
Crescent Park School	Cust Office Sink	2.7 ppb
Crescent Park School	Danielson Room Sink	0 ppb
Crescent Park School	Fitzmorris Room Sink	3.2 ppb
Crescent Park School	Gould Room Sink	0 ppb
Crescent Park School	Gym Bathroom Left Sink Boys	1.4 ppb
Crescent Park School	Gym Bathroom Right Sink Boys	1.4 ppb
Crescent Park School	Gym Bathroom Sink 1	1.2 ppb
Crescent Park School	Gym Bathroom Sink 2	1.1 ppb
Crescent Park School	Gym Bottle Station	0 ppb
Crescent Park School	Haines Room Sink	1.8 ppb
Crescent Park School	Hunt Room Sink	0 ppb
Crescent Park School	Ice Machine Tammy	0 ppb
Crescent Park School	Kennett Room Sink	0 ppb
Crescent Park School	Kitchen Br Sink	1.3 ppb
Crescent Park School	Kitchen By Dishwasher Sink	0 ppb
Crescent Park School	Kitchen Cust Sink	2.4 ppb
Crescent Park School	Kitchen Double Sink Left	3.4 ppb
Crescent Park School	Kitchen Double Sink Right	1.2 ppb
Crescent Park School	Lavoie Room Sink	0 ppb
Crescent Park School	Lee Room Sink	2.5 ppb
Crescent Park School	Main Floor Custodian Eye Wash	2.7 ppb
Crescent Park School	Meader Bathroom Sink	0 ppb
Crescent Park School	Mka Rm Sink	0 ppb
Crescent Park School	Nurse Room Sink	8.6 ppb
Crescent Park School	Old Kitchen Sink	1.5 ppb
Crescent Park School	Ot Room Sink	4.1 ppb
Crescent Park School	Outside Bathroom Sink	2 ppb
Crescent Park School	Special Ed Rm	0 ppb
Crescent Park School	Staff Bathroom Mcrum Room Sink	0 ppb
Crescent Park School	Staff Lunch Room Sink	0 ppb
Crescent Park School	Tammy Bm Sink	1.2 ppb
Crescent Park School	Upstaires Staff Br By Art Room	0 ppb
Crescent Park School	Welch Room Sink	0 ppb
Crescent Park School	Wight Room Sink	0 ppb

School Name	Sample Location	Lead Test Result
Crescent Park School	Zybes Room Sink	3.8 ppb
Crooked River Elementary School	2 Floor Hallway Across From Elev Bottle Fill	0 ppb
Crooked River Elementary School	2 Floor Hallway Across From Elevator Dwf	0 ppb
Crooked River Elementary School	Gym Hallway Bottle Fill	0 ppb
Crooked River Elementary School	Kitchen Sink Rm # 135	0 ppb
Crooked River Elementary School	Lobby Df # A	0 ppb
Crooked River Elementary School	Main Kitchen 3 Bay Sink Close To Diswasher	0 ppb
Crooked River Elementary School	Main Kitchen 3 Bay Sink-closet To Rear Door	1.3 ppb
Crooked River Elementary School	Main Kitchen Food Prep Sink	0 ppb
Crooked River Elementary School	Main Kitchen Hand Sink By Dishwasher	0 ppb
Crooked River Elementary School	Main Kitchen Hand Sink By Freezer	5.4 ppb
Crooked River Elementary School	Main Lobby Df # Bottle Fill	0 ppb
Crooked River Elementary School	Main Lobby Df Lower	0 ppb
Crooked River Elementary School	Main Office Sink	0 ppb
Crooked River Elementary School	New Wing Hallway 1st Floor Dwf	0 ppb
Crooked River Elementary School	New Wing Hallway 1st Floor Dwf Bottle Fill	0 ppb
Crooked River Elementary School	New Wing Hallway 2nd Floor Bottle Fill	0 ppb
Crooked River Elementary School	New Wing Hallway 2nd Floor Dwf	0 ppb
Crooked River Elementary School	Nurse Dwf	0 ppb
Crooked River Elementary School	Nurse Ice Maker	0 ppb
Crooked River Elementary School	Nurse Sink	0 ppb
Crooked River Elementary School	Rm 142 Dwf	0 ppb
Crooked River Elementary School	Rm 142 Sink	0 ppb
Crooked River Elementary School	Rm 143 Dwf	0 ppb
Crooked River Elementary School	Rm 143 Sink	0 ppb
Crooked River Elementary School	Rm 149 Dwf	0 ppb
Crooked River Elementary School	Rm 149 Sink	0 ppb
Crooked River Elementary School	Rm 152 Dwf	0 ppb
Crooked River Elementary School	Rm 152 Sink	0 ppb
Crooked River Elementary School	Rm 153 Dwf	0 ppb
Crooked River Elementary School	Rm 153 Sink	0 ppb
Crooked River Elementary School	Rm 201 Dwf	0 ppb
Crooked River Elementary School	Rm 201 Sink	0 ppb
Crooked River Elementary School	Rm 209 Art Room Sink # A	0 ppb
Crooked River Elementary School	Rm 209 Art Room Sink # B	2.9 ppb
Crooked River Elementary School	Rm 214 Dwf	1.6 ppb
Crooked River Elementary School	Rm 214 Sink	12.1 ppb
Crooked River Elementary School	Rm 217 Dwf	0 ppb
Crooked River Elementary School	Rm 217 Sink	5.6 ppb
Crooked River Elementary School	Rm 219 Dwf	0 ppb
Crooked River Elementary School	Rm 219 Sink	3.1 ppb
Crooked River Elementary School	Rm 222 Dwf	0 ppb
Crooked River Elementary School	Rm 222 Sink	0 ppb
Crooked River Elementary School	Rm 227 Dwf	0 ppb

School Name	Sample Location	Lead Test Result
Crooked River Elementary School	Rm 227 Sink	0 ppb
Crooked River Elementary School	Rm 228 Dwf	0 ppb
Crooked River Elementary School	Rm 228 Sink	0 ppb
Crooked River Elementary School	Rm 234 Dwf	0 ppb
Crooked River Elementary School	Rm 234 Sink	0 ppb
Crooked River Elementary School	Rm 237 Dwf	0 ppb
Crooked River Elementary School	Rm 237 Sink	0 ppb
Crooked River Elementary School	Rm 238 Dwf	0 ppb
Crooked River Elementary School	Rm 238 Sink	0 ppb
Crooked River Elementary School	Rm 241 Library Work Room Sink	0 ppb
Crooked River Elementary School	Staff Break Rm -upstairs By Art Rm	1.3 ppb
Ctr for Autism & Dev Disorders	No Samples Yet Taken	
Cushing Community School	Boys Bathroom Sink	13 ppb
Cushing Community School	Faculty Bathroom Sink	7 ppb
Cushing Community School	Girls Bathroom Sink	8.2 ppb
Cushing Community School	Kitchen - Double Basin Sink	1.4 ppb
Cushing Community School	Kitchen - Hand Wash Sink	9.5 ppb
Cushing Community School	Kitchen - Sink With Sprayer	7.8 ppb
Cushing Community School	Nurses Office Sink	6.6 ppb
Cushing Community School	Room 1 Third Grade Sink	10.1 ppb
Cushing Community School	Room 10 Second Grade Sink	6.4 ppb
Cushing Community School	Room 11 First Grade Sink	6 ppb
Cushing Community School	Room 12 Kindergarten Bathroom Sink	5.8 ppb
Cushing Community School	Room 12 Kindergarten Kitchen Sink	5.4 ppb
Cushing Community School	Room 7 Fifth Grade Sink	9.8 ppb
Cushing Community School	Room 8 Fourth Grade Sink	10.6 ppb
Cushing Community School	Teachers Lounge Sink	6.1 ppb
Cushing Community School	Water Fountain - By Teachers Lounge	0 ppb
Cushing Community School	Water Fountain Gym	0 ppb
Damariscotta Montessori School	Drinking Fountain Outdoors By Classrm Bldg.	8.3 ppb
Damariscotta Montessori School	Eagle's Nest Classroom Sink	6.4 ppb
Damariscotta Montessori School	Heron's Nest Classrm Sink Drinking Fountain	3.6 ppb
Damariscotta Montessori School	Heron's Nest Classroom Sink Faucet	5 ppb
Damariscotta Montessori School	Kitchen- Admin Bldg.	4.5 ppb
Damariscotta Montessori School	Kitchen- Classroom Bldg.	3.5 ppb
Damariscotta Montessori School	Loon's Nest Classroom Sink	1.9 ppb
Damariscotta Montessori School	Osprey's Nest Classrm Sink Drnkg Fountain	22.7 ppb
Damariscotta Montessori School	Osprey's Nest Classroom Sink Faucet	26.6 ppb
Damariscotta Montessori School	Puffin's Nest Classroom Sink	2 ppb
Daniel F. Mahoney Middle School	1st Flr..kitchen Sink 3	0 ppb
Daniel F. Mahoney Middle School	1st Flr...kitchen Sink 1	0 ppb
Daniel F. Mahoney Middle School	1st Flr...kitchen Sink 2	0 ppb
Daniel F. Mahoney Middle School	2nd Flr...room 215	0 ppb
Daniel F. Mahoney Middle School	Bottle Fill Station 2nd Flr	0 ppb

School Name	Sample Location	Lead Test Result
Daniel F. Mahoney Middle School	Bottle Fill Station 2nd Flr	0 ppb
Daniel F. Mahoney Middle School	Bottle Fill Station 3rd Flr	0 ppb
Daniel F. Mahoney Middle School	Bottle Fill Station 3rd Flr	0 ppb
Daniel F. Mahoney Middle School	Home Ec Room..1st Flr	1.6 ppb
Daniel W Merritt School	Drinking Fountain Next To Pre-k	1.3 ppb
Daniel W Merritt School	Drinking Fountain Next To Teaches Room	1.9 ppb
Daniel W Merritt School	Gym Drinking Fountain	1.4 ppb
Daniel W Merritt School	Kitchen Food Prep Sink	14.6 ppb
Dawn F Barnes Elementary Sch	2nd Sink In Kitchen	49.7 ppb
Dawn F Barnes Elementary Sch	Employee Bathroom Sink	21.3 ppb
Dawn F Barnes Elementary Sch	Faucet In Garage	0 ppb
Dawn F Barnes Elementary Sch	Faucet In Janitor Room	152 ppb
Dawn F Barnes Elementary Sch	Faucet In Kitchen Restroom	43.8 ppb
Dawn F Barnes Elementary Sch	Grade 6-8 Sink	20.7 ppb
Dawn F Barnes Elementary Sch	Outside Hose Hook Up At Garage	31.9 ppb
Dawn F Barnes Elementary Sch	Outside Spicket In Front Of Office	37.4 ppb
Dawn F Barnes Elementary Sch	Sink In Art Room	148 ppb
Dawn F Barnes Elementary Sch	Sink In Boys Bathroom	27.3 ppb
Dawn F Barnes Elementary Sch	Sink In Dishwashing Room	32.4 ppb
Dawn F Barnes Elementary Sch	Sink In Girls Bathroom	43.7 ppb
Dawn F Barnes Elementary Sch	Sink In Grades 3-5	10.3 ppb
Dawn F Barnes Elementary Sch	Sink In Kitchen	25 ppb
Dawn F Barnes Elementary Sch	Sink In Playroom	38.2 ppb
Dawn F Barnes Elementary Sch	Sink In Pre-k Room	10.2 ppb
Dawn F Barnes Elementary Sch	Sink In Town Office Bathroom	14.4 ppb
Dawn F Barnes Elementary Sch	Water Fountain In Gym	0 ppb
Dawn F Barnes Elementary Sch	Water Fountain Near Main Entrance	3.3 ppb
Dayton Consolidated School	Dwf Obr	0 ppb
Dayton Consolidated School	Dwf Orm 2a	0 ppb
Dayton Consolidated School	Dwf Rm 11	5.3 ppb
Dayton Consolidated School	Snk Kitchen A	2.2 ppb
Dayton Consolidated School	Snk Kitchen B	11 ppb
Dayton Consolidated School	Snk Mod Bldg	0 ppb
Dayton Consolidated School	Snk Rm 11	1.2 ppb
Dayton Consolidated School	Snk Rm 5	9 ppb
Dayton Consolidated School	Teacher's Room Sink	19.5 ppb
Dedham School	2-5 Boys Bathroom Sink	0 ppb
Dedham School	2-5 Water Fountain	0 ppb
Dedham School	Boys Bathroom Across From Office	1.1 ppb
Dedham School	Kitchen 2 Bay Sink	3.3 ppb
Dedham School	Middle School Boys Bathroom Sink	0 ppb
Dedham School	Middle School Water Fountain	0 ppb
Dedham School	Science Lab Left Sink Bay	0 ppb
Dedham School	Teachers Room Kitchen Sink	0 ppb
Dedham School	Water Fountain Across From Office	0 ppb
Deer Isle-Stonington Elementary Sch	Art Room Sink Left	22.5 ppb
Deer Isle-Stonington Elementary Sch	Art Room Sink Right	19.3 ppb

School Name	Sample Location	Lead Test Result
Deer Isle-Stonington Elementary Sch	Cafeteria Mini Kitchen Sink By Dryer	4 ppb
Deer Isle-Stonington Elementary Sch	Cafeteria Mini Kitchen Sink By Dw	6.3 ppb
Deer Isle-Stonington Elementary Sch	End Of 3-4 Hall Sink	1.1 ppb
Deer Isle-Stonington Elementary Sch	Fountain 2nd Floor By Elevator Lower	0 ppb
Deer Isle-Stonington Elementary Sch	Fountain 2nd Floor By Elevator Upper	0 ppb
Deer Isle-Stonington Elementary Sch	Fountain 5-7 Hall Lower	2.1 ppb
Deer Isle-Stonington Elementary Sch	Fountain 5-7 Hall Upper	1.9 ppb
Deer Isle-Stonington Elementary Sch	Fountain By Cafeteria Lower	3.6 ppb
Deer Isle-Stonington Elementary Sch	Fountain By Cafeteria Upper	2.7 ppb
Deer Isle-Stonington Elementary Sch	Fountain By Elevator 1st Floor Lower	1.2 ppb
Deer Isle-Stonington Elementary Sch	Fountain By Elevator 1st Floor Upper	1.4 ppb
Deer Isle-Stonington Elementary Sch	Fountain Gym Bottle Fill	0 ppb
Deer Isle-Stonington Elementary Sch	Fountain Gym Lower	0 ppb
Deer Isle-Stonington Elementary Sch	Fountain Gym Upper	0 ppb
Deer Isle-Stonington Elementary Sch	Kitchen Kettle Fill	68.9 ppb
Deer Isle-Stonington Elementary Sch	Kitchen Prep Sink	10 ppb
Deer Isle-Stonington Elementary Sch	Library Sink	78.2 ppb
Deer Isle-Stonington Elementary Sch	Room 105 Faucet	8.5 ppb
Deer Isle-Stonington Elementary Sch	Room 118 Faucet	2.6 ppb
Deer Isle-Stonington Elementary Sch	Room 118 Fountain	1.2 ppb
Deer Isle-Stonington Elementary Sch	Room 119 Faucet	2.2 ppb
Deer Isle-Stonington Elementary Sch	Room 119 Fountain	0 ppb
Deer Isle-Stonington Elementary Sch	Room 120 Faucet	3.2 ppb
Deer Isle-Stonington Elementary Sch	Room 120 Fountain	0 ppb
Deer Isle-Stonington Elementary Sch	Room 121 Faucet	1.8 ppb
Deer Isle-Stonington Elementary Sch	Room 121 Fountain	0 ppb
Deer Isle-Stonington Elementary Sch	Room 122 Faucet	1.4 ppb
Deer Isle-Stonington Elementary Sch	Room 122 Fountain	1.4 ppb
Deer Isle-Stonington Elementary Sch	Room 124 Faucet	3 ppb
Deer Isle-Stonington Elementary Sch	Room 124 Fountain	1.5 ppb
Deer Isle-Stonington Elementary Sch	Room 125 Faucet	6.8 ppb
Deer Isle-Stonington Elementary Sch	Room 125 Fountain	3.2 ppb
Deer Isle-Stonington Elementary Sch	Room 204 Sink	1.6 ppb
Deer Isle-Stonington Elementary Sch	Room 223 Faucet	5.7 ppb
Deer Isle-Stonington Elementary Sch	Staff Room Sink	5.5 ppb
Deer Isle-Stonington High Sch	Art Room Sink Left	23.3 ppb
Deer Isle-Stonington High Sch	Art Room Sink Right	23.2 ppb
Deer Isle-Stonington High Sch	Central Office Staff Lunch Area	5.8 ppb
Deer Isle-Stonington High Sch	Drinking Fountain Academic Wing	1.7 ppb
Deer Isle-Stonington High Sch	Drinking Fountain By Cafeteria	2 ppb
Deer Isle-Stonington High Sch	Drinking Fountain By Cafeteria Bottle Fill	5.3 ppb
Deer Isle-Stonington High Sch	Drinking Water Fountain Bottle Fill Station	2.5 ppb
Deer Isle-Stonington High Sch	Kitchen Food Prep Sink	29 ppb
Deer Isle-Stonington High Sch	Kitchen Scrub Sink	10.2 ppb
Deer Isle-Stonington High Sch	Life Skills Room Sink	3.9 ppb
Deer Isle-Stonington High Sch	Office	6.1 ppb
Deer Isle-Stonington High Sch	Shop Deep Sink Left	36.4 ppb

School Name	Sample Location	Lead Test Result
Deer Isle-Stonington High Sch	Staff Room Sink	8.4 ppb
Deering High School	126	0 ppb
Deering High School	1st Floor	0 ppb
Deering High School	2nd Floor	0 ppb
Deering High School	301-1	689 ppb
Deering High School	301-2	25.5 ppb
Deering High School	302-1	2800 ppb
Deering High School	302-2	6020 ppb
Deering High School	303-1	33.9 ppb
Deering High School	303-2	9 ppb
Deering High School	304-1	1.8 ppb
Deering High School	305-1	11.1 ppb
Deering High School	305-2	15.5 ppb
Deering High School	306-1	41.1 ppb
Deering High School	306-2	30.3 ppb
Deering High School	307-1	8.1 ppb
Deering High School	307-2	7.5 ppb
Deering High School	308-1	13.8 ppb
Deering High School	308-2	8 ppb
Deering High School	318-1	20600 ppb
Deering High School	318-2	42200 ppb
Deering High School	319-1	67.3 ppb
Deering High School	319-2	6 ppb
Deering High School	320-1	134 ppb
Deering High School	320-2	28.8 ppb
Deering High School	321-1	2460 ppb
Deering High School	3rd Floor	0 ppb
Deering High School	Gym Lobby	0 ppb
Deering High School	Kitchen - Next To Hood	3.9 ppb
Deering High School	Kitchen - Next To Kitchen Office	5 ppb
Deering High School	Kitchen (cappuccino)	81.6 ppb
Deering High School	Kitchen (coffee)	29.6 ppb
Deering High School	Pos-1	199 ppb
Denmark Elementary School	Classroom #1	8 ppb
Denmark Elementary School	Classroom #2	10.4 ppb
Denmark Elementary School	Classroom #3	7.8 ppb
Denmark Elementary School	Classroom #4	5.4 ppb
Denmark Elementary School	Classroom #5	21.8 ppb
Denmark Elementary School	Kitchen	6.3 ppb
Denmark Elementary School	Main Entry	0 ppb
Denmark Elementary School	Nurse Room	0 ppb
Denmark Elementary School	Staff Room	1.9 ppb
Dexter Regional High School	Boys Locker Room Sink	3.2 ppb
Dexter Regional High School	Cafe Fountain	0 ppb
Dexter Regional High School	Downstairs Custodian Room Sink	8 ppb
Dexter Regional High School	Fountain By 104	58.1 ppb
Dexter Regional High School	Girls Locker Room Sink	4.4 ppb

School Name	Sample Location	Lead Test Result
Dexter Regional High School	Kitchen 2 Bay Sink	14.6 ppb
Dexter Regional High School	Kitchen 3 Bay Sink	25.7 ppb
Dexter Regional High School	Kitchen Bathroom Sink	3.5 ppb
Dexter Regional High School	Lobby Fountain	50.9 ppb
Dexter Regional High School	Main Hall Fountain	16.4 ppb
Dexter Regional High School	Main Office Sink	5.7 ppb
Dexter Regional High School	Room 109 Bathroom Sink	6 ppb
Dexter Regional High School	Room 109 Sink	6.1 ppb
Dexter Regional High School	Upstairs Custodian Room Sink	6.8 ppb
Dexter Regional High School	Upstairs Fountain	61 ppb
Dike-Newell School	Drinking Fountain By Bathroom	7.8 ppb
Dike-Newell School	Drinking Fountain By Gym	123 ppb
Dike-Newell School	Drinking Fountain By Rm 32	27.7 ppb
Dike-Newell School	Drinking Fountain Rm 1	22.5 ppb
Dike-Newell School	Drinking Fountain Rm 2	17.2 ppb
Dike-Newell School	Drinking Fountain Rm 27	1.3 ppb
Dike-Newell School	Drinking Fountain Rm 27a	7.4 ppb
Dike-Newell School	Drinking Fountain Rm 28	2.9 ppb
Dike-Newell School	Drinking Fountain Rm 3	6.6 ppb
Dike-Newell School	Drinking Fountain Rm 35	8.4 ppb
Dike-Newell School	Drinking Fountain Rm 4	4.2 ppb
Dike-Newell School	Drinking Fountain Rm 5	7 ppb
Dike-Newell School	Drinking Fountain/sink Rm 29	22.1 ppb
Dike-Newell School	Dwf Outside Of Cafe	2.1 ppb
Dike-Newell School	Sink Kitchen	0 ppb
Dike-Newell School	Sink Main Office	16.4 ppb
Dike-Newell School	Sink Nurses Office	5.7 ppb
Dike-Newell School	Sink Staff Rm 2nd Floor	18.9 ppb
Dimensions Academy	Fountain In Hallway Across From Office	1.8 ppb
Dimensions Academy	Large Kitchen Sink	1.4 ppb
Dimensions Academy	Room 5 Sink	2 ppb
Dimensions Academy	Room 6 Sink	2.5 ppb
Dimensions Academy	Room 8 Sink	0 ppb
Dimensions Academy	Room 9 Sink	3.2 ppb
Dimensions Academy	Staff Room Kitchen	0 ppb
Dirigo Elementary School	Down Stairs Bottle Fill	0 ppb
Dirigo Elementary School	Kitchen 3 Bay Sink	11.2 ppb
Dirigo Elementary School	Kitchen Hand Wash Sink # 1	0 ppb
Dirigo Elementary School	Kitchen Hand Wash Sink # 2	4 ppb
Dirigo Elementary School	Kitchen Kettle # 1	2430 ppb
Dirigo Elementary School	Kitchen Kettle # 2	7.2 ppb
Dirigo Elementary School	Kitchen Single Bay Sink	11.8 ppb
Dirigo Elementary School	Main Libby Bottle Fill	0 ppb
Dirigo Elementary School	Room A 100 Sink #1	1.5 ppb
Dirigo Elementary School	Room A 100 Sink #2	1.3 ppb
Dirigo Elementary School	Room A 101 Room Sink	0 ppb
Dirigo Elementary School	Room A 109 Room Sink	1.1 ppb

School Name	Sample Location	Lead Test Result
Dirigo Elementary School	Room A 123 Sink # 1	2.5 ppb
Dirigo Elementary School	Room A 123 Sink # 2	0 ppb
Dirigo Elementary School	Room A 123 Sink # 3	2.7 ppb
Dirigo Elementary School	Room A 124 Sink # 1	0 ppb
Dirigo Elementary School	Room A 124 Sink # 2	1.3 ppb
Dirigo Elementary School	Room A 124 Sink # 3	0 ppb
Dirigo Elementary School	Room A 131 Bathroom Sink	1 ppb
Dirigo Elementary School	Room A 155 Room Sink	0 ppb
Dirigo Elementary School	Room A 159 Bathroom Sink	1.9 ppb
Dirigo Elementary School	Room A 159 Room Sink	0 ppb
Dirigo Elementary School	Room A 161 Bathroom Sink	1.3 ppb
Dirigo Elementary School	Room A 161 Room Sink	0 ppb
Dirigo Elementary School	Room A 163 Bathroom Sink	3.6 ppb
Dirigo Elementary School	Room A 163 Room Sink	0 ppb
Dirigo Elementary School	Room A 165 Bathroom Sink	0 ppb
Dirigo Elementary School	Room A 165 Room Sink	0 ppb
Dirigo Elementary School	Room A 166 Sink	0 ppb
Dirigo Elementary School	Room B 102 Bathroom Sink	1.1 ppb
Dirigo Elementary School	Room B 102 Room Sink	0 ppb
Dirigo Elementary School	Room B 104 Bathroom Sink	0 ppb
Dirigo Elementary School	Room B 104 Room Sink	0 ppb
Dirigo Elementary School	Room B 106 Bathroom Sink	1.6 ppb
Dirigo Elementary School	Room B 106 Room Sink	0 ppb
Dirigo Elementary School	Room B 108 Bathroom Sink	0 ppb
Dirigo Elementary School	Room B 108 Room Sink	0 ppb
Dirigo Elementary School	Room B 110 Bathroom Sink	0 ppb
Dirigo Elementary School	Room B 110 Room Sink	0 ppb
Dirigo Elementary School	Room B 133 Bathroom Sink	1.2 ppb
Dirigo Elementary School	Room B 133 Room Sink	0 ppb
Dirigo Elementary School	Room B 135 Bathroom Sink	0 ppb
Dirigo Elementary School	Room B 135 Room Sink	0 ppb
Dirigo Elementary School	Room B 137 Bathroom Sink	0 ppb
Dirigo Elementary School	Room B 137 Room Sink	0 ppb
Dirigo Elementary School	Room B 140 Bathroom Sink	1 ppb
Dirigo Elementary School	Room B 140 Room Sink	0 ppb
Dirigo Elementary School	Room B 143 Bathroom Sink	0 ppb
Dirigo Elementary School	Room B 143 Room Sink	0 ppb
Dirigo Elementary School	Room B 145 Bathroom Sink	1.2 ppb
Dirigo Elementary School	Room B 145 Room Sink	0 ppb
Dirigo Elementary School	Room B 204 Room Sink	0 ppb
Dirigo Elementary School	Room B 205 Room Sink	0 ppb
Dirigo Elementary School	Room B 206 Room Sink	0 ppb
Dirigo Elementary School	Room B 207 Room Sink	0 ppb
Dirigo Elementary School	Room B 208 Room Sink	0 ppb
Dirigo Elementary School	Room B 209 Sink # 1	0 ppb
Dirigo Elementary School	Room B 209 Sink # 2	1.1 ppb
Dirigo Elementary School	Room B 209 Sink # 3	0 ppb

School Name	Sample Location	Lead Test Result
Dirigo Elementary School	Room B 218 Room Sink	1.1 ppb
Dirigo Elementary School	Room B 219 Room Sink	0 ppb
Dirigo Elementary School	Room B 220 Room Sink	0 ppb
Dirigo Elementary School	Room B 223 Room Sink	0 ppb
Dirigo Elementary School	Room B 225 Room Sink	0 ppb
Dirigo Elementary School	Room B 226 Sink # 1	0 ppb
Dirigo Elementary School	Room B 226 Sink # 2	1.4 ppb
Dirigo Elementary School	Room B 226 Sink # 3	0 ppb
Dirigo Elementary School	Room B 227 Room Sink	0 ppb
Dirigo Elementary School	Room B 228 Room Sink	0 ppb
Dirigo Elementary School	Up Stairs Bottle Fill	0 ppb
Dirigo High School	Down Stairs Bottle Fill Station	0 ppb
Dirigo High School	Kitchen Sink	3.3 ppb
Dirigo High School	Lobby Bottle Fill Station	0 ppb
Dirigo High School	Nurse Bathroom	1.7 ppb
Dirigo High School	Room 206 Sink 1	2.4 ppb
Dirigo High School	Room 206 Sink 2	1 ppb
Dirigo High School	Room 206 Sink 3	7.2 ppb
Dirigo High School	Room 206 Sink 4	0 ppb
Dirigo High School	Teacher Room Sink	1.7 ppb
Dirigo High School	Up Stairs Bottle Fill Station	0 ppb
Dora L Small Elementary School	1st Fl..bottle Fill Station..near Gym	0 ppb
Dora L Small Elementary School	1st Fl..bottle Fill Station..near Restrooms	0 ppb
Dora L Small Elementary School	1st Fl..bottle Fill Station..near Restrooms	0 ppb
Dora L Small Elementary School	2nd Fl..bottle Fill Station	0 ppb
Dora L Small Elementary School	2nd Fl..bottle Fill Station	0 ppb
Dora L Small Elementary School	Art	0 ppb
Dora L Small Elementary School	Kitchen	0 ppb
Dora L Small Elementary School	Nurse Office	0 ppb
Dora L Small Elementary School	Room 101	0 ppb
Dora L Small Elementary School	Room 102	0 ppb
Dora L Small Elementary School	Room 103	0 ppb
Dora L Small Elementary School	Room 104	0 ppb
Dora L Small Elementary School	Room 105	0 ppb
Dora L Small Elementary School	Room 106	0 ppb
Dora L Small Elementary School	Room 110	0 ppb
Dora L Small Elementary School	Room 112	0 ppb
Dora L Small Elementary School	Room 113	0 ppb
Dora L Small Elementary School	Room 201	0 ppb
Dora L Small Elementary School	Room 202	0 ppb
Dora L Small Elementary School	Room 203	0 ppb
Dora L Small Elementary School	Room 204	0 ppb
Dora L Small Elementary School	Room 205	0 ppb
Dora L Small Elementary School	Room 206	0 ppb
Dora L Small Elementary School	Room 207	0 ppb
Dora L Small Elementary School	Teacher Break Room	0 ppb
Downeast School	Bottle Fill Station - B Wing	23.9 ppb

School Name	Sample Location	Lead Test Result
Downeast School	Drinking Water Tap - Room A1	35.4 ppb
Downeast School	Drinking Water Tap - Room A2	16.3 ppb
Downeast School	Drinking Water Tap - Room B14	45.9 ppb
Downeast School	Drinking Water Tap - Room B16	32.7 ppb
Downeast School	Drinking Water Tap - Room B17	66.7 ppb
Downeast School	Drinking Water Tap - Room B18	22.6 ppb
Downeast School	Drinking Water Tap - Room B19	16 ppb
Downeast School	Drinking Water Tap - Room C20	15.7 ppb
Downeast School	Drinking Water Tap - Room C21	6.9 ppb
Downeast School	Drinking Water Tap - Room C22	10.4 ppb
Downeast School	Drinking Water Tap - Room C23	14.5 ppb
Downeast School	Drinking Water Tap - Room C24	21.8 ppb
Downeast School	Drinking Water Tap - Room C25	1500 ppb
Downeast School	Drinking Water Tap - Room D5	714 ppb
Downeast School	Drinking Water Tap - Room D6	13.3 ppb
Downeast School	Drinking Water Tap - Room D7	12.2 ppb
Downeast School	Drinking Water Tap - Room D8	20 ppb
Downeast School	Drinking Water Tap - Room D9	7.9 ppb
Downeast School	Drinking Water Tap - Room E10	5.1 ppb
Downeast School	Drinking Water Tap - Room E11	11 ppb
Downeast School	Drinking Water Tap - Room E12	4.5 ppb
Downeast School	Drinking Water Tap - Room E13	31.2 ppb
Downeast School	Faucet - Book Room	663 ppb
Downeast School	Faucet - Main Office	24.9 ppb
Downeast School	Faucet - Nurse Station	30.2 ppb
Downeast School	Faucet - Teacher's Lounge	4.9 ppb
Downeast School	Kitchen - Food Prep Faucet	7.1 ppb
Downeast School	Kitchen-kettle	7.6 ppb
Dr Lewis S Libby School	Kitchen Hand Wash Sink	3.6 ppb
Dr Lewis S Libby School	Kitchen Kettle	18.2 ppb
Dr Lewis S Libby School	Kitchen Veg Sink-left	41.9 ppb
Dr Lewis S Libby School	Kitchen Veg Sink-right	583 ppb
Dr Lewis S Libby School	Outside Kitchen-bottle Fill Station	0 ppb
Dr Lewis S Libby School	Outside Kitchen-boys Bathroom Sink	0 ppb
Dr Lewis S Libby School	Outside Kitchen-girls Bathroom Sink	0 ppb
Dr Lewis S Libby School	Outside Room 202- Bottle Fill Station	0 ppb
Dr Lewis S Libby School	Outside Room 208-unisex Bathroom	0 ppb
Dr Lewis S Libby School	Outside Room 213-bottle Fill Station	0 ppb
Dr Lewis S Libby School	Room 105-bathroom Sink	1.4 ppb
Dr Lewis S Libby School	Room 108-office Bathroom Sink	5.5 ppb
Dr Lewis S Libby School	Room 108-sink	5.1 ppb
Dr Lewis S Libby School	Room 109-sink	2.2 ppb
Dr Lewis S Libby School	Room 110- Sink	1.5 ppb
Dr Lewis S Libby School	Room 113-fountain	22.7 ppb
Dr Lewis S Libby School	Room 113-left Sink	25.4 ppb
Dr Lewis S Libby School	Room 113-right Sink	6.5 ppb
Dr Lewis S Libby School	Room 114-fountain	88.7 ppb

School Name	Sample Location	Lead Test Result
Dr Lewis S Libby School	Room 114-sink	5.4 ppb
Dr Lewis S Libby School	Room 115-fountain	40.8 ppb
Dr Lewis S Libby School	Room 115-sink	61.2 ppb
Dr Lewis S Libby School	Room 116-left Sink	3460 ppb
Dr Lewis S Libby School	Room 118-sink	9.1 ppb
Dr Lewis S Libby School	Room 119-sink	5.7 ppb
Dr Lewis S Libby School	Room 120-fountain	14.5 ppb
Dr Lewis S Libby School	Room 120-sink	3.2 ppb
Dr Lewis S Libby School	Room 121-fountain	8.3 ppb
Dr Lewis S Libby School	Room 121-sink	1.3 ppb
Dr Lewis S Libby School	Room 122-fountain	22.2 ppb
Dr Lewis S Libby School	Room 122-sink	3.5 ppb
Dr Lewis S Libby School	Room 124-bottle Fill Station	0 ppb
Dr Lewis S Libby School	Room 124-fountain	0 ppb
Dr Lewis S Libby School	Room 125-sink	0 ppb
Dr Lewis S Libby School	Room 126-sink 1 (interior)	56.7 ppb
Dr Lewis S Libby School	Room 126-sink 2	68.5 ppb
Dr Lewis S Libby School	Room 126-sink 3	15.9 ppb
Dr Lewis S Libby School	Room 126-sink 4 (exterior)	10.2 ppb
Dr Lewis S Libby School	Room 128- Small Sink	6.8 ppb
Dr Lewis S Libby School	Room 128-janitors Sink	60.6 ppb
Dr Lewis S Libby School	Room 128-large Sink	52.2 ppb
Dr Lewis S Libby School	Room 133-fountain	0 ppb
Dr Lewis S Libby School	Room 133-sink	1.4 ppb
Dr Lewis S Libby School	Room 134-fountain	0 ppb
Dr Lewis S Libby School	Room 134-sink	1.4 ppb
Dr Lewis S Libby School	Room 136-left Sink	52 ppb
Dr Lewis S Libby School	Room 137-fountain	26.6 ppb
Dr Lewis S Libby School	Room 137-sink	1.6 ppb
Dr Lewis S Libby School	Room 138-fountain	18.3 ppb
Dr Lewis S Libby School	Room 138-sink	12.4 ppb
Dr Lewis S Libby School	Room 139-fountain	22.5 ppb
Dr Lewis S Libby School	Room 139-sink	3.3 ppb
Dr Lewis S Libby School	Room 142-fountain	17.4 ppb
Dr Lewis S Libby School	Room 142-sink	0 ppb
Dr Lewis S Libby School	Room 143- Kitchenette Sink	27.7 ppb
Dr Lewis S Libby School	Room 143-bathroom Sink	1.4 ppb
Dr Lewis S Libby School	Room 144-fountain	13.1 ppb
Dr Lewis S Libby School	Room 144-sink	1.7 ppb
Dr Lewis S Libby School	Room 146-fountain	8.5 ppb
Dr Lewis S Libby School	Room 146-sink	1.1 ppb
Dr Lewis S Libby School	Room 147-fountain	15.9 ppb
Dr Lewis S Libby School	Room 147-sink	0 ppb
Dr Lewis S Libby School	Room 148-fountain	8 ppb
Dr Lewis S Libby School	Room 148-sink	0 ppb
Dr Lewis S Libby School	Room 149-fountain	40.7 ppb
Dr Lewis S Libby School	Room 149-sink	0 ppb

School Name	Sample Location	Lead Test Result
Dr Lewis S Libby School	Room 150-dwf	14 ppb
Dr Lewis S Libby School	Room 150-sink	342 ppb
Dr Lewis S Libby School	Room 200-fountain	30.7 ppb
Dr Lewis S Libby School	Room 200-sink	5.2 ppb
Dr Lewis S Libby School	Room 205-bathroom Sink	4.8 ppb
Dr Lewis S Libby School	Room 207-left Sink	10.5 ppb
Dr Lewis S Libby School	Room 207-right Sink	3.8 ppb
Dr Lewis S Libby School	Room 208-left Sink	8.2 ppb
Dr Lewis S Libby School	Room 208-right Sink	98.9 ppb
Dr Lewis S Libby School	Room 209-left Sink	2.2 ppb
Dr Lewis S Libby School	Room 209-right Sink	3.4 ppb
Dr Lewis S Libby School	Room 210-left Sink	3.3 ppb
Dr Lewis S Libby School	Room 210-right Sink	1.6 ppb
Dresden Elementary School	3d Teachers Lounge Sink	0 ppb
Dresden Elementary School	Art Room Sink A	0 ppb
Dresden Elementary School	Art Room Sink B	0 ppb
Dresden Elementary School	Downstairs Boys Bathroom Sink	1.5 ppb
Dresden Elementary School	Downstairs Girls Bathroom Sink	1.1 ppb
Dresden Elementary School	Downstairs Water Fountain- Main Hall	0 ppb
Dresden Elementary School	Gym Boys Restroom- Sink	0 ppb
Dresden Elementary School	Gym Drinking Water Fountain	0 ppb
Dresden Elementary School	Gym Girls Restroom- Sink	0 ppb
Dresden Elementary School	Kitchen Hand Wash Sink	61.4 ppb
Dresden Elementary School	Kitchen Sink 2 Bay	1.8 ppb
Dresden Elementary School	Rm 13u Fountain	1.3 ppb
Dresden Elementary School	Rm 13u Sink	7.1 ppb
Dresden Elementary School	Rm 14u Foutain	1.8 ppb
Dresden Elementary School	Rm 14u Sink	2.9 ppb
Dresden Elementary School	Rm 16u Fountain	1.9 ppb
Dresden Elementary School	Rm 16u Sink	3.1 ppb
Dresden Elementary School	Rm 6u Sink	0 ppb
Dresden Elementary School	Rm 7u Sink- Nurses Office	0 ppb
Dresden Elementary School	Rm 8u Fountain	1.6 ppb
Dresden Elementary School	Rm 8u Sink	4.6 ppb
Dresden Elementary School	Teacher Lounge Downstairs Rr Sink (rm# 3d)	18.2 ppb
Dresden Elementary School	Upstair Teachers Bathroom Sink	0 ppb
Dresden Elementary School	Upstairs Water Fountain	0 ppb
Durham Community School	106	1.1 ppb
Durham Community School	107	1.7 ppb
Durham Community School	108	0 ppb
Durham Community School	109	2.1 ppb
Durham Community School	116	1 ppb
Durham Community School	117	7.1 ppb
Durham Community School	118	1.3 ppb
Durham Community School	119	0 ppb
Durham Community School	120	1.1 ppb

School Name	Sample Location	Lead Test Result
Durham Community School	123	2.6 ppb
Durham Community School	124	4.2 ppb
Durham Community School	125	2.8 ppb
Durham Community School	126	3.7 ppb
Durham Community School	127	2.2 ppb
Durham Community School	133	3.1 ppb
Durham Community School	134	1.1 ppb
Durham Community School	1st Floor Gang Bathroom	0 ppb
Durham Community School	201	1.3 ppb
Durham Community School	202	0 ppb
Durham Community School	203	0 ppb
Durham Community School	204	1.9 ppb
Durham Community School	205	0 ppb
Durham Community School	206	1.1 ppb
Durham Community School	207	0 ppb
Durham Community School	210	3 ppb
Durham Community School	211	2.4 ppb
Durham Community School	212	0 ppb
Durham Community School	213	1.4 ppb
Durham Community School	214	1.1 ppb
Durham Community School	215	1.6 ppb
Durham Community School	Cafeteria	0 ppb
Durham Community School	Gym Locker Rooms	0 ppb
Durham Community School	Ice Machine	0 ppb
Durham Community School	Kitchen Sink	0 ppb
Durham Community School	Left Main Hall At Room 109	0 ppb
Durham Community School	Main Straight At Room 127	0 ppb
Durham Community School	Nurses Office	3.5 ppb
Durham Community School	Room 105 #2	1.4 ppb
Durham Community School	Room 130	0 ppb
Durham Community School	Upper Level At Room 208	1.4 ppb
Dyer Elementary School	Art	0 ppb
Dyer Elementary School	Bottle Fill Near Main Office	0 ppb
Dyer Elementary School	Bottle Fill Station..near Restrooms	0 ppb
Dyer Elementary School	Bottle Fill Station..near Restrooms	0 ppb
Dyer Elementary School	Bottle Fill Stationà.near Main Office	0 ppb
Dyer Elementary School	Kitchen....sink	0 ppb
Dyer Elementary School	Nurse Office	0 ppb
Dyer Elementary School	Room 10	1.1 ppb
Dyer Elementary School	Room 11	0 ppb
Dyer Elementary School	Room 12	0 ppb
Dyer Elementary School	Room 13	0 ppb
Dyer Elementary School	Room 14	0 ppb
Dyer Elementary School	Room 2	0 ppb
Dyer Elementary School	Room 3	0 ppb
Dyer Elementary School	Room 4	0 ppb
Dyer Elementary School	Room 5	0 ppb

School Name	Sample Location	Lead Test Result
Dyer Elementary School	Room 6	0 ppb
Dyer Elementary School	Room 7	0 ppb
Dyer Elementary School	Room 8	0 ppb
Dyer Elementary School	Room 9	0 ppb
Dyer Elementary School	Special Ed...room 18	0 ppb
Dyer Elementary School	Teacher Breakroom..workroom 10	1.2 ppb
Earl C McGraw School	Classroom 1	2.5 ppb
Earl C McGraw School	Classroom 10	3.4 ppb
Earl C McGraw School	Classroom 11	0 ppb
Earl C McGraw School	Classroom 12	0 ppb
Earl C McGraw School	Classroom 13	1.8 ppb
Earl C McGraw School	Classroom 14	2.8 ppb
Earl C McGraw School	Classroom 15	1.8 ppb
Earl C McGraw School	Classroom 16	1.9 ppb
Earl C McGraw School	Classroom 17	60.3 ppb
Earl C McGraw School	Classroom 18	7.3 ppb
Earl C McGraw School	Classroom 3	2.1 ppb
Earl C McGraw School	Classroom 4	2.2 ppb
Earl C McGraw School	Classroom 5	1.2 ppb
Earl C McGraw School	Classroom 6	2.8 ppb
Earl C McGraw School	Classroom 7	1.7 ppb
Earl C McGraw School	Classroom 8	3.5 ppb
Earl C McGraw School	Classroom 9	2.9 ppb
Earl C McGraw School	Drinking Fountain In Cafeteria	2.3 ppb
Earl C McGraw School	Drinking Fountain Next To Custodial Closet	1.7 ppb
Earl C McGraw School	Kitchen 2-bay Sink Next To Office	7.9 ppb
Earl C McGraw School	Main Office Bathroom Faucet	10.2 ppb
East Auburn Community School	Basement Last Room End Of Hall Faucet	10.2 ppb
East Auburn Community School	Basement Room Across From M Stair Bubbler	35.2 ppb
East Auburn Community School	Basement Room Across From M Stair Faucet	37.8 ppb
East Auburn Community School	Boys Bathroom Across From 101 L Faucet	0 ppb
East Auburn Community School	Boys Bathroom Across From 101 R Faucet	0 ppb
East Auburn Community School	Bubbler Across From 101	0 ppb
East Auburn Community School	Girls Bathroom Across From 101 L Faucet	0 ppb
East Auburn Community School	Girls Bathroom Across From 101 R Faucet	0 ppb
East Auburn Community School	Hall Bathroom Across From Room 106 Faucet	0 ppb
East Auburn Community School	Hallway By Office 3 Bathroom Cluster C Faucet	0 ppb
East Auburn Community School	Hallway By Office 3 Bathroom Cluster L Faucet	0 ppb
East Auburn Community School	Hallway By Office 3 Bathroom Cluster R Faucet	0 ppb
East Auburn Community School	Hallway By Office Bubbler	0 ppb

School Name	Sample Location	Lead Test Result
East Auburn Community School	Hallway By Office Water Bottle Filler	0 ppb
East Auburn Community School	Kitchen Faucet	1 ppb
East Auburn Community School	Nurses Office Faucet	2.5 ppb
East Auburn Community School	Room 102 Faucet	4.6 ppb
East Auburn Community School	Room 103 Across From Bell Rope Faucet	4.5 ppb
East Auburn Community School	Room 104 Faucet	3.8 ppb
East Auburn Community School	Room 106 Faucet	1.5 ppb
East Auburn Community School	Room 109 Faucet	1.8 ppb
East Auburn Community School	Room 110 Bathroom Faucet	1.9 ppb
East Auburn Community School	Room 110 Left Faucet	1.9 ppb
East Auburn Community School	Room 110 Right Faucet	3.3 ppb
East Auburn Community School	Room 111 Faucet	2.4 ppb
East Auburn Community School	Room 113 Faucet	0 ppb
East Auburn Community School	Room 115 Faucet	1.4 ppb
East Auburn Community School	Water Bottle Filling Station Across From 101	0 ppb
East Belfast School	Classroom 2nd Grade (no Door #)	0 ppb
East Belfast School	Hallway By Room 109 1	0 ppb
East Belfast School	Hallway By Room 109 2	0 ppb
East Belfast School	Kitchen Left	5 ppb
East Belfast School	Kitchen Right	5.6 ppb
East Belfast School	Main Entrance 1	0 ppb
East Belfast School	Main Entrance 2	0 ppb
East Belfast School	Nexis Classroom	0 ppb
East Belfast School	Pre-k Classroom	1.7 ppb
East Belfast School	Resource Room	4.9 ppb
East Belfast School	Room 109	1.3 ppb
East Belfast School	Room 123	1.1 ppb
East Belfast School	Room 126	3.2 ppb
East Belfast School	Room 129	0 ppb
East Belfast School	Staff Lounge	2.8 ppb
East Belfast School	Title One Room	2 ppb
East End Community School	106	0 ppb
East End Community School	107	1 ppb
East End Community School	108	0 ppb
East End Community School	109	1.1 ppb
East End Community School	110	0 ppb
East End Community School	111	2.4 ppb
East End Community School	112	0 ppb
East End Community School	113	0 ppb
East End Community School	114	0 ppb
East End Community School	115	1.1 ppb
East End Community School	116	0 ppb
East End Community School	119	0 ppb
East End Community School	120	0 ppb
East End Community School	121	0 ppb
East End Community School	122	1.3 ppb

School Name	Sample Location	Lead Test Result
East End Community School	123	0 ppb
East End Community School	125	1.2 ppb
East End Community School	127	0 ppb
East End Community School	133	0 ppb
East End Community School	151	0 ppb
East End Community School	153	43.6 ppb
East End Community School	159	7.7 ppb
East End Community School	205	1.1 ppb
East End Community School	206	0 ppb
East End Community School	207	0 ppb
East End Community School	208	1.7 ppb
East End Community School	209	0 ppb
East End Community School	210	0 ppb
East End Community School	212	1.5 ppb
East End Community School	213	1.1 ppb
East End Community School	214	0 ppb
East End Community School	215	0 ppb
East End Community School	216	0 ppb
East End Community School	219	0 ppb
East End Community School	220	0 ppb
East End Community School	221	0 ppb
East End Community School	222	1.5 ppb
East End Community School	223	1.5 ppb
East End Community School	228	1.1 ppb
East End Community School	229	1.9 ppb
East End Community School	235	1.6 ppb
East End Community School	Hall - By 128	0 ppb
East End Community School	Hall - By 153	0 ppb
East End Community School	Hall - By 231	0 ppb
East End Community School	Hall - By Locker Rooms	0 ppb
East End Community School	Pos-1	0 ppb
East Grand School	Afterschool Program Fountain	0 ppb
East Grand School	Afterschool Program Sink	1.8 ppb
East Grand School	Cafeteria Ice Machine	0 ppb
East Grand School	Elementary Fountain	0 ppb
East Grand School	Gym Fountain	0 ppb
East Grand School	High School Fountain	4.7 ppb
East Grand School	Middle School Fountain	0 ppb
East Grand School	School Cafeteria Sink	1.4 ppb
East Grand School	Special Education Sink	1.2 ppb
East Grand School	Teachers Room Ice Machine	0 ppb
East Grand School	Teachers Room Sink	2.6 ppb
East Range II CSD School	Boys Bathroom Sink Front Entrance	3.1 ppb
East Range II CSD School	Boys Bathroom Sink Gym	2.9 ppb
East Range II CSD School	Girls Bathroom Sink Front Entrance	8.1 ppb
East Range II CSD School	Girls Bathroom Sink Gym	3.5 ppb
East Range II CSD School	K-2 Sink	2.5 ppb

School Name	Sample Location	Lead Test Result
East Range II CSD School	K-2 Water Fountain	9.2 ppb
East Range II CSD School	Kitchen Handwash Sink	7.2 ppb
East Range II CSD School	Kitchen Sink	2.4 ppb
East Range II CSD School	Staff Bathroom Sink	4.1 ppb
East Range II CSD School	Water Fountain Front Entrance	0 ppb
East Range II CSD School	Water Fountain Gym	1.3 ppb
Easton Elementary School	Boy's Locker Rm Adj Gym Snk#1	15 ppb
Easton Elementary School	Boy's Rest Rm Adj Gym Snk #1	4 ppb
Easton Elementary School	Boy's Rest Rm Adj Gym Snk #2	2.9 ppb
Easton Elementary School	Custodian Snk Adj Boiler Rm	22.1 ppb
Easton Elementary School	Exterior Water Tap N.e. Corner	6.5 ppb
Easton Elementary School	Girl's Lckr Rm Adj Gym Snk	1.8 ppb
Easton Elementary School	Girl's Rest Rm Adj Gym Snk#1	4.2 ppb
Easton Elementary School	Girl's Rest Rm Adj Gym Snk#2	3.5 ppb
Easton Elementary School	Gym Water Fountain	3.7 ppb
Easton Elementary School	Ktchn Hand Wash Adj Restroom	16.6 ppb
Easton Elementary School	Ktchn N. Wall Hand Wash Snk	22 ppb
Easton Elementary School	Ktchn N. Wall Snk	5 ppb
Easton Elementary School	Ktchn Rest Rm Snk	5.8 ppb
Easton Elementary School	Ktchn W. Wall Snk	5.2 ppb
Easton Elementary School	Nurse's Snk	1.5 ppb
Easton Elementary School	P.e. Office Snk	34.6 ppb
Easton Elementary School	Rm 101 Grd2 Snk	8.6 ppb
Easton Elementary School	Rm 201 Art Snk	1.9 ppb
Easton Elementary School	Rm 302 Grd5 Snk	5.2 ppb
Easton Elementary School	Rm102 Pre-k Snk	2.4 ppb
Easton Elementary School	Rm103 Grd1 Snk	5.5 ppb
Easton Elementary School	Rm104 K Fountain	2 ppb
Easton Elementary School	Rm104 K Snk	2.3 ppb
Easton Elementary School	S. Hall Bottle Station	0 ppb
Easton Elementary School	S. Hall Boy's Rest Rm Snk#1	2.1 ppb
Easton Elementary School	S. Hall Boy's Rest Rm Snk#2	3.7 ppb
Easton Elementary School	S. Hall Girl's Rest Rm Snk#1	45.5 ppb
Easton Elementary School	S. Hall Girl's Rest Rm Snk#2	2.8 ppb
Easton Elementary School	Teacher's Rm Men Sink	3.6 ppb
Easton Elementary School	Teacher's Rm Women Sink	2.9 ppb
Easton Elementary School	W. Hall Boy's Rest Rm Snk#1	3 ppb
Easton Elementary School	W. Hall Boy's Rest Rm Snk#2	6.9 ppb
Easton Elementary School	W. Hall Girl's Rest Rm Snk#1	8.2 ppb
Easton Elementary School	W. Hall Girl's Rest Rm Snk#2	2.3 ppb
Easton Elementary School	W. Hall Water Fountain	0 ppb
Easton Junior-Senior High Sch	Boy's Locker Rm Sink	1.4 ppb
Easton Junior-Senior High Sch	Boy's Rest Rm Sink #1	2.6 ppb
Easton Junior-Senior High Sch	Boy's Rest Rm Sink #2	2.1 ppb
Easton Junior-Senior High Sch	Boy's Rest Rm Sink #3	2.7 ppb
Easton Junior-Senior High Sch	Faculty Rest Rm Sink	9.7 ppb
Easton Junior-Senior High Sch	Garage Spigot	1.2 ppb

School Name	Sample Location	Lead Test Result
Easton Junior-Senior High Sch	Girl's Locker Rm Sink	6.5 ppb
Easton Junior-Senior High Sch	Girl's Rest Rm Sink #1	3.9 ppb
Easton Junior-Senior High Sch	Girl's Rest Rm Sink #2	1.1 ppb
Easton Junior-Senior High Sch	Girl's Rest Rm Sink #3	3.8 ppb
Easton Junior-Senior High Sch	Hall Bottle Filling Station	2.3 ppb
Easton Junior-Senior High Sch	Library Rest Rm Sink	1.2 ppb
Easton Junior-Senior High Sch	Nurse Office	1.3 ppb
Easton Junior-Senior High Sch	Rm 12 Envirothon Sink	1.8 ppb
Easton Junior-Senior High Sch	Rm 6 Art Sink	9.9 ppb
Easton Junior-Senior High Sch	Science Rm Faucet #4	30.8 ppb
Easton Junior-Senior High Sch	Science Rm Faucet #5	34.8 ppb
Eastport Elementary School	Kitchen 3 Bay Sink	0 ppb
Eastport Elementary School	Kitchen Produce Sink	2.3 ppb
Eastport Elementary School	Kitchen Steam Kettle Faucet	1.5 ppb
Eastport Elementary School	Main Office Clinic	0 ppb
Eastport Elementary School	Rm 104 Bay Sink With Drinking Fountain	0 ppb
Eastport Elementary School	Rm 106 Bay Sink With Drinking Fountain	0 ppb
Eastport Elementary School	Rm 108 Bay Sink With Drinking Fountain	0 ppb
Eastport Elementary School	Rm 110 Bay Sink With Drinking Fountain	0 ppb
Eastport Elementary School	Rm 112 Bay Sink With Drinking Fountain	0 ppb
Eastport Elementary School	Rm 202 1 Bay Sink	0 ppb
Eastport Elementary School	Staff Room 1 Bay Sink	0 ppb
Eastport Elementary School	Supper's Office Bay Sink With Drinking Fountain	0 ppb
Eastport Elementary School	Upper Hallway Water Fountain	0 ppb
Ecology Learning Ctr	Bathroom Floor 1 5cc	1.5 ppb
Ecology Learning Ctr	Bathroom Floor 2 5cc	1.4 ppb
Ecology Learning Ctr	Kitchenette	4.7 ppb
Ecology Learning Ctr	Lg Bathroom 1 Floor	4.9 ppb
Ecology Learning Ctr	Nor'east Bathroom	8.2 ppb
Ecology Learning Ctr	Rufus Bathroom	7 ppb
Ecology Learning Ctr	Small Bathroom Foyer Side	3.7 ppb
Ecology Learning Ctr	Small Bathroom Hallway Side	3.2 ppb
Ecology Learning Ctr	Spigot 1 Rt Of Front Door	19.1 ppb
Ecology Learning Ctr	Spigot 2 Lf Of Front Door	151 ppb
Ecology Learning Ctr	Spigot 3 Under Fire Escape South	24.3 ppb
Ecology Learning Ctr	Spigot 4 Lf Of Back Door	28.7 ppb
Ecology Learning Ctr	Tea/coffee Station	2.5 ppb
Ecology Learning Ctr	Tea/coffee Station 5cc	10 ppb
Eddington School	Hallway 111	0 ppb
Eddington School	Hallway 125	0 ppb
Eddington School	Portable 1	0 ppb
Eddington School	Room 101	5.4 ppb
Eddington School	Room 102	3.7 ppb
Eddington School	Room 103	8.8 ppb
Eddington School	Room 104	3.9 ppb
Eddington School	Room 130	4.7 ppb

School Name	Sample Location	Lead Test Result
Eddington School	Room 140	1.1 ppb
Eddington School	Room 143	0 ppb
Edgecomb Eddy School	1st Grade #31 Casey Single Sink Faucet	3 ppb
Edgecomb Eddy School	2nd Grade #3 Gooslin; Single Sink Faucet	1 ppb
Edgecomb Eddy School	3rd Grade #20 Forten Single Sink Faucet	1.3 ppb
Edgecomb Eddy School	4th Grade #1 Currier Single Sink Faucet	1.8 ppb
Edgecomb Eddy School	5th Grade Rose Single Sink Faucet	2.9 ppb
Edgecomb Eddy School	6th Grade #10 Ellis Single Sink Faucet	2 ppb
Edgecomb Eddy School	Drinking Water Fountain By Staff Room	0 ppb
Edgecomb Eddy School	Kindergarten Kelly Single Sink Faucet	3.1 ppb
Edgecomb Eddy School	Kitchen; Left Hand Faucet #1	15.7 ppb
Edgecomb Eddy School	Kitchen; Right Hand Faucet #2	6.2 ppb
Edgecomb Eddy School	Nurse Room Single Sink Faucet	1.9 ppb
Edgecomb Eddy School	Prek; Monroe; Single Sink #39	2.1 ppb
Edgecomb Eddy School	Special Ed Room Single Sink Faucet	3.7 ppb
Edgecomb Eddy School	Staff Room Single Sink Kitchen Faucet	3.6 ppb
Edmunds Consolidated School	Gym - Bottle Fill Station	0 ppb
Edmunds Consolidated School	Hall Near Girls Rr - Bottle Fill Station	0 ppb
Edmunds Consolidated School	Kitchen - Faucet	33 ppb
Edmunds Consolidated School	Lower Hall - Bottle Fill Station	0 ppb
Edmunds Consolidated School	Staff Break Room - Faucet	2 ppb
Edna Drinkwater School	1st Grade Classroom	0 ppb
Edna Drinkwater School	2nd Grade Classroom	0 ppb
Edna Drinkwater School	Bottle Station	0 ppb
Edna Drinkwater School	Kindergarten Room	0 ppb
Edna Drinkwater School	Kitchen Sink - Main One Little Sink	0 ppb
Edna Drinkwater School	Kitchen Sink - Secondary Big One To Right	8.4 ppb
Edna Drinkwater School	Nurses Office	0 ppb
Edna Drinkwater School	Sink - Art/music/tech Room	0 ppb
Edna Drinkwater School	Sink - Nate's Classroom	0 ppb
Edna Drinkwater School	Sink - Science Room - #1 Near Window	1.6 ppb
Edna Drinkwater School	Sink - Science Room - #2 Next In Line	2.2 ppb
Edna Drinkwater School	Sink - Science Room - #3 Next In Line	0 ppb
Edna Drinkwater School	Sink - Science Room - #4 By Door	0 ppb
Edna Drinkwater School	Sink - Science Room - #5 Separate One To Right	0 ppb
Edna Libby Elementary School	Art Room Faucet A	9.4 ppb
Edna Libby Elementary School	Art Room Faucet B	8.1 ppb
Edna Libby Elementary School	Bottle Fill By Gym	0 ppb
Edna Libby Elementary School	Clinic Faucet 1	5.3 ppb
Edna Libby Elementary School	Fountain Across From Clinic	0 ppb
Edna Libby Elementary School	Fountain Across From Office	2.6 ppb
Edna Libby Elementary School	Fountain By Boys Restroom 2nd Floor	1.3 ppb
Edna Libby Elementary School	Fountain By Girls Restroom 2nd Floor	1.7 ppb
Edna Libby Elementary School	Fountain By Gym	0 ppb
Edna Libby Elementary School	Kitchen Prep Sink	3.6 ppb
Edna Libby Elementary School	Room 10 Faucet	5.6 ppb

School Name	Sample Location	Lead Test Result
Edna Libby Elementary School	Room 10 Fountain	4.4 ppb
Edna Libby Elementary School	Room 11 Faucet	1.8 ppb
Edna Libby Elementary School	Room 11 Fountain	4.9 ppb
Edna Libby Elementary School	Room 12 Faucet	4.1 ppb
Edna Libby Elementary School	Room 12 Fountain	7.9 ppb
Edna Libby Elementary School	Room 13 Faucet	10 ppb
Edna Libby Elementary School	Room 13 Fountain	11.4 ppb
Edna Libby Elementary School	Room 17 Fountain A	12.5 ppb
Edna Libby Elementary School	Room 17 Fountain B	8.4 ppb
Edna Libby Elementary School	Room 17 Sink A	4.3 ppb
Edna Libby Elementary School	Room 17 Sink B	7 ppb
Edna Libby Elementary School	Room 18 Fountain A	4.3 ppb
Edna Libby Elementary School	Room 18 Fountain B	11.7 ppb
Edna Libby Elementary School	Room 18 Sink A	5.8 ppb
Edna Libby Elementary School	Room 18 Sink B	5.3 ppb
Edna Libby Elementary School	Room 19 Faucet	2.5 ppb
Edna Libby Elementary School	Room 19 Fountain	8.6 ppb
Edna Libby Elementary School	Room 20 Faucet	2.3 ppb
Edna Libby Elementary School	Room 20 Fountain	6.4 ppb
Edna Libby Elementary School	Room 21 Faucet	3.8 ppb
Edna Libby Elementary School	Room 21 Fountain	4.8 ppb
Edna Libby Elementary School	Room 22 Faucet	3.5 ppb
Edna Libby Elementary School	Room 22 Fountain	6 ppb
Edna Libby Elementary School	Room 23 Faucet	3.8 ppb
Edna Libby Elementary School	Room 23 Fountain	6 ppb
Edna Libby Elementary School	Room 24 Faucet	5.4 ppb
Edna Libby Elementary School	Room 24 Fountain	7.3 ppb
Edna Libby Elementary School	Room 25 Faucet	2.4 ppb
Edna Libby Elementary School	Room 25 Fountain	4.6 ppb
Edna Libby Elementary School	Room 26 Faucet	2.6 ppb
Edna Libby Elementary School	Room 26 Fountain	7.3 ppb
Edna Libby Elementary School	Room 27 Faucet	14.7 ppb
Edna Libby Elementary School	Room 27 Fountain	22.9 ppb
Edna Libby Elementary School	Room 30 Faucet	18.1 ppb
Edna Libby Elementary School	Room 30 Fountain	6.3 ppb
Edna Libby Elementary School	Room 3a Faucet	5.4 ppb
Edna Libby Elementary School	Room 3a Fountain	4.2 ppb
Edna Libby Elementary School	Room 4 Faucet	6.4 ppb
Edna Libby Elementary School	Room 4 Fountain	4.4 ppb
Edna Libby Elementary School	Room 5 Faucet	4 ppb
Edna Libby Elementary School	Room 5 Fountain	4.3 ppb
Edna Libby Elementary School	Room 6 Faucet	4.6 ppb
Edna Libby Elementary School	Room 6 Fountain	5.3 ppb
Edna Libby Elementary School	Room 8 Fountain	5.1 ppb
Edna Libby Elementary School	Room 8 Faucet	5 ppb
Edna Libby Elementary School	Room 9 Faucet	6.6 ppb
Edna Libby Elementary School	Room 9 Fountain	10.2 ppb

School Name	Sample Location	Lead Test Result
Edna Libby Elementary School	Staff Room Faucet 1	1.1 ppb
Edward Little High School	Adult Ed Bathroom Faucet	11.4 ppb
Edward Little High School	Bottle Filler And Bubbler	0 ppb
Edward Little High School	Bottle Filler And Bubbler By Ice Maker Gym	0 ppb
Edward Little High School	Bottle Filler By Office	1.5 ppb
Edward Little High School	Bottle Filler By Room 224	0 ppb
Edward Little High School	Boys Restroom Faucet	0 ppb
Edward Little High School	Bubbler By Girls Room Gym	13.1 ppb
Edward Little High School	Bubbler By Office	2.4 ppb
Edward Little High School	Bubbler By Room 124	0 ppb
Edward Little High School	Bubbler By Room 216	6.6 ppb
Edward Little High School	Bubbler By Room 224	0 ppb
Edward Little High School	Bubbler Next Room 116	5.7 ppb
Edward Little High School	Bubbler Next To Room 101	7.2 ppb
Edward Little High School	Bubbler Next To Teachers Room	8.9 ppb
Edward Little High School	Cafeteria Kitchen 3 Bay Sink	3.5 ppb
Edward Little High School	Cafeteria Kitchen Bottle Filler	0 ppb
Edward Little High School	Cafeteria Kitchen Bubbler	0 ppb
Edward Little High School	Cafeteria Kitchen L Faucet	6.4 ppb
Edward Little High School	Cafeteria Kitchen R Faucet	3.9 ppb
Edward Little High School	Concession Boys Room L Faucet	569 ppb
Edward Little High School	Concession Boys Room Left Center Faucet	18.7 ppb
Edward Little High School	Concession Boys Room Right Center Faucet	2.1 ppb
Edward Little High School	Concession Boys Room Right Faucet	5.8 ppb
Edward Little High School	Concession Room Faucet	95 ppb
Edward Little High School	Culinary Arts Room L Center Faucet	0 ppb
Edward Little High School	Culinary Arts Room L Faucet	0 ppb
Edward Little High School	Culinary Arts Room R Center Faucet	2.2 ppb
Edward Little High School	Culinary Arts Room R Faucet	0 ppb
Edward Little High School	Dark Room Sink By Boiler Room	2.7 ppb
Edward Little High School	Football Locker Room Bubbler	0 ppb
Edward Little High School	Football Locker Room Faucet	31.7 ppb
Edward Little High School	Girls Bathroom Next To Teach Room L Faucet	1 ppb
Edward Little High School	Girls Bathroom Next To Teach Room R Faucet	0 ppb
Edward Little High School	Girls Restroom Faucet	1.9 ppb
Edward Little High School	Girls Room By Room 216 L Faucet	1.8 ppb
Edward Little High School	Girls Room By Room 216 R Faucet	2.4 ppb
Edward Little High School	Guidance Room Faucet	201 ppb
Edward Little High School	Gym Bubbler	0 ppb
Edward Little High School	Gym Faucet	4.2 ppb
Edward Little High School	Gym Girls Room L Faucet	4.1 ppb
Edward Little High School	Gym Girls Room Left Center Faucet	2.6 ppb
Edward Little High School	Gym Girls Room Right Center Faucet	5.2 ppb

School Name	Sample Location	Lead Test Result
Edward Little High School	Gym Girls Room Right Faucet	122 ppb
Edward Little High School	Hallway Bubbler By Room 206	7.1 ppb
Edward Little High School	Hallway By Room 211 Bottle Filler	1.6 ppb
Edward Little High School	Hallway By Room 211 Bubbler	2.3 ppb
Edward Little High School	Ice Maker Gym	3.6 ppb
Edward Little High School	Mens Locker Room Left Faucet	6.5 ppb
Edward Little High School	Mens Locker Room Right Faucet	3.6 ppb
Edward Little High School	Mens Room By Room 212 L Faucet	1.6 ppb
Edward Little High School	Mens Room By Room 212 R Faucet	1.6 ppb
Edward Little High School	Mens Room Next To Room 116 L Faucet	1.6 ppb
Edward Little High School	Mens Room Next To Room 116 R Faucet	1.7 ppb
Edward Little High School	Nurses 2nd Exam Room Faucet By Window	20.7 ppb
Edward Little High School	Nurses 2nd Exam Room On Right Faucet	3.8 ppb
Edward Little High School	Nurses Office Faucet	52 ppb
Edward Little High School	Nurses Room 1st Exam Room On Left Faucet	5.4 ppb
Edward Little High School	Nurses Room Bathroom Faucet	1.9 ppb
Edward Little High School	Nurses Room Entry Room Faucet	2.2 ppb
Edward Little High School	Nurses Room Exam Room On Right Faucet	1.8 ppb
Edward Little High School	Office Bathroom Faucet	4 ppb
Edward Little High School	Principals Office Bathroom Faucet	30.4 ppb
Edward Little High School	Print Shop Sink	167 ppb
Edward Little High School	Room 106 Bathroom Faucet	2 ppb
Edward Little High School	Room 106 Faucet	2.3 ppb
Edward Little High School	Room 110 Left Faucet	16.2 ppb
Edward Little High School	Room 110 Right Faucet	95.9 ppb
Edward Little High School	Room 123 Faucet	6.5 ppb
Edward Little High School	Room 139 Faucet	1.2 ppb
Edward Little High School	Room 141 1st Faucet On Right	2.1 ppb
Edward Little High School	Room 141 2nd Faucet On Right	2.4 ppb
Edward Little High School	Room 143 Faucet	3.6 ppb
Edward Little High School	Room 143 Faucet Dark Room	8.8 ppb
Edward Little High School	Room 144 Faucet	0 ppb
Edward Little High School	Room 211 Upon Entry L Faucet	73.7 ppb
Edward Little High School	Room 211 Upon Entry R Faucet	101 ppb
Edward Little High School	Room 213 Faucet In Storage Room	101 ppb
Edward Little High School	Room 214 Faucet	10.6 ppb
Edward Little High School	Room 215 Upon Entry L Faucet	11200 ppb
Edward Little High School	Room 215 Upon Entry R Faucet	10.1 ppb
Edward Little High School	Room 217 Faucet At Rear Of Room	76.8 ppb
Edward Little High School	Room 217 Faucet By Entry	2.3 ppb
Edward Little High School	Room 219 Faucet	1.8 ppb
Edward Little High School	Room 220 Faucet W/ Eye Station	9.8 ppb
Edward Little High School	Room 220 Station 1 Faucet	5.7 ppb
Edward Little High School	Room 220 Station 10 Faucet	4.8 ppb
Edward Little High School	Room 220 Station 11 Faucet	15.5 ppb
Edward Little High School	Room 220 Station 12 Faucet	33.9 ppb

School Name	Sample Location	Lead Test Result
Edward Little High School	Room 220 Station 2 Faucet	4.5 ppb
Edward Little High School	Room 220 Station 3 Faucet	4.7 ppb
Edward Little High School	Room 220 Station 4 Faucet	3.8 ppb
Edward Little High School	Room 220 Station 5 Faucet	6.5 ppb
Edward Little High School	Room 220 Station 6 Faucet	6.3 ppb
Edward Little High School	Room 220 Station 7 Faucet	6.8 ppb
Edward Little High School	Room 220 Station 8 Faucet	6.3 ppb
Edward Little High School	Room 220 Station 9 Faucet	5.6 ppb
Edward Little High School	Room 221 Faucet	91.1 ppb
Edward Little High School	Room 222 Faucet	49.2 ppb
Edward Little High School	Room 223 Faucet	6.8 ppb
Edward Little High School	Room 224 Faucet	18.4 ppb
Edward Little High School	Room 84 1st Sink On Right	2.4 ppb
Edward Little High School	Room 84 2nd Sink On Right	23.4 ppb
Edward Little High School	Room 87 Faucet	5 ppb
Edward Little High School	Shower Room Under Stairwell Faucet	3.8 ppb
Edward Little High School	Staff Bathroom By Room 136 Faucet	0 ppb
Edward Little High School	Teachers Room Faucet	8.6 ppb
Edward Little High School	Teachers Room Mens Bathroom Faucet	1.2 ppb
Edward Little High School	Teachers Room Womens Bathroom Faucet	1.5 ppb
Edward Little High School	Teachers Womens Restroom Faucet	2.2 ppb
Edward Little High School	Undesignated Locker Mens Bathroom Center Faucet	2.7 ppb
Edward Little High School	Undesignated Locker Mens Bathroom L Center Faucet	1.7 ppb
Edward Little High School	Undesignated Locker Mens Bathroom L Faucet	778 ppb
Edward Little High School	Undesignated Locker Mens Bathroom R Cent. Faucet	2.6 ppb
Edward Little High School	Undesignated Locker Mens Bathroom Right Faucet	4 ppb
Edward Little High School	Undesignated Locker Mens Faucet	3.1 ppb
Edward Little High School	Weight Room Left Faucet	210 ppb
Edward Little High School	Weight Room Right Faucet	6.5 ppb
Edward Little High School	Womens Bathroom L Cent. Faucet	3.3 ppb
Edward Little High School	Womens Bathroom Left Faucet	2.4 ppb
Edward Little High School	Womens Bathroom R Cent. Faucet	4.4 ppb
Edward Little High School	Womens Bathroom Right Faucet	1.8 ppb
Edward Little High School	Womens Locker Room Faucet	3.2 ppb
Eight Corners Elementary School	Art Room Sink	5.9 ppb
Eight Corners Elementary School	Clinic Sink	1.2 ppb
Eight Corners Elementary School	Culligan Water Dispenser	0 ppb
Eight Corners Elementary School	Hall Bath Sink 1	1 ppb
Eight Corners Elementary School	Hall Bath Sink 2	0 ppb
Eight Corners Elementary School	Hall Filler	0 ppb
Eight Corners Elementary School	Hall Fountain	0 ppb
Eight Corners Elementary School	Kitchen 3-bay R Faucet	4.4 ppb

School Name	Sample Location	Lead Test Result
Eight Corners Elementary School	Library Sink	4.1 ppb
Eight Corners Elementary School	Room 10 Fountain	1 ppb
Eight Corners Elementary School	Room 10 Sink	2.5 ppb
Eight Corners Elementary School	Room 11 Fountain	0 ppb
Eight Corners Elementary School	Room 11 Sink	3.6 ppb
Eight Corners Elementary School	Room 13 Fountain	6.7 ppb
Eight Corners Elementary School	Room 13 Sink	2.4 ppb
Eight Corners Elementary School	Room 14 Fountain	0 ppb
Eight Corners Elementary School	Room 14 Sink	2.2 ppb
Eight Corners Elementary School	Room 15 Fountain	1.5 ppb
Eight Corners Elementary School	Room 15 Sink	3.5 ppb
Eight Corners Elementary School	Room 16 Fountain	0 ppb
Eight Corners Elementary School	Room 16 Sink	3.5 ppb
Eight Corners Elementary School	Room 17 Fountain	1.1 ppb
Eight Corners Elementary School	Room 17 Sink	2.2 ppb
Eight Corners Elementary School	Room 18 Sink	1.6 ppb
Eight Corners Elementary School	Room 19 Sink	1.2 ppb
Eight Corners Elementary School	Room 20 Sink	0 ppb
Eight Corners Elementary School	Room 21 Sink	0 ppb
Eight Corners Elementary School	Room 24 Sink	0 ppb
Eight Corners Elementary School	Room 25 Sink	0 ppb
Eight Corners Elementary School	Room 6 Fountain	1.4 ppb
Eight Corners Elementary School	Room 6 Sink	1.9 ppb
Eight Corners Elementary School	Room 7 Fountain	1.3 ppb
Eight Corners Elementary School	Room 7 Sink	2.5 ppb
Eight Corners Elementary School	Room 8 Fountain	0 ppb
Eight Corners Elementary School	Room 8 Sink	6 ppb
Eight Corners Elementary School	Room 9 Fountain	2.9 ppb
Eight Corners Elementary School	Room 9 Sink	3.1 ppb
Eight Corners Elementary School	Teacher Room Sink	2.4 ppb
Eliot Elementary School	1st Floor Hallway Across From Main Office	0 ppb
Eliot Elementary School	1st Floor Staff Kitchen/ Lounge Next To Ramp	10.3 ppb
Eliot Elementary School	2nd Floor Hallway Across From Rm. #24	0 ppb
Eliot Elementary School	2nd Floor Over Office Wing Hallway After Rm. #212	0 ppb
Eliot Elementary School	Bottom Of Ramp Rm. #225	0 ppb
Eliot Elementary School	Bottom Of Ramp Rm. #226	1.6 ppb
Eliot Elementary School	Cafeteria	0 ppb
Eliot Elementary School	Gymnasium	0 ppb
Eliot Elementary School	Kitchen 2-bay Sink Left Side	0 ppb
Eliot Elementary School	Kitchen 2-bay Sink Right Side	0 ppb
Eliot Elementary School	Nurse Office Rm. #277	0 ppb
Ella Lewis School	Kitchen Fixture	1.4 ppb
Ella Lewis School	Main Hallway Water Fountain	6.6 ppb
Ella P Burr School	4 Yr Old Drinking Fountain	0 ppb
Ella P Burr School	District Office Conference Room Br Sink	9.3 ppb

School Name	Sample Location	Lead Test Result
Ella P Burr School	District Office Kitchen Sink	0 ppb
Ella P Burr School	District Office Superintendents Br Sink	0 ppb
Ella P Burr School	Gym Drinking Fountain	2 ppb
Ella P Burr School	Kitchen 3 Bay Sink North Faucet	3.6 ppb
Ella P Burr School	Kitchen 3 Bay Sink South Faucet	100 ppb
Ella P Burr School	Kitchen Hand Wash Sink	3.1 ppb
Ella P Burr School	Kitchen Sink In Food Prep Area	0 ppb
Ella P Burr School	Lower Wing Boys Br Sink 1	2.7 ppb
Ella P Burr School	Lower Wing Boys Br Sink 2	2.9 ppb
Ella P Burr School	Lower Wing Boys Br Sink 3	2.6 ppb
Ella P Burr School	Lower Wing Boys Br Sink 4	3.1 ppb
Ella P Burr School	Lower Wing Girls Br Sink 1	3.7 ppb
Ella P Burr School	Lower Wing Girls Br Sink 2	2 ppb
Ella P Burr School	Lower Wing Girls Br Sink 3	1.8 ppb
Ella P Burr School	Lower Wing Girls Br Sink 4	3 ppb
Ella P Burr School	Lower Wing North Drinking Fountain	2.1 ppb
Ella P Burr School	Lower Wing South Bottle Filler	0 ppb
Ella P Burr School	Lower Wing South Drinking Fountain	3.7 ppb
Ella P Burr School	Mail Room Br Sink	3.6 ppb
Ella P Burr School	Outside Spigot South Gym Wall	177 ppb
Ella P Burr School	Room 17 Sink	3.4 ppb
Ella P Burr School	Room 18 Drinking Fountain	3.8 ppb
Ella P Burr School	Room 18 Sink	1.1 ppb
Ella P Burr School	Room 19 Drinking Fountain	2 ppb
Ella P Burr School	Room 19 Sink	0 ppb
Ella P Burr School	Room 20 Sink	0 ppb
Ella P Burr School	Room 21 Sink	0 ppb
Ella P Burr School	Room 22 Sink	0 ppb
Ella P Burr School	Room 23 Sink	0 ppb
Ella P Burr School	Room 24 Drinking Fountain	0 ppb
Ella P Burr School	Room 24 Sink	0 ppb
Ella P Burr School	Room 25 Drinking Fountain	4.3 ppb
Ella P Burr School	Room 25 Sink	1.1 ppb
Ella P Burr School	Room 26 Sink	2.8 ppb
Ella P Burr School	Staff Br By Office Sink	0 ppb
Ella P Burr School	Upper Wing Boys Br 1st Sink	1.7 ppb
Ella P Burr School	Upper Wing Boys Br 2nd Sink	2.3 ppb
Ella P Burr School	Upper Wing Boys Br 3rd Sink	3.6 ppb
Ella P Burr School	Upper Wing Faculty Br Sink	1.1 ppb
Ella P Burr School	Upper Wing Girls Br 1st Sink	3.2 ppb
Ella P Burr School	Upper Wing Girls Br 2nd Sink	1.6 ppb
Ella P Burr School	Upper Wing Girls Br 3rd Sink	2.3 ppb
Ella P Burr School	Upper Wing South Drinking Fountain	0 ppb
Ella P Burr School	Upper Wing South Drinking Fountaion Bottle Filler	0 ppb
Ella P Burr School	Upper Wing Teachers Room Sink	2 ppb
Ellsworth Elementary-Middle School	7th Grade Staff Room	0 ppb

School Name	Sample Location	Lead Test Result
Ellsworth Elementary-Middle School	Cafeteria	0 ppb
Ellsworth Elementary-Middle School	E101	0 ppb
Ellsworth Elementary-Middle School	E102	0 ppb
Ellsworth Elementary-Middle School	E103	0 ppb
Ellsworth Elementary-Middle School	E104	0 ppb
Ellsworth Elementary-Middle School	E105	0 ppb
Ellsworth Elementary-Middle School	E106	0 ppb
Ellsworth Elementary-Middle School	E107	0 ppb
Ellsworth Elementary-Middle School	E108	0 ppb
Ellsworth Elementary-Middle School	E109	0 ppb
Ellsworth Elementary-Middle School	E110	0 ppb
Ellsworth Elementary-Middle School	E111	0 ppb
Ellsworth Elementary-Middle School	E112	0 ppb
Ellsworth Elementary-Middle School	E113	0 ppb
Ellsworth Elementary-Middle School	E114	0 ppb
Ellsworth Elementary-Middle School	E115	0 ppb
Ellsworth Elementary-Middle School	E116	0 ppb
Ellsworth Elementary-Middle School	E117	0 ppb
Ellsworth Elementary-Middle School	E118	0 ppb
Ellsworth Elementary-Middle School	E119	0 ppb
Ellsworth Elementary-Middle School	E120	0 ppb
Ellsworth Elementary-Middle School	E135	0 ppb
Ellsworth Elementary-Middle School	Eems Kitchen Sink 1	0 ppb
Ellsworth Elementary-Middle School	Eems Kitchen Sink 2	0 ppb
Ellsworth Elementary-Middle School	Eems Kitchen Sink 3	0 ppb
Ellsworth Elementary-Middle School	Green Wing	0 ppb
Ellsworth Elementary-Middle School	Gym Ice Machine	0 ppb
Ellsworth Elementary-Middle School	Lime Wing	0 ppb
Ellsworth Elementary-Middle School	M109	0 ppb
Ellsworth Elementary-Middle School	M162	0 ppb
Ellsworth Elementary-Middle School	Nurses Station	0 ppb
Ellsworth Elementary-Middle School	Orange Wing	0 ppb
Ellsworth Elementary-Middle School	Snack Shack	1.1 ppb
Ellsworth Elementary-Middle School	White Wing	0 ppb
Ellsworth Elementary-Middle School	Yellow Wing	0 ppb
Ellsworth High School	1st Floor Fountain	0 ppb
Ellsworth High School	2nd Floor Fountain	0 ppb
Ellsworth High School	3rd Floor Fountain	0 ppb
Ellsworth High School	Gym Fountain	0 ppb
Ellsworth High School	Kitchen Sink 1	1.1 ppb
Ellsworth High School	Kitchen Sink 2	0 ppb
Ellsworth High School	Kitchen Sink 3	1.8 ppb
Ellsworth High School	Locker Room Ice Machine	0 ppb
Ellsworth High School	Nurses Station Ice Machine	1 ppb
Ellsworth High School	Nurses Station Sink	0 ppb
Ellsworth High School	Office Kitchenette	1.7 ppb
Ellsworth High School	Room 117	1.6 ppb

School Name	Sample Location	Lead Test Result
Ellsworth High School	Room 117b	0 ppb
Elm Street School-East Machias	Art Room	3.4 ppb
Elm Street School-East Machias	Boys Locker Sink	0 ppb
Elm Street School-East Machias	Girls Locker Sink	0 ppb
Elm Street School-East Machias	Grade 1	3.6 ppb
Elm Street School-East Machias	Grade 2	75.1 ppb
Elm Street School-East Machias	Grade 5	1.8 ppb
Elm Street School-East Machias	Grade 6 Sink	0 ppb
Elm Street School-East Machias	Grade 7 Sink	1 ppb
Elm Street School-East Machias	Grade 8 Sink	0 ppb
Elm Street School-East Machias	Kindergarten	9.5 ppb
Elm Street School-East Machias	Kitchen Bathroom	0 ppb
Elm Street School-East Machias	Kitchen Bay Sink	1 ppb
Elm Street School-East Machias	Kitchen Dish Washer Sink	1.1 ppb
Elm Street School-East Machias	Kitchen Double Bay Sink (2 Fixtures)	1.8 ppb
Elm Street School-East Machias	Kitchen Single Sink	0 ppb
Elm Street School-East Machias	Lower Boys Bathroom	1.1 ppb
Elm Street School-East Machias	Lower Drinking Fountain	0 ppb
Elm Street School-East Machias	Lower Girls Bathroom	1.5 ppb
Elm Street School-East Machias	Lower Special Ed	15.2 ppb
Elm Street School-East Machias	Lower Staff Bathroom	1.3 ppb
Elm Street School-East Machias	Music Room	0 ppb
Elm Street School-East Machias	Prek	2.3 ppb
Elm Street School-East Machias	Speech Bathroom	0 ppb
Elm Street School-East Machias	Upper Boys Bathroom	0 ppb
Elm Street School-East Machias	Upper Custodian Sink	0 ppb
Elm Street School-East Machias	Upper End Special Ed	0 ppb
Elm Street School-East Machias	Upper Girls Bathroom	0 ppb
Elm Street School-East Machias	Upper Staff Bathroom	1.6 ppb
Elm Street School-East Machias	Upper Staff Kitchen Sink	2.1 ppb
Elm Street School-East Machias	Upper Water Fountain	0 ppb
Elm Street School-Mechanic Falls	5 & 6 Hallway Water Fountain	3.1 ppb
Elm Street School-Mechanic Falls	Adult Bathroom 1 Sink (adult Ed)	1.3 ppb
Elm Street School-Mechanic Falls	Adult Bathroom 2 Sink (adult Ed)	4.3 ppb
Elm Street School-Mechanic Falls	Adult Restroom Sink (by Nurse)	2.8 ppb
Elm Street School-Mechanic Falls	Art Room	6.7 ppb
Elm Street School-Mechanic Falls	Boy's Bathroom By Gym	7 ppb
Elm Street School-Mechanic Falls	Boy's Bathroom Sink 1	3.1 ppb
Elm Street School-Mechanic Falls	Boy's Bathroom Sink 1 (left To Right)	2.8 ppb
Elm Street School-Mechanic Falls	Boy's Bathroom Sink 2	12 ppb
Elm Street School-Mechanic Falls	Boy's Bathroom Sink 2 (left To Right)	1.9 ppb
Elm Street School-Mechanic Falls	Boy's Bathroom Sink 3	2.9 ppb
Elm Street School-Mechanic Falls	Boy's Bathroom Sink 3 (left To Right)	2.5 ppb
Elm Street School-Mechanic Falls	Boy's Bathroom Sink 4	3 ppb
Elm Street School-Mechanic Falls	Boy's Locker Room Shower 1	14.9 ppb
Elm Street School-Mechanic Falls	Boy's Locker Room Shower 2	3.2 ppb
Elm Street School-Mechanic Falls	Boy's Locker Room Shower 3	12.2 ppb

School Name	Sample Location	Lead Test Result
Elm Street School-Mechanic Falls	Boy's Locker Room Shower 4	10.9 ppb
Elm Street School-Mechanic Falls	Boy's Locker Room Shower 5	17.1 ppb
Elm Street School-Mechanic Falls	Boy's Locker Room Shower 6	3.1 ppb
Elm Street School-Mechanic Falls	Boy's Locker Room Sink	10.2 ppb
Elm Street School-Mechanic Falls	Boy's Room Sink (by Library)	4.2 ppb
Elm Street School-Mechanic Falls	Boy's Room Sink (by Nurse)	18.5 ppb
Elm Street School-Mechanic Falls	Custodian Closet	2.5 ppb
Elm Street School-Mechanic Falls	Girl's Bathroom By Gym	5.5 ppb
Elm Street School-Mechanic Falls	Girl's Bathroom Sink 1	524 ppb
Elm Street School-Mechanic Falls	Girl's Bathroom Sink 2	54.5 ppb
Elm Street School-Mechanic Falls	Girl's Bathroom Sink 3	704 ppb
Elm Street School-Mechanic Falls	Girl's Bathroom Sink 4	54.7 ppb
Elm Street School-Mechanic Falls	Girl's Locker Rm Bucket Sink Under Sink	1030 ppb
Elm Street School-Mechanic Falls	Girl's Locker Room Shower 1	43.9 ppb
Elm Street School-Mechanic Falls	Girl's Locker Room Shower 2	762 ppb
Elm Street School-Mechanic Falls	Girl's Locker Room Shower 3	46.8 ppb
Elm Street School-Mechanic Falls	Girl's Locker Room Shower 4	102 ppb
Elm Street School-Mechanic Falls	Girl's Locker Room Shower 5	341 ppb
Elm Street School-Mechanic Falls	Girl's Locker Room Shower 6	265 ppb
Elm Street School-Mechanic Falls	Girl's Locker Room Sink	119 ppb
Elm Street School-Mechanic Falls	Girl's Room Sink (by 3rd Grade - Left)	4.9 ppb
Elm Street School-Mechanic Falls	Girl's Room Sink (by Library)	20.6 ppb
Elm Street School-Mechanic Falls	Girl's Room Sink (by Nurse)	7.5 ppb
Elm Street School-Mechanic Falls	Gym Fountain	1.2 ppb
Elm Street School-Mechanic Falls	Hallway By Teachers Room Fountain	0 ppb
Elm Street School-Mechanic Falls	Hose Bib (pre-k)	87 ppb
Elm Street School-Mechanic Falls	Hose Bib Gym	49.3 ppb
Elm Street School-Mechanic Falls	Hose Bib Kitchen	778 ppb
Elm Street School-Mechanic Falls	Hose Bib Main Office	657 ppb
Elm Street School-Mechanic Falls	Kitchen Bathroom Sink	14.5 ppb
Elm Street School-Mechanic Falls	Kitchen Hand Sink	8.8 ppb
Elm Street School-Mechanic Falls	Kitchen Mop Sink	156 ppb
Elm Street School-Mechanic Falls	Kitchen Sprayer	4.3 ppb
Elm Street School-Mechanic Falls	Kitchen Wash Sink 1 (left)	28.5 ppb
Elm Street School-Mechanic Falls	Kitchen Wash Sink 2 (right)	3 ppb
Elm Street School-Mechanic Falls	Library Sink	52.9 ppb
Elm Street School-Mechanic Falls	Maintenance Room	7.2 ppb
Elm Street School-Mechanic Falls	Nurse's Room Sink	7.6 ppb
Elm Street School-Mechanic Falls	Room 11 Sink	10.2 ppb
Elm Street School-Mechanic Falls	Room 12 Sink	8.6 ppb
Elm Street School-Mechanic Falls	Room 32 Sink	11.5 ppb
Elm Street School-Mechanic Falls	Room 33 Sink	2.1 ppb
Elm Street School-Mechanic Falls	Room 34 Sink	1.7 ppb
Elm Street School-Mechanic Falls	Science Room Sick 1 (left To Right)	185 ppb
Elm Street School-Mechanic Falls	Science Room Sick 2 (left To Right)	153 ppb
Elm Street School-Mechanic Falls	Science Room Sick 3 (left To Right)	126 ppb
Elm Street School-Mechanic Falls	Science Room Sick 4 (left To Right)	382 ppb

School Name	Sample Location	Lead Test Result
Elm Street School-Mechanic Falls	Science Room Sick 5 (left To Right)	295 ppb
Elm Street School-Mechanic Falls	Science Room Sick 6 (left To Right)	2000 ppb
Elm Street School-Mechanic Falls	Small Counselor Room Sink	620 ppb
Elm Street School-Mechanic Falls	Teacher Room Sink 1 (left)	4.8 ppb
Elm Street School-Mechanic Falls	Teacher Room Sink 2 (right)	1110 ppb
Elm Street School-Mechanic Falls	Teachers Room Spigot	539 ppb
Elm Street School-Mechanic Falls	Water Fountain (by 3rd Grade)	11.5 ppb
Elm Street School-Mechanic Falls	Water Fountain (kg Hallway)	0 ppb
Elm Street School-Mechanic Falls	Water Fountain (top Of Stairs)	0 ppb
Enfield Station Elementary School	Art Room Sink # 1 Going Left To Right	56.5 ppb
Enfield Station Elementary School	Art Room Sink # 2 Going Left To Right	9.4 ppb
Enfield Station Elementary School	Art Room Sink # 3 Going Left To Right	4.4 ppb
Enfield Station Elementary School	Art Room Sink # 4 Going Left To Right	7.8 ppb
Enfield Station Elementary School	Art Room Sink # 5 Going Left To Right	18.6 ppb
Enfield Station Elementary School	Drinking Fountain In Gym	5 ppb
Enfield Station Elementary School	Drinking Fountain Outside Office	12.2 ppb
Enfield Station Elementary School	Drinking Fountain Project Room	4.9 ppb
Enfield Station Elementary School	Drinking Fountain Room # 106	1.1 ppb
Enfield Station Elementary School	Drinking Fountain Room # 108	0 ppb
Enfield Station Elementary School	Drinking Fountain Room # 109	9.1 ppb
Enfield Station Elementary School	Drinking Fountain Room # 114	0 ppb
Enfield Station Elementary School	Drinking Fountain Room # 117	2.5 ppb
Enfield Station Elementary School	Drinking Fountain Room # 126	1.9 ppb
Enfield Station Elementary School	Drinking Fountain Room # 127	9.7 ppb
Enfield Station Elementary School	Drinking Fountain Room # 129	3.9 ppb
Enfield Station Elementary School	Drinking Fountain Room # 202	4.7 ppb
Enfield Station Elementary School	Drinking Fountain Room # 203	9.3 ppb
Enfield Station Elementary School	Drinking Fountain Room # 205	13.2 ppb
Enfield Station Elementary School	Drinking Fountain Room # 209	61 ppb
Enfield Station Elementary School	Drinking Fountain Room # 210	6.4 ppb
Enfield Station Elementary School	Drinking Fountain Room # 213	5.4 ppb
Enfield Station Elementary School	Drinking Fountain Room # 216	8.9 ppb
Enfield Station Elementary School	Drinking Fountain Room # 217	29.1 ppb
Enfield Station Elementary School	Drinking Fountain Room # 218	12.6 ppb
Enfield Station Elementary School	Drinking Fountain Room # 244	2.1 ppb
Enfield Station Elementary School	Drinking Fountain Room 177	7.2 ppb
Enfield Station Elementary School	Drinking Fountainroom # 115	9.9 ppb
Enfield Station Elementary School	Kitchen Sink #1 Going Left To Right	3 ppb
Enfield Station Elementary School	Kitchen Sink #2 Going Left To Right	2.1 ppb
Enfield Station Elementary School	Kitchen Sink #3 Going Left To Right	1.6 ppb
Enfield Station Elementary School	Kitchen Sink #4 Going Left To Right	5.8 ppb
Enfield Station Elementary School	Music Room	5.5 ppb
Enfield Station Elementary School	Music Room Sink	1.8 ppb
Enfield Station Elementary School	Nurse Room	5.2 ppb
Enfield Station Elementary School	Project Room	2.9 ppb
Enfield Station Elementary School	Room 106	7.3 ppb
Enfield Station Elementary School	Room 108	4.6 ppb

School Name	Sample Location	Lead Test Result
Enfield Station Elementary School	Room 109	8.9 ppb
Enfield Station Elementary School	Room 114	7.6 ppb
Enfield Station Elementary School	Room 115	6.4 ppb
Enfield Station Elementary School	Room 117	4.8 ppb
Enfield Station Elementary School	Room 126	5.3 ppb
Enfield Station Elementary School	Room 127	12.1 ppb
Enfield Station Elementary School	Room 129	8 ppb
Enfield Station Elementary School	Room 202	4.6 ppb
Enfield Station Elementary School	Room 203	6 ppb
Enfield Station Elementary School	Room 205	15.3 ppb
Enfield Station Elementary School	Room 209	12.7 ppb
Enfield Station Elementary School	Room 210	6.3 ppb
Enfield Station Elementary School	Room 213	11.4 ppb
Enfield Station Elementary School	Room 216	5 ppb
Enfield Station Elementary School	Room 217	21.2 ppb
Enfield Station Elementary School	Room 218	12.2 ppb
Enfield Station Elementary School	Room 244	11.4 ppb
Enfield Station Elementary School	Teachers Room Sink	0 ppb
Eric L Knowlton School	Art Room Sink #1	11.4 ppb
Eric L Knowlton School	Art Room Sink #2	5.4 ppb
Eric L Knowlton School	Art Room Sink #3	6.1 ppb
Eric L Knowlton School	Cafe Drinking Water Fountain	0 ppb
Eric L Knowlton School	Classroom 110 Sink	1.3 ppb
Eric L Knowlton School	First Floor Hall Drinking Fountain	0 ppb
Eric L Knowlton School	Kitchen Prep Sink #1	8.5 ppb
Eric L Knowlton School	Kitchen Prep Sink #2	5.3 ppb
Eric L Knowlton School	Kitchen Prep Sink #3	8.9 ppb
Eric L Knowlton School	Nurse Office Sink	1.3 ppb
Eric L Knowlton School	Second Floor Hall Drinking Fountain	0 ppb
Eric L Knowlton School	Teachers Room Sink	7.1 ppb
Erskine Academy	Art Room Water Fountain	0 ppb
Erskine Academy	Business Office Downstairs Sink	1.6 ppb
Erskine Academy	Business Office Upstairs Sink	0 ppb
Erskine Academy	Fine Arts Water Fountain (norads)	0 ppb
Erskine Academy	Front Office Sink	2.5 ppb
Erskine Academy	Home Ec- Sink 1	2.2 ppb
Erskine Academy	Home Ec- Sink 2	1.2 ppb
Erskine Academy	Home Ec- Sink 3	3.1 ppb
Erskine Academy	Kitchen (steam Craft)	0 ppb
Erskine Academy	Kitchen Ice Maker	0 ppb
Erskine Academy	Kitchen Prep Sink (2) Back Rm	0 ppb
Erskine Academy	Kitchen Water Fountain	0 ppb
Erskine Academy	Maintenance Sink	9.5 ppb
Erskine Academy	Multi-purpose Rm Sink (bottle Filler)	0 ppb
Erskine Academy	Nurses Sink	1.4 ppb
Erskine Academy	Sink In Rm 121	4.3 ppb
Erskine Academy	Sink In Teachers Rm	0 ppb

School Name	Sample Location	Lead Test Result
Erskine Academy	Trainers Rm Ice Machine	2.9 ppb
Erskine Academy	Wash Sink Kitchen (prep Sink)	0 ppb
Erskine Academy	Water Filler Math Wing	0 ppb
Erskine Academy	Water Filler Outside Rm 113	0 ppb
Erskine Academy	Water Fountain (short) Gym Lobby	0 ppb
Erskine Academy	Water Fountain (tall) Gym Lobby	0 ppb
Erskine Academy	Water Fountain In Science Wing	0 ppb
Erskine Academy	Water Fountain Near Music Rm	0 ppb
Erskine Academy	Water Fountain Near Trainers Rm (left)	0 ppb
Erskine Academy	Water Fountain Near Trainers Rm (right)	0 ppb
Erskine Academy	Water Fountain Next To Boys Locker Rm	0 ppb
Erskine Academy	Water Fountain Outside Guidance	2.7 ppb
Erskine Academy	Water Fountain Outside M Soule Rm 223	3.1 ppb
Erskine Academy	Water Fountain Outside Rm 150	0 ppb
Etna-Dixmont School	1 Big Sink	4.7 ppb
Etna-Dixmont School	1 Sink	3.3 ppb
Etna-Dixmont School	10 Girls Left	0 ppb
Etna-Dixmont School	10 Girls Right	0 ppb
Etna-Dixmont School	11 Boys Left	0 ppb
Etna-Dixmont School	11 Boys Right	0 ppb
Etna-Dixmont School	12 Hall Fountain Down	0 ppb
Etna-Dixmont School	12 Hall Fountain Up	0 ppb
Etna-Dixmont School	12 Sink	0 ppb
Etna-Dixmont School	14 Hall Fountain	0 ppb
Etna-Dixmont School	21 Bathroom Sink	0 ppb
Etna-Dixmont School	21 Sink	0 ppb
Etna-Dixmont School	23 Girls Left	0 ppb
Etna-Dixmont School	23 Girls Right	1.3 ppb
Etna-Dixmont School	25 Sink	0 ppb
Etna-Dixmont School	27 Left	5 ppb
Etna-Dixmont School	27 Middle	3.3 ppb
Etna-Dixmont School	27 Right	4.7 ppb
Etna-Dixmont School	28 Left	0 ppb
Etna-Dixmont School	28 Right	1.7 ppb
Etna-Dixmont School	32 Girls Left	0 ppb
Etna-Dixmont School	32 Girls Right	0 ppb
Etna-Dixmont School	36 Sink	0 ppb
Etna-Dixmont School	Entrance Fountain Down	0 ppb
Etna-Dixmont School	Entrance Fountain Up	0 ppb
Etna-Dixmont School	Gym Boys Sink	0 ppb
Etna-Dixmont School	Kit Faucet Left	4.1 ppb
Etna-Dixmont School	Kit Faucet Right	4.9 ppb
Etna-Dixmont School	Kit Hand Sink 1	3.1 ppb
Etna-Dixmont School	Kit Hand Sink 2	0 ppb
Etna-Dixmont School	Nurse Sink	1.5 ppb
Eva Hoyt Zippel School	3rd Grade Hall	0 ppb
Eva Hoyt Zippel School	Gymnasium	0 ppb

School Name	Sample Location	Lead Test Result
Eva Hoyt Zippel School	Kitchen Sink #1	0 ppb
Eva Hoyt Zippel School	Kitchen Sink #2	0 ppb
Eva Hoyt Zippel School	Kitchen Sink #3	0 ppb
Eva Hoyt Zippel School	Kitchen Sink #4	0 ppb
Eva Hoyt Zippel School	Kitchen Tilt Skillet	0 ppb
Eva Hoyt Zippel School	Main Office Hall	1.5 ppb
Eva Hoyt Zippel School	Room 1	0 ppb
Eva Hoyt Zippel School	Room 11	0 ppb
Eva Hoyt Zippel School	Room 12	0 ppb
Eva Hoyt Zippel School	Room 2	0 ppb
Eva Hoyt Zippel School	Room 24	0 ppb
Eva Hoyt Zippel School	Room 25	1.5 ppb
Eva Hoyt Zippel School	Room 26	0 ppb
Eva Hoyt Zippel School	Room 27	2.8 ppb
Eva Hoyt Zippel School	Room 3	0 ppb
Eva Hoyt Zippel School	Room 4	1.1 ppb
Eva Hoyt Zippel School	Room 40	0 ppb
Eva Hoyt Zippel School	Room 47	0 ppb
Eva Hoyt Zippel School	Room 48	0 ppb
Eva Hoyt Zippel School	Room 49	0 ppb
Eva Hoyt Zippel School	Room 5	0 ppb
Eva Hoyt Zippel School	Room 50	0 ppb
Eva Hoyt Zippel School	Room 53	0 ppb
Eva Hoyt Zippel School	Room 54	0 ppb
Eva Hoyt Zippel School	Room 55	0 ppb
Eva Hoyt Zippel School	Room 56	0 ppb
Eva Hoyt Zippel School	Room 6	0 ppb
Fairfield Primary School	2nd Floor Teachers Room Sink	1.8 ppb
Fairfield Primary School	Basement Bathroom Sink #1	1.8 ppb
Fairfield Primary School	Basement Bathroom Sink #2	2.6 ppb
Fairfield Primary School	Drinking Fountain Across Main Office	0 ppb
Fairfield Primary School	Drinking Fountain On Basement Level	0 ppb
Fairfield Primary School	Kitchen Food Prep Sink	0 ppb
Fairfield Primary School	Kitchen Hand Sink	0 ppb
Fairfield Primary School	Main Hallway Boys Bathroom Sink #1	0 ppb
Fairfield Primary School	Main Hallway Boys Bathroom Sink #2	0 ppb
Fairfield Primary School	Main Hallway Girls Bathroom Sink #1	0 ppb
Fairfield Primary School	Main Hallway Girls Bathroom Sink #2	0 ppb
Fairfield Primary School	Room #12 Sink	3.5 ppb
Fairfield Primary School	Room #15 Sink	0 ppb
Fairfield Primary School	Room #6 Sink	0 ppb
Fairmount School	Bottle Fill Station - Annex Hallway	0 ppb
Fairmount School	Bottle Fill Station - Outside Copy Room	0 ppb
Fairmount School	Bottle Fill Station - Outside Room 10	0 ppb
Fairmount School	Bottle Fill Station - Outside Room 18	5.6 ppb
Fairmount School	Bottle Fill Station - Outside Room 8	1.8 ppb
Fairmount School	Drinking Water Fountain - Library	307 ppb

School Name	Sample Location	Lead Test Result
Fairmount School	Drinking Water Fountain - Room 19	67.6 ppb
Fairmount School	Drinking Water Fountain - Room 21	111 ppb
Fairmount School	Drinking Water Fountain - Room 22	82.9 ppb
Fairmount School	Faucet - Music Room	101 ppb
Fairmount School	Faucet - Room 24 Restroom	11.9 ppb
Fairmount School	Faucet - Teacher's Lounge	2.2 ppb
Fairmount School	Kitchen - Food Prep Faucet	1.5 ppb
Fairview School	2nd Floor Boys Room Left Faucet	0 ppb
Fairview School	2nd Floor Boys Room Right Faucet	1.1 ppb
Fairview School	2nd Floor Bubbler Between Restrooms	0 ppb
Fairview School	2nd Floor Girls Room Left Faucet	0 ppb
Fairview School	2nd Floor Girls Room Right Faucet	0 ppb
Fairview School	Art Room Center Faucet	0 ppb
Fairview School	Art Room Left Faucet	0 ppb
Fairview School	Art Room Right Faucet	7.3 ppb
Fairview School	Boys Room Across From 109 L Faucet	1.9 ppb
Fairview School	Boys Room Across From 109 L Center Faucet	1.8 ppb
Fairview School	Boys Room Across From 109 R Center Faucet	2 ppb
Fairview School	Boys Room Across From 109 R Faucet	0 ppb
Fairview School	Boys Room By Gym Left Faucet	0 ppb
Fairview School	Boys Room By Gym Right Faucet	0 ppb
Fairview School	Boys Room By Office Left Faucet	2.6 ppb
Fairview School	Boys Room By Office Right Faucet	2.4 ppb
Fairview School	Bubbler Between Restrooms	0 ppb
Fairview School	Bubbler By Boys Room	18.2 ppb
Fairview School	Bubbler By Girls Room	0 ppb
Fairview School	Bubbler By Room 109	0 ppb
Fairview School	Cafeteria Bubbler	0 ppb
Fairview School	Cafeteria Restroom Faucet	4 ppb
Fairview School	Cafeteria Water Bottle Filler	0 ppb
Fairview School	Girls From Across From 109 R Faucet	1.8 ppb
Fairview School	Girls Room Across From 109 L Center Faucet	1.9 ppb
Fairview School	Girls Room Across From 109 L Faucet	2.9 ppb
Fairview School	Girls Room By Gym Left Faucet	0 ppb
Fairview School	Girls Room By Gym Right Faucet	0 ppb
Fairview School	Girls Room By Office Center Faucet	2.3 ppb
Fairview School	Girls Room By Office L Faucet	2.6 ppb
Fairview School	Girls Room By Office R Faucet	1.5 ppb
Fairview School	Health Office Faucet	0 ppb
Fairview School	Kitchen Handwash Sink Faucet	1.2 ppb
Fairview School	Kitchen Kettle Faucet	2.2 ppb
Fairview School	Kitchen Sink Faucet	2.1 ppb
Fairview School	Library Faucet	7.9 ppb
Fairview School	Office Kitchen Faucet	0 ppb

School Name	Sample Location	Lead Test Result
Fairview School	Ot Room Faucet	13.4 ppb
Fairview School	Restroom Across From Office Faucet	0 ppb
Fairview School	Room 101 Bubbler	1.6 ppb
Fairview School	Room 101 Faucet	0 ppb
Fairview School	Room 102 Bubbler	0 ppb
Fairview School	Room 102 Faucet	0 ppb
Fairview School	Room 103 Bubbler	1.3 ppb
Fairview School	Room 103 Faucet	3.6 ppb
Fairview School	Room 104 Bubbler	57 ppb
Fairview School	Room 104 Faucet	5.1 ppb
Fairview School	Room 105 Bubbler	0 ppb
Fairview School	Room 105 Faucet	6.4 ppb
Fairview School	Room 106 Bubbler	7 ppb
Fairview School	Room 106 Faucet	4.1 ppb
Fairview School	Room 107 Bubbler	1 ppb
Fairview School	Room 107 Faucet	1.3 ppb
Fairview School	Room 108 Bubbler	52.3 ppb
Fairview School	Room 108 Faucet	3.7 ppb
Fairview School	Room 109 Bubbler	1.5 ppb
Fairview School	Room 109 Faucet	2 ppb
Fairview School	Room 111 A Faucet	23.1 ppb
Fairview School	Room 111 B Bathroom Faucet	19.7 ppb
Fairview School	Room 111 B Faucet	1.6 ppb
Fairview School	Room 112 Faucet	2.9 ppb
Fairview School	Room 121 Bubbler	1.4 ppb
Fairview School	Room 121 Faucet	0 ppb
Fairview School	Room 122 Bubbler	0 ppb
Fairview School	Room 122 Faucet	1.3 ppb
Fairview School	Room 123 Bubbler	0 ppb
Fairview School	Room 123 Faucet	1 ppb
Fairview School	Room 124 Bubbler	0 ppb
Fairview School	Room 124 Faucet	0 ppb
Fairview School	Room 125 Bubbler	6.9 ppb
Fairview School	Room 125 Faucet	2.1 ppb
Fairview School	Room 222 Bubbler	0 ppb
Fairview School	Room 222 Faucet	1.2 ppb
Fairview School	Room 223 Bubbler	0 ppb
Fairview School	Room 223 Faucet	0 ppb
Fairview School	Room 224 Bubbler	2.9 ppb
Fairview School	Room 224 Faucet	0 ppb
Fairview School	Room 225 Bubbler	0 ppb
Fairview School	Room 225 Faucet	1.5 ppb
Fairview School	Room 226 Bubbler	0 ppb
Fairview School	Room 226 Faucet	1.2 ppb
Fairview School	Room 227 Bubbler	10.2 ppb
Fairview School	Room 227 Faucet	1.6 ppb
Fairview School	Staff Bathroom Across From 109 Faucet	1.8 ppb

School Name	Sample Location	Lead Test Result
Fairview School	Staff Room Bathroom Faucet	1.8 ppb
Fairview School	Staff Room Faucet	0 ppb
Fairview School	Water Bottle Filler By Girls Room	0 ppb
Fairview School	Water Bottle Filler By Room 109	0 ppb
Falmouth Elementary School	Fl 1 Br By Lobby Near Gym	0 ppb
Falmouth Elementary School	Fl 1 Br By Lobby Near Gym (wb)	0 ppb
Falmouth Elementary School	Fl 1 Cafe By Stage (left Df)	0 ppb
Falmouth Elementary School	Fl 1 Cafe By Stage (right Df)	0 ppb
Falmouth Elementary School	Fl 1 Cafe By West Hall (left Df)	0 ppb
Falmouth Elementary School	Fl 1 Cafe By West Hall (right Df)	0 ppb
Falmouth Elementary School	Fl 1 Cafe By West Hall (wb)	0 ppb
Falmouth Elementary School	Fl 1 Cr A118 East Hall By Gym	0 ppb
Falmouth Elementary School	Fl 1 Cr A119 East Hall	0 ppb
Falmouth Elementary School	Fl 1 Cr A120 East Hall By Gym	0 ppb
Falmouth Elementary School	Fl 1 Kitchen Ds Middle Of Food Prep Area	0 ppb
Falmouth Elementary School	Fl 1 Kitchen Ss Middle Of Food Prep Area	1 ppb
Falmouth Elementary School	Fl 1 West Hall By Nurse's Office (left Df)	0 ppb
Falmouth Elementary School	Fl 1 West Hall By Nurse's Office (right Df)	0 ppb
Falmouth Elementary School	Fl 2 Art Rm Btwn G5 & G4	0 ppb
Falmouth Elementary School	Fl 2 Cr B213 By Hall Btwn G5 & G4	0 ppb
Falmouth Elementary School	Fl 2 Cr C213 By Hall Btwn G5 & G4	1.2 ppb
Falmouth Elementary School	Fl 2 Hall By Upper Main Lobby	0 ppb
Falmouth Elementary School	Fl 2 Hall By Upper Main Lobby Wb	0 ppb
Falmouth Elementary School	Wg A Fl 1 Gr 1 Cr A100	0 ppb
Falmouth Elementary School	Wg A Fl 1 Gr 1 Cr A101	0 ppb
Falmouth Elementary School	Wg A Fl 1 Gr 1 Cr A102	0 ppb
Falmouth Elementary School	Wg A Fl 1 Gr 1 Cr A103	0 ppb
Falmouth Elementary School	Wg A Fl 1 Gr 1 Cr A104	0 ppb
Falmouth Elementary School	Wg A Fl 1 Gr 1 Cr A105	0 ppb
Falmouth Elementary School	Wg A Fl 1 Gr 1 Cr A106	1 ppb
Falmouth Elementary School	Wg A Fl 1 Gr 1 Cr A108	0 ppb
Falmouth Elementary School	Wg A Fl 1 Gr 1 Cr A110	0.99 ppb
Falmouth Elementary School	Wg A Fl 2 Gr 3 Cr A200	0 ppb
Falmouth Elementary School	Wg A Fl 2 Gr 3 Cr A201	0 ppb
Falmouth Elementary School	Wg A Fl 2 Gr 3 Cr A202	0 ppb
Falmouth Elementary School	Wg A Fl 2 Gr 3 Cr A204	0 ppb
Falmouth Elementary School	Wg A Fl 2 Gr 3 Cr A205	1.2 ppb
Falmouth Elementary School	Wg A Fl 2 Gr 3 Cr A206	1 ppb
Falmouth Elementary School	Wg A Fl 2 Gr 3 Cr A207	2.5 ppb
Falmouth Elementary School	Wg A Fl 2 Gr 3 Cr Btwn A205 & A201	0 ppb
Falmouth Elementary School	Wg B Fl 1 Gr 2 Cr B100	0 ppb
Falmouth Elementary School	Wg B Fl 1 Gr 2 Cr B101	0 ppb
Falmouth Elementary School	Wg B Fl 1 Gr 2 Cr B102	0 ppb
Falmouth Elementary School	Wg B Fl 1 Gr 2 Cr B103	1 ppb
Falmouth Elementary School	Wg B Fl 1 Gr 2 Cr B104	0 ppb
Falmouth Elementary School	Wg B Fl 1 Gr 2 Cr B105	0 ppb
Falmouth Elementary School	Wg B Fl 1 Gr 2 Cr B106	2.3 ppb

School Name	Sample Location	Lead Test Result
Falmouth Elementary School	Wg B Fl 1 Gr 2 Cr B107	0 ppb
Falmouth Elementary School	Wg B Fl 1 Gr 2 Cr B108	0 ppb
Falmouth Elementary School	Wg B Fl 2 Gr 4 Cr B200	0 ppb
Falmouth Elementary School	Wg B Fl 2 Gr 4 Cr B201	0 ppb
Falmouth Elementary School	Wg B Fl 2 Gr 4 Cr B202	0 ppb
Falmouth Elementary School	Wg B Fl 2 Gr 4 Cr B203	0 ppb
Falmouth Elementary School	Wg B Fl 2 Gr 4 Cr B204	0 ppb
Falmouth Elementary School	Wg B Fl 2 Gr 4 Cr B205	0 ppb
Falmouth Elementary School	Wg B Fl 2 Gr 4 Cr B206	0 ppb
Falmouth Elementary School	Wg B Fl 2 Gr 4 Cr B207	0 ppb
Falmouth Elementary School	Wg B Fl 2 Gr 4 Cr B208	0 ppb
Falmouth Elementary School	Wg C Fl 1 Gr K Cr Andrea Romer	1.8 ppb
Falmouth Elementary School	Wg C Fl 1 Gr K Cr C100	1.1 ppb
Falmouth Elementary School	Wg C Fl 1 Gr K Cr C102	1.4 ppb
Falmouth Elementary School	Wg C Fl 1 Gr K Cr C103	0 ppb
Falmouth Elementary School	Wg C Fl 1 Gr K Cr C104	0 ppb
Falmouth Elementary School	Wg C Fl 1 Gr K Cr C105	1.8 ppb
Falmouth Elementary School	Wg C Fl 1 Gr K Cr C106	0 ppb
Falmouth Elementary School	Wg C Fl 1 Gr K Cr C107	0 ppb
Falmouth Elementary School	Wg C Fl 1 Gr K Cr C109	0 ppb
Falmouth Elementary School	Wg C Fl 1 Gr K Cr No # By Cr C103	0 ppb
Falmouth Elementary School	Wg C Fl 2 Gr 5 Cr C200	0 ppb
Falmouth Elementary School	Wg C Fl 2 Gr 5 Cr C201	0 ppb
Falmouth Elementary School	Wg C Fl 2 Gr 5 Cr C202	0 ppb
Falmouth Elementary School	Wg C Fl 2 Gr 5 Cr C203	0 ppb
Falmouth Elementary School	Wg C Fl 2 Gr 5 Cr C204	0 ppb
Falmouth Elementary School	Wg C Fl 2 Gr 5 Cr C205	0 ppb
Falmouth Elementary School	Wg C Fl 2 Gr 5 Cr C206	0 ppb
Falmouth Elementary School	Wg C Fl 2 Gr 5 Cr C207	0 ppb
Falmouth Elementary School	Wg C Fl 2 Gr 5 Cr C208	0 ppb
Falmouth Elementary School	Wg C Fl 2 Gr 5 Cr C209	1.3 ppb
Falmouth Elementary School	Wg C Fl 2 Gr 5 Work Rm By Cr C201	0 ppb
Falmouth High School	Fl 1 Bh By Kitchen (left Df)	0 ppb
Falmouth High School	Fl 1 Bh By Kitchen (right Df)	0 ppb
Falmouth High School	Fl 1 Bh To Small Gym (left Df)	0 ppb
Falmouth High School	Fl 1 Bh To Small Gym (right Df)	0 ppb
Falmouth High School	Fl 1 Ch Near Cr 110 (left Df)	0 ppb
Falmouth High School	Fl 1 Ch Near Cr 110 (right Df)	0 ppb
Falmouth High School	Fl 1 Entry By Rm 602 By Large Gym (left Df)	0 ppb
Falmouth High School	Fl 1 Entry By Rm 602 By Large Gym (right Df)	0 ppb
Falmouth High School	Fl 1 Front Hall By Doors To Bus Loop (left Df)	0 ppb
Falmouth High School	Fl 1 Front Hall By Doors To Bus Loop (right Df)	0 ppb
Falmouth High School	Fl 1 Hall Btwn Gym & Library (left Df)	0 ppb
Falmouth High School	Fl 1 Hall Btwn Gym & Library (right Df)	0 ppb

School Name	Sample Location	Lead Test Result
Falmouth High School	Fl 1 Room 683 Kitchen Dw Area Back Wall	0 ppb
Falmouth High School	Fl 1 Room 683 Kitchen Dw Area East Wall	1.9 ppb
Falmouth High School	Fl 1 Room 683 Kitchen Dw Area North Wall	2.1 ppb
Falmouth High School	Fl 1 Women's Lr Entry Area (left Df)	0 ppb
Falmouth High School	Fl 1 Women's Lr Entry Area (right Df)	0 ppb
Falmouth High School	Fl 2 Ch By Exit Doors #921 (left Df)	0 ppb
Falmouth High School	Fl 2 Ch By Exit Doors #921 (right Df)	0 ppb
Falmouth High School	Fl 2 Ch Near Cr 210 (left Df)	0 ppb
Falmouth High School	Fl 2 Ch Near Cr 210 (right Df)	0 ppb
Falmouth Middle School	A 2nd Food Preparation Sink In The Kitchen	4.1 ppb
Falmouth Middle School	Drinking Water Fountain In The Cafeteria	0 ppb
Falmouth Middle School	Fl 1 Gr 7/8 Btwn Boys & Girls Brs	0 ppb
Falmouth Middle School	Fl 1 Gr 7/8 Btwn Boys & Girls Brs (wb)	0 ppb
Falmouth Middle School	Fl 1 Hall By Gym Right Of Women's Br	0 ppb
Falmouth Middle School	Fl 1 Hall By Gym Right Of Women's Br (wb)	0 ppb
Falmouth Middle School	Fl 1 Kitchen Food Sink Left Of Mixer	7.4 ppb
Falmouth Middle School	Fl 1 Wg Gr6 Btwn Boys & Girls Brs (wb)	0 ppb
Falmouth Middle School	Fl 2 Wg Gr6 Btwn Boys & Girls Brs	0 ppb
Falmouth Middle School	Fl 2 Wg Gr6 Btwn Janitor Clos & Girls Br	0 ppb
Farrington School	3- Bay Sink Kitchen	0 ppb
Farrington School	Bottle Fill Station- Gym	0 ppb
Farrington School	Classroom 137	1.2 ppb
Farrington School	Classroom 139	1.3 ppb
Farrington School	Classroom 141	5.6 ppb
Farrington School	Classroom 143	0 ppb
Farrington School	Classroom 145	3.1 ppb
Farrington School	Classroom 147	0 ppb
Farrington School	Classroom 149	0 ppb
Farrington School	Classroom 151	0 ppb
Farrington School	Classroom 153	0 ppb
Farrington School	Classroom 155	0 ppb
Farrington School	Classroom 157	0 ppb
Farrington School	Classroom 158	0 ppb
Farrington School	Classroom 201	0 ppb
Farrington School	Classroom 203	0 ppb
Farrington School	Classroom 205	0 ppb
Farrington School	Classroom 207	0 ppb
Farrington School	Classroom 209	0 ppb
Farrington School	Classroom 211	0 ppb
Farrington School	Classroom 213	0 ppb
Farrington School	Classroom 215	0 ppb
Farrington School	Classroom 217	0 ppb
Farrington School	Classroom 219	0 ppb
Farrington School	Classroom 221	0 ppb
Farrington School	Classroom 223	0 ppb
Farrington School	Small Prep Sink Kitchen	13.4 ppb

School Name	Sample Location	Lead Test Result
Farrington School	Teachers Lounge	0 ppb
Farwell Elementary School	Gym Water Fountain High	0 ppb
Farwell Elementary School	Gym Water Fountain Low	0 ppb
Farwell Elementary School	Hall Water Fountain High	0 ppb
Farwell Elementary School	Hall Water Fountain Low	0 ppb
Farwell Elementary School	Kitchen 2 Bin Sink	1.3 ppb
Farwell Elementary School	Kitchen 3 Bin Sink	1.3 ppb
Farwell Elementary School	Kitchen Back Sink	0 ppb
Farwell Elementary School	Kitchen Front Sink	0 ppb
Farwell Elementary School	Kitchen Kettle	27.4 ppb
Farwell Elementary School	New Wing Water Fountain High	0 ppb
Farwell Elementary School	New Wing Water Fountain Low	0 ppb
Farwell Elementary School	Nurses Sink	1.4 ppb
Farwell Elementary School	Nurses Sink Bubbler	1.9 ppb
Farwell Elementary School	Rm 144 Bubbler	5.3 ppb
Farwell Elementary School	Rm 144 Sink	0 ppb
Farwell Elementary School	Rm 146 Bubbler	1.1 ppb
Farwell Elementary School	Rm 146 Sink	0 ppb
Farwell Elementary School	Rm 147 Bubbler	2.5 ppb
Farwell Elementary School	Rm 147 Sink	1.1 ppb
Farwell Elementary School	Rm 148 Bubbler	1.1 ppb
Farwell Elementary School	Rm 148 Sink	1.3 ppb
Farwell Elementary School	Rm 149 Sink	4.3 ppb
Farwell Elementary School	Rm 150 Bubbler	4.2 ppb
Farwell Elementary School	Rm 150 Sink	0 ppb
Farwell Elementary School	Rm 154 Bubbler	1.9 ppb
Farwell Elementary School	Rm 156 Bubbler	1.6 ppb
Farwell Elementary School	Rm 156 Sink	1 ppb
Farwell Elementary School	Rm 158 Bubbler	1.5 ppb
Farwell Elementary School	Rm 158 Sink	0 ppb
Farwell Elementary School	Rm 159 Sink	4 ppb
Farwell Elementary School	Rm 160 Bubbler	1.5 ppb
Farwell Elementary School	Rm 160 Sink	1.3 ppb
Farwell Elementary School	Rm 162 Bubbler	1.5 ppb
Farwell Elementary School	Rm 162 Sink	0 ppb
Farwell Elementary School	Rm 163 Bubbler	16.6 ppb
Farwell Elementary School	Rm 163 Sink	0 ppb
Farwell Elementary School	Rm 172 Bath Sink	0 ppb
Farwell Elementary School	Rm 173 Sink	0 ppb
Farwell Elementary School	Rm 174 Sink	0 ppb
Farwell Elementary School	Rm 175 Sink	0 ppb
Farwell Elementary School	Rm 176 Sink	0 ppb
Farwell Elementary School	Rm 177 Sink	0 ppb
Farwell Elementary School	Rm 178 Sink	0 ppb
Farwell Elementary School	Rm 200 Bubbler	2.2 ppb
Farwell Elementary School	Rm 200 Sink	0 ppb
Farwell Elementary School	Rm 202 Bubbler	1.2 ppb

School Name	Sample Location	Lead Test Result
Farwell Elementary School	Rm 202 Sink	1.5 ppb
Farwell Elementary School	Rm 204 Bubbler	1.4 ppb
Farwell Elementary School	Rm 204 Sink	0 ppb
Farwell Elementary School	Rm 206 Bubbler	0 ppb
Farwell Elementary School	Rm 206 Sink	3.5 ppb
Farwell Elementary School	Rm 212 Bubbler	2.6 ppb
Farwell Elementary School	Rm 212 Sink	1.8 ppb
Farwell Elementary School	Rm 214 Bubbler	3.1 ppb
Farwell Elementary School	Rm 214 Sink	2 ppb
Farwell Elementary School	Rm 216 Bubbler	5.5 ppb
Farwell Elementary School	Rm 216 Sink	0 ppb
Farwell Elementary School	Rm 217 Bubbler	3.4 ppb
Farwell Elementary School	Rm 217 Sink	1 ppb
Farwell Elementary School	Rm 218 Bubbler	3.6 ppb
Farwell Elementary School	Rm 218 Sink	1.3 ppb
Farwell Elementary School	Rm 220 Bubbler	0 ppb
Farwell Elementary School	Rm 220 Sink	0 ppb
Farwell Elementary School	Rm 221 Bubbler	6.1 ppb
Farwell Elementary School	Rm 221 Sink	3.3 ppb
Farwell Elementary School	Rm154 Sink	0 ppb
Fayette Central School	Art Room Sink	1.7 ppb
Fayette Central School	Boys Bathrrom Sink #1	7.2 ppb
Fayette Central School	Boys Bathrrom Sink #2	6.7 ppb
Fayette Central School	Custodian Floor Sink	5.2 ppb
Fayette Central School	Girls Bathroom Sink #1	6.7 ppb
Fayette Central School	Girls Bathroom Sink #2	5.1 ppb
Fayette Central School	Kindergarten Sink	8 ppb
Fayette Central School	Kitchen 2 Bay Sink	21.1 ppb
Fayette Central School	Kitchen Hand Wash Sink	4.9 ppb
Fayette Central School	Nurse's Office Sink	6.6 ppb
Fayette Central School	Outdoor Spigot	366 ppb
Fayette Central School	Staff Bathrrom Sink	6.9 ppb
Fayette Central School	Staff Room Sink	2.6 ppb
Fayette Central School	Water Fountain	0 ppb
Fiddlehead School of Arts & Science	Adult Bathroom Faucet	2.7 ppb
Fiddlehead School of Arts & Science	Children's Bathroom Faucet	2.1 ppb
Fiddlehead School of Arts & Science	Kitchen Faucet	4.7 ppb
Fiddlehead School of Arts & Science	Short Water Fountain Across 2nd Grade Rm	1.1 ppb
Fiddlehead School of Arts & Science	Tall Water Fountain Across 2nd Grade Rm	1.5 ppb
Fisher-Mitchell School	Drinking Fontain By Adut Br	8.8 ppb
Fisher-Mitchell School	Drinking Fontain By Rm 111	7.4 ppb
Fisher-Mitchell School	Drinking Fountain Cafe	0 ppb
Fisher-Mitchell School	Drinking Fountain Staff Rm 110	8.9 ppb
Fisher-Mitchell School	Drinkng Fountain Near Rm 128	14.2 ppb
Fisher-Mitchell School	Sink In Kitchen	2.6 ppb
Fisher-Mitchell School	Sink Nurses Office	15.8 ppb

School Name	Sample Location	Lead Test Result
Fisher-Mitchell School	Sink Rm 120	6.5 ppb
Fisher-Mitchell School	Sink Rm 121	9.3 ppb
Fisher-Mitchell School	Sink Rm 122	12.7 ppb
Fisher-Mitchell School	Sink Rm 123	6.9 ppb
Fisher-Mitchell School	Sink Rm 124	2.7 ppb
Fisher-Mitchell School	Sink Rm 125	38.2 ppb
Fisher-Mitchell School	Sink Rm 126	4.5 ppb
Fisher-Mitchell School	Sink Rm 127	35.8 ppb
Fisher-Mitchell School	Sink Rm 129	17.4 ppb
Fisher-Mitchell School	Sink Stage Storgae	282 ppb
Forest Hills Consolidated School	Elementary Water Fountain	0 ppb
Forest Hills Consolidated School	Gymnasium Water Fountain	21.5 ppb
Forest Hills Consolidated School	High School Water Fountain	0 ppb
Forest Hills Consolidated School	Home Economics; East Sink	8.6 ppb
Forest Hills Consolidated School	Home Economics; South Sink	5.9 ppb
Forest Hills Consolidated School	Home Economics; West Sink	45.4 ppb
Forest Hills Consolidated School	Kitchen; Cook Area; Ice Machine	0 ppb
Forest Hills Consolidated School	Kitchen; Cook Area; Large Sink	22.5 ppb
Forest Hills Consolidated School	Kitchen; Cook Area; Small Sink	2.6 ppb
Forest Hills Consolidated School	Kitchen; Dish Room; Large Sink	3.7 ppb
Forest Hills Consolidated School	Middle School Water Fountain	0 ppb
Fort Fairfield Elementary School	Art Room	6.9 ppb
Fort Fairfield Elementary School	Boys Bathroom Gym	1.2 ppb
Fort Fairfield Elementary School	Boys Bathroom Right	1.2 ppb
Fort Fairfield Elementary School	Faculty 2nd Floor Bathroom	4.4 ppb
Fort Fairfield Elementary School	Faculty Bathroom	6.5 ppb
Fort Fairfield Elementary School	Female Bathroom	2.1 ppb
Fort Fairfield Elementary School	Girls Bathroom Gym	5 ppb
Fort Fairfield Elementary School	Girls Bathroom Right	1.8 ppb
Fort Fairfield Elementary School	Gym	0 ppb
Fort Fairfield Elementary School	Gym Teachers Bathroom	2.2 ppb
Fort Fairfield Elementary School	Kitchen Sink East	15.1 ppb
Fort Fairfield Elementary School	Kitchen Sink North	19.5 ppb
Fort Fairfield Elementary School	Kitchen Sink South	0 ppb
Fort Fairfield Elementary School	Kitchen Sink West	2.8 ppb
Fort Fairfield Elementary School	Library 1	0 ppb
Fort Fairfield Elementary School	Library 2	9.4 ppb
Fort Fairfield Elementary School	Male Bathroom	0 ppb
Fort Fairfield Elementary School	Room 101	2.7 ppb
Fort Fairfield Elementary School	Room 103	3.2 ppb
Fort Fairfield Elementary School	Room 105	3.6 ppb
Fort Fairfield Elementary School	Room 107	3.3 ppb
Fort Fairfield Elementary School	Room 109	2.6 ppb
Fort Fairfield Elementary School	Room 111	1.7 ppb
Fort Fairfield Elementary School	Room 113	2.7 ppb
Fort Fairfield Elementary School	Room 115	3.6 ppb
Fort Fairfield Elementary School	Room 117	2.6 ppb

School Name	Sample Location	Lead Test Result
Fort Fairfield Elementary School	Room 119	1.9 ppb
Fort Fairfield Elementary School	Room 121	2 ppb
Fort Fairfield Elementary School	Room 137	4 ppb
Fort Fairfield Elementary School	Room 139 Faculty Sink	1 ppb
Fort Fairfield Elementary School	Room 201	0 ppb
Fort Fairfield Elementary School	Room 203	15.1 ppb
Fort Fairfield Elementary School	Room 205	4.1 ppb
Fort Fairfield Elementary School	Room 207	5.7 ppb
Fort Fairfield Elementary School	Room 208	2.8 ppb
Fort Fairfield Elementary School	Room 211	3.8 ppb
Fort Fairfield Elementary School	Room 213	5.8 ppb
Fort Fairfield Elementary School	Room 215	5.6 ppb
Fort Fairfield Elementary School	Room 217	3.5 ppb
Fort Fairfield Elementary School	Room 219	3.6 ppb
Fort Fairfield Elementary School	Single Female Bathroom	2.1 ppb
Fort Fairfield Elementary School	Single Male Bathroom	3.8 ppb
Fort Fairfield Elementary School	Spec Ed	0 ppb
Fort Fairfield Elementary School	Spec Ed Bathroom	0 ppb
Fort Fairfield Middle/High School	118 Female Bathroom	3.5 ppb
Fort Fairfield Middle/High School	210 Female Bathroom	8.8 ppb
Fort Fairfield Middle/High School	Art Room Double Basin	6.2 ppb
Fort Fairfield Middle/High School	Art Room Next To Weight Room	5.4 ppb
Fort Fairfield Middle/High School	Art Room Sink	13.6 ppb
Fort Fairfield Middle/High School	Boys Bathroom Supers Area	4.8 ppb
Fort Fairfield Middle/High School	Boys Locker	5.2 ppb
Fort Fairfield Middle/High School	Bubbler Hallway A	0 ppb
Fort Fairfield Middle/High School	Bubbler Hallway B	0 ppb
Fort Fairfield Middle/High School	Bus Garage Bathroom	1.2 ppb
Fort Fairfield Middle/High School	Girls Bathroom Supers Area	9.4 ppb
Fort Fairfield Middle/High School	Girls Locker	9.9 ppb
Fort Fairfield Middle/High School	Gym Bubbler	1.4 ppb
Fort Fairfield Middle/High School	Ice Machine	0 ppb
Fort Fairfield Middle/High School	Kitchen Bathroom	10.6 ppb
Fort Fairfield Middle/High School	Kitchen Dish Room	48.8 ppb
Fort Fairfield Middle/High School	Kitchen Double Basin North	30.3 ppb
Fort Fairfield Middle/High School	Kitchen Double Basin West	20 ppb
Fort Fairfield Middle/High School	Kitchen East	5.6 ppb
Fort Fairfield Middle/High School	Locker Room Hall Water Fnt East	10.9 ppb
Fort Fairfield Middle/High School	Locker Room Hall Water Fnt West	14 ppb
Fort Fairfield Middle/High School	Nurse Office	3.6 ppb
Fort Fairfield Middle/High School	Phy Therphy	7.5 ppb
Fort Fairfield Middle/High School	Rec Depart Building Basin	181 ppb
Fort Fairfield Middle/High School	Rec Dept Building Bathroom	38.6 ppb
Fort Fairfield Middle/High School	Room 126	0 ppb
Fort Fairfield Middle/High School	Room 128 North	6.7 ppb
Fort Fairfield Middle/High School	Room 211 Male Bathroom	2.4 ppb
Fort Fairfield Middle/High School	Room 215	4.3 ppb

School Name	Sample Location	Lead Test Result
Fort Fairfield Middle/High School	Room 215 East	152 ppb
Fort Fairfield Middle/High School	Room 215a	21.9 ppb
Fort Fairfield Middle/High School	Room 215a West	18.4 ppb
Fort Fairfield Middle/High School	South Hall	1.3 ppb
Fort Fairfield Middle/High School	Supers Kitchen	7 ppb
Fort Fairfield Middle/High School	Teachers Breakroom	4.7 ppb
Fort Fairfield Middle/High School	Teachers Female Bathroom	2 ppb
Fort Fairfield Middle/High School	Teachers Male Bathroom	2.2 ppb
Fort Fairfield Middle/High School	Weight Room	0 ppb
Fort Fairfield Middle/High School	Weight Room Bathroom	7.5 ppb
Fort Kent Community High School\Valley Rivers Middle School	Band Room	1.5 ppb
Fort Kent Community High School\Valley Rivers Middle School	Boys Bathroom Hallway Freshman Wing	0 ppb
Fort Kent Community High School\Valley Rivers Middle School	Chippy Kitchen Area	1.4 ppb
Fort Kent Community High School\Valley Rivers Middle School	Chippy Learning Lab	2 ppb
Fort Kent Community High School\Valley Rivers Middle School	Dish Room	4 ppb
Fort Kent Community High School\Valley Rivers Middle School	First Floor At Nurse Office	0 ppb
Fort Kent Community High School\Valley Rivers Middle School	Gym Main Entrance	0 ppb
Fort Kent Community High School\Valley Rivers Middle School	Hallway Cafe Entrance	0 ppb
Fort Kent Community High School\Valley Rivers Middle School	Kitchen Mid Island Sink 1	2.7 ppb
Fort Kent Community High School\Valley Rivers Middle School	Kitchen Mid Island Sink 2	0 ppb
Fort Kent Community High School\Valley Rivers Middle School	Left Hall Side Room 206	0 ppb
Fort Kent Elementary School	A Wing First Right	0 ppb
Fort Kent Elementary School	A Wing Hall Left Mid	0 ppb
Fort Kent Elementary School	A Wing Hall Right End	0 ppb
Fort Kent Elementary School	B Wing Hall Left End	0 ppb
Fort Kent Elementary School	B Wing Hall Right Mid	1.1 ppb
Fort Kent Elementary School	C Wing Hall At Restroom Doorways	0 ppb
Fort Kent Elementary School	C Wing Hall Main Door Student Acss	1.8 ppb
Fort Kent Elementary School	Gym Area Next To It Room	6.6 ppb
Fort Kent Elementary School	Kitchen Dish Room	4 ppb
Fort Kent Elementary School	Kitchen Far Right Sink	4.9 ppb
Fort Kent Elementary School	Kitchen Kettle	4.6 ppb
Fort Kent Elementary School	Kitchen Left Side Sink	2.7 ppb
Fort Kent Elementary School	Main Hall At Elavator Door	2.3 ppb
Fort Kent Elementary School	Main Hall Next To Paper Storage Room	0 ppb
Fort Kent Elementary School	Small Gym	27.4 ppb

School Name	Sample Location	Lead Test Result
Fort Kent Elementary School	Task Room Hall	53.6 ppb
Fort O'Brien School	2nd Floor drinking Fountain	1.5 ppb
Fort O'Brien School	Gym Drinking Fountain	13.9 ppb
Fort O'Brien School	Kitchen Food Prep Sink	6.4 ppb
Fort O'Brien School	Lower Floor Drinking Fountain	0 ppb
Fort O'Brien School	Pre-k Room Sink	8.4 ppb
Fort Street School	Kitchen Sink Left	1.5 ppb
Fort Street School	Kitchen Sink Right	7.4 ppb
Fort Street School	Kitchenette	5.2 ppb
Fort Street School	Lobby	0 ppb
Fort Street School	Nurse Office	7.9 ppb
Fort Street School	Rm 110	4.1 ppb
Fort Street School	Rm 111	5 ppb
Fort Street School	Rm 112	4.6 ppb
Fort Street School	Rm 113	8.9 ppb
Fort Street School	Rm 120	5.8 ppb
Fort Street School	Rm 124	18.5 ppb
Fort Street School	Rm 168	6.5 ppb
Fort Street School	Rm 170	4.5 ppb
Fort Street School	Rm 172	2.9 ppb
Fort Street School	Rm 174	5.9 ppb
Fort Street School	Rm 176	6.2 ppb
Fort Street School	Rm 178	6.4 ppb
Fort Street School	Staff Room	7.6 ppb
Fort Street School	Upper Wing Fountain	0 ppb
Fort Street School	Wf By Gym	0 ppb
Fourteenth Street School	Bottle Fill Station - Main Entrance	0 ppb
Fourteenth Street School	Drinking Water Tap - Room 1	8.5 ppb
Fourteenth Street School	Drinking Water Tap - Room 10	10.7 ppb
Fourteenth Street School	Drinking Water Tap - Room 11	25.3 ppb
Fourteenth Street School	Drinking Water Tap - Room 2	1.7 ppb
Fourteenth Street School	Drinking Water Tap - Room 3	45.9 ppb
Fourteenth Street School	Drinking Water Tap - Room 4	4.9 ppb
Fourteenth Street School	Drinking Water Tap - Room 5	15.2 ppb
Fourteenth Street School	Drinking Water Tap - Room 6	30.4 ppb
Fourteenth Street School	Drinking Water Tap - Room 7	424 ppb
Fourteenth Street School	Drinking Water Tap - Room 8	10.7 ppb
Fourteenth Street School	Drinking Water Tap - Room 9	9.2 ppb
Fourteenth Street School	Faucet - Teacher's Lounge	15 ppb
Fourteenth Street School	Kitchen - Faucet On 3 Basin Sink	7.1 ppb
Foxcroft Academy	Dish Wash Sprayer	2.6 ppb
Foxcroft Academy	Kitchen Sink Left	0 ppb
Foxcroft Academy	Kitchen Sink Right	0 ppb
Frank H Harrison Middle School	1 Bottle Fill / Drinking Fountain 2	1.4 ppb
Frank H Harrison Middle School	Across Room B153 Fountain	0 ppb
Frank H Harrison Middle School	Across Room B213 Fountain	0 ppb
Frank H Harrison Middle School	Bottle Fill / Drinking Fountain 1	1 ppb

School Name	Sample Location	Lead Test Result
Frank H Harrison Middle School	Kitchen Sink 1	10.1 ppb
Frank H Harrison Middle School	Kitchen Sink 2	7.9 ppb
Frank H Harrison Middle School	Kitchen Steamer	4.7 ppb
Frank H Harrison Middle School	Room A107 Nurse Office Sink	7.7 ppb
Frank H Harrison Middle School	Room A113 Library Sink	7.7 ppb
Frank H Harrison Middle School	Room A121 Health Room Sink 1	5 ppb
Frank H Harrison Middle School	Room A121 Health Room Sink 2	12.3 ppb
Frank H Harrison Middle School	Room A121 Health Room Sink 3	12.2 ppb
Frank H Harrison Middle School	Room A121 Health Room Sink 4	7.1 ppb
Frank H Harrison Middle School	Room B141 Fountain 1	14.4 ppb
Frank H Harrison Middle School	Room B142 Fountain	11.5 ppb
Frank H Harrison Middle School	Room B143 Fountain	5.8 ppb
Frank H Harrison Middle School	Room B144 Fountain	13.7 ppb
Frank H Harrison Middle School	Room B146 Fountain	23.5 ppb
Frank H Harrison Middle School	Room B153 Fountain	17.4 ppb
Frank H Harrison Middle School	Room B155 Fountain	12.3 ppb
Frank H Harrison Middle School	Room B157 Fountain	4.4 ppb
Frank H Harrison Middle School	Room B158 Fountain	5.6 ppb
Frank H Harrison Middle School	Room B159 Fountain	19.1 ppb
Frank H Harrison Middle School	Room B160 Fountain	9 ppb
Frank I Brown Elementary School	1st Fl...art Room	0 ppb
Frank I Brown Elementary School	2nd Fl...bottle Fill Station	0 ppb
Frank I Brown Elementary School	2nd Flàbottle Fill Station	0 ppb
Frank I Brown Elementary School	3rd Fl...bottle Fill Station	0 ppb
Frank I Brown Elementary School	3rd Flàbottle Fill Station	0 ppb
Frank I Brown Elementary School	Bottle Fill Station..1st Fl	0 ppb
Frank I Brown Elementary School	Bottle Fill Station..1st Fl	0 ppb
Frank I Brown Elementary School	Kitchen	1.1 ppb
Frank I Brown Elementary School	Nurse Office	0 ppb
Frank I Brown Elementary School	Pre-k	0 ppb
Frank I Brown Elementary School	Room 1	0 ppb
Frank I Brown Elementary School	Room 10	0 ppb
Frank I Brown Elementary School	Room 11	0 ppb
Frank I Brown Elementary School	Room 12	0 ppb
Frank I Brown Elementary School	Room 13	0 ppb
Frank I Brown Elementary School	Room 14	0 ppb
Frank I Brown Elementary School	Room 15	0 ppb
Frank I Brown Elementary School	Room 16	0 ppb
Frank I Brown Elementary School	Room 2	0 ppb
Frank I Brown Elementary School	Room 3	0 ppb
Frank I Brown Elementary School	Room 5	0 ppb
Frank I Brown Elementary School	Room 6	0 ppb
Frank I Brown Elementary School	Room 7	0 ppb
Frank I Brown Elementary School	Room 8	0 ppb
Frank I Brown Elementary School	Room 9	0 ppb
Frank Jewett School	Drink Fountain Room 15	2.5 ppb
Frank Jewett School	Drinking Fountain By Elevator	0 ppb

School Name	Sample Location	Lead Test Result
Frank Jewett School	Drinking Fountain By Room 19	1.3 ppb
Frank Jewett School	Drinking Fountain By Room 3	13.9 ppb
Frank Jewett School	Drinking Fountain Room 5	13.7 ppb
Frank Jewett School	Drinking Fountain Room 7	48.2 ppb
Frank Jewett School	Drinking Fountain Staff Room	4.5 ppb
Frank Jewett School	Faucet Room 15	6.5 ppb
Frank Jewett School	Faucet Room 17	1.7 ppb
Frank Jewett School	Faucet Room 2	2 ppb
Frank Jewett School	Faucet Room 4	8.5 ppb
Frank Jewett School	Faucet Room 5	133 ppb
Frank Jewett School	Faucet Room 6	46.5 ppb
Frank Jewett School	Faucet Room 7	23.4 ppb
Frank Jewett School	Faucet Staff Room	6.8 ppb
Frank Jewett School	Kitchen Prep Faucet	10.4 ppb
Franklin Alternative School	Bathroom By Copy Room Faucet	0 ppb
Franklin Alternative School	Boys Bathroom L Faucet	0 ppb
Franklin Alternative School	Boys Bathroom R Faucet	0 ppb
Franklin Alternative School	Cafeteria Bubbler	0 ppb
Franklin Alternative School	Cafeteria Water Fountain Bottle Filler	0 ppb
Franklin Alternative School	Girls Bathroom L Faucet	0 ppb
Franklin Alternative School	Girls Bathroom R Faucet	0 ppb
Franklin Alternative School	Hallway Bubbler	0 ppb
Franklin Alternative School	Hallway Right Bubbler	0 ppb
Franklin Alternative School	Hallway Water Fountain Bottle Filler	0 ppb
Franklin Alternative School	Office Area Bathroom Faucet	0 ppb
Franklin Alternative School	Room 101 Art Room L Faucet	2.4 ppb
Franklin Alternative School	Room 101 Art Room R Faucet	4.5 ppb
Franklin Alternative School	Room Between 203 And 206 Faucet	127 ppb
Franklin Alternative School	Teachers Room Kitchen Faucet	7.4 ppb
Franklin Alternative School	Technology Room Bathroom Faucet	0 ppb
Fraser-Ford Child Development Center	Filtered Bottle Fill Outside Of Rm 113a (lft Wll)	0 ppb
Fraser-Ford Child Development Center	Room 113a - Faucet On Single Basin Sink (rht)	2.5 ppb
Fraser-Ford Child Development Center	Room 113a - Faucet On Triple Basin Sink (lft)	3 ppb
Fraser-Ford Child Development Center	Room 113a - Sprayer On Triple Basin Sink (lft)	4.7 ppb
Fraser-Ford Child Development Center	Room 133a - Faucet On Double Basin Sink (bck Wll)	5.1 ppb
Freeport High School	100 Wing At Room 112	0 ppb
Freeport High School	200 West	0 ppb
Freeport High School	200 Wing At Cust Room	0 ppb
Freeport High School	200 Wing At Room 204	0 ppb
Freeport High School	300 Wing At Entry	0 ppb
Freeport High School	400 Wing South	0 ppb
Freeport High School	Auditorium Lobby	0 ppb

School Name	Sample Location	Lead Test Result
Freeport High School	Cafeteria	0 ppb
Freeport High School	Gym	0 ppb
Freeport High School	Ice Machine	0 ppb
Freeport High School	Kitchen Sink	0 ppb
Freeport High School	Snack Bar Auditorium	0 ppb
Freeport High School	Teachers Room 700 Wing	0 ppb
Freeport Middle School	Back Hall Lower	0 ppb
Freeport Middle School	Cafeteria Dual	0 ppb
Freeport Middle School	Entry Hall	0 ppb
Freeport Middle School	Gym	11 ppb
Freeport Middle School	Ice Machine	0 ppb
Freeport Middle School	Kitchen Sink Cooking	0 ppb
Freeport Middle School	Main Hall Lower West End	0 ppb
Freeport Middle School	Teachers Room Sink	0 ppb
Freeport Middle School	Upper Hall (main West End)	0 ppb
Freeport Middle School	Upper Hall (main East End)	0 ppb
Freeport Middle School	Wing Upstairs Above Cafe	0 ppb
Frenchboro Elementary School	Basement Kitchen	22.1 ppb
Frenchboro Elementary School	Downstairs Bathroom	5.5 ppb
Frenchboro Elementary School	Upstairs Bathroom	3 ppb
Frenchboro Elementary School	Utility Sink Upstairs	21.8 ppb
Friendship Village School	Bottle Fill Gym	0 ppb
Friendship Village School	Bottle Fill Lobby	0 ppb
Friendship Village School	Boys Restroom Sink #38	2.7 ppb
Friendship Village School	Fountain Lobby	0 ppb
Friendship Village School	Fountain Room #5 3rd Grade	14 ppb
Friendship Village School	Fountain Room #6 2nd Grade	6.6 ppb
Friendship Village School	Fountain Room #7 1st Grade	6.2 ppb
Friendship Village School	Fountain Room #8 Kindergarten	4.8 ppb
Friendship Village School	Girls Restroom Sink #37	3.9 ppb
Friendship Village School	Gym Restroom Sink #16 Room	0 ppb
Friendship Village School	Janitor Closet Sink #25	52.2 ppb
Friendship Village School	Janitorial Art Storage Sink #18 Room	8.9 ppb
Friendship Village School	Kitchen Handwash Sink #19 Room	2 ppb
Friendship Village School	Kitchen Triple Sink Faucet & Sprayer #19 Room	4 ppb
Friendship Village School	Locker Room Music Storage Sink #17 Room	169 ppb
Friendship Village School	Locker Room P.e. Storage Sink #15 Room	61.1 ppb
Friendship Village School	Sink Room #5 3rd Grade	0 ppb
Friendship Village School	Sink Room #6 2nd Grade	1.5 ppb
Friendship Village School	Sink Room #7 1st Grade	0 ppb
Friendship Village School	Sink Room #8 Kindergarten	3.2 ppb
Friendship Village School	Staff Restroom Sink #36	6.5 ppb
Friendship Village School	Staff Room Sink #32	6.9 ppb
Friendship Village School	Upstairs Hall Bottle Fill #39	1.2 ppb
Fruit Street School	Bottle Fill Station - Near Nurse Station	0 ppb
Fruit Street School	Drinking Water Tap - Room 1	0 ppb

School Name	Sample Location	Lead Test Result
Fruit Street School	Drinking Water Tap - Room 10	1.6 ppb
Fruit Street School	Drinking Water Tap - Room 11	3.5 ppb
Fruit Street School	Drinking Water Tap - Room 12	10 ppb
Fruit Street School	Drinking Water Tap - Room 13	30.7 ppb
Fruit Street School	Drinking Water Tap - Room 14	12.1 ppb
Fruit Street School	Drinking Water Tap - Room 15	9.3 ppb
Fruit Street School	Drinking Water Tap - Room 16	4.9 ppb
Fruit Street School	Drinking Water Tap - Room 17	1.7 ppb
Fruit Street School	Drinking Water Tap - Room 18	3.3 ppb
Fruit Street School	Drinking Water Tap - Room 19	51.1 ppb
Fruit Street School	Drinking Water Tap - Room 2	1.3 ppb
Fruit Street School	Drinking Water Tap - Room 20	62.7 ppb
Fruit Street School	Drinking Water Tap - Room 21	4 ppb
Fruit Street School	Drinking Water Tap - Room 3	0 ppb
Fruit Street School	Drinking Water Tap - Room 4	0 ppb
Fruit Street School	Drinking Water Tap - Room 5	0 ppb
Fruit Street School	Drinking Water Tap - Room 6	0 ppb
Fruit Street School	Drinking Water Tap - Room 7	1.7 ppb
Fruit Street School	Drinking Water Tap - Room 8	4.4 ppb
Fruit Street School	Drinking Water Tap - Room 9	1.1 ppb
Fruit Street School	Faucet - Teacher's Lounge	1.2 ppb
Fruit Street School	Kitchen - Food Prep Faucet Left	5.8 ppb
Fruit Street School	Kitchen - Food Prep Faucet Middle	1.6 ppb
Fruit Street School	Kitchen - Food Prep Faucet Right	4.4 ppb
Fryeburg Academy	686 Conf	0 ppb
Fryeburg Academy	686 Kitchen	0 ppb
Fryeburg Academy	Chase1	0 ppb
Fryeburg Academy	Chase2	0 ppb
Fryeburg Academy	Curtis Hall	0 ppb
Fryeburg Academy	Cutter Hall	0 ppb
Fryeburg Academy	Dh Coffee	0 ppb
Fryeburg Academy	Dh Dispenser 1	0 ppb
Fryeburg Academy	Dh Dispenser 3	0 ppb
Fryeburg Academy	Frye 1	0 ppb
Fryeburg Academy	Frye 2	0 ppb
Fryeburg Academy	Gym Boosters	1.3 ppb
Fryeburg Academy	Gym Fitness	0 ppb
Fryeburg Academy	Gym Locker	3 ppb
Fryeburg Academy	Gym Restroom	0 ppb
Fryeburg Academy	Gym Trainer	0 ppb
Fryeburg Academy	Hastings 1	0 ppb
Fryeburg Academy	Hastings 2	0 ppb
Fryeburg Academy	la Metal	0 ppb
Fryeburg Academy	la Woods	0 ppb
Fryeburg Academy	Kitchen Island	0 ppb
Fryeburg Academy	Kitchen Wall	0 ppb
Fryeburg Academy	Main Bus.	0 ppb

School Name	Sample Location	Lead Test Result
Fryeburg Academy	Main Deans	0 ppb
Fryeburg Academy	Main Hos	0 ppb
Fryeburg Academy	Pac Green Rm	0 ppb
Fryeburg Academy	Pac Lobby	0 ppb
Fryeburg Academy	Page House	1.4 ppb
Fryeburg Academy	Pm 1	0 ppb
Fryeburg Academy	Pm 2	0 ppb
Fryeburg Academy	School Nurse	0 ppb
Fryeburg Academy	Science Hall	5.4 ppb
Fryeburg Academy	Science Prep	15.5 ppb
Fryeburg Academy	Student Kitchen	0 ppb
Fryeburg Academy	Su	0 ppb
Fryeburg Academy	Su Conference	0 ppb
Fryeburg Academy	Teachers Rm	0 ppb
Fryeburg Academy	True House	0 ppb
Fryeburg Academy	Webster 1	0 ppb
G Herbert Jewett School	"near ""back"" Parking Lot / Closest To Stage"	0 ppb
G Herbert Jewett School	Clinic	33.1 ppb
G Herbert Jewett School	Kitchen	0 ppb
G Herbert Jewett School	Near Gym Bathrooms	0 ppb
G Herbert Jewett School	Rm. 01 North	0 ppb
G Herbert Jewett School	Rm. 02 North	4.4 ppb
G Herbert Jewett School	Rm. 03 North	1.6 ppb
G Herbert Jewett School	Rm. 04 North	1.7 ppb
G Herbert Jewett School	Rm. 06 North	5.4 ppb
G Herbert Jewett School	Rm. 1 - 6 Hall Fountain	0 ppb
G Herbert Jewett School	Rm. 10 East	16 ppb
G Herbert Jewett School	Rm. 19 East	1.8 ppb
G Herbert Jewett School	Rm. 20 East	0 ppb
G Herbert Jewett School	Rm. 21 West	0 ppb
G Herbert Jewett School	Rm. 22 West	0 ppb
G Herbert Jewett School	Rm. 29 West	5.7 ppb
G Herbert Jewett School	Room 26	2.6 ppb
G Herbert Jewett School	Room 9	20.9 ppb
G Herbert Jewett School	Sped	42.7 ppb
Gardiner Area High School	Booster	0 ppb
Gardiner Area High School	Bottle Fill 1st Floor C-wing	0 ppb
Gardiner Area High School	Bottle Fill 2nd Floor C-wing	0 ppb
Gardiner Area High School	Bottle Fill Library Hall	0 ppb
Gardiner Area High School	Bottle Fill Music Lobby	0 ppb
Gardiner Area High School	Bottle Fill T-wing 1st Floor	0 ppb
Gardiner Area High School	Bottle Fill T-wing Upstairs	0 ppb
Gardiner Area High School	Drinking Fountain 1st Floor C-wing	0 ppb
Gardiner Area High School	Drinking Fountain Music Lobby	0 ppb
Gardiner Area High School	Fitness Room T-wing 1st Floor Bottle Fill	1.3 ppb
Gardiner Area High School	Gym Lobby Bottle Fill	0 ppb

School Name	Sample Location	Lead Test Result
Gardiner Area High School	Ice Machine Gym	0 ppb
Gardiner Area High School	Ice Machine Kitchen	0 ppb
Gardiner Area High School	Kitchen Hand Wash Sink	1.1 ppb
Gardiner Area High School	Kitchen Prep Sink	0 ppb
Gardiner Area High School	Main Office Hall Bottle Fill	0 ppb
Gardiner Area High School	Nurse Sink	1.7 ppb
Gardiner Area High School	Room 119	0 ppb
Gardiner Area High School	Room 313 A-wing	0 ppb
Gardiner Area High School	Room 406	0 ppb
Gardiner Regional Middle School	Acadia Bottle Fill	0 ppb
Gardiner Regional Middle School	Allagash Bottle Fill	11.5 ppb
Gardiner Regional Middle School	Anna's Kitchen	1.2 ppb
Gardiner Regional Middle School	Chamberlan Bottle Fill	0 ppb
Gardiner Regional Middle School	Gym Lobby Bottle Fill	0 ppb
Gardiner Regional Middle School	Hermitage Bottle Fill	0 ppb
Gardiner Regional Middle School	Kitchen Hand Wash Sink	2 ppb
Gardiner Regional Middle School	Kitchen Ice Machine	0 ppb
Gardiner Regional Middle School	Kitchen Prep	1.2 ppb
Gardiner Regional Middle School	Library Office	3.9 ppb
Gardiner Regional Middle School	Lysobe 1-1	1.4 ppb
Gardiner Regional Middle School	Moosehead Bottle Fill	0 ppb
Gardiner Regional Middle School	Moosehead Quirion	1.3 ppb
Gardiner Regional Middle School	Music Art Bottle Fill	0 ppb
Gardiner Regional Middle School	Nurse Sink	2.4 ppb
Gardiner Regional Middle School	Shop	1.1 ppb
Gardiner Regional Middle School	Sped Wallace	2 ppb
Gardiner Regional Middle School	Stem Back Room	1.5 ppb
Gardiner Regional Middle School	Teacher's Room	0 ppb
Garret Schenck School	Bottle Filler 1st Floor Bathrooms	0 ppb
Garret Schenck School	Bottle Filler 2nd Floor	0 ppb
Garret Schenck School	Bottle Filler By Main Office	0 ppb
Garret Schenck School	Sink In Kitchen	27.7 ppb
Garret Schenck School	Sink Teachers Room	0 ppb
Garret Schenck School	Water Fountain 1st Grade	8.1 ppb
Garret Schenck School	Water Fountain 4th Grade	22.1 ppb
Garret Schenck School	Water Fountain 5th Grade	14.2 ppb
Garret Schenck School	Water Fountain Across From Pre-k	31.5 ppb
Garret Schenck School	Water Fountain Art Room	3.9 ppb
Garret Schenck School	Water Fountain Hall 2nd Floor	0 ppb
Garret Schenck School	Water Fountain K	2 ppb
Garret Schenck School	Water Fountain Resource Room	7 ppb
Gartley School	Gym Hallway Bathroom #1	13.8 ppb
Gartley School	Gym Hallway Bathroom #2	2.9 ppb
Gartley School	Gym Hallway Drinking Fountain	0 ppb
Gartley School	Kitchen Faucet #1	0 ppb
Gartley School	Kitchen Faucet #2	3.7 ppb
Gartley School	Kitchen Wash Sink	21.9 ppb

School Name	Sample Location	Lead Test Result
Gartley School	Main Hallway Bathroom Left Large	8.3 ppb
Gartley School	Main Hallway Bathroom Right Small	5.9 ppb
Gartley School	Main Hallway Staff Kitchen	3.1 ppb
Gartley School	Room 7 Kitchen Sink	4.3 ppb
Gartley School	Supts Ladies Bathroom	9.5 ppb
Gartley School	Supts Mens Bathroom	17.8 ppb
George B Weatherbee School	2nd Flr - Across From Rm 215	0 ppb
George B Weatherbee School	2nd Flr - Next To Rm 204	0 ppb
George B Weatherbee School	3rd Grade Wing - Lower Level	2.4 ppb
George B Weatherbee School	Drinking Fountain @ Main Entrance	1.1 ppb
George B Weatherbee School	Kitchen 3-bay Sink	17.3 ppb
George E Jack School	Art Room Faucet	1 ppb
George E Jack School	Bottle Fill Outside Cafeteria	0 ppb
George E Jack School	Clinic Faucet	0 ppb
George E Jack School	Faucet Room 2	0 ppb
George E Jack School	Faucet Room 3	0 ppb
George E Jack School	Faucet Room 4	6.6 ppb
George E Jack School	Fountain Outside Cafeteria	0 ppb
George E Jack School	High Fountain By Room 8	0 ppb
George E Jack School	Kitchen Prep Sink	1.3 ppb
George E Jack School	Main Entrance Bottle Fill	0 ppb
George E Jack School	Main Entrance Fountain	0 ppb
George E Jack School	Staff Room Faucet	0 ppb
George J Mitchell School	A Wing Bathroom Sink	2 ppb
George J Mitchell School	A Wing Conference Room Sink	9.4 ppb
George J Mitchell School	A1 Classroom Sink	1.7 ppb
George J Mitchell School	A3 Classroom Sink	1.4 ppb
George J Mitchell School	A4 Classroom Sink	3.1 ppb
George J Mitchell School	A5 Classroom Sink	1.4 ppb
George J Mitchell School	A6 Classroom Sink	1.4 ppb
George J Mitchell School	A7 Classroom Sink	0 ppb
George J Mitchell School	A8 Classroom Sink	1.7 ppb
George J Mitchell School	B Wing Boys Bathroom Sink 1	1.2 ppb
George J Mitchell School	B Wing Boys Bathroom Sink 2	0 ppb
George J Mitchell School	B Wing Boys Bathroom Sink 3	1.2 ppb
George J Mitchell School	B Wing Ctr Bathroom Sink	3.3 ppb
George J Mitchell School	B Wing Girls Bathroom Sink 1	1.5 ppb
George J Mitchell School	B Wing Girls Bathroom Sink 2	1.6 ppb
George J Mitchell School	B Wing Girls Bathroom Sink 3	4.9 ppb
George J Mitchell School	B10 Classroom Sink	1.1 ppb
George J Mitchell School	B11 Classroom Sink	1.9 ppb
George J Mitchell School	B12 Classroom Sink	1.7 ppb
George J Mitchell School	B13 Classroom Sink	3 ppb
George J Mitchell School	B14 Classroom Sink	1.7 ppb
George J Mitchell School	B15 Classroom Sink	3.3 ppb
George J Mitchell School	B16 Classroom Sink	2.5 ppb
George J Mitchell School	B9 Classroom Sink	1.7 ppb

School Name	Sample Location	Lead Test Result
George J Mitchell School	C Wing Ctr Bathroom Sink	1.5 ppb
George J Mitchell School	C17 Classroom Sink	2.4 ppb
George J Mitchell School	C18 Classroom Sink	5.4 ppb
George J Mitchell School	C19 Classroom Sink	3.6 ppb
George J Mitchell School	C20 Classroom Sink	1.4 ppb
George J Mitchell School	C21 Classroom Sink 1	2.2 ppb
George J Mitchell School	C21 Classroom Sink 2	0 ppb
George J Mitchell School	C21 Classroom Sink 3	1.6 ppb
George J Mitchell School	C21 Classroom Sink 4	2.8 ppb
George J Mitchell School	C22 Classroom Sink 1	1.5 ppb
George J Mitchell School	C22 Classroom Sink 2	2.8 ppb
George J Mitchell School	C22 Classroom Sink 3	2.7 ppb
George J Mitchell School	C22 Classroom Sink 4	1.6 ppb
George J Mitchell School	C23 Classroom Sink	2.4 ppb
George J Mitchell School	C24 Classroom Sink	3.6 ppb
George J Mitchell School	Childcare Bathroom Sink 1	0 ppb
George J Mitchell School	Childcare Bathroom Sink 2	1.9 ppb
George J Mitchell School	D Wing Ctr Bathroom Sink	1.7 ppb
George J Mitchell School	D25 Classroom Sink	1.4 ppb
George J Mitchell School	D26 Classroom Sink	0 ppb
George J Mitchell School	D27 Classroom Sink	0 ppb
George J Mitchell School	D28 Classroom Sink	0 ppb
George J Mitchell School	D29 Classroom Sink	0 ppb
George J Mitchell School	D30 Classroom Sink	1.3 ppb
George J Mitchell School	D31 Classroom Sink	0 ppb
George J Mitchell School	D32 Classroom Sink	0 ppb
George J Mitchell School	Gym Drinking Water Fountain	0 ppb
George J Mitchell School	K Wing Teachers Bathroom Sink	0 ppb
George J Mitchell School	K Wing Teachers Room Sink	1.1 ppb
George J Mitchell School	K1 Classroom Sink 1l	0 ppb
George J Mitchell School	K1 Classroom Sink 1r	0 ppb
George J Mitchell School	K2 Classroom Sink 1l	0 ppb
George J Mitchell School	K2 Classroom Sink 1r	0 ppb
George J Mitchell School	K3 Classroom Sink 1l	0 ppb
George J Mitchell School	K3 Classroom Sink 1r	0 ppb
George J Mitchell School	K4 Classroom Sink 1l	0 ppb
George J Mitchell School	K4 Classroom Sink 1r	1.1 ppb
George J Mitchell School	K5 Classroom Sink 1l	0 ppb
George J Mitchell School	K5 Classroom Sink 1r	0 ppb
George J Mitchell School	K6 Classroom Sink 1l	0 ppb
George J Mitchell School	K6 Classroom Sink 1r	0 ppb
George J Mitchell School	K7 Classroom Sink 1l	1.1 ppb
George J Mitchell School	K7 Classroom Sink 1r	0 ppb
George J Mitchell School	K8 Classroom Sink 1l	0 ppb
George J Mitchell School	K8 Classroom Sink 1r	0 ppb
George J Mitchell School	Kitchen Bathroom Sink	2 ppb
George J Mitchell School	Kitchen Sink 1	2.6 ppb

School Name	Sample Location	Lead Test Result
George J Mitchell School	Kitchen Sink 2	21.6 ppb
George J Mitchell School	Kitchen Sink 3	0 ppb
George J Mitchell School	Main Hallway Bathroom Sink 1	0 ppb
George J Mitchell School	Main Hallway Bathroom Sink 2	0 ppb
George J Mitchell School	Main Hallway Drinking Water Fountain	0 ppb
George J Mitchell School	Main Office Bathroom Sink	6.1 ppb
George J Mitchell School	Main Office Nurses Station Bathroom Sink	2.2 ppb
George J Mitchell School	Main Office Nurses Station Sink	1.7 ppb
George J Mitchell School	Shop Sink	1.3 ppb
George J Mitchell School	Teachers Lounge Sink	2.1 ppb
George Stevens Academy	Butler Drinking Fountain	11.9 ppb
George Stevens Academy	Café Coffee Maker	11.1 ppb
George Stevens Academy	Café Drinking Fountain	6.9 ppb
George Stevens Academy	Drinking Fountain Gym	0 ppb
George Stevens Academy	Drinking Water Fill Trophy 1	0 ppb
George Stevens Academy	Drinking Water Fill Trophy 2	0 ppb
George Stevens Academy	Gails Office Kitchen	0 ppb
George Stevens Academy	Ice Machine	0 ppb
George Stevens Academy	Library Back Rm Sink	12.1 ppb
George Stevens Academy	Main Kitchen Faucet	2.7 ppb
George Stevens Academy	Mcintire Fountain-bottle Fill 1	0 ppb
George Stevens Academy	Mcintire Fountain-bottle Fill 2	0 ppb
George Stevens Academy	Metal Shop Drink Fountain	12 ppb
George Stevens Academy	Rm 114 Sink	8.5 ppb
George Stevens Academy	Rm 133 Sink	8.3 ppb
George Stevens Academy	Rm 220 Teachers Lounge	2.2 ppb
George Stevens Academy	Rm 222 Nurse Sink	2.7 ppb
George Stevens Academy	Sci Wing Drink Bottle-bottle 1	0 ppb
George Stevens Academy	Sci Wing Drink Bottle-bottle 2	0 ppb
Georgetown Central School	Bubbler Hall By Gym	0 ppb
Georgetown Central School	Kitchen 2 Bay Sink	3 ppb
Georgetown Central School	Main Hall Bottle Filler	0 ppb
Georgetown Central School	Room 10 Bubbler	3.3 ppb
Georgetown Central School	Staff Room Sink	2.1 ppb
Gerald D Cushing School	Bottle Fill	2.2 ppb
Gerald D Cushing School	Kitchen Sink	27.1 ppb
Gerald D Cushing School	Sink Pre-k	8 ppb
Gerald D Cushing School	Sink Room 30	5.3 ppb
Gerald D Cushing School	Sink Room 31	0 ppb
Gerald D Cushing School	Sink Room 32	1.3 ppb
Gerald D Cushing School	Sink Room 33	0 ppb
Gerald D Cushing School	Sink Staff Lounge	1.2 ppb
Gerald E Talbot Community School	101	2.6 ppb
Gerald E Talbot Community School	102	3.3 ppb
Gerald E Talbot Community School	103	1.6 ppb
Gerald E Talbot Community School	104	4 ppb
Gerald E Talbot Community School	108	2.8 ppb

School Name	Sample Location	Lead Test Result
Gerald E Talbot Community School	109	0 ppb
Gerald E Talbot Community School	110	0 ppb
Gerald E Talbot Community School	201	1.8 ppb
Gerald E Talbot Community School	202	2.2 ppb
Gerald E Talbot Community School	203	2.7 ppb
Gerald E Talbot Community School	204	17.4 ppb
Gerald E Talbot Community School	301	2.5 ppb
Gerald E Talbot Community School	302	1.8 ppb
Gerald E Talbot Community School	303	0 ppb
Gerald E Talbot Community School	304	4.1 ppb
Gerald E Talbot Community School	401	2.7 ppb
Gerald E Talbot Community School	402	1.6 ppb
Gerald E Talbot Community School	403	2 ppb
Gerald E Talbot Community School	404	2.9 ppb
Gerald E Talbot Community School	501	2.2 ppb
Gerald E Talbot Community School	502	2.1 ppb
Gerald E Talbot Community School	503	1.8 ppb
Gerald E Talbot Community School	504	2.2 ppb
Gerald E Talbot Community School	601	1.9 ppb
Gerald E Talbot Community School	602	0 ppb
Gerald E Talbot Community School	603	4.7 ppb
Gerald E Talbot Community School	604	2.6 ppb
Gerald E Talbot Community School	Art Room	4.4 ppb
Gerald E Talbot Community School	Cafeteria	2.8 ppb
Gerald E Talbot Community School	Community Entrance	0 ppb
Gerald E Talbot Community School	Community Kitchen	12 ppb
Gerald E Talbot Community School	Community Room - Left Sink	2.1 ppb
Gerald E Talbot Community School	Community Room - Right Sink	0 ppb
Gerald E Talbot Community School	Hall - Gym	0 ppb
Gerald E Talbot Community School	School Kitchen - Left Sink	7.7 ppb
Gerald E Talbot Community School	School Kitchen - Right Sink	3.3 ppb
Gerald E Talbot Community School	Staff Lounge	0 ppb
Gladys Weymouth Elem School	Hallway 1 By Custodian Closet	27.9 ppb
Gladys Weymouth Elem School	Hallway 1 New Fountain By Custodial Clostet	0 ppb
Gladys Weymouth Elem School	Hallway 2	13.3 ppb
Gladys Weymouth Elem School	Kitchen 1 Three Bay Sink	0 ppb
Gladys Weymouth Elem School	Kitchen 2	0 ppb
Glenburn Elementary School	4/5 Bottle Fill Station	0 ppb
Glenburn Elementary School	4/5 Drinking Water Fountain	0 ppb
Glenburn Elementary School	Gym Bottle Fill Station	0 ppb
Glenburn Elementary School	K/3 Bottle Fill Station	0 ppb
Glenburn Elementary School	Kitchen Dish Wash Sink	17.4 ppb
Glenburn Elementary School	Kitchen- Hand Wash - Sink 1	9.4 ppb
Glenburn Elementary School	Kitchen Handwash Sink 2	365 ppb
Glenburn Elementary School	Kitchen Main Sink	7.8 ppb
Glenburn Elementary School	Lobby - Bottle Fill Station	0 ppb

School Name	Sample Location	Lead Test Result
Glenburn Elementary School	Lobby - Drinking Water Station	0 ppb
Glenburn Elementary School	Lobby -drinking Water Station	0 ppb
Glenburn Elementary School	Room 101 Staff Room Kitchen Sink	6.1 ppb
Glenburn Elementary School	Room 104 Nurse Station Sink	6.9 ppb
Glenburn Elementary School	Room 205 Life Skills Room Sink	8.8 ppb
Glenburn Elementary School	Superintendent Main Bathroom Sink	1.3 ppb
Glenn Stratton Learning Center	Gslc Art / Music Room Sink	0 ppb
Glenn Stratton Learning Center	Gslc Conference Room Water Dispenser	0 ppb
Glenn Stratton Learning Center	Gslc Copy Room Water Dispenser	0 ppb
Glenn Stratton Learning Center	Gslc First Floor Bathroom #1 Sink	0 ppb
Glenn Stratton Learning Center	Gslc First Floor Bathroom #2 Sink	0 ppb
Glenn Stratton Learning Center	Gslc First Floor Bathroom #3 (base Of Steps) Sink	0 ppb
Glenn Stratton Learning Center	Gslc First Floor Kitchen	0 ppb
Glenn Stratton Learning Center	Gslc Medical Room Sink	0 ppb
Glenn Stratton Learning Center	Gslc Second Floor Bathroom #1 Sink	1.5 ppb
Glenn Stratton Learning Center	Gslc Second Floor Bathroom #2 Sink #1	5.3 ppb
Glenn Stratton Learning Center	Gslc Second Floor Bathroom #2 Sink #2	2 ppb
Glenn Stratton Learning Center	Gslc Second Floor Bathroom #3 Sink #1	2.6 ppb
Glenn Stratton Learning Center	Gslc Second Floor Bathroom #3 Sink #2	1.3 ppb
Glenn Stratton Learning Center	Gslc Second Floor Kitchen Sink	1.3 ppb
Glenn Stratton Learning Center	Gslc Second Floor Kitchen Water Dispenser	0 ppb
Glenn Stratton Learning Center	Gslc Third Floor Bathroom #1 Sink #1	1.1 ppb
Glenn Stratton Learning Center	Gslc Third Floor Bathroom #1 Sink #2	0 ppb
Glenn Stratton Learning Center	Gslc Third Floor Bathroom #2 Sink	1.4 ppb
Glenn Stratton Learning Center	Gslc Third Floor Drinking Fountain	0 ppb
Glenn Stratton Learning Center	Gslc Third Floor Kitchen Sink	1.8 ppb
Glenn Stratton Learning Center	Gslc Third Floor Teacher's Lounge Sink #1	0 ppb
Glenn Stratton Learning Center	Gslc Third Floor Teacher's Lounge Sink #2	1.4 ppb
Glenn Stratton Learning Center	Prescott Basement Bathroom #1 Sink	9.1 ppb
Glenn Stratton Learning Center	Prescott Basement Bathroom #2 Sink	0 ppb
Glenn Stratton Learning Center	Prescott Basement Bathroom #3 Sink #1	0 ppb
Glenn Stratton Learning Center	Prescott Basement Bathroom #3 Sink #2	0 ppb
Glenn Stratton Learning Center	Prescott Basement Bathroom #3 Sink #3	0 ppb
Glenn Stratton Learning Center	Prescott Basement Bathroom #3 Sink #4	0 ppb
Glenn Stratton Learning Center	Prescott First Floor Co-ed Bathroom Sink	1.3 ppb
Glenn Stratton Learning Center	Prescott First Floor Water Dispenser	0 ppb
Glenn Stratton Learning Center	Prescott First Floor Women's Bathroom Sink #1	6.5 ppb
Glenn Stratton Learning Center	Prescott First Floor Women's Bathroom Sink #2	5.1 ppb
Glenn Stratton Learning Center	Prescott First Floor Women's Bathroom Sink #3	5.2 ppb
Glenn Stratton Learning Center	Prescott First Floor Women's Bathroom Sink #4	1.2 ppb
Glenn Stratton Learning Center	Prescott Kitchen Sink #1	1.2 ppb

School Name	Sample Location	Lead Test Result
Glenn Stratton Learning Center	Prescott Kitchen Sink #2	2 ppb
Glenn Stratton Learning Center	Prescott Kitchen Sink #3	1.9 ppb
Glenn Stratton Learning Center	Prescott Kitchen Sink #4	1.6 ppb
Glenn Stratton Learning Center	Prescott Kitchen Sink #5	1.7 ppb
Glenn Stratton Learning Center	Prescott Second Floor Staff Bathroom Sink	0 ppb
Glickman Academy	1st Floor Bathroom Sink- By Rm 103 Staff	1.9 ppb
Glickman Academy	1st Floor Bathroom Sink By Rm 104 Student	1.6 ppb
Glickman Academy	1st Floor Bathroom Sink- By Rm 109 L	5.4 ppb
Glickman Academy	2nd Floor Sink Room 211	0 ppb
Glickman Academy	Basement Bathroom	0 ppb
Glickman Academy	Basement Handwash	1.1 ppb
Glickman Academy	Basement Sink In Kitchen	0 ppb
Glickman Academy	Bathroom Sink 109 R	4.2 ppb
Glickman Academy	Bathroom Sink By Room 209 A	2.1 ppb
Glickman Academy	Bathroom Sink By Room 209 B	3 ppb
Glickman Academy	Bathroom Sink By Room 209 C	3.5 ppb
Glickman Academy	Bathroom Sink By Room 209 D	2.1 ppb
Glickman Academy	Classroom 113 - Middle School Cedar	0 ppb
Glickman Academy	Classroom 114 - Middle School Hemlock	0 ppb
Glickman Academy	Classroom 116 - High School Oak	0 ppb
Glickman Academy	Classroom 126 - 1 On 1 Balsam	0 ppb
Glickman Academy	Classroom 133 - Elm	0 ppb
Glickman Academy	Classroom 135 - Birch	0 ppb
Glickman Academy	Classroom 144 - Daisy	0 ppb
Glickman Academy	Classroom 146 - Poppy	0 ppb
Glickman Academy	Classroom 150 - 3 - 5 Yr Sunflower	1.9 ppb
Glickman Academy	Classroom 152 - 3 - 5 Yr Buttercup	0 ppb
Glickman Academy	Classroom 154 - 3 - 5 Yr Bluebell	0 ppb
Glickman Academy	Classroom 156 - Preschool / Flex Sweet Pea	0 ppb
Glickman Academy	Exam Rm 165 - Patient Lab	5.6 ppb
Glickman Academy	Exam Rm 166 - Vitals	4.5 ppb
Glickman Academy	Exam Rm 172 - Dental	9 ppb
Glickman Academy	Exam Rm 174	5.4 ppb
Glickman Academy	Kitchen 121 - Life Skills	0 ppb
Glickman Academy	Kitchen 139 - Pre-school Food Prep	0 ppb
Glickman Academy	Laundry Sink A	22 ppb
Glickman Academy	Laundry Sink B	6.9 ppb
Glickman Academy	Nourishment Rm 132	0 ppb
Glickman Academy	Office 127 - Nurse Med	0 ppb
Gorham High School	A Hall Trainer Ice Machine	0 ppb
Gorham High School	A Hall Trainer Sink	10.4 ppb
Gorham High School	A Hall Trainer Washer Valve L	1.5 ppb
Gorham High School	A Hall Trainer Washer Valve R	228 ppb
Gorham High School	B Center Hall Near Elevator 2nd Floor	0 ppb
Gorham High School	B East Hall By Elevator 1st Floor High	0 ppb
Gorham High School	B East Hall By Elevator 1st Floor Low	0 ppb

School Name	Sample Location	Lead Test Result
Gorham High School	B North Hall Near Stair	0 ppb
Gorham High School	B-100 Concession	4.4 ppb
Gorham High School	B-138 Concession/custodial	2.1 ppb
Gorham High School	B-208 Sink	2.8 ppb
Gorham High School	C East Hall Opposite C-111 1st Floor	0 ppb
Gorham High School	C-108 Sink	5.3 ppb
Gorham High School	C-111 Sink	1.1 ppb
Gorham High School	D-105 Sink	2.6 ppb
Gorham High School	D-108 Sink	1.9 ppb
Gorham High School	D-109 Fountain	0 ppb
Gorham High School	D-109b Sink	1.9 ppb
Gorham High School	D-112 Kitchen Food Prep Sink	0 ppb
Gorham High School	D-112 Kitchen Sink East	5.2 ppb
Gorham High School	D-112 Kitchen Sink South	2.8 ppb
Gorham High School	Field House Kitchen 3-bay Sink	7.5 ppb
Gorham High School	Field House Kitchen Handwash Sink	26.9 ppb
Gorham High School	Field House Outside Hose Bib	1.1 ppb
Gorham High School	North Lobby A Fountain L-a	3.4 ppb
Gorham High School	North Lobby A Fountain L-c	14.6 ppb
Gorham High School	North Lobby A Fountain R-b	0 ppb
Gorham High School	North Lobby A Fountain R-d	13.3 ppb
Gorham Middle School	A114-a	1.3 ppb
Gorham Middle School	A114-b	0 ppb
Gorham Middle School	A115-a	0 ppb
Gorham Middle School	A115-b	0 ppb
Gorham Middle School	A115-c	3.1 ppb
Gorham Middle School	A115-d	1.3 ppb
Gorham Middle School	A139	0 ppb
Gorham Middle School	B240	0 ppb
Gorham Middle School	Concessions Ice Machine	0 ppb
Gorham Middle School	Concessions Outside Gym	4.1 ppb
Gorham Middle School	Kitchen-a	2.5 ppb
Gorham Middle School	Kitchen-b	5.4 ppb
Gorham Middle School	Kitchen-c	2.3 ppb
Gorham Middle School	Near A130-a	0 ppb
Gorham Middle School	Near A130-b	0 ppb
Gorham Middle School	Near A204-a	0 ppb
Gorham Middle School	Near A204-b	0 ppb
Gorham Middle School	Near B104-a	0 ppb
Gorham Middle School	Near B104-b	0 ppb
Gorham Middle School	Near B204-a	0 ppb
Gorham Middle School	Near B204-b	0 ppb
Gorham Middle School	Near C117-a	0 ppb
Gorham Middle School	Near C117-b	0 ppb
Gorham Middle School	Office Lunch Room	1 ppb
Gould Academy	Admissions Kitchen Sink	1.5 ppb
Gould Academy	Bingham Break Room Sink	1.3 ppb

School Name	Sample Location	Lead Test Result
Gould Academy	Bingham Fountain Gym	14 ppb
Gould Academy	Business Office Kitchen Sink	0 ppb
Gould Academy	Davidson Apt. 1st	2.3 ppb
Gould Academy	Davidson Apt. 2nd	1.2 ppb
Gould Academy	Davidson Apt. 3rd	0 ppb
Gould Academy	Davidson Fountain 1st	0 ppb
Gould Academy	Davidson Fountain 2nd	0 ppb
Gould Academy	Davidson Fountain 3rd	295 ppb
Gould Academy	Farnsworth Apt. Sink	5.1 ppb
Gould Academy	Farnsworth Fountain	0 ppb
Gould Academy	Farnsworth Ice Machine	0 ppb
Gould Academy	Farnsworth Trainer Sink	7 ppb
Gould Academy	Gehring Apt. 1st	0 ppb
Gould Academy	Gehring Apt. 2nd	0 ppb
Gould Academy	Gehring Apt. 3rd	0 ppb
Gould Academy	Gehring Apt. 4th	0 ppb
Gould Academy	Gehring Basement Kitchen Sink	0 ppb
Gould Academy	Gehring Lounge 1st	1.1 ppb
Gould Academy	Gehring Lounge 2nd	0 ppb
Gould Academy	Gehring Lounge 3rd	1.3 ppb
Gould Academy	Gehring Lounge 4th	12.7 ppb
Gould Academy	Hanscom Fountain 2nd	6.2 ppb
Gould Academy	Hanscom Fountain 3rd	0 ppb
Gould Academy	Hanscom Fountain Basement	0 ppb
Gould Academy	Hanscom Fountain Main	148 ppb
Gould Academy	Hanscom Sink For Coffee	1.6 ppb
Gould Academy	Health Center Basement Kitchen Sink	3980 ppb
Gould Academy	Health Center Bathroom Sink East	44.1 ppb
Gould Academy	Health Center Bathroom Sink West	18 ppb
Gould Academy	Health Center Kitchen Sink	8.7 ppb
Gould Academy	Holden Apt. A	2.1 ppb
Gould Academy	Holden Apt. B	6 ppb
Gould Academy	Holden Apt. C	0 ppb
Gould Academy	Holden Apt. D	38.4 ppb
Gould Academy	Mclaughlin Coffee	0 ppb
Gould Academy	Mclaughlin Fountain 1st	22.3 ppb
Gould Academy	Mclaughlin Fountain 1st Ada	30.1 ppb
Gould Academy	Mclaughlin Fountain 2nd	14.6 ppb
Gould Academy	Ordway Basement Kitchen	1.5 ppb
Gould Academy	Ordway Coffee Cafe	0 ppb
Gould Academy	Ordway Coffee Storage	467 ppb
Gould Academy	Ordway Fountain 1st	0 ppb
Gould Academy	Ordway Fountain Left	1.4 ppb
Gould Academy	Ordway Fountain Right	2.3 ppb
Gould Academy	Ordway Ice Machine	2.3 ppb
Gould Academy	Ordway Kitchen Sink Double Bay	1 ppb
Gould Academy	Ordway Kitchen Sink Triple Bay	2.7 ppb

School Name	Sample Location	Lead Test Result
Gould Academy	Park Street Apt. Kitchen Sink	0 ppb
Gould Academy	Vogt Kitchen Sink	0 ppb
Governor Baxter School for the Deaf	A-mansion/kitchen - Double Basin Sink	10.4 ppb
Governor Baxter School for the Deaf	C- Kitchen 1st Floor Double Basin Sink	0 ppb
Governor Baxter School for the Deaf	C- Kitchen 2nd Floor Double Basin Sink	4.4 ppb
Governor Baxter School for the Deaf	D- Go1 - Single Basin Sink/drink Spout	0 ppb
Governor Baxter School for the Deaf	D- Go2 - Single Basin Sink/drink Spout	0 ppb
Governor Baxter School for the Deaf	D- Go3 - Single Basin Sink/drink Spout	0 ppb
Governor Baxter School for the Deaf	D- Room #107 - Single Basin/drink Spout	0 ppb
Governor Baxter School for the Deaf	D- Room #110 - Single Basin/drink Spout	0 ppb
Governor Baxter School for the Deaf	D- Room #202 - Single Basin/drink Spout	1.2 ppb
Governor Baxter School for the Deaf	D- Room #204 - Single Basin/ Drink Spout	1.6 ppb
Governor Baxter School for the Deaf	D- Room #205 - Single Basin/ Drink Spout	0 ppb
Governor Baxter School for the Deaf	D- Room #207 - Single Basin/ Drink Spout	0 ppb
Governor Baxter School for the Deaf	D- Room #209 - Single Basin/ Drink Spout	0 ppb
Governor Baxter School for the Deaf	D-next To Exit Floor 1 - Fountain	0 ppb
Governor Baxter School for the Deaf	D-room #102 -double Basin Sink	0 ppb
Governor Baxter School for the Deaf	D-room #105-single Basin/drink Spout 1	2.3 ppb
Governor Baxter School for the Deaf	D-room #105-single Basin/drink Spout 2	0 ppb
Governor Baxter School for the Deaf	G- Hallway By Rm #26 - Fountain	11.6 ppb
Governor Baxter School for the Deaf	G- Room #22 - Single Basin Sink	559 ppb
Governor Baxter School for the Deaf	H- Main Ent. By Bathrooms - Fountain 1	2.7 ppb
Governor Baxter School for the Deaf	H- Main Ent. By Bathrooms - Fountain 2	2.1 ppb
Governor Baxter School for the Deaf	H- Room #106 - Single Basin Sink	4.9 ppb
Governor Baxter School for the Deaf	H- Room #108 - Single Basin Sink	1.9 ppb
Governor Baxter School for the Deaf	J- Anex Room #3 - Single Basin Sink	35.4 ppb
Governor Baxter School for the Deaf	J- Main Lobby - Fountain	0 ppb
Governor Baxter School for the Deaf	K-door #20 - Water Cooler	0 ppb
Governor Baxter School for the Deaf	K-main Kitchen - Coffee Machine	7.7 ppb
Governor Baxter School for the Deaf	K-main Kitchen - Double Basin Sink #1	2.8 ppb
Governor Baxter School for the Deaf	K-main Kitchen - Double Basin Sink #2	2.5 ppb
Governor Baxter School for the Deaf	K-main Kitchen - Ice Machine	0 ppb
Governor Baxter School for the Deaf	K-main Kitchen - Steamer # 1	16.7 ppb
Governor Baxter School for the Deaf	K-room #111 - Single Basin Sink	1620 ppb
Governor Baxter School for the Deaf	K-room #114 - Single Basin/drink Spout	15.8 ppb
Governor Baxter School for the Deaf	K-room #119 - Single Basin Sink	13.2 ppb
Governor James B Longley Elementary School	Bottle Filler Hall By Elev	0 ppb
Governor James B Longley Elementary School	Dish Room Bath Sink	4.9 ppb
Governor James B Longley Elementary School	Dish Room Sink	5 ppb
Governor James B Longley Elementary School	Girls Bath Lh Sink Main Hall	1.7 ppb
Governor James B Longley Elementary School	Girls Bath Rh Sink Main Hall	1 ppb

School Name	Sample Location	Lead Test Result
Governor James B Longley Elementary School	Ground Fl Water Fountain	4.2 ppb
Governor James B Longley Elementary School	Hall Water Fountain By Rm 122	0 ppb
Governor James B Longley Elementary School	Hand Wash Sink Dishroom Area	8.1 ppb
Governor James B Longley Elementary School	Kitchen 3 Bay Sink	0 ppb
Governor James B Longley Elementary School	Kitchen Corner Sink	40.5 ppb
Governor James B Longley Elementary School	Lobby Single Bath Sink	1.1 ppb
Governor James B Longley Elementary School	Lobby Staff Bath Sink	2.2 ppb
Governor James B Longley Elementary School	Mens Bath Lh Sink Main Hall	1.8 ppb
Governor James B Longley Elementary School	Mens Bath Rh Sink Main Hall	5.7 ppb
Governor James B Longley Elementary School	Rm 104 Sink	76.7 ppb
Governor James B Longley Elementary School	Rm 105 Bubbler	61.3 ppb
Governor James B Longley Elementary School	Rm 105 Sink	1.7 ppb
Governor James B Longley Elementary School	Rm 110 Staff Room Sink	2.9 ppb
Governor James B Longley Elementary School	Rm 110a Staff Bath Sink	7.5 ppb
Governor James B Longley Elementary School	Rm 111 Bubbler	39 ppb
Governor James B Longley Elementary School	Rm 111 Sink	5.3 ppb
Governor James B Longley Elementary School	Rm 113/113a Hall Bubbler	4.4 ppb
Governor James B Longley Elementary School	Rm 113/113a Hall Sink	5 ppb
Governor James B Longley Elementary School	Rm 116 Hall Bubbler	4.6 ppb
Governor James B Longley Elementary School	Rm 116 Hall Sink	11.3 ppb
Governor James B Longley Elementary School	Rm 118 Bubbler	2.7 ppb
Governor James B Longley Elementary School	Rm 118 Sink	2.6 ppb
Governor James B Longley Elementary School	Rm 123 Girls Bath Sink	3.1 ppb

School Name	Sample Location	Lead Test Result
Governor James B Longley Elementary School	Rm 125 Ladies Room Rh Sink	31.9 ppb
Governor James B Longley Elementary School	Rm 126 Mens Room Center Sink	4 ppb
Governor James B Longley Elementary School	Rm 126 Mens Room Rh Sink	1.9 ppb
Governor James B Longley Elementary School	Rm 127 Cafe Bottle Filler	0 ppb
Governor James B Longley Elementary School	Rm 127 Cafe Water Fountain	0 ppb
Governor James B Longley Elementary School	Rm 127b Sink	12.4 ppb
Governor James B Longley Elementary School	Rm 131 Library Bottle Filler	0 ppb
Governor James B Longley Elementary School	Rm 131 Library Water Fountain	0 ppb
Governor James B Longley Elementary School	Rm 134 A Sink	0 ppb
Governor James B Longley Elementary School	Rm 134 Bath Sink	0 ppb
Governor James B Longley Elementary School	Rm 135 Bath Sink	0 ppb
Governor James B Longley Elementary School	Rm 135 Sink	2 ppb
Governor James B Longley Elementary School	Rm 139 Bath Sink	2.6 ppb
Governor James B Longley Elementary School	Rm 139 Class Sink	2.9 ppb
Governor James B Longley Elementary School	Rm 140 Bath Sink	4.3 ppb
Governor James B Longley Elementary School	Rm 140 Class Sink	2.2 ppb
Governor James B Longley Elementary School	Rm 141 Gym Water Fountain	0 ppb
Governor James B Longley Elementary School	Rm 146 Office Sink	4 ppb
Governor James B Longley Elementary School	Rm 148 Sink	11.5 ppb
Governor James B Longley Elementary School	Rm 172a Sink	18.5 ppb
Governor James B Longley Elementary School	Room Left Side Of Elev Bath Sink	15.1 ppb
Governor James B Longley Elementary School	Room Right Side Of Elev Lh Sink	48.8 ppb
Governor James B Longley Elementary School	Room Right Side Of Elev Rh Sink	16 ppb

School Name	Sample Location	Lead Test Result
Governor James B Longley Elementary School	Teachers Room Back Sink	6.1 ppb
Governor James B Longley Elementary School	Teachers Room Bath Sink	4 ppb
Governor James B Longley Elementary School	Water Fountain Hall By Elev	0 ppb
Governor John Fairfield School	Drinking Water Fountain Bubbler Outside Bathroom	0 ppb
Governor John Fairfield School	Drinking Water Fountain Outside Bathroom B	0 ppb
Governor John Fairfield School	Dwf Obr	0 ppb
Governor John Fairfield School	Dwf Rm1	0 ppb
Governor John Fairfield School	Dwf Rm10	0 ppb
Governor John Fairfield School	Dwf Rm11	4.3 ppb
Governor John Fairfield School	Dwf Rm12	3 ppb
Governor John Fairfield School	Dwf Rm13	1.1 ppb
Governor John Fairfield School	Dwf Rm14	1.1 ppb
Governor John Fairfield School	Dwf Rm15	17.1 ppb
Governor John Fairfield School	Dwf Rm16	2.4 ppb
Governor John Fairfield School	Dwf Rm17	164 ppb
Governor John Fairfield School	Dwf Rm18	7.9 ppb
Governor John Fairfield School	Dwf Rm2	0 ppb
Governor John Fairfield School	Dwf Rm3	1.7 ppb
Governor John Fairfield School	Dwf Rm4	0 ppb
Governor John Fairfield School	Dwf Rm5	0 ppb
Governor John Fairfield School	Dwf Rm6	0 ppb
Governor John Fairfield School	Dwf Rm7	0 ppb
Governor John Fairfield School	Dwf Rm9	0 ppb
Governor John Fairfield School	Sink Fac Rm	0 ppb
Governor John Fairfield School	Sink Kitchen	0 ppb
Governor John Fairfield School	Sink Nurse Rm	0 ppb
Gr Portland Christian School	Drinking Water Fountain - Elem. Bottle Filler	0 ppb
Gr Portland Christian School	Drinking Water Fountain - Elementary	0 ppb
Gr Portland Christian School	Drinking Water Fountain - Gym	0 ppb
Gr Portland Christian School	Drinking Water Fountain - Gym Bottle Filler	0 ppb
Gr Portland Christian School	Drinking Water Fountain - High School	0 ppb
Gr Portland Christian School	Drinking Water Fountain - Hs Bottle Filler	0 ppb
Gr Portland Christian School	Drinking Water Fountain - Middle School	0 ppb
Gr Portland Christian School	Drinking Water Fountain - Ms Bottle Filler	0 ppb
Gr Portland Christian School	Secondary Teacher's Room Sink	3.4 ppb
Gr Portland Christian School	Spigot On Front Of Building Sports Water	42.5 ppb
Graham Lake School	Beehive (bldg 45)- Bathroom 1	0 ppb
Graham Lake School	Beehive- Bathroom 2	1.2 ppb
Graham Lake School	Beehive- Kitchenette Sink 2	1.9 ppb
Graham Lake School	Belgrade Building- Bathroom 1	0 ppb

School Name	Sample Location	Lead Test Result
Graham Lake School	Belgrade Building- Bathroom 2	0 ppb
Graham Lake School	Building 44- Bathroom 1	2.6 ppb
Graham Lake School	Building 44- Bathroom 2	3.5 ppb
Graham Lake School	Building 44- Kitchenette Sink 2	1.8 ppb
Graham Lake School	Cafeteria- Boys Bathroom Sink	1.3 ppb
Graham Lake School	Cafeteria- Girls Bathroom Sink	1.5 ppb
Graham Lake School	Cafeteria- Prep Station Sink	13.5 ppb
Graham Lake School	Cafeteria- Staff Bathroom Sink	1.8 ppb
Graham Lake School	Cfs (building 1)- Bathroom Sink	0 ppb
Graham Lake School	Cfs (building 1)- Kitchenette Sink	0 ppb
Graham Lake School	High School- Boys Bathroom	2 ppb
Graham Lake School	High School- Co-ed Bathroom	1.6 ppb
Graham Lake School	High School- Girls Bathroom	2.6 ppb
Graham Lake School	High School- Hallway Sink	0 ppb
Graham Lake School	Maintenance Bldg- Bathroom Sink	4.2 ppb
Graham Lake School	Medical Building- Nurses Sink	3 ppb
Graham Lake School	Pre-k (bldg 5)- Co-ed Bathroom 1	8.1 ppb
Graham Lake School	Pre-k (bldg 5)- Co-ed Bathroom 2	2.2 ppb
Graham Lake School	Pre-k (bldg 5)- Kitchenette 1	6.7 ppb
Graham Lake School	Pre-k (bldg 5)- Kitchenette 2	2.8 ppb
Graham Lake School	Ramsey-chamberlain-b.room Sink 1	1 ppb
Graham Lake School	Ramsey-chamberlain-b.room Snk 2	0 ppb
Graham Lake School	Ramsey-liberty- Bathroom Sink 1	34.2 ppb
Graham Lake School	Ramsey-liberty- Bathroom Sink 2	1.8 ppb
Graham Lake School	Ramsey-liberty- Office Sink	2.5 ppb
Graham Lake School	Ramsey-office-staff Kitchenette	0 ppb
Graham Lake School	Ramsey-rangely-bathroom Sink 1	0 ppb
Graham Lake School	Ramsey-rangely-bathroom Sink 2	1.1 ppb
Graham Lake School	Ramsey-schoodic- Bathroom Sink 1	0 ppb
Graham Lake School	Ramsey-schoodic- Bathroom Sink 2	1.3 ppb
Graham Lake School	Ramsey-schoodic- Staff Bathroom	0 ppb
Graham Lake School	Shop/garage-bathroom Sink	59.5 ppb
Graham Lake School	Training Building-bathroom Sink	2.1 ppb
Granite Street School	3rd Grade Room B	0 ppb
Granite Street School	3rd Grade Room C	0 ppb
Granite Street School	Art Room	17.6 ppb
Granite Street School	Bottle Fill Station By Cafeteria	0 ppb
Granite Street School	Bottle Fill Station By Main Office	0 ppb
Granite Street School	Bottle Fill Station Near Teachers Room	0 ppb
Granite Street School	Classroom #1	25.6 ppb
Granite Street School	Classroom #10	6.9 ppb
Granite Street School	Classroom #11	5.6 ppb
Granite Street School	Classroom #12	33.4 ppb
Granite Street School	Classroom #13	13.7 ppb
Granite Street School	Classroom #14	84.4 ppb
Granite Street School	Classroom #17	8.1 ppb
Granite Street School	Classroom #2	6.4 ppb

School Name	Sample Location	Lead Test Result
Granite Street School	Classroom #3	10.7 ppb
Granite Street School	Classroom #4	6.3 ppb
Granite Street School	Classroom #5	37.8 ppb
Granite Street School	Classroom #6	8.6 ppb
Granite Street School	Classroom #7	4.4 ppb
Granite Street School	Classroom #8	5.1 ppb
Granite Street School	Classroom #9	14.7 ppb
Granite Street School	Conference Room 18 Sink	4.9 ppb
Granite Street School	Kindergarten 1	3.1 ppb
Granite Street School	Kindergarten 2	4 ppb
Granite Street School	Kitchen Double Sink	3 ppb
Granite Street School	Nurses Room Sink	3.1 ppb
Granite Street School	Resource A	2 ppb
Granite Street School	Teachers Room	5 ppb
Gray-New Gloucester High School	2nd Fl Hallway Next To Boys Restroom	0 ppb
Gray-New Gloucester High School	Athletic Trainer Office Rm #144	14.9 ppb
Gray-New Gloucester High School	Boiler Room	6.8 ppb
Gray-New Gloucester High School	Cafe Lobby Next To Boys Restroom With Bubbler	0 ppb
Gray-New Gloucester High School	Cafe Lobby Next To Boys Restroom With Bubbler	0 ppb
Gray-New Gloucester High School	Concession Stand Rm #127	5.5 ppb
Gray-New Gloucester High School	Fls Rm #175 2 Handle Faucet	4.9 ppb
Gray-New Gloucester High School	Gym Lobby Entrance With Bubbler	0 ppb
Gray-New Gloucester High School	Hs Kitchen	1 ppb
Gray-New Gloucester High School	Kitchen Rm #121 2 Bay Food Prep Sink	4 ppb
Gray-New Gloucester High School	Kitchen Rm #121 3 Bay Kitchen Sink	6.9 ppb
Gray-New Gloucester High School	Kitchen Rm #121 Ice Maker	0 ppb
Gray-New Gloucester High School	Lavatory Faucet Nurse Exam Rm #104b	4.2 ppb
Gray-New Gloucester High School	Lavatory Faucet Nurse Exam Rm #104b	4.2 ppb
Gray-New Gloucester High School	Library Office	29.6 ppb
Gray-New Gloucester High School	Lower East Wing Hallway	0 ppb
Gray-New Gloucester High School	Science Wing Next To Guidance	0 ppb
Gray-New Gloucester High School	Teachers Lounge Sink	1.9 ppb
Gray-New Gloucester Middle School	2nd Fl Sink Rm# 200	5.4 ppb
Gray-New Gloucester Middle School	2nd Fl Teachers Lounge Rm #223	5.9 ppb
Gray-New Gloucester Middle School	2nd Fl Water Bottle Filler Wing C	0 ppb
Gray-New Gloucester Middle School	2nd Fl Water Bottle Filler Wing D	0 ppb
Gray-New Gloucester Middle School	Kitchen 3 Bay	0 ppb
Gray-New Gloucester Middle School	Kitchen Food Prep Sink	2.1 ppb
Gray-New Gloucester Middle School	Kitchen Pot Filler	27 ppb
Gray-New Gloucester Middle School	Library Sink	3.7 ppb
Gray-New Gloucester Middle School	Nurse Sink Rm # 101	2.2 ppb
Gray-New Gloucester Middle School	Sink Rm # 104a	3.4 ppb
Gray-New Gloucester Middle School	Sink Rm # 105	3.2 ppb

School Name	Sample Location	Lead Test Result
Gray-New Gloucester Middle School	Water Bottle Filler Outside Cafeteria	0 ppb
Gray-New Gloucester Middle School	Water Bottle Filler Outside Cafeteria	0 ppb
Gray-New Gloucester Middle School	Water Bottle Filler Wing A	0 ppb
Gray-New Gloucester Middle School	Water Bottle Filler Wing B	0 ppb
Great Falls Elementary School	B107	0 ppb
Great Falls Elementary School	B110	0 ppb
Great Falls Elementary School	B111	0 ppb
Great Falls Elementary School	B113	0 ppb
Great Falls Elementary School	B114	0 ppb
Great Falls Elementary School	B116	0 ppb
Great Falls Elementary School	B117	0 ppb
Great Falls Elementary School	B207	0 ppb
Great Falls Elementary School	B208	0 ppb
Great Falls Elementary School	B210	0 ppb
Great Falls Elementary School	B211	1.1 ppb
Great Falls Elementary School	B213	0 ppb
Great Falls Elementary School	B214	0 ppb
Great Falls Elementary School	B217	0 ppb
Great Falls Elementary School	C109	0 ppb
Great Falls Elementary School	C111	0 ppb
Great Falls Elementary School	C114	0 ppb
Great Falls Elementary School	C115	0 ppb
Great Falls Elementary School	C120	0 ppb
Great Falls Elementary School	C124	1.1 ppb
Great Falls Elementary School	C209	0 ppb
Great Falls Elementary School	C210	0 ppb
Great Falls Elementary School	C211	0 ppb
Great Falls Elementary School	C214	0 ppb
Great Falls Elementary School	C215	0 ppb
Great Falls Elementary School	C216	0 ppb
Great Falls Elementary School	Cafe-a	2.7 ppb
Great Falls Elementary School	Cafe-b	1.7 ppb
Great Falls Elementary School	Corridor Near C101-a	0 ppb
Great Falls Elementary School	Corridor Near C101-b	0 ppb
Great Falls Elementary School	Corridor Outside B204-a	0 ppb
Great Falls Elementary School	Corridor Outside B204-b	0 ppb
Great Falls Elementary School	Corridor Outside C201-a	0 ppb
Great Falls Elementary School	Corridor Outside C201-b	0 ppb
Great Falls Elementary School	K103	0 ppb
Great Falls Elementary School	K105	1.7 ppb
Great Falls Elementary School	K107	1.2 ppb
Great Falls Elementary School	K109	0 ppb
Great Falls Elementary School	K111	0 ppb
Great Falls Elementary School	K113	0 ppb
Great Falls Elementary School	Kitchen	0 ppb

School Name	Sample Location	Lead Test Result
Great Falls Elementary School	Main Lobby-a	0 ppb
Great Falls Elementary School	Main Lobby-b	0 ppb
Great Falls Elementary School	Near B104-2	0 ppb
Great Falls Elementary School	Near B104-a	0 ppb
Great Falls Elementary School	Playground Entrance-a	0 ppb
Great Falls Elementary School	Playground Entrance-b	0 ppb
Great Salt Bay Community School	Boys Lockerroom	7.3 ppb
Great Salt Bay Community School	Cafeteria	2.9 ppb
Great Salt Bay Community School	Classroom 169	3.1 ppb
Great Salt Bay Community School	Classroom 167	2.1 ppb
Great Salt Bay Community School	Classroom 171	2 ppb
Great Salt Bay Community School	Classroom 174	10.8 ppb
Great Salt Bay Community School	East Hallway / K-3	2.7 ppb
Great Salt Bay Community School	East Side Sink # 4	6.3 ppb
Great Salt Bay Community School	Girls Lockerroom	37.6 ppb
Great Salt Bay Community School	Gym	0 ppb
Great Salt Bay Community School	Ice Machine	61.8 ppb
Great Salt Bay Community School	Kitchen - Kettle	111 ppb
Great Salt Bay Community School	Kitchen Skillet	41.2 ppb
Great Salt Bay Community School	North Hallway / Main Hall	6 ppb
Great Salt Bay Community School	Nurse's Room	1.1 ppb
Great Salt Bay Community School	Outside Boilerroom / Sports Cooler	278 ppb
Great Salt Bay Community School	Room 163	3.2 ppb
Great Salt Bay Community School	Room 165	4.5 ppb
Great Salt Bay Community School	Room 166	6.2 ppb
Great Salt Bay Community School	Room 159	5.7 ppb
Great Salt Bay Community School	Room 160	9.2 ppb
Great Salt Bay Community School	Room 161	4.4 ppb
Great Salt Bay Community School	Room 162	3.4 ppb
Great Salt Bay Community School	Room 164	10.2 ppb
Great Salt Bay Community School	South Hallway / 4-5	7.9 ppb
Great Salt Bay Community School	West Hallway Jr. High	5.8 ppb
Great Salt Bay Community School	West Side Sink # 2	35.8 ppb
Great Salt Bay Community School	West Side Sink #1	14 ppb
Greater Houlton Christian Academy	1st Floor Water Fountain	2.4 ppb
Greater Houlton Christian Academy	Gym Water Fountain	1.3 ppb
Greater Houlton Christian Academy	Kitchen Faucet	2.2 ppb
Greater Houlton Christian Academy	Little Eagles Faucet Room 103	1.7 ppb
Greater Houlton Christian Academy	Pre-k Faucet Room 102	0 ppb
Greater Houlton Christian Academy	Upstairs Water Fountain	1.9 ppb
Greely High School	1st Fl Main Hlwy Boys Bth Sink #2	0 ppb
Greely High School	1st Fl Main Hlwy Boys Bth Sink #3	6.1 ppb
Greely High School	1st Fl Main Hlwy Boys Bth Sink1 By Door	0 ppb
Greely High School	1st Fl Main Hlwy Girls Bth Sink #2	0 ppb
Greely High School	1st Fl Main Hlwy Girls Bth Sink #3	1.6 ppb
Greely High School	1st Flr Main Hlwy Girls Bth Sink1 By Door	0 ppb
Greely High School	1st Staff Rest By Teachers Rm Sink	1.1 ppb

School Name	Sample Location	Lead Test Result
Greely High School	2nd Fl Boys Gang Restsink #1 By Door	0 ppb
Greely High School	2nd Fl Girls Gang Rest Sink #1 By Door	1.1 ppb
Greely High School	2nd Floor Boys Gang Restroom Sink #2	1.6 ppb
Greely High School	2nd Floor Boys Gang Restroom Sink #3	5.6 ppb
Greely High School	2nd Floor Girls Gang Restroom Sink #2	2 ppb
Greely High School	2nd Floor Girls Gang Restroom Sink #3	1.6 ppb
Greely High School	2nd Staff Rest By Teachers Rm Sink	0 ppb
Greely High School	Art Rm Sink Off Computer Room	7.9 ppb
Greely High School	Bob's Restroom Sink	4.6 ppb
Greely High School	Bottle Fountain Across From Music Rm	0 ppb
Greely High School	Bottle Fountain Main Hallway	0 ppb
Greely High School	Botto's Artroom Sink #1 By Windows	5.5 ppb
Greely High School	Botto's Artroom Sink #2	10.2 ppb
Greely High School	Botto's Artroom Sink #3	10.5 ppb
Greely High School	Botto's Artroom Sink #4 By Door	7.3 ppb
Greely High School	Boys Downstairs Locker Room Sink #1	6.4 ppb
Greely High School	Boys Downstairs Locker Room Sink #2	7.8 ppb
Greely High School	Boys Downstairs Locker Room Sink #3	4.3 ppb
Greely High School	Boys Downstairs Locker Room Sink #4	7 ppb
Greely High School	Boys Upstairs Locker Room Sink #2	12.6 ppb
Greely High School	Boys Upstairs Locker Room Sink #3	41.2 ppb
Greely High School	Boys Upstairs Lockerrm Sink #1 By Wall	51.9 ppb
Greely High School	Commons Boys Bth Sink #1 By Urinal	0 ppb
Greely High School	Commons Boys Bth Sink #2	0 ppb
Greely High School	Commons Girls Bth Sink #1 By Stall	0 ppb
Greely High School	Commons Girls Bth Sink #2	0 ppb
Greely High School	Denise Allens Room Sink	0 ppb
Greely High School	Dressing Room A Restroom Sink	5.3 ppb
Greely High School	Dressing Room B Restroom Sink	1.9 ppb
Greely High School	Dressing Room B Sink	13.4 ppb
Greely High School	Food Service 2 Bay Sink	1.6 ppb
Greely High School	Food Service Dish Room Sink	3.7 ppb
Greely High School	Food Service Hand Sink In Kitchen	0 ppb
Greely High School	Food Service Hand Sink On Serving Line	2 ppb
Greely High School	Food Service Restroom Sink	0 ppb
Greely High School	Fountain Higher One	0 ppb
Greely High School	Fountain In Pool Area	3.3 ppb
Greely High School	Fountain Lower One	0 ppb
Greely High School	Fountain Main Hlwy (next To Copy Room)	0 ppb
Greely High School	Girls Downstairs Locker Room Sink #1	7 ppb
Greely High School	Girls Downstairs Locker Room Sink #2	12.1 ppb
Greely High School	Girls Downstairs Locker Room Sink #3	4.5 ppb
Greely High School	Girls Downstairs Locker Room Sink #4	2.7 ppb
Greely High School	Girls Restroom Sink #1 By Door	4.8 ppb
Greely High School	Girls Restroom Sink #2	0 ppb
Greely High School	Girls Upstairs Locker Room Sink #2	2 ppb
Greely High School	Girls Upstairs Locker Room Sink #3	1.5 ppb

School Name	Sample Location	Lead Test Result
Greely High School	Girls Upstairs Lockerrm Sink #1 By Wall	1.5 ppb
Greely High School	Gyger Rm Sink	6.1 ppb
Greely High School	Handicap Restroom Sink	0 ppb
Greely High School	Heather Geoghans Office Sink	4.5 ppb
Greely High School	Ia Room Left Wall Sink #1	0 ppb
Greely High School	Ia Room Right Side Sink#4	4.3 ppb
Greely High School	Ia Room Sink #5	5.5 ppb
Greely High School	Ia Room Straight Ahead Sink #2	66.7 ppb
Greely High School	Ia Room Straight Ahead Sink #3	3.7 ppb
Greely High School	Kiln Room Sink	5.9 ppb
Greely High School	Library Fountain	69.5 ppb
Greely High School	Library Side Room Sink	32.2 ppb
Greely High School	Lower Water Fountain	0 ppb
Greely High School	Main Office Sink	1.4 ppb
Greely High School	Math Wing Girls Rest Sink #1 By Door	4 ppb
Greely High School	Math Wing Girls Restroom Sink #3	1.5 ppb
Greely High School	Math Wing Girls Restroom Sink # 2	1.6 ppb
Greely High School	Math Wing Mens Rest Sink #1 By Door	5.5 ppb
Greely High School	Math Wing Mens Restroom Sink #3	4.4 ppb
Greely High School	Math Wing Mens Restroom Sink #2	0 ppb
Greely High School	Mens Restroom Sink #1 By Door	1.5 ppb
Greely High School	Mens Restroom Sink #2	1.7 ppb
Greely High School	Multi Purpose Room	6.2 ppb
Greely High School	Nurses Office Bathroom Sink	3.5 ppb
Greely High School	Nurses Office Sink	4.8 ppb
Greely High School	Paul's Hlwy Girls Room Sink #1 By Stalls	1.4 ppb
Greely High School	Paul's Hlwy Girls Room Sink #2	0 ppb
Greely High School	Pauls Hlwy Mens Room Sink #1 By Door	3.1 ppb
Greely High School	Paul's Hlwy Mens Room Sink #2	5.4 ppb
Greely High School	Psyc Office Restroom Sink	2 ppb
Greely High School	Psyc Office Sink	6.5 ppb
Greely High School	Restroom Behind Stage Sink #1	0 ppb
Greely High School	Restroom Behind Stage Sink #2	0 ppb
Greely High School	Rm # 130 Sink # 9 In Closet	3.6 ppb
Greely High School	Rm # 131 Sink #2 In Back Of Room By Door	1.5 ppb
Greely High School	Rm # 132 Next Counter #3	7.9 ppb
Greely High School	Rm # 134 Back Wall Sink #8	10.1 ppb
Greely High School	Rm #130 Next Table Sink #8	20.1 ppb
Greely High School	Rm #130 Back Wall Sink #5 By Windows	5.4 ppb
Greely High School	Rm #130 Next Table In Back Sink #6	8.1 ppb
Greely High School	Rm #130 Next Table Sink #3	8.2 ppb
Greely High School	Rm #130 Next Table Sink #4	10.8 ppb
Greely High School	Rm #130 Sink #1 Up Front By White Board	19.8 ppb
Greely High School	Rm #130 Sink#2 Right Facing Back Of Room	66.4 ppb
Greely High School	Rm #130 Table- Back Left Wall, Sink #7	10.1 ppb
Greely High School	Rm #131 Sink #1 Up Front	10 ppb

School Name	Sample Location	Lead Test Result
Greely High School	Rm #131 Sink #3 Back Of Room By Windows	1.4 ppb
Greely High School	Rm #132 Counter On Right Side Sink #2	5.4 ppb
Greely High School	Rm #132 Counter, Right, Back Wall Sink #4	9.3 ppb
Greely High School	Rm #132 Next Counter On Left Sink #7	6.9 ppb
Greely High School	Rm #132 Next Counter On Left Sink #6	8.2 ppb
Greely High School	Rm #132 Sink #1 Up Front	17.7 ppb
Greely High School	Rm #133 Back Room/closet Sink #11	16.7 ppb
Greely High School	Rm #133 Counter On Left Sink #6	6.7 ppb
Greely High School	Rm #133 Counter On Left, Left Side Sink # 8	5.8 ppb
Greely High School	Rm #133 Counter Right Facing Back Sink #2	7.2 ppb
Greely High School	Rm #133 Counter Right, Left Side Sink #4	5 ppb
Greely High School	Rm #133 Next Sink #3	5.2 ppb
Greely High School	Rm #133 Next Sink #5	5.9 ppb
Greely High School	Rm #133 Next Sink #7	4.9 ppb
Greely High School	Rm #133 Next Sink #9	5.6 ppb
Greely High School	Rm #133 Sink #1 Up Font	177 ppb
Greely High School	Rm #133 Sink On Side Wall Sink #10	9.4 ppb
Greely High School	Rm #134 Left Side Next Table Sink #6	7.4 ppb
Greely High School	Rm #134 Left Side Next Table Sink #7	21.4 ppb
Greely High School	Rm #134 Left Side Table #1 Sink #5	21.1 ppb
Greely High School	Rm #134 Next Table Sink #3	6 ppb
Greely High School	Rm #134 Next Table Sink #4	7.6 ppb
Greely High School	Rm #134 Sink #1 Front By White Board	8.5 ppb
Greely High School	Rm #135 Counter Left Left Side Sink #8	2.8 ppb
Greely High School	Rm #135 Counter Left Left Side Sink #9	1.6 ppb
Greely High School	Rm #135 Counter Left Right Side Sink #6	4.8 ppb
Greely High School	Rm #135 Counter Left Right Side Sink #7	1.5 ppb
Greely High School	Rm #135 Counter On Right Side Sink #2	1.9 ppb
Greely High School	Rm #135 Counter On Right Side Sink #3	7.3 ppb
Greely High School	Rm #135 Counter Right Left Side Sink #4	6.4 ppb
Greely High School	Rm #135 Counter Right Left Side Sink #5	16.3 ppb
Greely High School	Rm #135 Sink #1 Front By Teachers Desk	4.5 ppb
Greely High School	Rm #137 From Front Left Side Sink #6	11.1 ppb
Greely High School	Rm #137 From Front Left Side Sink #7	10.4 ppb
Greely High School	Rm #137 From Front Right Side Sink #2	9.2 ppb
Greely High School	Rm #137 From Front Right Side Sink #4	12.3 ppb
Greely High School	Rm #137 From Frontleft Side Sink #8	8.1 ppb
Greely High School	Rm #137 Sink #1 By White Board	3.1 ppb
Greely High School	Rm #137 Sink #5 (back Of Room)	5.6 ppb
Greely High School	Rm #139 Restroom Sink	2.3 ppb
Greely High School	Rm #139 Sink In Kitchen	0 ppb
Greely High School	Rm #141 Sink In Front Of Room	4.6 ppb
Greely High School	Rm #142 Sink In Front Of Room	3.9 ppb
Greely High School	Rm #143 Sink #1 Right Side By Door	8.2 ppb
Greely High School	Rm #143 Sink #2 Towards Windows	25.8 ppb
Greely High School	Rm #143 Sink #4 By Teachers Desk	54.3 ppb

School Name	Sample Location	Lead Test Result
Greely High School	Rm #143 Sink #5 In Front Of Room	8.3 ppb
Greely High School	Rm#132 Counter On Right, Left Side Sink #5	18.2 ppb
Greely High School	Rm#134 Table Right Facing Back Sink #2	6.3 ppb
Greely High School	Rm#137 From Front Right Side Sink#3	8.2 ppb
Greely High School	Rm#143 Sink #3 Other Side By Windows	27.3 ppb
Greely High School	Room #136 Sink	12.3 ppb
Greely High School	Rupe's Artroom Sink #1 By Door	2.2 ppb
Greely High School	Rupe's Artroom Sink #2	8.3 ppb
Greely High School	Rupe's Artroom Sink #3	1.1 ppb
Greely High School	Rupe's Artroom Sink #4 By Windows	2.1 ppb
Greely High School	Schaefer's Large Bth Sink	2.9 ppb
Greely High School	Schaefer's Room Sink	0 ppb
Greely High School	Schaefer's Small Restroom Sink	0 ppb
Greely High School	Staff Bth Sink (near Isolation Room)	1.4 ppb
Greely High School	Staff Bth Sink (next To Nurse Ofc)	0 ppb
Greely High School	Staff Restroom Sink #1	2.2 ppb
Greely High School	Staff Restroom Sink #2	1.1 ppb
Greely High School	Teachers Lounge Sink	0 ppb
Greely High School	Teachers Room Sink	0 ppb
Greely High School	Water Fountain #1	0 ppb
Greely High School	Water Fountain 2	0 ppb
Greely High School	Water Fountain Higher One	0 ppb
Greely High School	Water Fountain Higher(near Main Ofc)	0 ppb
Greely High School	Water Fountain Lower (near Main Ofc)	0 ppb
Greely High School	Water Fountain Paul's Hlwy (low One)	1.2 ppb
Greely High School	Water Fountain With Bottle Filler #1	0 ppb
Greely High School	Water Fountain With Bottle Filler 2	0 ppb
Greely High School	Water Fountainpaul's Hlwy (high One)	0 ppb
Greely Middle School	# 2 Fountain Low One On Right	0 ppb
Greely Middle School	#1 Fountain High One On Left	0 ppb
Greely Middle School	#1 Fountain Low One On Right	0 ppb
Greely Middle School	#2 Fountain High One On Left	0 ppb
Greely Middle School	3 Basin Sink In Kitchen	0 ppb
Greely Middle School	Bottle Filler	0 ppb
Greely Middle School	Boys Home Lr Sink On Right	1.8 ppb
Greely Middle School	Boys Home Lr Sink Onleft	2.2 ppb
Greely Middle School	Boys Visitor Lr Sink On Left	2.8 ppb
Greely Middle School	Boys Visitor Lr Sink On Right	2.6 ppb
Greely Middle School	Cyr/sullivan Restroom Sink	5.9 ppb
Greely Middle School	Fountain Outside Rm #232 Leftside	0 ppb
Greely Middle School	Fountain Outside Rm #232 Rightside	0 ppb
Greely Middle School	Girls Lr On Right Sink On Left	1.2 ppb
Greely Middle School	Girls Lr On Right Sink On Right	1.7 ppb
Greely Middle School	Girls Lr Visitors Sink #1 On Left	1.8 ppb
Greely Middle School	Girls Lr Visitors Sink #2 On Right	0 ppb
Greely Middle School	Hand Sink In Kitchen	0 ppb

School Name	Sample Location	Lead Test Result
Greely Middle School	Isolation Room Restroom Sink	1.4 ppb
Greely Middle School	Nurse/guidance Isolation Rr Sink	0 ppb
Greely Middle School	Nurse's Office Sink	0 ppb
Greely Middle School	Nutrition Lab Sink By Fridge	0 ppb
Greely Middle School	Nutrition Lab Sink By Popcorn Machine	1.1 ppb
Greely Middle School	Nutrition Lab Sink On Left Side Of Room	3.3 ppb
Greely Middle School	Nutrition Lab Sink Right Of Entrance	0 ppb
Greely Middle School	Restroom #1 Grade 8	2.6 ppb
Greely Middle School	Restroom #2 Grade 8	5.7 ppb
Greely Middle School	Restroom 5th Grade Boys Sink	2.4 ppb
Greely Middle School	Restroom 5th Grade Girls Sink	0 ppb
Greely Middle School	Restroom 7th Grade Boys Sink	2 ppb
Greely Middle School	Restroom 7th Grade Girls Sink	0 ppb
Greely Middle School	Restroom 8th Grade Boys Sink	2 ppb
Greely Middle School	Restroom 8th Grade Girls Sink	0 ppb
Greely Middle School	Restroom Adult On Left	2.1 ppb
Greely Middle School	Restroom Adult On Right	1.4 ppb
Greely Middle School	Restroom Adult Sink	0 ppb
Greely Middle School	Restroom Boys Grade 6	2.2 ppb
Greely Middle School	Restroom By Maryann's Closet	0 ppb
Greely Middle School	Restroom Gender Neutral On Left	1.5 ppb
Greely Middle School	Restroom Gender Neutral On Right	2.2 ppb
Greely Middle School	Restroom Gender Neutral Student Sink	1.4 ppb
Greely Middle School	Restroom Girls Grade 6	1.5 ppb
Greely Middle School	Restroom In Kitchen	0 ppb
Greely Middle School	Restroom In Main Office	1.7 ppb
Greely Middle School	Restroom Inside Staff Prep Room	0 ppb
Greely Middle School	Restroom Mens Sink #1 By Door	0 ppb
Greely Middle School	Restroom Mens Sink #2 By Urinal	1.2 ppb
Greely Middle School	Restroom Sink	0 ppb
Greely Middle School	Restroom Womens Sink #1 By Door	3.7 ppb
Greely Middle School	Restroom Womens Sink #2 By Stalls	0 ppb
Greely Middle School	Rm # 104 1st Sink Left Of Door	0 ppb
Greely Middle School	Rm # 104 Right Sink By Window	0 ppb
Greely Middle School	Rm # 110 Bathroom Sink	1.4 ppb
Greely Middle School	Rm # 226 Sink W/fountain	0 ppb
Greely Middle School	Rm #102 Sink #1 By Door	0 ppb
Greely Middle School	Rm #102 Sink #2	0 ppb
Greely Middle School	Rm #102 Sink #3	0 ppb
Greely Middle School	Rm #103 Sink #1 By Door	0 ppb
Greely Middle School	Rm #103 Sink #2	0 ppb
Greely Middle School	Rm #103 Sink #3	0 ppb
Greely Middle School	Rm #104 Left Sink By Window	0 ppb
Greely Middle School	Rm #107 Sink	0 ppb
Greely Middle School	Rm #110 Sink	5.2 ppb
Greely Middle School	Rm #112 Sink	0 ppb
Greely Middle School	Rm #125 Sink W/fountain	0 ppb

School Name	Sample Location	Lead Test Result
Greely Middle School	Rm #126 Sink W/fountain	1.5 ppb
Greely Middle School	Rm #127 Sink W/fountain	0 ppb
Greely Middle School	Rm #128 Sink W/fountain	0 ppb
Greely Middle School	Rm #129 Sink #1 Back Wall Right To Left	0 ppb
Greely Middle School	Rm #129 Sink #2	0 ppb
Greely Middle School	Rm #129 Sink #3	1 ppb
Greely Middle School	Rm #129 Sink #4 By Windows	1.7 ppb
Greely Middle School	Rm #129 Sink W/fountain	0 ppb
Greely Middle School	Rm #131 Sink W/fountain	2.5 ppb
Greely Middle School	Rm #133 Sink Across Room	0 ppb
Greely Middle School	Rm #133 Sink By Door	0 ppb
Greely Middle School	Rm #133 Sink By Teacher's Desk	0 ppb
Greely Middle School	Rm #133 Sink By Window	0 ppb
Greely Middle School	Rm #134 Sink W/fountain	2.1 ppb
Greely Middle School	Rm #136 Sink W/fountain	3 ppb
Greely Middle School	Rm #137 Sink W/fountain	0 ppb
Greely Middle School	Rm #138 Sink W/fountain	0 ppb
Greely Middle School	Rm #139 Going Left To Right Sink #1	2.4 ppb
Greely Middle School	Rm #139 Sink #2	2.7 ppb
Greely Middle School	Rm #139 Sink #3	4.3 ppb
Greely Middle School	Rm #139 Sink #4 By Windows	6.3 ppb
Greely Middle School	Rm #139 Sink W/fountain	7.7 ppb
Greely Middle School	Rm #141 Sink W/ Fountain	0 ppb
Greely Middle School	Rm #142 Sink W/fountain	1.4 ppb
Greely Middle School	Rm #143 Sink W/fountain	1.1 ppb
Greely Middle School	Rm #147 Sink W/fountain	0 ppb
Greely Middle School	Rm #228 Sink W/fountain	0 ppb
Greely Middle School	Rm #229 2nd Sink On Leftside	0 ppb
Greely Middle School	Rm #229 3rd Sink On Leftside	0 ppb
Greely Middle School	Rm #229 4th Sink Behind Teacher's Desk	0 ppb
Greely Middle School	Rm #229 On Back Wall Right To Left	0 ppb
Greely Middle School	Rm #229 Sink W/fountain On Rightside	0 ppb
Greely Middle School	Rm #231 Sink W/fountain	0 ppb
Greely Middle School	Rm #232 Sink W/fountain	0 ppb
Greely Middle School	Rm #233 Next Sink Right Side	0 ppb
Greely Middle School	Rm #233 Next Sink W/fountain	0 ppb
Greely Middle School	Rm #233 Sink Across Room	0 ppb
Greely Middle School	Rm #233 Sink Leftside By Teachers Desk	0 ppb
Greely Middle School	Rm #233 Sink Right Side Of Door	0 ppb
Greely Middle School	Rm #236 Sink W/fountain	0 ppb
Greely Middle School	Rm #237 Sink W/fountain	0 ppb
Greely Middle School	Rm #238 Sink W/fountain	0 ppb
Greely Middle School	Rm #239 Back Wall Left To Right Sink	0 ppb
Greely Middle School	Rm #239 Left Of Room Sink W/fountain	0 ppb
Greely Middle School	Rm #239 Next Sink On Right	0 ppb
Greely Middle School	Rm #239 Sink Behind Teacher's Desk	0 ppb
Greely Middle School	Rm #244 Sink W/fountain	0 ppb

School Name	Sample Location	Lead Test Result
Greely Middle School	Rm 105 Sink Left Of Door	1.2 ppb
Greely Middle School	Rm 132 Sink With Fountain	2.6 ppb
Greely Middle School	Room #104 2nd Sink Left Of Door	1.6 ppb
Greely Middle School	Science Prep Room Sink	1.3 ppb
Greely Middle School	Sink Across From Pan Rack In Kitchen	0 ppb
Greely Middle School	Staff Prep Restroom	1.4 ppb
Greely Middle School	Staff Prep Room Sink	0 ppb
Greely Middle School	Staff Prep Sink	1.2 ppb
Greely Middle School	Teacher/staff Room Sink	0 ppb
Greely Middle School	Teachers/staff Room Restroom Sink	2.8 ppb
Greely Middle School 4-5	Boys Restroom #1	0 ppb
Greely Middle School 4-5	Boys Restroom #2	0 ppb
Greely Middle School 4-5	Boys Restroom #3	0 ppb
Greely Middle School 4-5	Boys Restroom#4	0 ppb
Greely Middle School 4-5	Fountain In Hlwy(leftside) By Rm #211	0 ppb
Greely Middle School 4-5	Fountain In Hlwy(rightside) By Rm #211	0 ppb
Greely Middle School 4-5	Girls Restroom #1	0 ppb
Greely Middle School 4-5	Girls Restroom #2	0 ppb
Greely Middle School 4-5	Girls Restroom #3	0 ppb
Greely Middle School 4-5	Girls Restroom #4	0 ppb
Greely Middle School 4-5	Restroom In Staff Prep Room	0 ppb
Greely Middle School 4-5	Restroom Main Hlwy By Elevator(gn)	1.6 ppb
Greely Middle School 4-5	Rm #202 Sink W/fountain	0 ppb
Greely Middle School 4-5	Rm #204 Sink W/fountain	0 ppb
Greely Middle School 4-5	Rm #205 Sink W/fountain	2.6 ppb
Greely Middle School 4-5	Rm #206 Sink W/fountain	0 ppb
Greely Middle School 4-5	Rm #207 Sink W/fountain	2 ppb
Greely Middle School 4-5	Rm #210 Sink #1 To Left Back Of Room	3.1 ppb
Greely Middle School 4-5	Rm #210 Sink #2 Second Sink On Left	0 ppb
Greely Middle School 4-5	Rm #210 Sink #3 Third Sink On Back Wall	0 ppb
Greely Middle School 4-5	Rm #210 Sink #4 Fourth Sink By Windows	2.1 ppb
Greely Middle School 4-5	Rm #210 Sinkw/fountain Rightside Room	7.1 ppb
Greely Middle School 4-5	Rm #212 Sink By Door Into Other Room	0 ppb
Greely Middle School 4-5	Rm #212 Sink By Main Door	0 ppb
Greely Middle School 4-5	Rm #212 Sink By Windows	0 ppb
Greely Middle School 4-5	Rm #212 Sink By Wooden Shelf	0 ppb
Greely Middle School 4-5	Rm #212 Sink W/fountain	0 ppb
Greely Middle School 4-5	Rm #214 Sink W/fountain	0 ppb
Greely Middle School 4-5	Rm #216 Sink #1 From Left To Right	0 ppb
Greely Middle School 4-5	Rm #216 Sink #4 Next To #3	0 ppb
Greely Middle School 4-5	Rm #216 Sink W/fountain	3.8 ppb
Greely Middle School 4-5	Rm #218 Sink W/fountain	0 ppb
Greely Middle School 4-5	Rm #219 Wink W/fountain	0 ppb
Greely Middle School 4-5	Rm #220 Sink W/ Fountain	2.5 ppb
Greely Middle School 4-5	Rm #221 Sink W/fountain	0 ppb
Greely Middle School 4-5	Rm #223 Sink W/fountain	0 ppb
Greely Middle School 4-5	Rm #224 Sink W/fountain	0 ppb

School Name	Sample Location	Lead Test Result
Greely Middle School 4-5	Rm 213 Sink W/fountain	0 ppb
Greely Middle School 4-5	Room #211 Sink W/fountain	0 ppb
Greely Middle School 4-5	Room #216 Sink #2 Next To #1	1.5 ppb
Greely Middle School 4-5	Room #216 Sink #3 Next To #2	0 ppb
Greely Middle School 4-5	Staff Prep Room Sink	0 ppb
Greely Middle School 4-5	Staff Room Restroom Sink	1 ppb
Greene Central School	4th/5th Boys Bathroom Faucet	0 ppb
Greene Central School	4th/5th Girls Bathroom Faucet	1 ppb
Greene Central School	Bathroom Faucet Across 106	0 ppb
Greene Central School	Bathroom Faucet Across 225	0 ppb
Greene Central School	Bathroom Faucet Across 226	0 ppb
Greene Central School	Bathroom Faucet Across 229	0 ppb
Greene Central School	Bathroom Left Faucet Across 228	0 ppb
Greene Central School	Bathroom Right Faucet Across 228	0 ppb
Greene Central School	Bottle Fill Across 228	0 ppb
Greene Central School	Bottle Fill Near 220	0 ppb
Greene Central School	Boys Bathroom Faucet Across 206	0 ppb
Greene Central School	Cafeteria Fountain	0 ppb
Greene Central School	Dishroom Handwash Sink Faucet	23.8 ppb
Greene Central School	Fountain Across 228	0 ppb
Greene Central School	Fountain Near 220	0 ppb
Greene Central School	Girls Bathroom Faucet Across 206	0 ppb
Greene Central School	Gym Bathroom Left Faucet	1.6 ppb
Greene Central School	Gym Bathroom Right Faucet	0 ppb
Greene Central School	Hallway Bottle Fill Across 125	0 ppb
Greene Central School	Hallway Fountain Across 125	0 ppb
Greene Central School	Hallway Fountain Near 209	0 ppb
Greene Central School	Kitchen 3 Bay Sink Faucet	3.9 ppb
Greene Central School	Kitchen Handwash Sink Faucet	4.3 ppb
Greene Central School	Kitchen Prep Sink Faucet	2.7 ppb
Greene Central School	Kitchen Prep Sink Spray Hose	10.6 ppb
Greene Central School	Library Boys Bathroom Faucet Left	2.5 ppb
Greene Central School	Library Boys Bathroom Faucet Right	2 ppb
Greene Central School	Library Girls Bathroom Faucet Left	1.2 ppb
Greene Central School	Library Girls Bathroom Faucet Right	1.6 ppb
Greene Central School	Music Room Faucet	1.2 ppb
Greene Central School	Music Room Fountain	0 ppb
Greene Central School	Nurse Office Bathroom Faucet	0 ppb
Greene Central School	Nurse Office Handwash Sink Faucet	0 ppb
Greene Central School	Room 110 Bathroom Faucet	0 ppb
Greene Central School	Room 110 Work Room Faucet	18.4 ppb
Greene Central School	Room 111 Staff Room Faucet	0 ppb
Greene Central School	Room 116 Library Office Faucet	2.5 ppb
Greene Central School	Room 147 Faucet	0 ppb
Greene Central School	Room 148 Faucet	0 ppb
Greene Central School	Room 149 Faucet	0 ppb
Greene Central School	Room 150 Faucet	0 ppb

School Name	Sample Location	Lead Test Result
Greene Central School	Room 151 Faucet	0 ppb
Greene Central School	Room 152 Faucet	0 ppb
Greene Central School	Room 153 Faucet	0 ppb
Greene Central School	Room 154 Faucet	0 ppb
Greene Central School	Room 204 Faucet Left	1.4 ppb
Greene Central School	Room 204 Faucet Right	0 ppb
Greene Central School	Room 208 Faucet	0 ppb
Greene Central School	Room 217 Faucet	0 ppb
Greene Central School	Room 220 Faucet	16.2 ppb
Greene Central School	Room 224 Faucet	0 ppb
Greene Central School	Staff Bathroom Faucet Across 215	1.2 ppb
Greene Central School	Staff Bathroom Faucet Across 225	0 ppb
Greene Central School	Staff Bathroom Faucet Near 232	0 ppb
Greenville Consolidated School	Ad Office Sink	129 ppb
Greenville Consolidated School	Basement Bottle Fill Station By Kitchen	0 ppb
Greenville Consolidated School	Basement Drinking Fountain By Art Room	0 ppb
Greenville Consolidated School	Bottle Fill Station 1st Floor By Boys Bathroom	0 ppb
Greenville Consolidated School	Bottle Fill Station Floor 2 By Boys Bathroom	0 ppb
Greenville Consolidated School	Bottle Fill Station Gym	0 ppb
Greenville Consolidated School	Boys Bathroom 1st Floor Left Sink	5.1 ppb
Greenville Consolidated School	Boys Bathroom 1st Floor Right Sink	8.9 ppb
Greenville Consolidated School	Boys Bathroom Left Sink Floor 2	51.9 ppb
Greenville Consolidated School	Boys Bathroom Right Sink Floor 2	9.4 ppb
Greenville Consolidated School	Boys Locker Room Sink	21.9 ppb
Greenville Consolidated School	Carla Bathroom Sink	7.2 ppb
Greenville Consolidated School	Drinking Fountain 1st Floor By Girls Bathroom	0 ppb
Greenville Consolidated School	Drinking Fountain Floor 2 By Girls Bathroom	0 ppb
Greenville Consolidated School	Girls Bathroom 1st Floor Left Sink	11.5 ppb
Greenville Consolidated School	Girls Bathroom 1st Floor Right Sink	74 ppb
Greenville Consolidated School	Girls Bathroom Floor 2 Left Sink	28.1 ppb
Greenville Consolidated School	Girls Bathroom Floor 2 Right Sink	5 ppb
Greenville Consolidated School	Girls Locker Room Sink	14.7 ppb
Greenville Consolidated School	Gym Teacher Office Sink	20.2 ppb
Greenville Consolidated School	Kitchen 3 Bay Sink Left Faucet	3.6 ppb
Greenville Consolidated School	Kitchen 3 Bay Sink Right Faucet	4 ppb
Greenville Consolidated School	Nurse Office Sink	46.5 ppb
Greenville Consolidated School	Outside Spigot West Side Of Gym	3220 ppb
Greenville Consolidated School	Room # 13 One Bay Sink	132 ppb
Greenville Consolidated School	Superintendent Bathroom Sink	43.8 ppb
Greenville Consolidated School	Teacher Room Sink	38.7 ppb
Guy E Rowe School	173 Teachers Coffee Fill	7.9 ppb
Guy E Rowe School	176 Teachers Coffee Fill	4.8 ppb
Guy E Rowe School	236. Classroom Upstairs	13.2 ppb

School Name	Sample Location	Lead Test Result
Guy E Rowe School	Fountain Outside Room 106	1.9 ppb
Guy E Rowe School	Fountain Outside Room 126	2.4 ppb
Guy E Rowe School	Gym	5.7 ppb
Guy E Rowe School	Hall By The Main Office	0 ppb
Guy E Rowe School	Kitchen	9.8 ppb
Guy E Rowe School	Music Room	0 ppb
Guy E Rowe School	Nurse Station	4.2 ppb
Guy E Rowe School	Outside Of The Girls Bathroom	0 ppb
Guy E Rowe School	Outside Room 203 Fountain	0 ppb
Guy E Rowe School	Pre K Room #2	3 ppb
Guy E Rowe School	Pre-k	5.6 ppb
Guy E Rowe School	Room 104	4.7 ppb
Guy E Rowe School	Room 122	25 ppb
Guy E Rowe School	Room 125	29.9 ppb
Guy E Rowe School	Room 126	4.7 ppb
Guy E Rowe School	Room 137	8.6 ppb
Guy E Rowe School	Room 138	89.2 ppb
Guy E Rowe School	Room 139	29.7 ppb
Guy E Rowe School	Room 152 Double Sink	4.6 ppb
Guy E Rowe School	Room 152 Small Sink	35.8 ppb
Guy E Rowe School	Room 203 Fountain	8 ppb
Guy E Rowe School	Room 216	19.4 ppb
Guy E Rowe School	Room 217	29.7 ppb
Guy E Rowe School	Room 218	15.4 ppb
Guy E Rowe School	Room 220	16.7 ppb
Guy E Rowe School	Room 221	26 ppb
Guy E Rowe School	Room 222	11.7 ppb
Guy E Rowe School	Room 223	14.3 ppb
H B Emery Jr Memorial School	Bottle Fill By Custodial Room	0 ppb
H B Emery Jr Memorial School	Faucet 1 In Art Room	4.5 ppb
H B Emery Jr Memorial School	Faucet 2 In Art Room	9.3 ppb
H B Emery Jr Memorial School	Faucet In Staff Room	0 ppb
H B Emery Jr Memorial School	Faucet Room 11	2.6 ppb
H B Emery Jr Memorial School	Faucet Room 21	4.8 ppb
H B Emery Jr Memorial School	Faucet Room 22	2.9 ppb
H B Emery Jr Memorial School	Faucet Room 3	8.2 ppb
H B Emery Jr Memorial School	Faucet Room 5	6.8 ppb
H B Emery Jr Memorial School	Faucet Room 6	4.5 ppb
H B Emery Jr Memorial School	Faucet Room 7	1.8 ppb
H B Emery Jr Memorial School	Faucet Room 8	3.7 ppb
H B Emery Jr Memorial School	Fountain By Custodial Room	0 ppb
H B Emery Jr Memorial School	Fountain In Cafeteria	0 ppb
H B Emery Jr Memorial School	Fountain Room 21	10.9 ppb
H B Emery Jr Memorial School	Fountain Room 22	10.5 ppb
H B Emery Jr Memorial School	Fountain Room 3	19.8 ppb
H B Emery Jr Memorial School	Fountain Room 5	19.4 ppb
H B Emery Jr Memorial School	Fountain Room 6	8.8 ppb

School Name	Sample Location	Lead Test Result
H B Emery Jr Memorial School	Fountain Room 7	7.8 ppb
H B Emery Jr Memorial School	Fountain Room 8	6.2 ppb
H B Emery Jr Memorial School	High Fountain In Hallway	0 ppb
H B Emery Jr Memorial School	Kitchen Prep Sink	20.5 ppb
H B Emery Jr Memorial School	Low Fountain In Hallway	0 ppb
Hall-Dale Elementary School	002 Copy Room Offic Sink	0 ppb
Hall-Dale Elementary School	101 Right Side Wall	0 ppb
Hall-Dale Elementary School	102 Left Side Wall	0 ppb
Hall-Dale Elementary School	103 Right Side Center Wall	0 ppb
Hall-Dale Elementary School	105 Right Side Center Wall	0 ppb
Hall-Dale Elementary School	106 Left Side Center Wall	0 ppb
Hall-Dale Elementary School	107 Right Side Center Wall	0 ppb
Hall-Dale Elementary School	108 Left Side Center Wall	0 ppb
Hall-Dale Elementary School	109 Left Center Wall	2.7 ppb
Hall-Dale Elementary School	110 Right Center Wall	0 ppb
Hall-Dale Elementary School	111 Right Center Wall	0 ppb
Hall-Dale Elementary School	115 Center Left- Teachers Lounge	0 ppb
Hall-Dale Elementary School	122 Gang Bathroom By Gym- Left Center	0 ppb
Hall-Dale Elementary School	123 Gang Bathroom By Gym- Right Center	0 ppb
Hall-Dale Elementary School	129 Art Room (left Side) A	0 ppb
Hall-Dale Elementary School	129 Art Room (left Side) B	0 ppb
Hall-Dale Elementary School	129 Art Room (left Side) C	0 ppb
Hall-Dale Elementary School	132 Nurses Bathroom Sink (right)	0 ppb
Hall-Dale Elementary School	132 Nurses Sink (left Side)	1.5 ppb
Hall-Dale Elementary School	201- Right Corner Wall	0 ppb
Hall-Dale Elementary School	202- Right Corner Wall	0 ppb
Hall-Dale Elementary School	203- Right Corner Wall	0 ppb
Hall-Dale Elementary School	204- Right Corner Wall	0 ppb
Hall-Dale Elementary School	205- Right Corner Wall	0 ppb
Hall-Dale Elementary School	206- Right Corner Wall	0 ppb
Hall-Dale Elementary School	207- Right Corner Wall	0 ppb
Hall-Dale Elementary School	208- Right Corner Wall	0 ppb
Hall-Dale Elementary School	209- Right Corner Wall	0 ppb
Hall-Dale Elementary School	221- Bathroom Center- Bottler Filler	0 ppb
Hall-Dale Elementary School	221- Bathroom Center- Fountain	0 ppb
Hall-Dale Elementary School	Cafeteria Right Side (handwash Area)	1.1 ppb
Hall-Dale Elementary School	Hallway By Music Room-fountain	0 ppb
Hall-Dale Elementary School	Kitchen- 2 Emergency Eye Wash- Center A	2.1 ppb
Hall-Dale Elementary School	Kitchen- 2 Emergency Eye Wash- Center B	1.4 ppb
Hall-Dale Elementary School	Kitchen- Center Wall Sink	1.3 ppb
Hall-Dale Elementary School	Kitchen- Left Wall Sink	2.4 ppb
Hall-Dale Elementary School	Kitchen- Right Side Center	4.1 ppb
Hall-Dale Middle and High School	Bottle Fill/ Fountain By Ms Nurse Office	0 ppb
Hall-Dale Middle and High School	Bottle Fill/ Fountain By Rm 100 Hs	0 ppb
Hall-Dale Middle and High School	Bottle Fill/ Fountain By Rm 201 Hs	0 ppb
Hall-Dale Middle and High School	Bottle Fill/ Fountain Hs Gym Coridor	0 ppb
Hall-Dale Middle and High School	Bottle Fill/ Fountain Ms Gym Corridor	0 ppb

School Name	Sample Location	Lead Test Result
Hall-Dale Middle and High School	Bottle Fill/ Fountain Ms Lower Corridor	0 ppb
Hall-Dale Middle and High School	Bottle Fill/ Fountain Ms Upper Corridor	0 ppb
Hall-Dale Middle and High School	Coffee Machine Kitchen Sink- Left	2.3 ppb
Hall-Dale Middle and High School	Double Sink Back Island Hs Rm 99	5.1 ppb
Hall-Dale Middle and High School	Double Sink Front Island Hs Rm 99	1.6 ppb
Hall-Dale Middle and High School	Double Sink Kitchen By Dishwasher- Left	4.8 ppb
Hall-Dale Middle and High School	Double Sink Left Wall Hs Rm 99	4 ppb
Hall-Dale Middle and High School	Double Sink- Nurses Office	1.4 ppb
Hall-Dale Middle and High School	Double Sink Rear Wall Hs Rm 99	5.4 ppb
Hall-Dale Middle and High School	Hs 1st Floor Boys Rr Sink- Left	4.7 ppb
Hall-Dale Middle and High School	Hs 1st Floor Boys Rr Sink- Right	3.3 ppb
Hall-Dale Middle and High School	Hs 1st Floor Girls Rr Sink- Left	4 ppb
Hall-Dale Middle and High School	Hs 1st Floor Girls Rr Sink- Right	4.5 ppb
Hall-Dale Middle and High School	Hs 1st Floor Staff Rr Sink	1.9 ppb
Hall-Dale Middle and High School	Hs 2nd Floor Boys Rr Sink- Left	2.7 ppb
Hall-Dale Middle and High School	Hs 2nd Floor Boys Rr Sink- Right	2.7 ppb
Hall-Dale Middle and High School	Hs 2nd Floor Girls Rr Sink- Left	3.2 ppb
Hall-Dale Middle and High School	Hs 2nd Floor Girls Rr Sink- Right	3.4 ppb
Hall-Dale Middle and High School	Hs 2nd Floor Staff Rr Sink	2.1 ppb
Hall-Dale Middle and High School	Hs Art Room Deep Sink	2.1 ppb
Hall-Dale Middle and High School	Hs Boys Locker Rm Left Sink	1.9 ppb
Hall-Dale Middle and High School	Hs Boys Locker Rm Right Sink	1.3 ppb
Hall-Dale Middle and High School	Hs Girls Locker Rm Center Sink	5.3 ppb
Hall-Dale Middle and High School	Hs Girls Locker Rm Right Sink	3 ppb
Hall-Dale Middle and High School	Hs Girls Lockers Rm Left Sink	90.6 ppb
Hall-Dale Middle and High School	Hs Gym Corridor Boys Rr Left Sink	11.3 ppb
Hall-Dale Middle and High School	Hs Gym Corridor Boys Rr Right Sink	2.1 ppb
Hall-Dale Middle and High School	Hs Gym Corridor Girls Rr Left Sink	2.1 ppb
Hall-Dale Middle and High School	Hs Gym Corridor Girls Rr Right Sink	5.2 ppb
Hall-Dale Middle and High School	Hs Lab Rm 212 Front Island Sink	12.4 ppb
Hall-Dale Middle and High School	Hs Lab Rm 212 Left Center Sink	7.6 ppb
Hall-Dale Middle and High School	Hs Lab Rm 212 Left Front Sink	8.3 ppb
Hall-Dale Middle and High School	Hs Lab Rm 212 Left Rear Sink	7 ppb
Hall-Dale Middle and High School	Hs Lab Rm 212 Right Center Sink	5.7 ppb
Hall-Dale Middle and High School	Hs Lab Rm 212 Right Front Sink	271 ppb
Hall-Dale Middle and High School	Hs Lab Rm 212 Right Rear Sink	8.4 ppb
Hall-Dale Middle and High School	Hs Lab Rm 213 Island Sink	4.6 ppb
Hall-Dale Middle and High School	Hs Lab Rm 213 Left Wall 2nd Sink	19.5 ppb
Hall-Dale Middle and High School	Hs Lab Rm 213 Left Wall 3rd Sink	14.6 ppb
Hall-Dale Middle and High School	Hs Lab Rm 213 Left Wall 4th Sink	19.6 ppb
Hall-Dale Middle and High School	Hs Lab Rm 213 Left Wall First Sink	21.1 ppb
Hall-Dale Middle and High School	Hs Lab Rm 213 Right Wall By Door Sink	1.2 ppb
Hall-Dale Middle and High School	Hs Lab Rm 214 Left Wall 1st Sink	7.3 ppb
Hall-Dale Middle and High School	Hs Lab Rm 214 Left Wall 2nd Sink	8.7 ppb
Hall-Dale Middle and High School	Hs Lab Rm 214 Left Wall 3rd Sink	7.3 ppb
Hall-Dale Middle and High School	Hs Lab Rm 214 Left Wall 4th Sink	14 ppb
Hall-Dale Middle and High School	Library Office Sink	0 ppb

School Name	Sample Location	Lead Test Result
Hall-Dale Middle and High School	Ms Art Rm Left Double Sink	3.7 ppb
Hall-Dale Middle and High School	Ms Art Rm Right Double Sink	2.5 ppb
Hall-Dale Middle and High School	Ms Boys Locker Rm Left Sink	3.8 ppb
Hall-Dale Middle and High School	Ms Boys Locker Rm Right Sink	2.7 ppb
Hall-Dale Middle and High School	Ms Boys Lower Rr Sink Left	1.8 ppb
Hall-Dale Middle and High School	Ms Boys Lower Rr Sink Right	2 ppb
Hall-Dale Middle and High School	Ms Coaches Office Sink	10.7 ppb
Hall-Dale Middle and High School	Ms Girls Lock Rm Left Sink	2 ppb
Hall-Dale Middle and High School	Ms Girls Locker Rm Right Sink	1.9 ppb
Hall-Dale Middle and High School	Ms Girls Lower Rr Sink Left	1.8 ppb
Hall-Dale Middle and High School	Ms Girls Lower Rr Sink Right	1.8 ppb
Hall-Dale Middle and High School	Ms Girls Rr Center Sink	1.7 ppb
Hall-Dale Middle and High School	Ms Girls Rr Left Sink	2.1 ppb
Hall-Dale Middle and High School	Ms Girls Rr Right Sink	2.2 ppb
Hall-Dale Middle and High School	Ms Left Rr Sink By Band Rm	3.7 ppb
Hall-Dale Middle and High School	Ms Right Rr Sink By Band Rm	4.7 ppb
Hall-Dale Middle and High School	Ms Rm 105 Double Sink	1.4 ppb
Hall-Dale Middle and High School	Ms Rm 106 Sink	2.2 ppb
Hall-Dale Middle and High School	Ms Rm 202 Double Sink	2.3 ppb
Hall-Dale Middle and High School	Ms Rm 204 Sink	1.3 ppb
Hall-Dale Middle and High School	Ms Rm 207 Double Sink	2 ppb
Hall-Dale Middle and High School	Ms Rm 209 Sink	0 ppb
Hall-Dale Middle and High School	Ms Rm 210 Sink	17.2 ppb
Hall-Dale Middle and High School	Ms Rm 219 Rr Sink	1.9 ppb
Hall-Dale Middle and High School	Ms Rm 219 Sink	0 ppb
Hall-Dale Middle and High School	Ms Staff Rr Sink By Office	1.1 ppb
Hall-Dale Middle and High School	Ms Staff Rr Sink By Rm 204	3.2 ppb
Hall-Dale Middle and High School	Ms Upstair Boys Rr Center Sink	3.4 ppb
Hall-Dale Middle and High School	Ms Upstair Boys Rr Left Sink	2 ppb
Hall-Dale Middle and High School	Ms Upstair Boys Rr Right Sink	91.2 ppb
Hall-Dale Middle and High School	Spigot By Ice Machine Closet Boys Hs Locker Hall	6.2 ppb
Hall-Dale Middle and High School	Spigot Outside North Facing Tennis Court	12.3 ppb
Hall-Dale Middle and High School	Teachers Rm Sink Hs Rm 100	3.8 ppb
Hampden Academy	Dining Commons Drinking Fountain	0 ppb
Hampden Academy	Dish Room Sink	0 ppb
Hampden Academy	Guidence Drinking Fountain	0 ppb
Hampden Academy	Kitchen Ice Maker	0 ppb
Hampden Academy	Prep Sink @ Oven Area	0 ppb
Hampden Academy	Prep Sink @ Salad Bar Area	2.3 ppb
Hampden Academy	Room 1104 Administration Break Room	0 ppb
Hampden Academy	Room 1129 Nurse Break Room	0 ppb
Hampden Academy	Room 116 - Sped - Freshman	0 ppb
Hampden Academy	Room 133 - Alt Ed Classroom	0 ppb
Hampden Academy	Room 134 - Life Skill Classroom	0 ppb
Hampden Academy	Room 144 - Teacher Break Room	0 ppb
Hampden Academy	Room 145 -1 @ Fridge - Consumer Science	1.7 ppb

School Name	Sample Location	Lead Test Result
Hampden Academy	Room 145-2 Asile 1	1.5 ppb
Hampden Academy	Room 145-3 Asile 1	1.1 ppb
Hampden Academy	Room 145-4 Asile 1	1.2 ppb
Hampden Academy	Room 145-5 Asile 2	1.1 ppb
Hampden Academy	Room 145-6 Asile 2	2.5 ppb
Hampden Academy	Room 145-7 Asile 2	0 ppb
Hampden Academy	Room 147-1 North	0 ppb
Hampden Academy	Room 147-2 East	0 ppb
Hampden Academy	Room 152 Fitness Room	0 ppb
Hampden Academy	Room 179e Athletic Trainer Sink	7 ppb
Hampden Academy	Room 179e Athletic Trainer Ice Maker	0 ppb
Hampden Academy	Room 182 Band Room	1 ppb
Hampden Academy	Room 183 Music/choir Room	0 ppb
Hampden Academy	Room 2107 Library Break Room	0 ppb
Hampden Academy	Room 2107 Library Garage	0 ppb
Hampden Academy	Room 2219 Learning Center	2.9 ppb
Hampden Academy	Room 230 Study Hall Room	1 ppb
Hampden Academy	Room 244 Teacher Break Room	0 ppb
Hancock County Technical Center	Carpentry Hallway	6 ppb
Hancock County Technical Center	Diesel Tech Classroom	8.6 ppb
Hancock County Technical Center	Down Stairs Hallway Fountain	16.9 ppb
Hancock County Technical Center	Early Childhood Kitchenette	10.3 ppb
Hancock County Technical Center	Kitchen Ice Machine	0 ppb
Hancock County Technical Center	Kitchen Sink 1	14.9 ppb
Hancock County Technical Center	Kitchen Sink 2	14.1 ppb
Hancock County Technical Center	Office Kitchenette	7.9 ppb
Hancock County Technical Center	Upstairs Hallway Fountain	14.1 ppb
Hancock Grammar School	Drinking Fountain By Main Entrance	0 ppb
Hancock Grammar School	Drinking Fountain By Staff Lounge	0 ppb
Hancock Grammar School	Drinking Fountain Class 15/16	0 ppb
Hancock Grammar School	Drinking Fountain Gym	0 ppb
Hancock Grammar School	Kitchen Handwashing Sink	16.4 ppb
Hancock Grammar School	Kitchen Sink	2.1 ppb
Hancock Grammar School	Sink By Main Entrance	8.3 ppb
Hancock Grammar School	Sink In Staff Lounge	2.9 ppb
Hancock Grammar School	Water Cooler Staff Lounge	0 ppb
Hanson School	Art Room Sink #1	2.5 ppb
Hanson School	Art Room Sink #2	2.6 ppb
Hanson School	Cafe Drinking Fountain	0 ppb
Hanson School	Classroom #1 Sink/bubbler	41 ppb
Hanson School	Classroom #10 Sink/bubbler	0 ppb
Hanson School	Classroom #11 Sink/bubbler	0 ppb
Hanson School	Classroom #12 Sink/bubbler	0 ppb
Hanson School	Classroom #13 Sink/bubbler	0 ppb
Hanson School	Classroom #2 Sink/bubbler	8.2 ppb
Hanson School	Classroom #23 Sink/bubbler	7.1 ppb
Hanson School	Classroom #24 Sink/bubbler	1.2 ppb

School Name	Sample Location	Lead Test Result
Hanson School	Classroom #25 Sink/bubbler	5 ppb
Hanson School	Classroom #27 Sink/bubbler	30.5 ppb
Hanson School	Classroom #28 Sink/bubbler	44.2 ppb
Hanson School	Classroom #29 Sink/bubbler	4.6 ppb
Hanson School	Classroom #3 Sink/bubbler	6 ppb
Hanson School	Classroom #30 Sink/bubbler	4.4 ppb
Hanson School	Classroom #31 Sink/bubbler	2 ppb
Hanson School	Classroom #32 Sink	7 ppb
Hanson School	Classroom #4 Sink/bubbler	49.7 ppb
Hanson School	Classroom #5 Sink/bubbler	39.8 ppb
Hanson School	Classroom #6 Sink/bubbler	72.5 ppb
Hanson School	Classroom #7 Sink/bubbler	9.7 ppb
Hanson School	Kindergarten Hallway Drinking Fountain	0 ppb
Hanson School	Kitchen Prep Sink #1	3.5 ppb
Hanson School	Kitchen Prep Sink #2	4.4 ppb
Hanson School	Kitchen Prep Sink #3	3 ppb
Hanson School	Kitchen Steam Kettle	2.1 ppb
Hanson School	Library Sink	3.7 ppb
Hanson School	Main Lobby Drinking Fountain	0 ppb
Hanson School	Music Room Sink/bubbler	2.3 ppb
Hanson School	Nurse Sink	3.5 ppb
Hanson School	Principal Office Sink	39.5 ppb
Hanson School	Room #22 Excel	6.8 ppb
Hanson School	Second Floor Hallway Fountain #1	0 ppb
Hanson School	Second Floor Hallway Fountain #2	0 ppb
Hanson School	Teachers Room Sink	7.8 ppb
Harmony Elementary	Kitchen Double Sink	2.7 ppb
Harmony Elementary	Kitchen Handwash Sink	2.1 ppb
Harmony Elementary	Office Bathroom Sink	1.7 ppb
Harmony Elementary	Teachers Lounge	2.2 ppb
Harmony Elementary	Wbfs-next To Boys Bathroom	0 ppb
Harmony Elementary	Wbfs-next To Girls Bathroom	0 ppb
Harpswell Community School	1 Kitchen Hand Wash Sink	17.4 ppb
Harpswell Community School	10 Water Fountain Gym	0 ppb
Harpswell Community School	12 Water Fountain Gym	2.2 ppb
Harpswell Community School	2 Kitchen Prep Sink	8.7 ppb
Harpswell Community School	20 Fridge Ice Machine	0 ppb
Harpswell Community School	21 Kitchen Faucet Staff Room	2.7 ppb
Harpswell Community School	22 Room 8 Kitchen Faucet	3.1 ppb
Harpswell Community School	23 Water Fountain	4.2 ppb
Harpswell Community School	27 Water Fountain	6.3 ppb
Harpswell Community School	3 Kitchen Dishwasher Sprayer	0 ppb
Harpswell Community School	32 Room 14 Kitchen Faucet	0 ppb
Harpswell Community School	33 Room 14 Water Fountain	1.7 ppb
Harpswell Community School	36 Spigot	11.8 ppb
Harpswell Community School	37 Spigot	16.4 ppb
Harpswell Community School	38 Spigot	45.7 ppb

School Name	Sample Location	Lead Test Result
Harpswell Community School	8 Water Fountain Gym	0 ppb
Harpswell Community School	9 Nurses Room Faucet	2.2 ppb
Harriet Beecher Stowe Elementary	2nd Floor West End Corridor	0 ppb
Harriet Beecher Stowe Elementary	2nd Floor West End Corridor Hc	0 ppb
Harriet Beecher Stowe Elementary	Bottle Fill Outside #120	0 ppb
Harriet Beecher Stowe Elementary	Bottle Fill Outside #201	1 ppb
Harriet Beecher Stowe Elementary	Classroom 100a	0 ppb
Harriet Beecher Stowe Elementary	Classroom 100a #2	0 ppb
Harriet Beecher Stowe Elementary	Classroom 100b	2.6 ppb
Harriet Beecher Stowe Elementary	Common Area	0 ppb
Harriet Beecher Stowe Elementary	Common Area 2nd Floor	0 ppb
Harriet Beecher Stowe Elementary	Common Area 2nd Floor Hc	0 ppb
Harriet Beecher Stowe Elementary	Common Area Hc	0 ppb
Harriet Beecher Stowe Elementary	Corridor Outside Library	3.6 ppb
Harriet Beecher Stowe Elementary	Corridor Outside Library Hc	0 ppb
Harriet Beecher Stowe Elementary	Cr 102	0 ppb
Harriet Beecher Stowe Elementary	Cr 105	0 ppb
Harriet Beecher Stowe Elementary	Cr 107	0 ppb
Harriet Beecher Stowe Elementary	Cr 111	0 ppb
Harriet Beecher Stowe Elementary	Cr 113	0 ppb
Harriet Beecher Stowe Elementary	Cr 115	0 ppb
Harriet Beecher Stowe Elementary	Cr 117	0 ppb
Harriet Beecher Stowe Elementary	Cr 118	0 ppb
Harriet Beecher Stowe Elementary	Cr 119	0 ppb
Harriet Beecher Stowe Elementary	Cr 121	3.5 ppb
Harriet Beecher Stowe Elementary	Cr 125	0 ppb
Harriet Beecher Stowe Elementary	Cr 127	0 ppb
Harriet Beecher Stowe Elementary	Cr 201	0 ppb
Harriet Beecher Stowe Elementary	Cr 202	0 ppb
Harriet Beecher Stowe Elementary	Cr 203	0 ppb
Harriet Beecher Stowe Elementary	Cr 204	0 ppb
Harriet Beecher Stowe Elementary	Cr 205	0 ppb
Harriet Beecher Stowe Elementary	Cr 206	0 ppb
Harriet Beecher Stowe Elementary	Cr 207	0 ppb
Harriet Beecher Stowe Elementary	Cr 208	0 ppb
Harriet Beecher Stowe Elementary	Cr 209	0 ppb
Harriet Beecher Stowe Elementary	Cr 210	1.3 ppb
Harriet Beecher Stowe Elementary	Cr 211	0 ppb
Harriet Beecher Stowe Elementary	Cr 212	0 ppb
Harriet Beecher Stowe Elementary	Cr 213	1.4 ppb
Harriet Beecher Stowe Elementary	Cr 215	0 ppb
Harriet Beecher Stowe Elementary	Cr 218	0 ppb
Harriet Beecher Stowe Elementary	Cr 219	0 ppb
Harriet Beecher Stowe Elementary	Cr 220	0 ppb
Harriet Beecher Stowe Elementary	Cr 222	0 ppb
Harriet Beecher Stowe Elementary	Cr 224	0 ppb
Harriet Beecher Stowe Elementary	Cr 226	0 ppb

School Name	Sample Location	Lead Test Result
Harriet Beecher Stowe Elementary	Cr103	0 ppb
Harriet Beecher Stowe Elementary	Cr109	0 ppb
Harriet Beecher Stowe Elementary	Cr217	0 ppb
Harriet Beecher Stowe Elementary	Gym Outside Locker Rooms	0 ppb
Harriet Beecher Stowe Elementary	Gym Outside Locker Rooms Hc	0 ppb
Harriet Beecher Stowe Elementary	Kitchen Food Prep Area	0 ppb
Harriet Beecher Stowe Elementary	Kitchenette Room 101e	2.5 ppb
Harriet Beecher Stowe Elementary	Library Kithenette	0 ppb
Harriet Beecher Stowe Elementary	Main Lobby North Wall	0 ppb
Harriet Beecher Stowe Elementary	Main Lobby North Wall Bottle Fill	0 ppb
Harriet Beecher Stowe Elementary	Main Lobby North Wall Hc	0 ppb
Harriet Beecher Stowe Elementary	Rm 114 Teacher Lounge	0 ppb
Harriet Beecher Stowe Elementary	West End Corridor Outside Bathroom 5	0 ppb
Harriet Beecher Stowe Elementary	West End Corridor Outside Bathroom Hc	0 ppb
Harrington Elementary School	1st Floor Drinking Water Fountain	0 ppb
Harrington Elementary School	2nd Floor Drinking Water Fountain	0 ppb
Harrington Elementary School	Gym Drinking Water Fountain	0 ppb
Harrington Elementary School	Kitchen Food Prep Sink	2.9 ppb
Harrison Elementary	1st Floor Lobby	0 ppb
Harrison Elementary	Gym	0 ppb
Harrison Elementary	Library 201	3.6 ppb
Harrison Elementary	Room 100	1.4 ppb
Harrison Elementary	Room 101	1.9 ppb
Harrison Elementary	Room 102	5.9 ppb
Harrison Elementary	Room 103	1.4 ppb
Harrison Elementary	Room 104	1.2 ppb
Harrison Elementary	Room 105	2.5 ppb
Harrison Elementary	Room 202	2 ppb
Harrison Elementary	Room 203	2.6 ppb
Harrison Elementary	Room 204	2.5 ppb
Harrison Elementary	Room 205	1.5 ppb
Harrison Elementary	Room 206	6 ppb
Harrison Lyseth Elem School	1	0 ppb
Harrison Lyseth Elem School	15	0 ppb
Harrison Lyseth Elem School	16	0 ppb
Harrison Lyseth Elem School	17	1.4 ppb
Harrison Lyseth Elem School	18	0 ppb
Harrison Lyseth Elem School	19	0 ppb
Harrison Lyseth Elem School	2	0 ppb
Harrison Lyseth Elem School	20	0 ppb
Harrison Lyseth Elem School	21	0 ppb
Harrison Lyseth Elem School	22	0 ppb
Harrison Lyseth Elem School	24	0 ppb
Harrison Lyseth Elem School	25	0 ppb
Harrison Lyseth Elem School	26	0 ppb
Harrison Lyseth Elem School	27	1.6 ppb
Harrison Lyseth Elem School	28	7.3 ppb

School Name	Sample Location	Lead Test Result
Harrison Lyseth Elem School	29	1.2 ppb
Harrison Lyseth Elem School	3	0 ppb
Harrison Lyseth Elem School	30	0 ppb
Harrison Lyseth Elem School	31	7.1 ppb
Harrison Lyseth Elem School	32	2.8 ppb
Harrison Lyseth Elem School	33	4.1 ppb
Harrison Lyseth Elem School	34	1.3 ppb
Harrison Lyseth Elem School	35	2.9 ppb
Harrison Lyseth Elem School	47 Art - Front	0 ppb
Harrison Lyseth Elem School	47 Art - Rear	1.7 ppb
Harrison Lyseth Elem School	49 Teachers Lounge	0 ppb
Harrison Lyseth Elem School	5	0 ppb
Harrison Lyseth Elem School	5th Grade Wing	0 ppb
Harrison Lyseth Elem School	6	0 ppb
Harrison Lyseth Elem School	Gym	0 ppb
Harrison Lyseth Elem School	Gym - Left Bubbler	0 ppb
Harrison Lyseth Elem School	Gym -right Bubbler	0 ppb
Harrison Lyseth Elem School	Kitchen	3.4 ppb
Harrison Lyseth Elem School	Main Hall - Bottle Filler Combo	0 ppb
Harrison Lyseth Elem School	Main Hall Entrance - Left Bubbler	0 ppb
Harrison Lyseth Elem School	Main Hall Entrance - Right Bubbler	0 ppb
Harrison Lyseth Elem School	Middle Hall	0 ppb
Harrison Lyseth Elem School	Nurse	0 ppb
Hartford-Sumner Elementary School	102- Nurses Room	0 ppb
Hartford-Sumner Elementary School	103- Computer Room	0 ppb
Hartford-Sumner Elementary School	104- Grade 3	2.8 ppb
Hartford-Sumner Elementary School	106- Grade 3	2.9 ppb
Hartford-Sumner Elementary School	107- Art Room A	4.8 ppb
Hartford-Sumner Elementary School	107- Art Room B	4.6 ppb
Hartford-Sumner Elementary School	108- Grade 2	9.9 ppb
Hartford-Sumner Elementary School	110- Grade 2	14.3 ppb
Hartford-Sumner Elementary School	111- Grade 2	1.4 ppb
Hartford-Sumner Elementary School	113- Title 1	11.2 ppb
Hartford-Sumner Elementary School	114- Teachers Work Room	13.2 ppb
Hartford-Sumner Elementary School	120- Special Ed	82.4 ppb
Hartford-Sumner Elementary School	123- Grade 5	48.8 ppb
Hartford-Sumner Elementary School	131- Pre-k	0 ppb
Hartford-Sumner Elementary School	134- Pe	1580 ppb
Hartford-Sumner Elementary School	136- Kindergarten	1.5 ppb
Hartford-Sumner Elementary School	137- Kindergarten	1 ppb
Hartford-Sumner Elementary School	138- Kindergarten	2.7 ppb
Hartford-Sumner Elementary School	140- Grade 1	0 ppb
Hartford-Sumner Elementary School	141- Special Ed	1.3 ppb
Hartford-Sumner Elementary School	142- Grade 1	0 ppb
Hartford-Sumner Elementary School	143- Grade 1	0 ppb
Hartford-Sumner Elementary School	Boys Bathroom A	0 ppb
Hartford-Sumner Elementary School	Boys Bathroom B	18.9 ppb

School Name	Sample Location	Lead Test Result
Hartford-Sumner Elementary School	Boys Bathroom C	1.5 ppb
Hartford-Sumner Elementary School	Boys Locker Room	97.4 ppb
Hartford-Sumner Elementary School	Cafeteria Sink	0 ppb
Hartford-Sumner Elementary School	Down Stairs Bathroom A	28.6 ppb
Hartford-Sumner Elementary School	Down Stairs Bathroom B	26.4 ppb
Hartford-Sumner Elementary School	Drinking Water Fountain A	0 ppb
Hartford-Sumner Elementary School	Drinking Water Fountain B	0 ppb
Hartford-Sumner Elementary School	Drinking Water Fountain C	0 ppb
Hartford-Sumner Elementary School	Drinking Water Fountain D	0 ppb
Hartford-Sumner Elementary School	Girls Bathroom B	2.3 ppb
Hartford-Sumner Elementary School	Girls Bathroom C	0 ppb
Hartford-Sumner Elementary School	Kitchen Sink A	34.7 ppb
Hartford-Sumner Elementary School	Kitchen Sink B	1.9 ppb
Hartford-Sumner Elementary School	Kitchen Sink C	3 ppb
Hartford-Sumner Elementary School	Kitchen Sink D	6.6 ppb
Hartford-Sumner Elementary School	Kitchen Sink E	1.3 ppb
Hartford-Sumner Elementary School	Large Hand Washer B	1.8 ppb
Hartford-Sumner Elementary School	Staff Bathroom A	1.2 ppb
Hartford-Sumner Elementary School	Staff Bathroom B	3.2 ppb
Hartford-Sumner Elementary School	Water Fountain C	0 ppb
Hebron Academy	Atwood Dorm 2nd Floor Water Cooler	0 ppb
Hebron Academy	Business Office 1st Floor Sink	0 ppb
Hebron Academy	Field House G Floor Boys Restroom Sink	0 ppb
Hebron Academy	Field House G Floor Girls Restroom Sink	1.4 ppb
Hebron Academy	Field House Mens Faculty Locker Room Sink	0 ppb
Hebron Academy	Field House Mens Home Locker Room Sink	0 ppb
Hebron Academy	Field House Mens Team Locker Room #2 Sink	0 ppb
Hebron Academy	Field House Mens Visiting Locker Room Sink	0 ppb
Hebron Academy	Field House Trainers Ice Machine	0 ppb
Hebron Academy	Field House Weight Room Water Cooler	0 ppb
Hebron Academy	Field House Womens Faculty Locker Room Sink	0 ppb
Hebron Academy	Field House Womens Home Locker Room Sink	0 ppb
Hebron Academy	Field House Womens Visiting Locker Room Sink	3.8 ppb
Hebron Academy	Halford Dorm 1 Bay Sink	1.6 ppb
Hebron Academy	Halford Dorm 1st Floor Water Cooler	0 ppb
Hebron Academy	Halford Dorm 2nd Floor Water Cooler	0 ppb
Hebron Academy	Halford Dorm 3rd Floor Water Cooler	0 ppb
Hebron Academy	Halford Student Union 1 Bay Sink	4.5 ppb
Hebron Academy	Halford Student Union 3 Bay Sink	0 ppb
Hebron Academy	Halford Student Union Ice Machine	0 ppb
Hebron Academy	Kaneb Center Water Cooler	0 ppb

School Name	Sample Location	Lead Test Result
Hebron Academy	Lepage Dine Arts 1st Floor Water Cooler	0 ppb
Hebron Academy	Lepage Dine Arts Water Cooler	0 ppb
Hebron Academy	Red Lion 1st Floor Kitchen Sink	0 ppb
Hebron Academy	Robinson Arena Boys Locker Room Sink	4.7 ppb
Hebron Academy	Robinson Arena Boys Public Restroom Sink	1.9 ppb
Hebron Academy	Robinson Arena Girls Locker Room Sink	4.1 ppb
Hebron Academy	Robinson Arena Girls Public Restroom Sink	1.7 ppb
Hebron Academy	Robinson Arena Pavilion Rest Room Sink	1.7 ppb
Hebron Academy	Robinson Arena Trainers Ice Machine	0 ppb
Hebron Academy	Science Building 1st Floor Teachers Lounge	13.5 ppb
Hebron Academy	Science Building 1st Floor Water Cooler	0 ppb
Hebron Academy	Stanley 1st Floor Kitchen Sink	5.8 ppb
Hebron Academy	Sturtevant Bake Shop Sink	1.9 ppb
Hebron Academy	Sturtevant Dorm 1st Floor N Water Cooler	0 ppb
Hebron Academy	Sturtevant Dorm 1st Floor S Water Cooler	0 ppb
Hebron Academy	Sturtevant Dorm 2nd Floor N Water Cooler	0 ppb
Hebron Academy	Sturtevant Dorm 2nd Floor S Water Cooler	0 ppb
Hebron Academy	Sturtevant Dorm 3rd Floor N Water Cooler	0 ppb
Hebron Academy	Sturtevant Dorm 3rd Floor S Water Cooler	0 ppb
Hebron Academy	Sturtevant Kitchen 1 Bay Sink	0 ppb
Hebron Academy	Sturtevant Kitchen 2 Bay Sink	1.7 ppb
Hebron Academy	Sturtevant Kitchen 3 Bay Sink	1.8 ppb
Hebron Academy	Sturtevant Kitchen Ice Machine	0 ppb
Hebron Academy	Sturtevant Kitchen Servery Sink	0 ppb
Hebron Academy	Sturtevant Kitchen Tilt Skillet	0 ppb
Hebron Academy	Sturtevant Nurses Station Water Cooler	0 ppb
Hebron Academy	Sturtevant School House 1st Floor Faculty Sink	0 ppb
Hebron Academy	Sturtevant School House 1st Floor Water Cooler	0 ppb
Helen S Dunn Elementary School	Bottle Fill Station - Jr High Wing	0 ppb
Helen S Dunn Elementary School	Bottle Fill Station - Main Lobby	0 ppb
Helen S Dunn Elementary School	Bottle Fill Station -in Hall Outside Gym	0 ppb
Helen S Dunn Elementary School	Drinking Water Fountain - In Hall Outside Gym	0 ppb
Helen S Dunn Elementary School	Drinking Water Fountain - Jr High Wing	0 ppb
Helen S Dunn Elementary School	Drinking Water Fountain - Main Lobby	0 ppb
Helen S Dunn Elementary School	Drinking Water Fountain - Room #12	1.6 ppb
Helen S Dunn Elementary School	Drinking Water Fountain - Room #14	1.7 ppb
Helen S Dunn Elementary School	Drinking Water Fountain - Room #15	2.7 ppb
Helen S Dunn Elementary School	Drinking Water Fountain - Room #16	2 ppb
Helen S Dunn Elementary School	Drinking Water Fountain - Room #17	2 ppb
Helen S Dunn Elementary School	Drinking Water Fountain - Room #23	4.9 ppb
Helen S Dunn Elementary School	Drinking Water Fountain - Room #24	2.3 ppb
Helen S Dunn Elementary School	Hand Washing Sink - Classroom #1	0 ppb
Helen S Dunn Elementary School	Kitchen - Double Basin Sink	0 ppb
Helen S Dunn Elementary School	Nurses Office Sink	2.4 ppb

School Name	Sample Location	Lead Test Result
Helen S Dunn Elementary School	Staff Lunch Room	1.8 ppb
Helen Thompson School	Between Lower And Upper Pod Bottle Fill	0 ppb
Helen Thompson School	Front Lobby Bottle Fill	0 ppb
Helen Thompson School	Gym Lobby Bottle Fill	0 ppb
Helen Thompson School	Kitchen Entrance Spigot Outside	27 ppb
Helen Thompson School	Kitchen Sink Back	10.3 ppb
Helen Thompson School	Kitchen Sink Front 1 Facing Left	3 ppb
Helen Thompson School	Kitchen Sink Front 1 Facing Right	1.3 ppb
Helen Thompson School	Modular Breakroom	0 ppb
Helen Thompson School	Modular Hallway Bottle Fill	0 ppb
Helen Thompson School	Nurse Office Sink	1.4 ppb
Helen Thompson School	Playground Spigot Outside Wall	443 ppb
Helen Thompson School	Steps Room	0 ppb
Helen Thompson School	Teacher's Breakroom	0 ppb
Helen Thompson School	Teacher's Prep Room	0 ppb
Hermon High School	2nd Floor Bottle Fill Station	1.2 ppb
Hermon High School	Classroom #209 Kitchen Sink	0 ppb
Hermon High School	Faculty Rm Hand Wash Sink	1.3 ppb
Hermon High School	Gym Drinking Fountain	2.4 ppb
Hermon High School	Gym Lobby Bottle Fill Station	2.3 ppb
Hermon High School	Ice Maker In Gym Storage Room	0 ppb
Hermon High School	Kitchen Dish Sink	3.1 ppb
Hermon High School	Kitchen Hand Wash Sink	3.1 ppb
Hermon High School	Kitchen Kettle	4.3 ppb
Hermon High School	Kitchen Prep Sink	4.5 ppb
Hermon High School	Main Custodial Rm Hand Wash Sink	4.3 ppb
Hermon High School	Main Lobby 1st Floor Bottle Fill	1.4 ppb
Hermon High School	Nurse Office Hand Wash Sink	1 ppb
Hermon Middle School	Bottle Fill Station By Rm #106	5.6 ppb
Hermon Middle School	Bottle Fill Station By Rm #116	5 ppb
Hermon Middle School	Bottle Fill Station By Rm #125	1.4 ppb
Hermon Middle School	Gym Lobby Bottle Fill Station	4.7 ppb
Hermon Middle School	Kitchen Dish Sink	6 ppb
Hermon Middle School	Kitchen Hand Wash Sink In Dish Rm	4.6 ppb
Hermon Middle School	Kitchen Hand Wash Sink In Serving Area	5.1 ppb
Hermon Middle School	Nurse Hand Wash Sink	5 ppb
Hichborn Middle School	Bottle Filler By Gym	0 ppb
Hichborn Middle School	Drinking Fountain By Gym #1	0 ppb
Hichborn Middle School	Drinking Fountain By Gym #2	0 ppb
Hichborn Middle School	Teachers Room Sink By Office	26.8 ppb
Hodgdon Middle/High School	3 Bay Kitchen Sink	5.2 ppb
Hodgdon Middle/High School	Biology Lab Sink Room 103	2.4 ppb
Hodgdon Middle/High School	Bottle Fill Station Beside Room 111	0 ppb
Hodgdon Middle/High School	Bottle Fill Station Gym	0 ppb
Hodgdon Middle/High School	Bottle Fill Station Second Floor	0 ppb
Hodgdon Middle/High School	Gym Boys Locker Room Hand Wash Sink	1.6 ppb
Hodgdon Middle/High School	Gym Girls Locker Room Hasnd Wash Sink	2.3 ppb

School Name	Sample Location	Lead Test Result
Hodgdon Middle/High School	Handwash Sink Nurses Office	2.4 ppb
Hodgdon Middle/High School	Kitchen Rinse Sink	9.2 ppb
Hodgdon Middle/High School	Kitchen Sink Room 202	4.4 ppb
Hodgdon Middle/High School	Kitchen Sink Teachers Room	6.5 ppb
Hodgdon Middle/High School	Lab Sink 2	18.5 ppb
Hodgdon Middle/High School	Lab Sink 3	28.4 ppb
Hodgdon Middle/High School	Room104 Chem. Lab Sink I	15.8 ppb
Hodgdon Middle/High School	Sink Room 109	15 ppb
Holbrook School	Hallway 118	0 ppb
Holbrook School	Hallway 127	0 ppb
Holbrook School	Hallway 204	0 ppb
Holbrook School	Hallway 43	0 ppb
Holbrook School	Room 20	0 ppb
Holbrook School	Room 38	4.5 ppb
Holbrook School	Room 38a	1.2 ppb
Holbrook School	Room 39	2.4 ppb
Holbrook School	Room143	12.5 ppb
Holden School	Hallway 43	0 ppb
Holden School	Hallway 44	0 ppb
Holden School	Hallway 46	0 ppb
Holden School	Room 18	8.8 ppb
Holden School	Room 2	4.5 ppb
Holden School	Room 32	0 ppb
Holden School	Room 4	14.1 ppb
Holden School	Room 6	1.4 ppb
Holden School	Room 8	3.4 ppb
Hollis School	Bottle Fill By Room #5	0 ppb
Hollis School	Clinic Faucet	0 ppb
Hollis School	Drinking Fountain Room #18	2.1 ppb
Hollis School	Drinking Fountain Room #19	1.1 ppb
Hollis School	Drinking Fountain Room #20	0 ppb
Hollis School	Drinking Fountain Room #21	1.8 ppb
Hollis School	Drinking Fountain Room #22	1.7 ppb
Hollis School	Drinking Fountain Room #23	1.2 ppb
Hollis School	Drinking Fountain Room #24	0 ppb
Hollis School	Drinking Fountain Room #25	2.7 ppb
Hollis School	Drinking Fountian By Room #5	0 ppb
Hollis School	Drinking Fountian Room #12	1.6 ppb
Hollis School	Drinking Fountian Room #13	1.1 ppb
Hollis School	Drinking Fountian Room #15	4.3 ppb
Hollis School	Drinking Fountian Room #16	1.4 ppb
Hollis School	Drinking Fountian Room #17	1.9 ppb
Hollis School	Faucet A Room #14	2 ppb
Hollis School	Faucet B Room #14	5.2 ppb
Hollis School	Faucet Room #10	3.2 ppb
Hollis School	Faucet Room #12	1.7 ppb
Hollis School	Faucet Room #13	0 ppb

School Name	Sample Location	Lead Test Result
Hollis School	Faucet Room #15	3.3 ppb
Hollis School	Faucet Room #16	3.1 ppb
Hollis School	Faucet Room #17	2.8 ppb
Hollis School	Faucet Room #18	1.3 ppb
Hollis School	Faucet Room #19	1.6 ppb
Hollis School	Faucet Room #20	1.3 ppb
Hollis School	Faucet Room #21	1.1 ppb
Hollis School	Faucet Room #22	1.3 ppb
Hollis School	Faucet Room #23	1.1 ppb
Hollis School	Faucet Room #24	2.1 ppb
Hollis School	Faucet Room #25	2.1 ppb
Hollis School	Faucet Room #9	8.9 ppb
Hollis School	Gym Drinking Fountian	0 ppb
Hollis School	Kitchen Prep Sink Faucet	0 ppb
Hollis School	Lower Drinking Fountian By Room #2	4.2 ppb
Hollis School	Portable 1 Faucet	0 ppb
Hollis School	Staff Room Faucet Room #27	3 ppb
Hollis School	Upper Drinking Fountian By Room #2	4.7 ppb
Holy Cross School-S Portland	Bathroom Sink 2nd Floor	6.6 ppb
Holy Cross School-S Portland	Bathroom Sink 3rd Floor	7.9 ppb
Holy Cross School-S Portland	Kitchen Sink 1st Floor	1.8 ppb
Hope Elementary School	Art Room 17 Sink A	0 ppb
Hope Elementary School	Art Room 17 Sink B	1 ppb
Hope Elementary School	Art Room 17 Sink C	0 ppb
Hope Elementary School	Art Room 17 Sink D	0 ppb
Hope Elementary School	Boyæ Potty Sink A	0 ppb
Hope Elementary School	Boyæ Potty Sink B	0 ppb
Hope Elementary School	Boys Room Sink A	0 ppb
Hope Elementary School	Boys Room Sink B	0 ppb
Hope Elementary School	Danielleæ Office Sink	1.8 ppb
Hope Elementary School	Elementary Hallway Sink A	0 ppb
Hope Elementary School	Elementary Hallway Sink B	0 ppb
Hope Elementary School	Elementary Hallway Sink C	0 ppb
Hope Elementary School	Girlæ Potty Sink A	0 ppb
Hope Elementary School	Girlæ Potty Sink B	0 ppb
Hope Elementary School	Girls Room Sink A	0 ppb
Hope Elementary School	Girls Room Sink B	0 ppb
Hope Elementary School	Gym Boy Sink	0 ppb
Hope Elementary School	Gym Girl Sink	1.3 ppb
Hope Elementary School	Hall Fountain A	0 ppb
Hope Elementary School	Hall Fountain B	0 ppb
Hope Elementary School	Hall Near Room 11 Potty Hand Washing Sink	0 ppb
Hope Elementary School	Hall Near Room 9 Potty Hand Washing Sink	0 ppb
Hope Elementary School	Hose Outside Mr. Ha	23.2 ppb
Hope Elementary School	Kitchen 1 Bay Faucet	1.5 ppb
Hope Elementary School	Kitchen 3 Bay Sink A Faucet	0 ppb

School Name	Sample Location	Lead Test Result
Hope Elementary School	Kitchen 3 Bay Sink B Faucet	7.8 ppb
Hope Elementary School	Kitchen 3 Bay Sink C Faucet	2 ppb
Hope Elementary School	Kitchen Dishwasher Sprayer	3.4 ppb
Hope Elementary School	Kitchen Hand Washing Sink	1.9 ppb
Hope Elementary School	Lobby Fountain	0 ppb
Hope Elementary School	Me Hall Sink C	0 ppb
Hope Elementary School	Ms Hall Sink A	1 ppb
Hope Elementary School	Ms Hall Sink B	1.1 ppb
Hope Elementary School	Pre K Hose Near Field	0 ppb
Hope Elementary School	Pre K Left Potty Sink	0 ppb
Hope Elementary School	Pre K Left Sink	0 ppb
Hope Elementary School	Pre K Right Potty Sink	0 ppb
Hope Elementary School	Pre K Right Sink	0 ppb
Hope Elementary School	Room 1 Sink A	14.9 ppb
Hope Elementary School	Room 1 Sink B	33.5 ppb
Hope Elementary School	Room 1 Sink C	16.6 ppb
Hope Elementary School	Room 1 Sink D	7.3 ppb
Hope Elementary School	Room 1 Sink E	19.5 ppb
Hope Elementary School	Room 1 Sink F	9.2 ppb
Hope Elementary School	Room 1 Sink G	14.2 ppb
Hope Elementary School	Room 1 Sink H	5.5 ppb
Hope Elementary School	Room 1 Sink I	1.7 ppb
Hope Elementary School	Room 1 Sink J	4.1 ppb
Hope Elementary School	Room 1 Sink K	6 ppb
Hope Elementary School	Room 1 Sink L	11 ppb
Hope Elementary School	Room 1 Sink M	13.4 ppb
Hope Elementary School	Room 1 Sink N	23.8 ppb
Hope Elementary School	Room 1 Sink O	23.8 ppb
Hope Elementary School	Room 1 Sink P	7.3 ppb
Hope Elementary School	Room 1 Sink Q	3.7 ppb
Hope Elementary School	Room 1 Sink R	3.9 ppb
Hope Elementary School	Room 1 Sink S	3.7 ppb
Hope Elementary School	Room 1 Sink T	9.9 ppb
Hope Elementary School	Room 1 Sink U	7.7 ppb
Hope Elementary School	Room 1 Sink V	10.5 ppb
Hope Elementary School	Room 1 Sink W	10.9 ppb
Hope Elementary School	Room 1 Sink X	18.9 ppb
Hope Elementary School	Room 10 Fountain	3.1 ppb
Hope Elementary School	Room 10 Sink	0 ppb
Hope Elementary School	Room 11 Fountain	12 ppb
Hope Elementary School	Room 11 Sink	0 ppb
Hope Elementary School	Room 12 Fountain	5.8 ppb
Hope Elementary School	Room 12 Sink	0 ppb
Hope Elementary School	Room 13 Fountain	2.4 ppb
Hope Elementary School	Room 13 Sink	0 ppb
Hope Elementary School	Room 15 Sink	0 ppb
Hope Elementary School	Room 16 Sink	0 ppb

School Name	Sample Location	Lead Test Result
Hope Elementary School	Room 2 Fountain	3.9 ppb
Hope Elementary School	Room 2 Sink	3.3 ppb
Hope Elementary School	Room 20 Sink	3.5 ppb
Hope Elementary School	Room 3 Fountain	20.9 ppb
Hope Elementary School	Room 3 Sink	2.3 ppb
Hope Elementary School	Room 4 Fountain	27.5 ppb
Hope Elementary School	Room 4 Kitchen Sink	0 ppb
Hope Elementary School	Room 4 Sink	2.9 ppb
Hope Elementary School	Room 7 Sink	17.7 ppb
Hope Elementary School	Room 8 Fountain	7.4 ppb
Hope Elementary School	Room 8 Sink	0 ppb
Hope Elementary School	Room 9 Fountain	4 ppb
Hope Elementary School	Room 9 Sink	1.1 ppb
Hope Elementary School	Staff Potty Sink	1.1 ppb
Hope Elementary School	Staff Room Sink	0 ppb
Horace Mitchell Primary School	Boys Room Near Gym	11 ppb
Horace Mitchell Primary School	Fountain (cafe)	0 ppb
Horace Mitchell Primary School	Fountain (first Floor Hallway)	0 ppb
Horace Mitchell Primary School	Fountain (upstairs Hallway)	0 ppb
Horace Mitchell Primary School	Girls Room Near Gym	0 ppb
Horace Mitchell Primary School	Room 101 (office Kitchen Sink)	0 ppb
Horace Mitchell Primary School	Room 104 (nurse)	0 ppb
Horace Mitchell Primary School	Room 108	0 ppb
Horace Mitchell Primary School	Room 113	0 ppb
Horace Mitchell Primary School	Room 115 (kitchenette)	0 ppb
Horace Mitchell Primary School	Room 118	0 ppb
Horace Mitchell Primary School	Room 119	0 ppb
Horace Mitchell Primary School	Room 120	0 ppb
Horace Mitchell Primary School	Room 121	0 ppb
Horace Mitchell Primary School	Room 122	0 ppb
Horace Mitchell Primary School	Room 123	0 ppb
Horace Mitchell Primary School	Room 124	0 ppb
Horace Mitchell Primary School	Room 125	0 ppb
Horace Mitchell Primary School	Room 126	0 ppb
Horace Mitchell Primary School	Room 211	0 ppb
Horace Mitchell Primary School	Room 213	0 ppb
Horace Mitchell Primary School	Room 214	1.6 ppb
Horace Mitchell Primary School	Room 215	0 ppb
Horace Mitchell Primary School	Room 216	0 ppb
Horace Mitchell Primary School	Room 217	0 ppb
Horace Mitchell Primary School	Room 220	0 ppb
Horace Mitchell Primary School	Room 223	0 ppb
Horace Mitchell Primary School	Room 224	0 ppb
Horace Mitchell Primary School	Room 229	0 ppb
Horace Mitchell Primary School	Room 230	0 ppb
Horace Mitchell Primary School	Room 231	0 ppb
Horace Mitchell Primary School	Room 233	0 ppb

School Name	Sample Location	Lead Test Result
Horace Mitchell Primary School	Room 240 (kitchen)	0 ppb
Horace Mitchell Primary School	Room 250	0 ppb
Horace Mitchell Primary School	Room 251	0 ppb
Horace Mitchell Primary School	Room 252	0 ppb
Houlton Elementary School	Bus Office Sink	0 ppb
Houlton Elementary School	Gym Fountain	0 ppb
Houlton Elementary School	Kindergarten Hall Fountain	0 ppb
Houlton Elementary School	Kitchen 3-bay Dish Washer Sink	4.4 ppb
Houlton Elementary School	Kitchen Dish Sprayer	5.1 ppb
Houlton Elementary School	Kitchen Hand Wash Sink	6.9 ppb
Houlton Elementary School	Kitchen Skillet	28.4 ppb
Houlton Elementary School	Kitchen Steamer	20.7 ppb
Houlton Elementary School	Kitchen Veggie Wash Sink	5.4 ppb
Houlton Elementary School	Room #1 Sink	5.8 ppb
Houlton Elementary School	Room #2 Sink	10.3 ppb
Houlton Elementary School	Room #3 Sink	10.9 ppb
Houlton Elementary School	Room #4 Sink	7.3 ppb
Houlton Elementary School	Room #5 Sink	9.1 ppb
Houlton Elementary School	Room #6 Hall Fountain	0 ppb
Houlton Elementary School	Room 15 Hall Fountain (left)	0 ppb
Houlton Elementary School	Room 15 Hall Fountain (right)	0 ppb
Houlton Elementary School	Room 25 Hall Fountain (left)	0 ppb
Houlton Elementary School	Room 25 Hall Fountain (right)	0 ppb
Houlton High School	Auditorium Stage Sink	0 ppb
Houlton High School	Boy's Visitor Locker Room Sink	36.8 ppb
Houlton High School	B-wing Water Fountain	0 ppb
Houlton High School	Kitchen 3-bay Dish Wash Sink	1.5 ppb
Houlton High School	Kitchen Dish Sprayer	9.2 ppb
Houlton High School	Kitchen Hand Wash Sink	0 ppb
Houlton High School	Kitchen Hand Wash Sink By 3-bay Sink	14.4 ppb
Houlton High School	Kitchen Steamer	302 ppb
Houlton High School	Kitchen Veggie Wash Sink	4.9 ppb
Houlton High School	Library Kitchen Sink	9 ppb
Houlton High School	Pe Office Sink (graham)	40.2 ppb
Houlton High School	Pe Office Sink (willard)	7.8 ppb
Houlton High School	Room #105 Sink	5.6 ppb
Houlton High School	Room #106 Blue Sink	6 ppb
Houlton High School	Room #106 Green Sink	5.5 ppb
Houlton High School	Room #106 Red Sink	6.3 ppb
Houlton High School	Room #106 Yellow Sink	5.4 ppb
Houlton High School	Room #110 Left Sink	10.6 ppb
Houlton High School	Room #110 Right Sink	4.6 ppb
Houlton High School	Room #251 Back Sink	12.9 ppb
Houlton High School	Room #251 Front Sink	10.8 ppb
Houlton High School	Room #253 Back Sink	3.6 ppb
Houlton High School	Room #253 Front Sink	2.9 ppb
Houlton High School	Room #255 Front Sink	10.6 ppb

School Name	Sample Location	Lead Test Result
Houlton High School	Sink In Cafeteria	5.9 ppb
Houlton High School	Teacher's Room Sink	4.3 ppb
Houlton High School	Water Fountain In Boy's Locker Room	0 ppb
Houlton High School	Water Fountain Outside Auditorium	1.5 ppb
Houlton High School	Water Fountain Outside Coaches Room	0 ppb
Houlton High School	Water Fountain Outside Welding Shop	29.9 ppb
Houlton Junior High School	Nurse Office Sink	2.7 ppb
Houlton Junior High School	Room #225 Back Sink	3.5 ppb
Houlton Junior High School	Room #225 Front Sink	5.4 ppb
Houlton Junior High School	Room #227 Back Sink	4.2 ppb
Houlton Junior High School	Room #227 Front Sink	7.9 ppb
Houlton Junior High School	Water Fountain In Hall By Restrooms	0 ppb
Houlton Southside School	1st Floor Classroom Hall Fountain	0 ppb
Houlton Southside School	2nd Floor Classroom Hall Fountain	0 ppb
Houlton Southside School	Kitchen Bathroom Sink	4.1 ppb
Houlton Southside School	Kitchen Dish Sprayer	2.5 ppb
Houlton Southside School	Kitchen Dish Washer	2.5 ppb
Houlton Southside School	Kitchen Hand Wash Sink	3.4 ppb
Houlton Southside School	Kitchen Veggie Wash Sink	3 ppb
Houlton Southside School	Nurses Office Sink	1.9 ppb
Houlton Southside School	Room #121 Sink	1.4 ppb
Houlton Southside School	Room #123/124 Sink	2.4 ppb
Houlton Southside School	Room #126 Sink	2.2 ppb
Houlton Southside School	Room #127	1.4 ppb
Houlton Southside School	Room #128 Sink	3.9 ppb
Houlton Southside School	Room #131 Sink	1.9 ppb
Houlton Southside School	Room #132 Sink	2.7 ppb
Houlton Southside School	Room #223	2.4 ppb
Houlton Southside School	Room #226	3.6 ppb
Houlton Southside School	Room #228 Sink	2.4 ppb
Houlton Southside School	Room #230 Sink	2.5 ppb
Houlton Southside School	Teachers Room #104 Sink	3.2 ppb
Houlton Southside School	Water Fountain Outside Main Office	0 ppb
Howard C Reiche Community Sch	101	5.6 ppb
Howard C Reiche Community Sch	103 - Left	4.8 ppb
Howard C Reiche Community Sch	103 - Right	2.4 ppb
Howard C Reiche Community Sch	106 - Left	5.8 ppb
Howard C Reiche Community Sch	106 - Right	4.8 ppb
Howard C Reiche Community Sch	107	9.2 ppb
Howard C Reiche Community Sch	109	5.7 ppb
Howard C Reiche Community Sch	110	13 ppb
Howard C Reiche Community Sch	112	5.1 ppb
Howard C Reiche Community Sch	121	1 ppb
Howard C Reiche Community Sch	202 - Left	2.1 ppb
Howard C Reiche Community Sch	202 - Right	2.3 ppb
Howard C Reiche Community Sch	206 - Left	5 ppb
Howard C Reiche Community Sch	206 - Right	4.7 ppb

School Name	Sample Location	Lead Test Result
Howard C Reiche Community Sch	208 - Left	5.6 ppb
Howard C Reiche Community Sch	208 - Right	4.5 ppb
Howard C Reiche Community Sch	210 Counter A - Left	14.6 ppb
Howard C Reiche Community Sch	210 Counter A - Right	39.8 ppb
Howard C Reiche Community Sch	210 Counter B - Left	177 ppb
Howard C Reiche Community Sch	210 Counter B - Right	329 ppb
Howard C Reiche Community Sch	217	3.3 ppb
Howard C Reiche Community Sch	Cafeteria	0 ppb
Howard C Reiche Community Sch	Cafeteria	0 ppb
Howard C Reiche Community Sch	Copy Room 1st Floor	6.6 ppb
Howard C Reiche Community Sch	Gym	0 ppb
Howard C Reiche Community Sch	Gymnasium	0 ppb
Howard C Reiche Community Sch	Hall - 1st Floor Bathroom	0 ppb
Howard C Reiche Community Sch	Hall - 2nd Floor Bathroom	0 ppb
Howard C Reiche Community Sch	Kitchen - Left Sink	7.3 ppb
Howard C Reiche Community Sch	Kitchen - Right Sink	0 ppb
Howard C Reiche Community Sch	Nurse	2.5 ppb
Howard C Reiche Community Sch	Pos-1	0 ppb
Howard C Reiche Community Sch	Poucb-1 Rear Classroom Block Fountain/filler	0 ppb
Howard C Reiche Community Sch	Pourcb-1 Rear Classroom Block Fountain/filler	0 ppb
Howard C Reiche Community Sch	Room 110 Bathroom Sink	0 ppb
Howard C Reiche Community Sch	Room 110 Fountain	0 ppb
Howard C Reiche Community Sch	Room 110 Sink	0 ppb
Howard C Reiche Community Sch	Room 112 Bathroom Sink	0 ppb
Howard C Reiche Community Sch	Room 112 Fountain	0 ppb
Howard C Reiche Community Sch	Room 112 Sink	0 ppb
Howard C Reiche Community Sch	Room 113 Bathroom Sink	0 ppb
Howard C Reiche Community Sch	Room 113 Fountain	2.9 ppb
Howard C Reiche Community Sch	Room 113 Sink	0 ppb
Howard C Reiche Community Sch	Room 114 Bathroom Sink	0 ppb
Howard C Reiche Community Sch	Room 114 Fountain	1.3 ppb
Howard C Reiche Community Sch	Room 114 Sink	0 ppb
Howard C Reiche Community Sch	Room 115 Bathroom Sink	0 ppb
Howard C Reiche Community Sch	Room 115 Fountain	1.7 ppb
Howard C Reiche Community Sch	Room 115 Sink	1.3 ppb
Howard C Reiche Community Sch	Room 210 Fountain	0 ppb
Howard C Reiche Community Sch	Room 210 Sink	0 ppb
Howard C Reiche Community Sch	Room 211 Bathroom Sink	0 ppb
Howard C Reiche Community Sch	Room 211 Fountain	0 ppb
Howard C Reiche Community Sch	Room 211 Sink	0 ppb
Howard C Reiche Community Sch	Room 212 Fountain	1.5 ppb
Howard C Reiche Community Sch	Room 213 Fountain	0 ppb
Howard C Reiche Community Sch	Room 213 Sink	0 ppb
Howard C Reiche Community Sch	Teacher Lounge	3.2 ppb
Hyde School	Bottle Fill Station (a-wing)	0 ppb

School Name	Sample Location	Lead Test Result
Hyde School	Bottle Fill Station (gym)	0 ppb
Hyde School	Coffee Station (frc)	0 ppb
Hyde School	Dishwasher Rinse Sink	0 ppb
Hyde School	Fresh Water/ice Dispenser In Café	0 ppb
Hyde School	Kitchen Ice Machine	1.6 ppb
Hyde School	Outdoor Spigot (gym)	0 ppb
Hyde School	Pot Rinsing Sink	0 ppb
Hyde School	Prep Table Sink	0 ppb
Hyde School	Salad Wash Station	0 ppb
Hyde School	Sanatize Sink	0 ppb
Hyde School	Wash/rinse Sink	0 ppb
Indian Island School	No Samples Yet Taken	
Indian Township School	Bilingual Rm 14 Main Building	9.7 ppb
Indian Township School	Boys' Bathroom Rm 65 Jr High Building	1.9 ppb
Indian Township School	Boys' Locker Room Rm 42 Main Building	9.9 ppb
Indian Township School	Faculty Restroom Office Area Rm 35 Main Building	9.8 ppb
Indian Township School	Girls' Bathroom Rm 66 Jr High Building	1.3 ppb
Indian Township School	Girls' Locker Room Rm 45 Main Building	19.2 ppb
Indian Township School	Grade 3 Bathroom Rm 54 3-5 Building	0 ppb
Indian Township School	Grade 4 Bathroom Rm 49 3-5 Building	0 ppb
Indian Township School	Grade 5 Bathroom Rm 53 3-5 Building	1.1 ppb
Indian Township School	Kindergarten Rm 25 Main Building	5.1 ppb
Indian Township School	Kitchen Rm 1 Main Building	10.6 ppb
Indian Township School	Library Rm 29 Main Building	6.6 ppb
Indian Township School	Life Skills/faculty Rm 61 Jr High Building	2 ppb
Indian Township School	Prek Rm 22 Main Building	9.4 ppb
Indian Township School	Special Ed Bathroom Rm 52 3-5 Building	2.2 ppb
Indian Township School	Teachers' Room Rm 27 Main Building	4.8 ppb
Ironwood School	Bathroom Sink	13 ppb
Ironwood School	Office Sink	7.9 ppb
Isle au Haut Rural School	Bathroom Sink	11.5 ppb
Isle au Haut Rural School	Kitchen Sink	5.3 ppb
Islesboro Central School	2/3 Classroom	1.5 ppb
Islesboro Central School	4/5 Classroom Sink	0 ppb
Islesboro Central School	Caf Sink	0 ppb
Islesboro Central School	English Room	0 ppb
Islesboro Central School	K/1 Classroom Sink	0 ppb
Islesboro Central School	Kitchen Deep Sink	0 ppb
Islesboro Central School	Kitchen Main Sink	0 ppb
Islesboro Central School	Main Floor Fountain	0 ppb
Islesboro Central School	New Wing Fountain	0 ppb
Islesboro Central School	Nurse Office	0 ppb
Islesboro Central School	Second Floor Fountain	1.9 ppb
Jack Memorial School	Drinking Fountain By Room 15	2.8 ppb
Jack Memorial School	Drinking Fountain By Room 2	1.6 ppb
Jack Memorial School	Faucet Room 15	7 ppb

School Name	Sample Location	Lead Test Result
Jack Memorial School	Faucet Room 3	3.3 ppb
Jack Memorial School	Kitchen Faucet Room 2	14.7 ppb
James F. Doughty School	Bottle Fill Station - 1st Floor Auditor.	0 ppb
James F. Doughty School	Bottle Fill Station - 2nd Floor Auditor.	0 ppb
James F. Doughty School	Bottle Fill Station - 2nd Floor Head End	0 ppb
James F. Doughty School	Bottle Fill Station - Cafeteria	0 ppb
James F. Doughty School	Bottle Fill Station - Dog House	15.3 ppb
James F. Doughty School	Bottle Fill Station - Grade 6 Hallway	0 ppb
James F. Doughty School	Bottle Fill Station - Gym	4.1 ppb
James F. Doughty School	Bottle Fill Station - Library	0 ppb
James F. Doughty School	Faucet - Teacher's Lounge	10.7 ppb
James F. Doughty School	Kitchen - Double Basin Sink Faucet	10.7 ppb
James F. Doughty School	Kitchen - Faucet Near Salad Refrig	5.6 ppb
James F. Doughty School	Kitchen - Kettle	19.1 ppb
James H Bean School	Across From Gym Bottle Fill Station	0 ppb
James H Bean School	Across/ Nurses Station Bathroom Sink	0 ppb
James H Bean School	Boys Gang Bathroom Sink A	2.2 ppb
James H Bean School	Boys Gang Bathroom Sink B	1.2 ppb
James H Bean School	Boys Gang Bathroom Sink C	1.2 ppb
James H Bean School	Boys South End Bathroom Sink A	0 ppb
James H Bean School	Boys South End Bathroom Sink B	1 ppb
James H Bean School	Girls Gang Bath Room Sink A	0 ppb
James H Bean School	Girls Gang Bath Room Sink B	0 ppb
James H Bean School	Girls Gang Bath Room Sink C	0 ppb
James H Bean School	Girls South End Bathroom Sink A	0 ppb
James H Bean School	Girls South End Bathroom Sink B	0 ppb
James H Bean School	Gym Bottle Fill Station	0 ppb
James H Bean School	Kitchen 3 Bay Sink A	0 ppb
James H Bean School	Kitchen 3 Bay Sink B	0 ppb
James H Bean School	Kitchen 304-a Bathroom -sink	4.3 ppb
James H Bean School	Kitchen Handwash Station A Sink	0 ppb
James H Bean School	Kitchen Handwash Station B Sink	27 ppb
James H Bean School	Kitchen Tilt Skillet	3 ppb
James H Bean School	Kitchen Vegetable Sink	2.5 ppb
James H Bean School	Library Kitchen - Sink	0 ppb
James H Bean School	Locker Room B - Sink	11.3 ppb
James H Bean School	Pe Teacher(locker Room) A Sink	7.3 ppb
James H Bean School	Room 002 Staff Lounge - Sink	0 ppb
James H Bean School	Room 002 Staff Lounge -bathroom Sink	0 ppb
James H Bean School	Room 204- Sink	0 ppb
James H Bean School	Room 206- Bathroom -sink	0 ppb
James H Bean School	Room 300-sink	1 ppb
James H Bean School	Room 306-sink	0 ppb
James H Bean School	Room 307-sink	0 ppb
James H Bean School	Room 308-sink	0 ppb
James H Bean School	Room 309 -sink	0 ppb
James H Bean School	Room 310 -sink	0 ppb

School Name	Sample Location	Lead Test Result
James H Bean School	Room 311-sink	0 ppb
James H Bean School	South End Bottle Fill Station	0 ppb
James H Bean School	South End(by Doors) Bottle Fill Station	0 ppb
James Otis Kaler Elementary School	1st Fl...bottle Fill Station	0 ppb
James Otis Kaler Elementary School	1st Fl...kitchen	0 ppb
James Otis Kaler Elementary School	1st Flàbottle Fill Station	0 ppb
James Otis Kaler Elementary School	1st Flàbottle Fill Station..near Restrooms	0 ppb
James Otis Kaler Elementary School	1st Floor Bottle Fill Near Restrooms	0 ppb
James Otis Kaler Elementary School	2nd Fl...room 9	1.1 ppb
James Otis Kaler Elementary School	2nd Flàbottle Fill Station	0 ppb
James Otis Kaler Elementary School	2nd Floor Bottle Fill Station	0 ppb
James Otis Kaler Elementary School	Nurse Office..1st Fl	0 ppb
James Otis Kaler Elementary School	Room 1	0 ppb
James Otis Kaler Elementary School	Room 10	5.6 ppb
James Otis Kaler Elementary School	Room 11	2.4 ppb
James Otis Kaler Elementary School	Room 12	0 ppb
James Otis Kaler Elementary School	Room 13	0 ppb
James Otis Kaler Elementary School	Room 14	0 ppb
James Otis Kaler Elementary School	Room 2	0 ppb
James Otis Kaler Elementary School	Room 2a	0 ppb
James Otis Kaler Elementary School	Room 3	0 ppb
James Otis Kaler Elementary School	Room 4	0 ppb
James Otis Kaler Elementary School	Room 5	0 ppb
James Otis Kaler Elementary School	Room 6	0 ppb
James Otis Kaler Elementary School	Room 7	0 ppb
James Otis Kaler Elementary School	Room 7a	0 ppb
James Otis Kaler Elementary School	Room 8	0 ppb
James Otis Kaler Elementary School	Teacher Breakroom	0 ppb
Jameson Elementary School	Bottle Fill Station Outside Custodial	0 ppb
Jameson Elementary School	Bottle Fill Station Outside Gym	0 ppb
Jameson Elementary School	Bottle Fill Station Outside Rm 8	0 ppb
Jameson Elementary School	Double Basink Sink Kitchen	1.1 ppb
Jameson Elementary School	Kitchen Sink Near Office	2.4 ppb
Jameson Elementary School	Rm 1 Water Fountain	8.8 ppb
Jameson Elementary School	Rm 14 Water Fountain	2.7 ppb
Jameson Elementary School	Rm 15 Water Fountain	5.8 ppb
Jameson Elementary School	Rm 16 Water Fountain	9.1 ppb
Jameson Elementary School	Rm 17 Water Fountain	13.9 ppb
Jameson Elementary School	Rm 18 Water Fountain	9.8 ppb
Jameson Elementary School	Rm 19 Water Fountain	60.4 ppb
Jameson Elementary School	Rm 2 Water Fountain	3.8 ppb
Jameson Elementary School	Rm 20 Sink	8.4 ppb
Jameson Elementary School	Rm 21 Water Fountain	10.3 ppb
Jameson Elementary School	Rm 3 Water Fountain	0 ppb
Jameson Elementary School	Rm 4 Water Fountain	4.8 ppb
Jameson Elementary School	Rm 5 Water Fountain	4.3 ppb
Jameson Elementary School	Rm 6 Water Fountain	2.1 ppb

School Name	Sample Location	Lead Test Result
Jameson Elementary School	Rm 7 Sink	151 ppb
Jameson Elementary School	Rm 8 Sink	126 ppb
Jameson Elementary School	Rm 9 Water Fountain	1.3 ppb
Jameson Elementary School	Teachers Lounge	12 ppb
Jefferson Village School	2 Basin Sink Utility Faucet Sink 1 Rm 101	0 ppb
Jefferson Village School	2 Basin Sink Utility Faucet Sink 2 Rm 101	0 ppb
Jefferson Village School	Bathroom Hand Washing Sink- Nurses Office	0 ppb
Jefferson Village School	Bathroom Hand Washing Sink Rm 104	0 ppb
Jefferson Village School	Bathroom Hand Washing Sink Rm Staff Bath 1	0 ppb
Jefferson Village School	Bathroom Hand Washing Sink Rm Staff Bath 2	0 ppb
Jefferson Village School	Bathroom Hand Washing Sink Rm Staff Bath 3	0 ppb
Jefferson Village School	Blue Bottle Filling Station	0 ppb
Jefferson Village School	Blue Boys Bathroom Hand Washing Sink Left	0 ppb
Jefferson Village School	Blue Boys Bathroom Hand Washing Sink Right	0 ppb
Jefferson Village School	Blue Girls Bathroom Hand Washing Sink Left	0 ppb
Jefferson Village School	Blue Girls Bathroom Hand Washing Sink Right	0 ppb
Jefferson Village School	Cafe Trough Sink Faucet 1	1.7 ppb
Jefferson Village School	Cafe Trough Sink Faucet 2	1.1 ppb
Jefferson Village School	Cafe Trough Sink Faucet 3	0 ppb
Jefferson Village School	Drinking Fountain Rm 411	2 ppb
Jefferson Village School	Green Drinking Bottle Filling Sink	0 ppb
Jefferson Village School	Kitchen 3 Basin Rinse Sink- Utility Faucet	2 ppb
Jefferson Village School	Kitchen 3 Basin Wash Sink- Utility Faucet	1.2 ppb
Jefferson Village School	Kitchen Hand Washing Sink 1	1.7 ppb
Jefferson Village School	Kitchen Hand Washing Sink 2	0 ppb
Jefferson Village School	Kitchen Prep Sink	0 ppb
Jefferson Village School	Kitchen Single Basin Dish Washer Prep Sink	0 ppb
Jefferson Village School	Red Drinking Bottle Filling Sink	0 ppb
Jefferson Village School	Single Basin Sink 1 Rm 101	0 ppb
Jefferson Village School	Single Basin Sink 102	0 ppb
Jefferson Village School	Single Basin Sink 2 Rm 101	0 ppb
Jefferson Village School	Single Basin Sink Rm 104	0 ppb
Jefferson Village School	Single Basin Sink Rm 121 Nurses	0 ppb
Jefferson Village School	Single Basin Sink Rm 201	0 ppb
Jefferson Village School	Single Basin Sink Rm 203	0 ppb
Jefferson Village School	Single Basin Sink Rm 204	0 ppb
Jefferson Village School	Single Basin Sink Rm 209	0 ppb
Jefferson Village School	Single Basin Sink Rm 210	0 ppb

School Name	Sample Location	Lead Test Result
Jefferson Village School	Single Basin Sink Rm 406 Sink 1	1.5 ppb
Jefferson Village School	Single Basin Sink Rm 406 Sink 2	1.3 ppb
Jefferson Village School	Single Basin Sink Rm 406 Sink 3	2 ppb
Jefferson Village School	Single Basin Sink Rm 406 Sink 4	64.9 ppb
Jefferson Village School	Single Basin Sink Rm 411	0 ppb
Jefferson Village School	Single Basin Sink Rm 501	0 ppb
Jefferson Village School	Single Basin Sink Rm 502	0 ppb
Jefferson Village School	Single Basin Sink Rm 503	0 ppb
Jefferson Village School	Single Basin Sink Rm 504	0 ppb
Jefferson Village School	Single Basin Sink Rm 505	0 ppb
Jefferson Village School	Single Basin Sink Rm 506	0 ppb
Jefferson Village School	Single Basin Sink Rm Work Room	0 ppb
Jefferson Village School	Tilt Skillet Utility Faucet- Kitchen	0 ppb
John Bapst Memorial High School	1st Floor Boys Room Sink	12.6 ppb
John Bapst Memorial High School	1st Floor Drinking Fountain	0 ppb
John Bapst Memorial High School	1st Floor Girls Room Sink	12.8 ppb
John Bapst Memorial High School	2nd Floor Boys Room Sink	8 ppb
John Bapst Memorial High School	2nd Floor Drinking Fountain	9.2 ppb
John Bapst Memorial High School	2nd Floor Girls Room Sink	23.7 ppb
John Bapst Memorial High School	2nd Floor Teacher Room Sink	16.2 ppb
John Bapst Memorial High School	3rd Floor Drinking Fountain	2.5 ppb
John Bapst Memorial High School	3rd Floor Girls Room Sink	15.1 ppb
John Bapst Memorial High School	3rd Floor Teacher Room Sink	29.6 ppb
John Bapst Memorial High School	Academic Dean Office Sink	23.7 ppb
John Bapst Memorial High School	Ad Office Sink	32.6 ppb
John Bapst Memorial High School	Basement Water Fountain	70.4 ppb
John Bapst Memorial High School	Boys Locker Room Sink	21.8 ppb
John Bapst Memorial High School	Darling Center Boys Room Sink	1.3 ppb
John Bapst Memorial High School	Darling Center Girls Room Sink	0 ppb
John Bapst Memorial High School	Darling Center Water Fountain	0 ppb
John Bapst Memorial High School	Dean Of Students Office Sink	23.2 ppb
John Bapst Memorial High School	Girls Locker Room Sink	13.7 ppb
John Bapst Memorial High School	1st Floor Ladies Room Sink	3.1 ppb
John Bapst Memorial High School	Nurse Office Sink	23.5 ppb
John Bapst Memorial High School	Warming Room Sink	10.1 ppb
John Bapst Memorial High School	Water Spicket South Knuckle	15.4 ppb
John F Kennedy Memorial School	Cafeteria- Drinking Water Fountain	33.1 ppb
John F Kennedy Memorial School	Dwf Orm1	17.5 ppb
John F Kennedy Memorial School	Dwf Orm104	20.5 ppb
John F Kennedy Memorial School	Dwf Orm112	12.1 ppb
John F Kennedy Memorial School	Dwf Orm14	23.6 ppb
John F Kennedy Memorial School	Snk Kitchen A	4.1 ppb
John F Kennedy Memorial School	Snk Kitchen B	7.9 ppb
John F Kennedy Memorial School	Snk Kitchen C	26.2 ppb
John F Kennedy Memorial School	Snk Kitchen D	1.5 ppb
John F Kennedy Memorial School	Snk Rm2 A	9.5 ppb
John F Kennedy Memorial School	Snk Rm2 B	27.8 ppb

School Name	Sample Location	Lead Test Result
Jonesboro Elementary School	Gym Drinking Foutain	0 ppb
Jonesboro Elementary School	Kitchen Food Prep Sink	12.2 ppb
Jonesboro Elementary School	Teachers Room	3.8 ppb
Jonesport Elementary School	3 Bay Kitchen Sink	1.1 ppb
Jonesport Elementary School	Food Prep Sink	1.7 ppb
Jonesport Elementary School	Kindergarten Room Sink	4.5 ppb
Jonesport Elementary School	Pre-k Room Sink	5.7 ppb
Jonesport-Beals High School	Consumer Science Room Sink 1	3.4 ppb
Jonesport-Beals High School	Consumer Science Room Sink 2	11 ppb
Jonesport-Beals High School	Consumer Science Room Sink 3	2 ppb
Jordan-Small Middle School	A Wing Water Fountain- Bottle Fill	0 ppb
Jordan-Small Middle School	A Wing Water Fountain- High Fountain	0 ppb
Jordan-Small Middle School	A Wing Water Fountain- Low Fountain	0 ppb
Jordan-Small Middle School	B Wing Water Fountain- Bottle Fill	0 ppb
Jordan-Small Middle School	B Wing Water Fountain- High Fountain	0 ppb
Jordan-Small Middle School	B Wing Water Fountain- Low Fountain	0 ppb
Jordan-Small Middle School	C Wing Custodial- Sink Faucet	6.5 ppb
Jordan-Small Middle School	Caft Water Fountain- Bottle Fill	0 ppb
Jordan-Small Middle School	Caft Water Fountain- High Fountain	0 ppb
Jordan-Small Middle School	Caft Water Fountain- Low Fountain	0 ppb
Jordan-Small Middle School	Gym Lobby Wf By Entrance- Bottle Fill	0 ppb
Jordan-Small Middle School	Gym Lobby Wf By Entrance- Low Fountain	0 ppb
Jordan-Small Middle School	Gym Lobby Wf By Entrance-high Fountain	0 ppb
Jordan-Small Middle School	Kitchen- Dishwash Sink Faucet #1 Left	3.8 ppb
Jordan-Small Middle School	Kitchen- Dishwash Sink Faucet #2 Right	8.9 ppb
Jordan-Small Middle School	Kitchen- Dishwash Spray Faucet	8.8 ppb
Jordan-Small Middle School	Kitchen- Prep Sink Faucet	10 ppb
Jordan-Small Middle School	Rm A102- Demonstration Table Faucet #2 Cw	36.2 ppb
Jordan-Small Middle School	Rm A102- Left Island Faucet #1 Cw	29.5 ppb
Jordan-Small Middle School	Rm A102- Left Island Faucet #3 Cw	36 ppb
Jordan-Small Middle School	Rm A102- Left Island Faucet #5 Cw	32.5 ppb
Jordan-Small Middle School	Rm A102- Right Island Faucet #1 Cw	1.6 ppb
Jordan-Small Middle School	Rm A102- Right Island Faucet #3 Cw	28.8 ppb
Jordan-Small Middle School	Rm A102- Right Island Faucet #5 Cw	44.3 ppb
Jordan-Small Middle School	Rm A103- Bubbler	9.3 ppb
Jordan-Small Middle School	Rm A105- Bubbler	8.4 ppb
Jordan-Small Middle School	Rm A106- Bubbler	28.5 ppb
Jordan-Small Middle School	Rm A108- Bubbler	8.5 ppb
Jordan-Small Middle School	Rm A110- Bubbler	10.5 ppb
Jordan-Small Middle School	Rm A112- Bubbler	20.5 ppb
Jordan-Small Middle School	Rm A113- Bubbler	5.7 ppb
Jordan-Small Middle School	Rm A114 Teachers Break Rm- Faucet (in Hall)	2.8 ppb
Jordan-Small Middle School	Rm A114 Teachers Break Rm-hot & Cold Water Cooler	0 ppb
Jordan-Small Middle School	Rm B102 (art)- Island #2 Sink Faucet	4.6 ppb

School Name	Sample Location	Lead Test Result
Jordan-Small Middle School	Rm B103- Bubbler	6.2 ppb
Jordan-Small Middle School	Rm C110- Bubbler	8.3 ppb
Jordan-Small Middle School	Rm C111- Back Bench 1st Faucet On Right Cw	37.5 ppb
Jordan-Small Middle School	Rm C111- Back Bench 3rd Faucet Cw	37.7 ppb
Jordan-Small Middle School	Rm C111- Back Bench 5th Faucet Cw	31.8 ppb
Jordan-Small Middle School	Rm C111- Back Bench 7th Faucet Cw	30.8 ppb
Jordan-Small Middle School	Rm C111- Back Bench 9th Faucet Cw	23.6 ppb
Jordan-Small Middle School	Rm C113- Bubbler	13.5 ppb
Jordan-Small Middle School	Rm C119- Bubbler	3.9 ppb
Jordan-Small Middle School	Rm C120- Bubbler	4.7 ppb
Jordan-Small Middle School	Rm C122- Bubbler	5.4 ppb
Katahdin Elementary School	Boys Bathroom	0 ppb
Katahdin Elementary School	Boys Locker Hall	12.5 ppb
Katahdin Elementary School	Boys Locker Room	8.1 ppb
Katahdin Elementary School	Girls Bathroom	0 ppb
Katahdin Elementary School	Girls Locker Hall	0 ppb
Katahdin Elementary School	Girls Locker Room	0 ppb
Katahdin Elementary School	Hall Fountain	0 ppb
Katahdin Elementary School	Hall Water Fountain	0 ppb
Katahdin Elementary School	Jaides Room	0 ppb
Katahdin Elementary School	Main Office	0 ppb
Katahdin Elementary School	Ne Bathroom Boys	0 ppb
Katahdin Elementary School	Ne Bathroom Girls	1.1 ppb
Katahdin Elementary School	Red Hall	0 ppb
Katahdin Elementary School	Rinse	11 ppb
Katahdin Elementary School	Room 224	0 ppb
Katahdin Elementary School	Room 229	0 ppb
Katahdin Elementary School	Room 230	0 ppb
Katahdin Elementary School	Room 235	0 ppb
Katahdin Elementary School	Room 237	0 ppb
Katahdin Elementary School	Room 238	2.5 ppb
Katahdin Elementary School	Room 239	0 ppb
Katahdin Elementary School	Room 240	0 ppb
Katahdin Elementary School	Room 241	0 ppb
Katahdin Elementary School	Room 242	0 ppb
Katahdin Elementary School	Room 243	0 ppb
Katahdin Elementary School	Room 244	0 ppb
Katahdin Elementary School	Room 246	0 ppb
Katahdin Elementary School	Room 248	0 ppb
Katahdin Elementary School	Room 269	0 ppb
Katahdin Elementary School	Room 280	0 ppb
Katahdin Elementary School	Sanitize	4.1 ppb
Katahdin Elementary School	Teachers Room	1.2 ppb
Katahdin Elementary School	Wash Kitchen (1)	1.5 ppb
Katahdin Elementary School	Wash Kitchen (2)	0 ppb
Katahdin Middle/High School	Gym	0 ppb

School Name	Sample Location	Lead Test Result
Katahdin Middle/High School	Ice Machine	0 ppb
Katahdin Middle/High School	Kitchen Sink (1)	0 ppb
Katahdin Middle/High School	Kitchen Sink (2)	0 ppb
Katahdin Middle/High School	Main Hall	0 ppb
Katahdin Middle/High School	Middle School Hall	0 ppb
Katahdin Middle/High School	Room 701	4.6 ppb
Katahdin Middle/High School	Sink 1	0 ppb
Katahdin Middle/High School	Sink 2	0 ppb
Katahdin Middle/High School	Sink 3	0 ppb
Katahdin Middle/High School	Teachers Room	1.1 ppb
Katahdin Middle/High School	Upper Hall	31.2 ppb
Kate Furbish Elementary School	Bathroom 1	0 ppb
Kate Furbish Elementary School	Bathroom 10	0 ppb
Kate Furbish Elementary School	Bathroom 11	0 ppb
Kate Furbish Elementary School	Bathroom 12	18.7 ppb
Kate Furbish Elementary School	Bathroom 13	0 ppb
Kate Furbish Elementary School	Bathroom 14	0 ppb
Kate Furbish Elementary School	Bathroom 15	0 ppb
Kate Furbish Elementary School	Bathroom 16	0 ppb
Kate Furbish Elementary School	Bathroom 17	0 ppb
Kate Furbish Elementary School	Bathroom 18	0 ppb
Kate Furbish Elementary School	Bathroom 19	0 ppb
Kate Furbish Elementary School	Bathroom 2	0 ppb
Kate Furbish Elementary School	Bathroom 20	0 ppb
Kate Furbish Elementary School	Bathroom 21	0 ppb
Kate Furbish Elementary School	Bathroom 22	0 ppb
Kate Furbish Elementary School	Bathroom 23	0 ppb
Kate Furbish Elementary School	Bathroom 24	0 ppb
Kate Furbish Elementary School	Bathroom 25	0 ppb
Kate Furbish Elementary School	Bathroom 26	0 ppb
Kate Furbish Elementary School	Bathroom 27	0 ppb
Kate Furbish Elementary School	Bathroom 28	0 ppb
Kate Furbish Elementary School	Bathroom 29	0 ppb
Kate Furbish Elementary School	Bathroom 3	0 ppb
Kate Furbish Elementary School	Bathroom 30	0 ppb
Kate Furbish Elementary School	Bathroom 31	0 ppb
Kate Furbish Elementary School	Bathroom 32	0 ppb
Kate Furbish Elementary School	Bathroom 33	0 ppb
Kate Furbish Elementary School	Bathroom 34	0 ppb
Kate Furbish Elementary School	Bathroom 35	0 ppb
Kate Furbish Elementary School	Bathroom 36	0 ppb
Kate Furbish Elementary School	Bathroom 37	0 ppb
Kate Furbish Elementary School	Bathroom 38	0 ppb
Kate Furbish Elementary School	Bathroom 39	0 ppb
Kate Furbish Elementary School	Bathroom 4	0 ppb
Kate Furbish Elementary School	Bathroom 40	0 ppb
Kate Furbish Elementary School	Bathroom 5	0 ppb

School Name	Sample Location	Lead Test Result
Kate Furbish Elementary School	Bathroom 6	0 ppb
Kate Furbish Elementary School	Bathroom 7	0 ppb
Kate Furbish Elementary School	Bathroom 8	0 ppb
Kate Furbish Elementary School	Bathroom 9	0 ppb
Kate Furbish Elementary School	Cafe/lunch Room Handwash Sink #1	0 ppb
Kate Furbish Elementary School	Cafe/lunch Room Handwashsink #2	0 ppb
Kate Furbish Elementary School	Cafe/lunch Room Handwashsink #3	0 ppb
Kate Furbish Elementary School	Drink Fountain #1 Pine Hall 1fl (bottle)	0 ppb
Kate Furbish Elementary School	Drink Fountain #1 Pine Hall 1fl (drink)	0 ppb
Kate Furbish Elementary School	Drink Fountain #2 Adjacent Artoom (bottle)	0 ppb
Kate Furbish Elementary School	Drink Fountain #2 Adjacent Artoom (drink)	0 ppb
Kate Furbish Elementary School	Drink Fountain #3 Lunch Room (bottle)	0 ppb
Kate Furbish Elementary School	Drink Fountain #3 Lunch Room (drink)	0 ppb
Kate Furbish Elementary School	Drink Fountain #4 Gymnasium (bottle)	0 ppb
Kate Furbish Elementary School	Drink Fountain #4 Gymnasium (drink)	0 ppb
Kate Furbish Elementary School	Drink Fountain #5 Oak Hall F1 (bottle)	0 ppb
Kate Furbish Elementary School	Drink Fountain #5 Oak Hall F1 (drink)	0 ppb
Kate Furbish Elementary School	Drinking Fountain #6 Pine Hall F12 (bottle)	0 ppb
Kate Furbish Elementary School	Drinking Fountain #6 Pine Hall F12 (drink)	0 ppb
Kate Furbish Elementary School	Drinking Fountain #7 Oak Hall F12 (bottle)	0 ppb
Kate Furbish Elementary School	Drinking Fountain #7 Oak Hall F12 (drink)	0 ppb
Kate Furbish Elementary School	Kitchen Sink #1	0 ppb
Kate Furbish Elementary School	Kitchen Sink #2	0 ppb
Kate Furbish Elementary School	Kitchen Sink #3	0 ppb
Kate Furbish Elementary School	Kitchen Sink #4	1.1 ppb
Kate Furbish Elementary School	Kitchen Sink #5 (kettle)	545 ppb
Kate Furbish Elementary School	Kitchen Sink #6	1.2 ppb
Kate Furbish Elementary School	Kitchen Sink #7	0 ppb
Kate Furbish Elementary School	Kitchen Sink #8	0 ppb
Kate Furbish Elementary School	Room 100 Classroom Bathroom Sink	0 ppb
Kate Furbish Elementary School	Room 100 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 100 Icemaker	0 ppb
Kate Furbish Elementary School	Room 110 Classroom Bathroom Sink	0 ppb
Kate Furbish Elementary School	Room 110 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 110 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 111 Classroom Bathroom Sink	0 ppb
Kate Furbish Elementary School	Room 111 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 111 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 112 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 112 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 113 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 113 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 114 Classroom Bathroom Sink	0 ppb
Kate Furbish Elementary School	Room 114 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 114 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 115 Classroom Bathroom Sink	0 ppb

School Name	Sample Location	Lead Test Result
Kate Furbish Elementary School	Room 115 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 115 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 116 Classroom Bathroom Sink	0 ppb
Kate Furbish Elementary School	Room 116 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 116 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 117 Classroom Bathroom Sink	0 ppb
Kate Furbish Elementary School	Room 117 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 117 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 118 Classroom Bathroom Sink	0 ppb
Kate Furbish Elementary School	Room 118 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 118 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 119 Classroom Bathroom Sink	0 ppb
Kate Furbish Elementary School	Room 119 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 119 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 120 Classroom Bathroom Sink	0 ppb
Kate Furbish Elementary School	Room 120 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 120 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 121 Classroom Bathroom Sink	0 ppb
Kate Furbish Elementary School	Room 121 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 121 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 122 Classroom Bathroom Sink	0 ppb
Kate Furbish Elementary School	Room 122 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 122 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 123	0 ppb
Kate Furbish Elementary School	Room 124 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 124 Icemaker	0 ppb
Kate Furbish Elementary School	Room 133 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 136 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 136 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 139 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 139 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 144 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 144 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 149 Classroom Bathroom Sink	0 ppb
Kate Furbish Elementary School	Room 159 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 159 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 166 Classroom Sink (#1)	0 ppb
Kate Furbish Elementary School	Room 166 Classroom Sink (#2)	0 ppb
Kate Furbish Elementary School	Room 166 Classroom Sink (#3)	0 ppb
Kate Furbish Elementary School	Room 171 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 171 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 172 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 172 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 174 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 174 Icemaker	1.4 ppb
Kate Furbish Elementary School	Room 175 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 175 Classroom Sink	0 ppb

School Name	Sample Location	Lead Test Result
Kate Furbish Elementary School	Room 216 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 216 Icemaker	1.4 ppb
Kate Furbish Elementary School	Room 219 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 220 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 220 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 230 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 230 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 231 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 231 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 232 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 232 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 233 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 233 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 234 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 234 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 235 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 235 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 236 Classroom Drink Fountain	0 ppb
Kate Furbish Elementary School	Room 236 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 238 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 239 Classroom Sink	0 ppb
Kate Furbish Elementary School	Room 239 Icemaker	1 ppb
Kennebec Montessori School	Art Kitchen	0 ppb
Kennebec Montessori School	Before Care/after Care Kitchen	2.9 ppb
Kennebec Montessori School	Drinking Fountain, Atrium	0 ppb
Kennebec Montessori School	Le1 Kitchen	0 ppb
Kennebec Montessori School	Le2 Kitchen	0 ppb
Kennebec Montessori School	P1 Kitchen	0 ppb
Kennebec Montessori School	P2 Kitchen	0 ppb
Kennebec Montessori School	P3 Kitchen	0 ppb
Kennebec Montessori School	Staff Kitchen	1.2 ppb
Kennebec Montessori School	Ue Kitchen	0 ppb
Kennebunk Elementary School	A101 Faucet Sink	0 ppb
Kennebunk Elementary School	A118 Class Sink	0 ppb
Kennebunk Elementary School	A123 Class Sink	0 ppb
Kennebunk Elementary School	A136 Mrs. Towne Sink	1.5 ppb
Kennebunk Elementary School	A145 Office Sink	0 ppb
Kennebunk Elementary School	Art Room Sinks Drinking Water #1	0 ppb
Kennebunk Elementary School	Art Room Sinks Drinking Water #2	0 ppb
Kennebunk Elementary School	Art Room Sinks Drinking Water #3	0 ppb
Kennebunk Elementary School	Art Room Sinks Drinking Water #4	0 ppb
Kennebunk Elementary School	B108 Mail Room Sink	0 ppb
Kennebunk Elementary School	B114 Nurse Sink	1.7 ppb
Kennebunk Elementary School	B114 Nurse Sink #2	0 ppb
Kennebunk Elementary School	B121 Office Sink	0 ppb
Kennebunk Elementary School	B140 Library Sink	0 ppb

School Name	Sample Location	Lead Test Result
Kennebunk Elementary School	Bottle Fill Station A Wing Main Hall Bath Room	0 ppb
Kennebunk Elementary School	Bottle Fill Station East Wing Near Gang Bathroom	0 ppb
Kennebunk Elementary School	Bottle Fill Station Gym Bath Walk In	0 ppb
Kennebunk Elementary School	Bottle Fill Station North Wing Near Gang Bathroom	0 ppb
Kennebunk Elementary School	Bottle Fill Station West Wing Near Gang Bathroom	0 ppb
Kennebunk Elementary School	C104 Learning Lab #1	0 ppb
Kennebunk Elementary School	C104 Learning Lab #2	0 ppb
Kennebunk Elementary School	C106	0 ppb
Kennebunk Elementary School	C109	0 ppb
Kennebunk Elementary School	C110	0 ppb
Kennebunk Elementary School	C114	0 ppb
Kennebunk Elementary School	C117	0 ppb
Kennebunk Elementary School	C118	0 ppb
Kennebunk Elementary School	C119	0 ppb
Kennebunk Elementary School	C120	0 ppb
Kennebunk Elementary School	C122	0 ppb
Kennebunk Elementary School	C123	0 ppb
Kennebunk Elementary School	C124	0 ppb
Kennebunk Elementary School	C136	0 ppb
Kennebunk Elementary School	C137	0 ppb
Kennebunk Elementary School	C140	0 ppb
Kennebunk Elementary School	D101	0 ppb
Kennebunk Elementary School	D102	0 ppb
Kennebunk Elementary School	D103	0 ppb
Kennebunk Elementary School	D107	0 ppb
Kennebunk Elementary School	D109	0 ppb
Kennebunk Elementary School	D117	0 ppb
Kennebunk Elementary School	D118	0 ppb
Kennebunk Elementary School	D119	0 ppb
Kennebunk Elementary School	D121	0 ppb
Kennebunk Elementary School	D122	0 ppb
Kennebunk Elementary School	D123	0 ppb
Kennebunk Elementary School	D124	0 ppb
Kennebunk Elementary School	D130	0 ppb
Kennebunk Elementary School	D134	0 ppb
Kennebunk Elementary School	D135	0 ppb
Kennebunk Elementary School	E101	0 ppb
Kennebunk Elementary School	E102	0 ppb
Kennebunk Elementary School	E103	0 ppb
Kennebunk Elementary School	E106	0 ppb
Kennebunk Elementary School	E107	1.7 ppb
Kennebunk Elementary School	E108	0 ppb
Kennebunk Elementary School	E109	0 ppb

School Name	Sample Location	Lead Test Result
Kennebunk Elementary School	E110	0 ppb
Kennebunk Elementary School	E124	0 ppb
Kennebunk Elementary School	E126	0 ppb
Kennebunk Elementary School	E127	0 ppb
Kennebunk Elementary School	E128	0 ppb
Kennebunk Elementary School	Kitchen 3 Bay Sink	1.3 ppb
Kennebunk Elementary School	Kitchen Dish Washer Sink	4 ppb
Kennebunk Elementary School	Kitchen Hand Sink By Dish Washer	4.4 ppb
Kennebunk Elementary School	Kitchen Hand Sink By Oven	0 ppb
Kennebunk Elementary School	Kitchen Tilt Kettle	0 ppb
Kennebunk Elementary School	Kitchen Work Station Sink	0 ppb
Kennebunk High School	A Gym Water Bottle Fill Station	0 ppb
Kennebunk High School	Art Wing Gang Bathroom Water Fill	0 ppb
Kennebunk High School	C Building Water Fill Bottle	0 ppb
Kennebunk High School	Concession Stand Sample	0 ppb
Kennebunk High School	Concession Stand Sample Inside	0 ppb
Kennebunk High School	Concession Stand Sample Outside	0 ppb
Kennebunk High School	Fill Sink #1	0 ppb
Kennebunk High School	Fill Sink #2	0 ppb
Kennebunk High School	Fill Sink #3	0 ppb
Kennebunk High School	Khs Kitchen Sink	0 ppb
Kennebunk High School	Khs Main Lobby	0 ppb
Kennebunk High School	Kitchen Sink #1	0 ppb
Kennebunk High School	Kitchen Sink #2	0 ppb
Kennebunk High School	Kitchen Sink #3	0 ppb
Kennebunk High School	Kitchen Sink #4	0 ppb
Kennebunk High School	Kitchen Sink #5	4.5 ppb
Kennebunk High School	Kitchen Sink #6	0 ppb
Kennebunk High School	Math Gang Bathroom	0 ppb
Kennebunk High School	Nurse Office	0 ppb
Kennebunk High School	Regal Sink	0 ppb
Kennebunk High School	Tilt Skillet	2.8 ppb
Kennebunkport Consolidated Sch	Drinking Fountain Outside Gym	0 ppb
Kennebunkport Consolidated Sch	Outside Rm 127	0 ppb
Kennebunkport Consolidated Sch	Rm 129 Sink	0 ppb
Kennebunkport Consolidated Sch	Rm 155 #2	0 ppb
Kennebunkport Consolidated Sch	Rm 155 #3	0 ppb
Kennebunkport Consolidated Sch	Rm 155 #4	0 ppb
Kennebunkport Consolidated Sch	Room 155	0 ppb
Kennebunkport Consolidated Sch	Water Fill Station Room 104 #1	0 ppb
Kennebunkport Consolidated Sch	Water Fill Station Room 104 #2	0 ppb
Kennebunkport Consolidated Sch	Water Fill Station Room 104 #3	0 ppb
Kents Hill School	Akin Ctr-bottle Filling Stn-basement	0 ppb
Kents Hill School	Akin Ctr-bottle Filling Stn-floor 1	0 ppb
Kents Hill School	Akin Ctr-kitchenette Room 104	0 ppb
Kents Hill School	Akin Ctr-kitchenette Room 117	0 ppb
Kents Hill School	Alfond Athletic Ctr-fountain-floor 1	0 ppb

School Name	Sample Location	Lead Test Result
Kents Hill School	Alfond Athletic Ctr-fountain-floor 2	0 ppb
Kents Hill School	Alfond Athletic Ctr-ice Machine	0 ppb
Kents Hill School	Bearce Hall Admissions - Kitchenette	0 ppb
Kents Hill School	Bodman/newton-fountain-lobby	0 ppb
Kents Hill School	Bodman/newton-kitchenette	2.6 ppb
Kents Hill School	Dining Commons-hall Bottle Filling Stn	0 ppb
Kents Hill School	Dining Commons-ice Machine	0 ppb
Kents Hill School	Dining Commons-ktchn Food Prep Sink	0 ppb
Kents Hill School	Dining Commons-ktchn Vegetable Sink	0 ppb
Kents Hill School	Health Clinic- Nurses Station Side Hall	0 ppb
Kents Hill School	Health Clinic-isolation Wng Kitchenette	1.3 ppb
Kents Hill School	Health Clinic-kichenette	0 ppb
Kents Hill School	Ricker Hall Drinking Fountain Floor 2	0 ppb
Kents Hill School	Ricker Hall Drinking Fountain-floor 3	3.3 ppb
Kents Hill School	Ricker Hall Sudent Center-ice Machine	0 ppb
Kents Hill School	Ricker Hall Sudent Ctr-prep Kitchen	0 ppb
Kents Hill School	Sampson Hall Library-filling Station	0 ppb
Kents Hill School	Ski Lodge Drinking Fountain-floor 1	0 ppb
Kermit S Nickerson School	Classroom 103	0 ppb
Kermit S Nickerson School	Classroom 104	0 ppb
Kermit S Nickerson School	Classroom 105	0 ppb
Kermit S Nickerson School	Classroom 106	0 ppb
Kermit S Nickerson School	Classroom 108	0 ppb
Kermit S Nickerson School	Classroom 109	0 ppb
Kermit S Nickerson School	Classroom 110	0 ppb
Kermit S Nickerson School	Classroom 117	0 ppb
Kermit S Nickerson School	Clinic 1	0 ppb
Kermit S Nickerson School	Hallway 1	0 ppb
Kermit S Nickerson School	Hallway 2	0 ppb
Kermit S Nickerson School	Kitchen 1	0 ppb
Kermit S Nickerson School	Kitchen 2	0 ppb
Kermit S Nickerson School	Kitchen 3	0 ppb
Kidspeace Old Town	1 Bathroom Sink-mens	2.5 ppb
Kidspeace Old Town	1 Bathroom Sink-womens	2.9 ppb
Kidspeace Old Town	2 Bathroom Sink-mens	2.5 ppb
Kidspeace Old Town	2 Bathroom Sink-womens	2.3 ppb
Kidspeace Old Town	Utility Sink	1.8 ppb
KidsPeace-Millinocket	Auditorium-mens Bathroom	4.9 ppb
KidsPeace-Millinocket	Auditorium-womens Bathroom	9.2 ppb
KidsPeace-Millinocket	High School Gym Dwf	0 ppb
KidsPeace-Millinocket	Main Hallway Dwf	0 ppb
KidsPeace-Millinocket	Main Hallway-mens Bathroom	4.1 ppb
KidsPeace-Millinocket	Main Hallway-womens Bathroom	1.9 ppb
KidsPeace-Millinocket	Middle School Gym Dwf (west)	0 ppb
KidsPeace-Millinocket	Office Hallway Dwf	0 ppb
KidsPeace-Millinocket	Pre-k Classroom Sink	1.7 ppb
KidsPeace-Millinocket	Resource Room Sink	1.9 ppb

School Name	Sample Location	Lead Test Result
Kieve-Wavus Education Inc (NTP)	Buck Lower	7.8 ppb
Kieve-Wavus Education Inc (NTP)	Buck Upper	4 ppb
Kieve-Wavus Education Inc (NTP)	Cutler Large	1.9 ppb
Kieve-Wavus Education Inc (NTP)	Cutler Small	1 ppb
Kieve-Wavus Education Inc (NTP)	J 3 Bay	0 ppb
Kieve-Wavus Education Inc (NTP)	J Coffee Station	0 ppb
Kieve-Wavus Education Inc (NTP)	J Deck	128 ppb
Kieve-Wavus Education Inc (NTP)	J Dining Hall	0 ppb
Kieve-Wavus Education Inc (NTP)	J Ice	0 ppb
Kieve-Wavus Education Inc (NTP)	J Lower	0 ppb
Kieve-Wavus Education Inc (NTP)	J Skillet	0 ppb
Kieve-Wavus Education Inc (NTP)	J Veg Sink	2.5 ppb
Kieve-Wavus Education Inc (NTP)	Mem Appt	1.4 ppb
Kieve-Wavus Education Inc (NTP)	Pq	6.8 ppb
Kieve-Wavus Education Inc (NTP)	Pq 3 Bay	46.4 ppb
Kieve-Wavus Education Inc (NTP)	Pq Ice	15 ppb
Kieve-Wavus Education Inc (NTP)	Pq Skillet	35.9 ppb
King Middle School	107-1	3.1 ppb
King Middle School	107-2	4.2 ppb
King Middle School	111-1	1.4 ppb
King Middle School	111-2	1.9 ppb
King Middle School	114 - 1st Sink To The Left	7.5 ppb
King Middle School	114 - 2nd Sink To The Left	2.2 ppb
King Middle School	114 - 3rd Sink To The Left	5.8 ppb
King Middle School	116-1	2.3 ppb
King Middle School	116-2	6.3 ppb
King Middle School	207-1	0 ppb
King Middle School	207-2	2.1 ppb
King Middle School	215-1	3.6 ppb
King Middle School	215-2	4.5 ppb
King Middle School	229-1	1.5 ppb
King Middle School	229-2	1.4 ppb
King Middle School	Bottle Filler - By 107	0 ppb
King Middle School	Bottle Filler - By 203	0 ppb
King Middle School	Bottle Filler - By 207	0 ppb
King Middle School	Bottle Filler - By 223	0 ppb
King Middle School	Bottle Filler - By Custodial Office By 114	0 ppb
King Middle School	Bottle Filler - On Ramp By Cafeteria 1st Floor	0 ppb
King Middle School	Kitchen Sink - 1st Floor	1.1 ppb
King Middle School	Nurse Sink - 1st Floor	1.5 ppb
King Middle School	Pos-1	118 ppb
Kingfield Elementary School	Kitchen 3 Bay Sink Lhs	63.1 ppb
Kingfield Elementary School	Kitchen 3 Bay Sink Rhs	53.9 ppb
Kingfield Elementary School	Kitchen Prep Sink	2.8 ppb
Kingfield Elementary School	Room C-pk Lhs	3.8 ppb
Kingfield Elementary School	Room C-pk Rhs	3.5 ppb

School Name	Sample Location	Lead Test Result
Kingfield Elementary School	Room D	0 ppb
Kingfield Elementary School	Room E	0 ppb
Kingfield Elementary School	Room F	1.1 ppb
Kingfield Elementary School	Room G	0 ppb
Kingfield Elementary School	Room H	1.4 ppb
Kingfield Elementary School	Room X	0 ppb
Kingfield Elementary School	Staff Room	4.2 ppb
Kingfield Elementary School	Upper Grade Wing Water Cooler #1	0 ppb
Kingfield Elementary School	Upper Grade Wing Water Cooler #2	0 ppb
Kingman Elementary School	Boy's Bathroom Sink	6 ppb
Kingman Elementary School	Drinking Water Dispensor-cafeteria	0 ppb
Kingman Elementary School	Girl's Bathroom Sink	11.8 ppb
Kingman Elementary School	Grades 2-6 Classroom Sink	12.4 ppb
Kingman Elementary School	Ice Making Machine	4.7 ppb
Kingman Elementary School	Kitchen Sink	5.8 ppb
Kingman Elementary School	Library/sped Classroom Sink	12.8 ppb
Kingman Elementary School	Prek-1 Classroom Sink	14.3 ppb
Kingman Elementary School	Staff Bathroom Sink	92.6 ppb
Kittery Academy	Has Water Brought In- No Water From Their Plumbing	
Kittery Kids Academy	Has Water Brought In- No Water Is Served From Their Plumbing	
Lake Region High School	Boys Locker Rm Ice Machine	1.2 ppb
Lake Region High School	Conession Sink	53.5 ppb
Lake Region High School	Girls Locker Rm Ice Machine	0 ppb
Lake Region High School	Hallway Dwf Bottle Fill Outside Rm 146	4.5 ppb
Lake Region High School	Hallway Dwf Outside Rm 146	4.9 ppb
Lake Region High School	Hallway Outside V 102 Bottle Fill	0 ppb
Lake Region High School	Hallway Outside V 102 Dwf A	0 ppb
Lake Region High School	Hallway Outside V 102 Dwf B	0 ppb
Lake Region High School	Main Hallway Df Outside Rm 168	0 ppb
Lake Region High School	Main Kitchen 3 Bay Sink Faucet A	0 ppb
Lake Region High School	Main Kitchen 3 Bay Sink Faucet B	0 ppb
Lake Region High School	Main Kitchen Grille Top	2.2 ppb
Lake Region High School	Main Kitchen Hand Sink A	7.6 ppb
Lake Region High School	Main Kitchen Hand Sink B	4.8 ppb
Lake Region High School	Main Kitchen Hand Sink C	0 ppb
Lake Region High School	Main Kitchen Hand Sink D	0 ppb
Lake Region High School	Main Kitchen Kettle	7.2 ppb
Lake Region High School	Main Kitchendouble Sink	0 ppb
Lake Region High School	Nurses Office Exam Rm Sink	4.4 ppb
Lake Region High School	Nurses Office Ice Machine	0 ppb
Lake Region High School	Nurses Office Sink	0 ppb
Lake Region High School	Rm 138 Sink	0 ppb
Lake Region High School	Rm 139 Sink	1.6 ppb
Lake Region High School	Rm 140 Sink	0 ppb
Lake Region High School	Rm 148 Sink Faucet A	3 ppb

School Name	Sample Location	Lead Test Result
Lake Region High School	Rm 148 Sink Faucet B	1.7 ppb
Lake Region High School	Rm 150 Sink	2.8 ppb
Lake Region High School	Rm 151 Sink Faucet A	0 ppb
Lake Region High School	Rm 151 Sink Faucet B	2.5 ppb
Lake Region High School	Rm 152 Sink	1.3 ppb
Lake Region High School	Rm 153 Sink	2.6 ppb
Lake Region High School	Rm 216 Sink	0 ppb
Lake Region High School	Rm 223 Sink A	0 ppb
Lake Region High School	Rm 223 Sink B	0 ppb
Lake Region High School	Rm 223 Sink C	7.9 ppb
Lake Region High School	Rm V 109 2 Bay Sink	0 ppb
Lake Region High School	Rm V 112 2 Bay Sink	1.3 ppb
Lake Region High School	Rm V 113 Sink	1.2 ppb
Lake Region High School	Rm V 118 2 Bay Sink	0 ppb
Lake Region High School	Rm V 125 Dish Washer Sink	3.2 ppb
Lake Region High School	Rm V 125 Hand Sink A	0 ppb
Lake Region High School	Rm V 125 Hand Sink B	1.1 ppb
Lake Region High School	Rm V 125 Hand Sink C	1.9 ppb
Lake Region High School	Rm V 125 Sink	2 ppb
Lake Region High School	Rm V 129 Sink	0 ppb
Lake Region High School	Rm V125 3 Bay Sink Faucet A	0 ppb
Lake Region High School	Rm V125 3 Bay Sink Faucet B	0 ppb
Lake Region High School	Rm V125 Ice Machine	0 ppb
Lake Region High School	Rm V129 3- Bay Sink Faucet A	0 ppb
Lake Region High School	Rm V129 3- Bay Sink Faucet B	5.2 ppb
Lake Region High School	Rm V133 Sink	1.2 ppb
Lake Region High School	Wh- Break Rm Sink	0 ppb
Lake Region High School	Wh- Hallway Main Entrance Bottle Fill Dwf	0 ppb
Lake Region High School	Wh Rm 101 Sink	0 ppb
Lake Region High School	Wh- Rm 102 Sink	0 ppb
Lake Region High School	Wh-hallway Main Entrance Dwf	0 ppb
Lake Region High School	Wh-maint Shop Sink	0 ppb
Lake Region High School	Y Hallway Drinking Water Bottle Fill	0 ppb
Lake Region High School	Y Hallway Drinking Water Fountain A	0 ppb
Lake Region High School	Y Hallway Drinking Water Fountain B	0 ppb
Lake Region Middle School	Art Rm # B Sink	3.7 ppb
Lake Region Middle School	Art Rm Sink # A Sink	4 ppb
Lake Region Middle School	Bottle Fill Across Rm 117	0 ppb
Lake Region Middle School	Bottle Fill Hallway Across Rm 201	0 ppb
Lake Region Middle School	Bottle Fill Hallway Across Rm 217	0 ppb
Lake Region Middle School	Dwf Across Rm 117	0 ppb
Lake Region Middle School	Dwf Hallway Across Rm 201	0 ppb
Lake Region Middle School	Dwf Hallway Across Rm 217	0 ppb
Lake Region Middle School	Home Ec Rm Sink # A	1.1 ppb
Lake Region Middle School	Home Ec Rm Sink # B	1.3 ppb
Lake Region Middle School	Home Ec Rm Sink # C	3.2 ppb
Lake Region Middle School	Home Ec Rm Sink # D	4.9 ppb

School Name	Sample Location	Lead Test Result
Lake Region Middle School	Home Ec Rm Sink # E	4.4 ppb
Lake Region Middle School	Home Ec Rm Sink # F	5 ppb
Lake Region Middle School	Library Sink	22.1 ppb
Lake Region Middle School	Lower Level Hallway Bottle Fill	0 ppb
Lake Region Middle School	Lower Level Hallway Dwf	0 ppb
Lake Region Middle School	Lower Level Hallway Sink	2.6 ppb
Lake Region Middle School	Lower Level Rm 1 Sink	0 ppb
Lake Region Middle School	Lower Level Staff Rm Sink	0 ppb
Lake Region Middle School	Main Kitchen Double Bay Sink Faucet	3.4 ppb
Lake Region Middle School	Main Kitchen Double Bay Sink Sprayer	4.8 ppb
Lake Region Middle School	Main Kitchen Single Bay Sink Facuet	9.5 ppb
Lake Region Middle School	Main Kitchen Single Bay Sink Sprayer	9.8 ppb
Lake Region Middle School	Main Lobby Bottle Fill	0 ppb
Lake Region Middle School	Main Lobby Dwf	0 ppb
Lake Region Middle School	Maine Kitchen Hand Sink	28.9 ppb
Lake Region Middle School	Nurse Office Ice Maker	0 ppb
Lake Region Middle School	Nurse Office Sink	2.1 ppb
Lake Region Middle School	Rm 106 Sink	1.4 ppb
Lake Region Middle School	Rm 120 Sink	5.4 ppb
Lake Region Middle School	Rm 209 Sink	20.5 ppb
Lake Region Middle School	Rm 219 Sink	5.3 ppb
Lake Region Middle School	Staff Room Sink	1.5 ppb
Lake Region Vocational Center	Coession Stand Sink	0 ppb
Lake Region Vocational Center	Drinking Fountain Hallway Lrvc # B	0 ppb
Lake Region Vocational Center	Drinking Fountain Hallway Lrvc Bottle Fill	0 ppb
Lake Region Vocational Center	Drinking Fountain Hallway Lrvc Side #a	0 ppb
Lake Region Vocational Center	Drinking Fountain Hallways Services # B	0 ppb
Lake Region Vocational Center	Drinking Fountain Hallways Services #a	0 ppb
Lake Region Vocational Center	Drinking Fountain Hallways Services Bottle Fill	0 ppb
Lake Region Vocational Center	Kitchen Sink-break Room	0 ppb
Lamoine Consolidated School	Food Prep Sink In Kitchen	117 ppb
Lamoine Consolidated School	Front Hallway Drinking Fountain & Bottle Fill	6.1 ppb
Lamoine Consolidated School	Lower End Drinking Fountain	10.9 ppb
Lamoine Consolidated School	Office Faucet	11.7 ppb
Laura E Richards School	Bottle Fill Cafeteria Alcove - Gang Bathroom	0 ppb
Laura E Richards School	Bottle Fill Gang Bathroom Upstairs	0 ppb
Laura E Richards School	Bottle Fill Gang Bathroom Upstairs End Of Hallway	0 ppb
Laura E Richards School	Bottle Fill Gym Lobby	0 ppb
Laura E Richards School	Cafe Handwash Faucet Left Of Art Room	0 ppb
Laura E Richards School	Cafe Handwash Faucet Right Of Art Room	0 ppb
Laura E Richards School	Kitchen Double Basin Sink Near Dishwasher	4 ppb

School Name	Sample Location	Lead Test Result
Laura E Richards School	Kitchen Single Basin Sink Next To Walk-in Freezer	0 ppb
Laura E Richards School	Nurse Bathroom Off Maine Office	0 ppb
Laura E Richards School	Staff Breakroom On Left Past Main Office Hw Sink	0 ppb
Laura E Richards School	Teach Bathroom Handwash Sink Bookroom	0 ppb
Lawrence High School	Annex Boys Bathroom Sink #1	10.9 ppb
Lawrence High School	Annex Boys Bathroom Sink #2	5 ppb
Lawrence High School	Annex Girls Bathroom Sink #1	1.9 ppb
Lawrence High School	Annex Girls Bathroom Sink #2	2.3 ppb
Lawrence High School	Boys Bathroom Main Lobby Sink	0 ppb
Lawrence High School	Boys Locker Room Sink	0 ppb
Lawrence High School	Cafeteria Drinking Fountain #1	0 ppb
Lawrence High School	Cafeteria Drinking Fountain #2	3.9 ppb
Lawrence High School	Coaches Office On Girls Side Sink	17 ppb
Lawrence High School	Coaches Room Boys Side Sink	8.6 ppb
Lawrence High School	Dean Of Students Bathroom Sink	1.7 ppb
Lawrence High School	Drinking Fountain Near B1/b2	58.5 ppb
Lawrence High School	Engli Wing Fountain	68.4 ppb
Lawrence High School	Girls Bathroom Main Lobby Sink	0 ppb
Lawrence High School	Girls Locker Room Sink #1	3 ppb
Lawrence High School	Girls Locker Room Sink #2	2 ppb
Lawrence High School	Health Center Bathroom Sink	1.5 ppb
Lawrence High School	Health Center Exam Rm #1 Sink	2.3 ppb
Lawrence High School	Health Center Nurses Station Sink	2.6 ppb
Lawrence High School	Isolation Room Sink	29.7 ppb
Lawrence High School	Kitchen Dishwashing Fixture #1	1.2 ppb
Lawrence High School	Kitchen Dishwashing Fixture #2	1.2 ppb
Lawrence High School	Library Sink Faucet	13 ppb
Lawrence High School	Main Hallway Drinking Fountain Annex	0 ppb
Lawrence High School	Main Lobby Drinking Fountain	0 ppb
Lawrence High School	Metal Shop Drinking Fountain	0 ppb
Lawrence High School	Metal Shop Sink	21.8 ppb
Lawrence High School	New Trainers Room Sink	1.6 ppb
Lawrence High School	Nurses Office Sink #1	4.7 ppb
Lawrence High School	Nurses Office Sink #2	3.7 ppb
Lawrence High School	Old Trainers Room Sink	1.2 ppb
Lawrence High School	Room C-2 Sink	3.5 ppb
Lawrence High School	Room C-2a Sink	8.7 ppb
Lawrence High School	Teachers Room Sink Across From C-5	47.8 ppb
Lawrence High School	Trainers Room Ice Maker	1.7 ppb
Lawrence High School	Trainers Sink	13.4 ppb
Lawrence High School	Wood Shop Drinking Fountain	0 ppb
Lawrence High School	Wood Shop Sink	25.9 ppb
Lawrence Jr High School	2nd Floor Hallway Drinking Fountain	0 ppb
Lawrence Jr High School	Boys Locker Room Sink #1	6.6 ppb
Lawrence Jr High School	Boys Locker Room Sink #2	5.2 ppb

School Name	Sample Location	Lead Test Result
Lawrence Jr High School	Cafeteria Drinking Fountain #1	23.4 ppb
Lawrence Jr High School	Cafeteria Drinking Fountain #2	0 ppb
Lawrence Jr High School	Girls Locker Room Sink #1	2.4 ppb
Lawrence Jr High School	Girls Locker Room Sink #2	0 ppb
Lawrence Jr High School	Gym Lobby Drinking Fountain	0 ppb
Lawrence Jr High School	Kitchen Faucet #1	0 ppb
Lawrence Jr High School	Kitchen Faucet #2	0 ppb
Lawrence Jr High School	Kitchen Faucet #3	0 ppb
Lawrence Jr High School	Loading Dock Ice Maker	0 ppb
Lawrence Jr High School	Main Hallway Boys Bathroom Sink #1	0 ppb
Lawrence Jr High School	Main Hallway Boys Bathroom Sink #2	0 ppb
Lawrence Jr High School	Main Hallway Drinking Fountain	3.4 ppb
Lawrence Jr High School	Main Hallway Girls Bathroom Sink #1	0 ppb
Lawrence Jr High School	Main Hallway Girls Bathroom Sink #2	0 ppb
Lawrence Jr High School	Nurses Area Bathroom Sink #1	1.6 ppb
Lawrence Jr High School	Nurses Area Bathroom Sink #2	1 ppb
Lawrence Jr High School	Room #100 Bathroom Sink	2.2 ppb
Lawrence Jr High School	Room #105 Sink #1	6.3 ppb
Lawrence Jr High School	Room #105 Sink #2	5 ppb
Lawrence Jr High School	Room #115 Sink	0 ppb
Lawrence Jr High School	Williamson Ctr Drinking Fountain #1	0 ppb
Lawrence Jr High School	Williamson Ctr Drinking Fountain #2	122 ppb
Lawrence Jr High School	Williamson Ctr Drinking Fountain 2nd Fl	0 ppb
Lawrence Jr High School	Wood Shop Drinking Fountain	0 ppb
Leavitt Area High School	Bottle Fill Across 105	0 ppb
Leavitt Area High School	Bottle Fill Across 143	0 ppb
Leavitt Area High School	Bottle Fill Across 204	0 ppb
Leavitt Area High School	Bottle Fill Across 226	0 ppb
Leavitt Area High School	Boys Bathroom Across 105 Faucet Left	1.1 ppb
Leavitt Area High School	Boys Bathroom Across 105 Faucet Middle	0 ppb
Leavitt Area High School	Boys Bathroom Across 105 Faucet Right	0 ppb
Leavitt Area High School	Boys Bathroom Across 143 Faucet Left	0 ppb
Leavitt Area High School	Boys Bathroom Across 143 Faucet Middle	0 ppb
Leavitt Area High School	Boys Bathroom Across 143 Faucet Right	0 ppb
Leavitt Area High School	Boys Bathroom Across 204 Faucet Left	3 ppb
Leavitt Area High School	Boys Bathroom Across 204 Faucet Middle	1.6 ppb
Leavitt Area High School	Boys Bathroom Across 204 Faucet Right	0 ppb
Leavitt Area High School	Boys Bathroom Across 226 Faucet Left	1.2 ppb
Leavitt Area High School	Boys Bathroom Across 226 Faucet Middle	0 ppb
Leavitt Area High School	Boys Bathroom Across 226 Faucet Right	0 ppb
Leavitt Area High School	Boys Coach's Room A Bathroom Faucet	4.8 ppb
Leavitt Area High School	Boys Coach's Room B Bathroom Faucet	5.2 ppb
Leavitt Area High School	Boys Locker Room A Handwash Sink	0 ppb
Leavitt Area High School	Boys Locker Room B Handwash Faucet Left	5.2 ppb
Leavitt Area High School	Boys Locker Room B Handwash Faucet Right	1.2 ppb

School Name	Sample Location	Lead Test Result
Leavitt Area High School	Drinking Fountain Near Boys Locker Room A	3.2 ppb
Leavitt Area High School	Drinking Fountain Near 183	12.1 ppb
Leavitt Area High School	Fountain Across 105	0 ppb
Leavitt Area High School	Fountain Across 143	0 ppb
Leavitt Area High School	Fountain Across 204	0 ppb
Leavitt Area High School	Fountain Across 226	0 ppb
Leavitt Area High School	Girls Bathroom Across 105 Faucet Left	1.6 ppb
Leavitt Area High School	Girls Bathroom Across 105 Faucet Middle	2 ppb
Leavitt Area High School	Girls Bathroom Across 105 Faucet Right	1.8 ppb
Leavitt Area High School	Girls Bathroom Across 143 Faucet Left	0 ppb
Leavitt Area High School	Girls Bathroom Across 143 Faucet Middle	0 ppb
Leavitt Area High School	Girls Bathroom Across 143 Faucet Right	0 ppb
Leavitt Area High School	Girls Bathroom Across 204 Faucet Left	6.1 ppb
Leavitt Area High School	Girls Bathroom Across 204 Faucet Middle	6.8 ppb
Leavitt Area High School	Girls Bathroom Across 204 Faucet Right	8.1 ppb
Leavitt Area High School	Girls Bathroom Across 226 Faucet Left	1.7 ppb
Leavitt Area High School	Girls Bathroom Across 226 Faucet Middle	0 ppb
Leavitt Area High School	Girls Bathroom Across 226 Faucet Right	0 ppb
Leavitt Area High School	Girls Coach's Room A Bathroom Faucet	24.7 ppb
Leavitt Area High School	Girls Coach's Room B Bathroom Faucet'	2.9 ppb
Leavitt Area High School	Girls Locker Room A Handwash Faucet	1.4 ppb
Leavitt Area High School	Girls Locker Room B Handwash Faucet Left	0 ppb
Leavitt Area High School	Girls Locker Room B Handwash Faucet Right	0 ppb
Leavitt Area High School	Gym Bottle Fill Left	0 ppb
Leavitt Area High School	Gym Bottle Fill Right	0 ppb
Leavitt Area High School	Gym Fountain Left	0 ppb
Leavitt Area High School	Gym Fountain Right	0 ppb
Leavitt Area High School	Gym Mens Bathroom Faucet Left	0 ppb
Leavitt Area High School	Gym Mens Bathroom Faucet Right	2 ppb
Leavitt Area High School	Gym Storage Room A Bathroom Faucet	20.6 ppb
Leavitt Area High School	Gym Womens Bathroom Faucet Left	1.2 ppb
Leavitt Area High School	Gym Womens Bathroom Faucet Right	4 ppb
Leavitt Area High School	Kitchen 3 Bay Sink Faucet	1.8 ppb
Leavitt Area High School	Kitchen 3 Bay Sink Spray Hose	10.3 ppb
Leavitt Area High School	Kitchen Bathroom Faucet	1.2 ppb
Leavitt Area High School	Kitchen Handwash Sink Faucet	0 ppb
Leavitt Area High School	Kitchen Prep Sink Faucet	1.4 ppb
Leavitt Area High School	Kitchen Prep Sink Spray Hose	0 ppb
Leavitt Area High School	Library Office Sink Faucet	1.5 ppb
Leavitt Area High School	Main Office Bathroom Faucet	1.1 ppb
Leavitt Area High School	Main Office Kitchen Faucet	1.2 ppb
Leavitt Area High School	Nurse Office Bathroom Faucet	0 ppb
Leavitt Area High School	Room 115 Fountain	0 ppb
Leavitt Area High School	Room 115 Sink Faucet	1.5 ppb
Leavitt Area High School	Room 118 Sink Faucet	15.8 ppb

School Name	Sample Location	Lead Test Result
Leavitt Area High School	Room 119 Darkroom Sink Faucet	32.9 ppb
Leavitt Area High School	Room 119 Inside Sink Faucet	5.5 ppb
Leavitt Area High School	Room 119 Outside Sink Faucet	5.2 ppb
Leavitt Area High School	Room 119 Utility Sink Faucet	1.6 ppb
Leavitt Area High School	Room 120 3 Bay Sink Faucet Left	3.8 ppb
Leavitt Area High School	Room 120 3 Bay Sink Faucet Right	0 ppb
Leavitt Area High School	Room 120 Inside Sink Faucet	1.3 ppb
Leavitt Area High School	Room 120 Outside Sink Faucet	1.5 ppb
Leavitt Area High School	Room 122 Staff Bathroom Left Faucet	0 ppb
Leavitt Area High School	Room 122 Staff Bathroom Right Faucet	0 ppb
Leavitt Area High School	Room 122 Staff Room Kitchen Faucet	0 ppb
Leavitt Area High School	Room 146 Bathroom Faucet	0 ppb
Leavitt Area High School	Room 146 Faucet	0 ppb
Leavitt Area High School	Room 147 Side Faucet	6 ppb
Leavitt Area High School	Room 147 Teacher's Station Faucet	39.4 ppb
Leavitt Area High School	Room 153 Handwash Sink Faucet	0 ppb
Leavitt Area High School	Room 153 Station 1 Faucet Left	1.7 ppb
Leavitt Area High School	Room 153 Station 1 Faucet Right	2.3 ppb
Leavitt Area High School	Room 153 Station 2 Faucet Left	2.8 ppb
Leavitt Area High School	Room 153 Station 2 Faucet Right	1.7 ppb
Leavitt Area High School	Room 153 Station 3 Faucet Left	2.5 ppb
Leavitt Area High School	Room 153 Station 3 Faucet Right	1.4 ppb
Leavitt Area High School	Room 153 Station 4 Faucet Left	1.8 ppb
Leavitt Area High School	Room 153 Station 4 Faucet Right	3.1 ppb
Leavitt Area High School	Room 153 Station 5 Faucet Left	1.6 ppb
Leavitt Area High School	Room 153 Station 5 Faucet Right	3.1 ppb
Leavitt Area High School	Room 153 Station 6 Faucet Left	2.6 ppb
Leavitt Area High School	Room 153 Station 6 Faucet Right	2.6 ppb
Leavitt Area High School	Room 154 Handwash Sink Faucet	4.2 ppb
Leavitt Area High School	Room 154 Station 1 Faucet Left	2.5 ppb
Leavitt Area High School	Room 154 Station 1 Faucet Right	2.4 ppb
Leavitt Area High School	Room 154 Station 2 Faucet Left	3.4 ppb
Leavitt Area High School	Room 154 Station 2 Faucet Right	1.7 ppb
Leavitt Area High School	Room 154 Station 3 Faucet Left	2.1 ppb
Leavitt Area High School	Room 154 Station 3 Faucet Right	0 ppb
Leavitt Area High School	Room 154 Station 7 Faucet Left	2.9 ppb
Leavitt Area High School	Room 154 Station 7 Faucet Right	1 ppb
Leavitt Area High School	Room 154 Station 8 Faucet Left	4.4 ppb
Leavitt Area High School	Room 154 Station 8 Faucet Right	0 ppb
Leavitt Area High School	Room 154 Station 9 Faucet Left	1.6 ppb
Leavitt Area High School	Room 154 Station 9 Faucet Right	3 ppb
Leavitt Area High School	Room 154/153 Storage Room Faucet	15.9 ppb
Leavitt Area High School	Room 155 Staff Bathroom Left Faucet	0 ppb
Leavitt Area High School	Room 155 Staff Bathroom Right Faucet	0 ppb
Leavitt Area High School	Room 155 Staff Room Kitchen Faucet	0 ppb
Leavitt Area High School	Room 158 Mailroom Bathroom Faucet	0 ppb
Leavitt Area High School	Room 158 Mailroom Kitchen Faucet	1.1 ppb

School Name	Sample Location	Lead Test Result
Leavitt Area High School	Room 173 Faucet	1.6 ppb
Leavitt Area High School	Room 174 Faucet Left	1.3 ppb
Leavitt Area High School	Room 174 Faucet Right	4.8 ppb
Leavitt Area High School	Room 183 Trainer's Room Faucet	0 ppb
Leavitt Area High School	Room 183 Trainer's Room Ice Machine	0 ppb
Leavitt Area High School	Room 212 Staff Bathroom Left Faucet	15.6 ppb
Leavitt Area High School	Room 212 Staff Bathroom Right Faucet	9.5 ppb
Leavitt Area High School	Room 212 Staff Room Kitchen Faucet	0 ppb
Leavitt Area High School	Room 224 Outside Sink Left	0 ppb
Leavitt Area High School	Room 224 Outside Sink Right	5.9 ppb
Leavitt Area High School	Room 224 Side Sink Left	1.3 ppb
Leavitt Area High School	Room 224 Side Sink Right	4.7 ppb
Leavitt Area High School	Room 224 Teacher's Station Sink Faucet	90.2 ppb
Leavitt Area High School	Room 226 Sink Faucet	0 ppb
Leavitt Area High School	Room 229 Outside Sink Faucet	4 ppb
Leavitt Area High School	Room 229 Side Sink Faucet	10 ppb
Leavitt Area High School	Room 229 Sink Faucet Left	1.5 ppb
Leavitt Area High School	Room 229 Sink Faucet Right	2.1 ppb
Leavitt Area High School	Room 230 Outside Sink Faucet	1.8 ppb
Leavitt Area High School	Room 230 Side Sink Faucet	3.1 ppb
Leavitt Area High School	Room 230 Sink Faucet Left	1.5 ppb
Leavitt Area High School	Room 230 Sink Faucet Right	2.1 ppb
Leavitt Area High School	Room 235 Inside Sink Faucet	0 ppb
Leavitt Area High School	Room 235 Outside Sink Faucet	14.7 ppb
Leavitt Area High School	Room 235 Side Sink Faucet	4.7 ppb
Leavitt Area High School	Room 236 Inside Sink Faucet	1.4 ppb
Leavitt Area High School	Room 236 Outside Sink Faucet	1.2 ppb
Leavitt Area High School	Room 236 Side Sink Faucet	3.4 ppb
Leavitt Area High School	Room 237 Staff Bathroom Left Faucet	0 ppb
Leavitt Area High School	Room 237 Staff Bathroom Right Faucet	0 ppb
Leavitt Area High School	Room 237 Staff Room Kitchen Faucet	0 ppb
Leavitt Area High School	Staff Bathroom Across 120 Faucet	1.8 ppb
Leavitt Area High School	Stock Room Faucet 229/230	0 ppb
Leavitt Area High School	Stock Room Faucet 235/236	2.1 ppb
Lebanon Elementary School	Classroom #1 Sink	8.1 ppb
Lebanon Elementary School	Classroom #2 Sink	6.8 ppb
Lebanon Elementary School	Classroom #6 Sink	9.2 ppb
Lebanon Elementary School	Classroom #7 Sink	11.8 ppb
Lebanon Elementary School	Classroom #8 Sink	5.6 ppb
Lebanon Elementary School	Kitchen Prep Sink #1	2 ppb
Lebanon Elementary School	Kitchen Prep Sink #2	0 ppb
Lebanon Elementary School	Main Hallway Drinking Fountain #1	0 ppb
Lebanon Elementary School	Main Hallway Drinking Fountain #2	0 ppb
Lebanon Elementary School	New Wing Drinking Fountain	0 ppb
Lebanon Elementary School	Nurse Sink	6.5 ppb
L'Ecole Francaise du Maine	Drinking Fountain Main Hallway	0 ppb
L'Ecole Francaise du Maine	Kitchen Handwash Sink	0 ppb

School Name	Sample Location	Lead Test Result
L'Ecole Francaise du Maine	Kitchen Main Sink/dishwashing	3.8 ppb
Lee Academy	Ab Boys Bathroom Sink	8.4 ppb
Lee Academy	Ab Girls Bathroom Sink	5.5 ppb
Lee Academy	Ab Kitchen Sink #1	3.6 ppb
Lee Academy	Ab Kitchen Sink #2	2.3 ppb
Lee Academy	Ab Kitchen Sink #3	1.4 ppb
Lee Academy	Ab Outside Spigot	1.4 ppb
Lee Academy	Alumni Bld Drinking Fountain	0 ppb
Lee Academy	Cobb Bld -apartment Sink	0 ppb
Lee Academy	Cobb Bld- Boys Bathroom Sink Dwn	1.1 ppb
Lee Academy	Cobb Bld -girls Bathroom Sink # 1 Up	1.7 ppb
Lee Academy	Cobb Bld -girls Bathroom Sink # 2 Up	0 ppb
Lee Academy	Cobb Bld -girls Bathroom Sink # 3 Up	1.7 ppb
Lee Academy	Cobb Bld- Girls Bathroom Sink Dwn	2.6 ppb
Lee Academy	Dew Drop Bathroom Sink 1st Fl	2.3 ppb
Lee Academy	Dew Drop Bathroom Sink 2nd Fl	2.3 ppb
Lee Academy	Dew Drop- Kitchen Sink	1.8 ppb
Lee Academy	Dh Boys Bathroom Sink	0 ppb
Lee Academy	Dh Dish Wash Sink	1.6 ppb
Lee Academy	Dh Food Prep Sink	1.2 ppb
Lee Academy	Dh Girls Bathroom Sink	0 ppb
Lee Academy	Dh Hand Wash Only Sink # 1	1.5 ppb
Lee Academy	Dh Hand Wash Only Sink #2	1.2 ppb
Lee Academy	Dingley Bio Lab Sink # 1	12.3 ppb
Lee Academy	Dingley Bio Lab Sink # 2	2.2 ppb
Lee Academy	Dingley Bio Lab Sink # 3	52.6 ppb
Lee Academy	Dingley Boys Bathroom Sink	29.2 ppb
Lee Academy	Dingley Chem Lab Sink # 1	46.8 ppb
Lee Academy	Dingley Chem Lab Sink # 2	2.9 ppb
Lee Academy	Dingley Chem Lab Sink # 5	10.7 ppb
Lee Academy	Dingley Girls Bathroom Sink	23.8 ppb
Lee Academy	Dingley- Water Fountain	0 ppb
Lee Academy	Haynes - Boys Bathroom Sink # 1	1.4 ppb
Lee Academy	Haynes - Boys Bathroom Sink # 2	1.5 ppb
Lee Academy	Haynes - Girls Bathroom Sink # 2	0 ppb
Lee Academy	Haynes - Girls Bathroom Sink # 1	0 ppb
Lee Academy	Haynes- 1st Fl Staff Bathroom	1.1 ppb
Lee Academy	Haynes- 2nd Fl Staff Bathroom	6 ppb
Lee Academy	Haynes- Art Room Sink	1.3 ppb
Lee Academy	Haynes- Water Fountain	0 ppb
Lee Academy	Pineo Bld Bathroom Sink	2 ppb
Lee Academy	Wh 2nd Fl Dorm Parent Bathroom Sink	3 ppb
Lee Academy	Wh 1 St Fl Dorm Parent Bathroom Sink	4.2 ppb
Lee Academy	Wh 1 St Fl Dorm Parent Sink	1.4 ppb
Lee Academy	Wh 1st Fl Bathroom Sink	2.1 ppb
Lee Academy	Wh 1st Fl Laundry Room Sink	0 ppb
Lee Academy	Wh 2nd Fl North Bathroom Sink # 1	0 ppb

School Name	Sample Location	Lead Test Result
Lee Academy	Wh 2nd Fl North Bathroom Sink # 2	0 ppb
Lee Academy	Wh 2nd Fl North Bathroom Sink # 3	1.3 ppb
Lee Academy	Wh 2nd Fl North Bathroom Sink # 4	0 ppb
Lee Academy	Wh 2nd Fl South Bathroom Sink # 1	0 ppb
Lee Academy	Wh 2nd Fl South Bathroom Sink # 2	0 ppb
Lee Academy	Wh 3rd Fl Dorm Parent Bathroom Sink	0 ppb
Lee Academy	Wh 3rd Fl North Bathroom Sink # 1	5.1 ppb
Lee Academy	Wh 3rd Fl North Bathroom Sink # 2	3.2 ppb
Lee Academy	Wh 3rd Fl North Bathroom Sink # 3	1.3 ppb
Lee Academy	Wh 3rd Fl North Bathroom Sink # 4	1.2 ppb
Lee Academy	Wh 3rd Fl South Bathroom Sink # 1	0 ppb
Lee Academy	Wh 3rd Fl South Bathroom Sink # 2	0 ppb
Lee Academy	Wh Rec Room Sink	0 ppb
Lee Academy	Wh Suite # 2 Bathroom Sink	0 ppb
Lee/Winn School	1st Grade Fountain	0 ppb
Lee/Winn School	1st Grade Sink	0 ppb
Lee/Winn School	2nd Grade Fountan	1.1 ppb
Lee/Winn School	2nd Grade Sink	0 ppb
Lee/Winn School	3rd Grade Fountain	0 ppb
Lee/Winn School	3rd Grade Sink	0 ppb
Lee/Winn School	4 Yr Old Fountain	0 ppb
Lee/Winn School	4 Yr Old Sink	0 ppb
Lee/Winn School	4th Grade Fountain	0 ppb
Lee/Winn School	4th Grade Sink	0 ppb
Lee/Winn School	Boys Bathroom Sink (gym)	0 ppb
Lee/Winn School	Chapter 1 Room Fountain	1.6 ppb
Lee/Winn School	Chapter 1 Room Sink	2.2 ppb
Lee/Winn School	Clinic/nurses Station Sink	1.2 ppb
Lee/Winn School	Dishwashing Sink Kitchen # 1	1.2 ppb
Lee/Winn School	Dishwashing Sink Kitchen # 2	0 ppb
Lee/Winn School	Drinking Fountain Gym	0 ppb
Lee/Winn School	Food Prep Sink Kitchen	0 ppb
Lee/Winn School	Girls Bathroom Sink (gym)	0 ppb
Lee/Winn School	Hallway Drinking Fountain	0 ppb
Lee/Winn School	Hand Wash Sink Kitchen	3.7 ppb
Lee/Winn School	Kindergarden Fountain	0 ppb
Lee/Winn School	Kindergarden Sink	0 ppb
Lee/Winn School	Library Sink	0 ppb
Lee/Winn School	Reading Recovery Sink	0 ppb
Lee/Winn School	Resource Room Fountain	0 ppb
Lee/Winn School	Resource Room Sink	0 ppb
Lee/Winn School	Special Ed Room Fountain	7.4 ppb
Lee/Winn School	Special Ed Room Sink	0 ppb
Lee/Winn School	Staff Bathroom Sink	0 ppb
Lee/Winn School	Teacher's Conference Room Fountain	0 ppb
Lee/Winn School	Teacher's Conference Room Sink	0 ppb
Leeds Central School	Bottle Fill Near Art Room	0 ppb

School Name	Sample Location	Lead Test Result
Leeds Central School	Bottle Fill Near Room 7	0 ppb
Leeds Central School	Boys Bathroom Faucet Left Near Room 3	0 ppb
Leeds Central School	Boys Bathroom Faucet Right Near Room 3	0 ppb
Leeds Central School	Boys Bathroom Sink Faucet	1.9 ppb
Leeds Central School	Boys Locker Room Faucet	6.2 ppb
Leeds Central School	Downstairs Sink Faucet	2.1 ppb
Leeds Central School	Fountain Near Art Room	0 ppb
Leeds Central School	Fountain Near Room 7	1 ppb
Leeds Central School	Girls Bathroom Faucet Left Near Room 3	0 ppb
Leeds Central School	Girls Bathroom Faucet Right Near Room 3	0 ppb
Leeds Central School	Girls Bathroom Sink Faucet	2 ppb
Leeds Central School	Girls Locker Room Faucet	7.7 ppb
Leeds Central School	Hallway Fountain Near Room 3	0 ppb
Leeds Central School	Kitchen 3 Bay Sink Faucet	59.7 ppb
Leeds Central School	Kitchen Bathroom Sink Faucet	15.3 ppb
Leeds Central School	Kitchen Handwash Sink Faucet	13.7 ppb
Leeds Central School	Kitchen Prep Sink Faucet	11.5 ppb
Leeds Central School	Office Handwash Sink Faucet	3.9 ppb
Leeds Central School	Room 10 Bathroom Sink Faucet	6.6 ppb
Leeds Central School	Room 12c Library Faucet	39.1 ppb
Leeds Central School	Room 12c Library Fountain	140 ppb
Leeds Central School	Room 14 Faucet Lf	7.4 ppb
Leeds Central School	Room 14 Fountain Rt	5.5 ppb
Leeds Central School	Room 16 Faucet	9.9 ppb
Leeds Central School	Room 16 Fountain	34.8 ppb
Leeds Central School	Room 18 Faucet	13.4 ppb
Leeds Central School	Room 18 Fountain	35.5 ppb
Leeds Central School	Room 2 Faucet	11.9 ppb
Leeds Central School	Room 20 Faucet	3.3 ppb
Leeds Central School	Room 20 Fountain	10.4 ppb
Leeds Central School	Room 22 Faucet	2.7 ppb
Leeds Central School	Room 22 Fountain	9.2 ppb
Leeds Central School	Room 24 Faucet	2.7 ppb
Leeds Central School	Room 24 Fountain	8.3 ppb
Leeds Central School	Room 25 Faucet	10.5 ppb
Leeds Central School	Room 25 Fountain	4.9 ppb
Leeds Central School	Room 26 Faucet	2.7 ppb
Leeds Central School	Room 26 Fountain	4.9 ppb
Leeds Central School	Room 28 Faucet	2.2 ppb
Leeds Central School	Room 28 Fountain	4.7 ppb
Leeds Central School	Room 30 Faucet	5.9 ppb
Leeds Central School	Room 30 Fountain	5.6 ppb
Leeds Central School	Room 6 Handwash Sink Faucet	18.1 ppb
Leeds Central School	Staff Bathroom Left Faucet	1.2 ppb
Leeds Central School	Staff Bathroom Right Faucet	0 ppb
Leroy H Smith School	2nd Floor Hallway Across From Room 207	0 ppb
Leroy H Smith School	Hallway @ Entrance To Room 111	1.7 ppb

School Name	Sample Location	Lead Test Result
Leroy H Smith School	Hallway Between Bathrooms In E/w Wing	0 ppb
Leroy H Smith School	Hallway. - Across From Room 115	0 ppb
Leroy H Smith School	Kitchen - @ 3-bay Sink - Left Faucet	0 ppb
Leroy H Smith School	Kitchen - @ 3-bay Sink - Right Faucet	0 ppb
Leroy H Smith School	Lobby - 1st Floor Across From The Elevator	0 ppb
Levey Day Sch	No Samples Yet Taken	
Lewiston High School	1st Fl Back C Water Fountain	0 ppb
Lewiston High School	2nd Ffl V Wing Water Fountain	0 ppb
Lewiston High School	2nd Fl Back C Water Fountain	0 ppb
Lewiston High School	2nd Fl V Wing Bottle Filler	0 ppb
Lewiston High School	A Wing 1st Fl Bottle Filler	0 ppb
Lewiston High School	A Wing 1st Fl Water Fountain	0 ppb
Lewiston High School	A105h Bath Sink	106 ppb
Lewiston High School	A203 Bath 1st Sink	1.1 ppb
Lewiston High School	A205 Bath 1st Sink	5.9 ppb
Lewiston High School	A205 Bath 3rd Sink	3.3 ppb
Lewiston High School	B116 Sink	21.9 ppb
Lewiston High School	B2 Staff Sink	2.9 ppb
Lewiston High School	B2 Student Sink	8.4 ppb
Lewiston High School	B2 Water Fountain	0 ppb
Lewiston High School	B2d Sink	3 ppb
Lewiston High School	Bottle Filler By V105	0 ppb
Lewiston High School	Boys Locker Room 1st Bath Rh Sink	1.4 ppb
Lewiston High School	Boys Lockeroom 2nd Fl Bath Sink	0 ppb
Lewiston High School	C105 Sink	5.1 ppb
Lewiston High School	C106 Sink	4.2 ppb
Lewiston High School	C108 Sink	18.9 ppb
Lewiston High School	C111 Bath 1st Sink	33 ppb
Lewiston High School	C113 Bath 1st Sink	22.6 ppb
Lewiston High School	C121 Sink	8.5 ppb
Lewiston High School	C121 Sm Sink Rh	5 ppb
Lewiston High School	C122 Sink	331 ppb
Lewiston High School	C123 Sink	147 ppb
Lewiston High School	C124 Sink	52.2 ppb
Lewiston High School	C126 Sink	20.9 ppb
Lewiston High School	C127 Sink	10 ppb
Lewiston High School	C128 Sink	73.2 ppb
Lewiston High School	C129 Sink	28.6 ppb
Lewiston High School	C207 Sink	1.2 ppb
Lewiston High School	Cafe Bottle Filler	0 ppb
Lewiston High School	Cafe Water Fountain	0 ppb
Lewiston High School	D Wing 1st Fl Bottle Filler	0 ppb
Lewiston High School	D Wing 1st Fl Lh Water Fountain	0 ppb
Lewiston High School	D Wing 1st Fl Rh Water Fountain	0 ppb
Lewiston High School	D Wing 2nd Fl Bottle Filler	0 ppb
Lewiston High School	D Wing 2nd Fl Lh Water Fountain	0 ppb
Lewiston High School	D Wing 2nd Fl Rh Water Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Lewiston High School	G Wing Hall Bottle Filler	0 ppb
Lewiston High School	G12 Bottle Filler	0 ppb
Lewiston High School	G12 Lh Water Fountain	0 ppb
Lewiston High School	G12 Rh Water Fountain	0 ppb
Lewiston High School	G12 Sink	1.5 ppb
Lewiston High School	G13c Bath Lh Sink	1.7 ppb
Lewiston High School	G13c Bubbler	1.4 ppb
Lewiston High School	G13f Sink	0 ppb
Lewiston High School	G13g Sink	1.3 ppb
Lewiston High School	G13k Sink	3.1 ppb
Lewiston High School	G6 Sink	1.4 ppb
Lewiston High School	G7 Hand Wash Sink	7.9 ppb
Lewiston High School	Gilrs Locker Room Back Sink	2.3 ppb
Lewiston High School	Girls Locker Room Front Sink	4.4 ppb
Lewiston High School	Gwing Hall Water Fountain	0 ppb
Lewiston High School	Gym Lobby Bottle Filler	0 ppb
Lewiston High School	Gym Lobby Water Fountain	0 ppb
Lewiston High School	Hall Water Fountain By Library	0 ppb
Lewiston High School	Kitchen 1st Prep Sink	0 ppb
Lewiston High School	Kitchen 1st Soup Kettle	1.3 ppb
Lewiston High School	Kitchen 2nd Prep Sink	1.5 ppb
Lewiston High School	Kitchen 2nd Soup Kettle	3 ppb
Lewiston High School	Kitchen Sink	0 ppb
Lewiston High School	Kitchen Small Sink	0 ppb
Lewiston High School	Library Office Sink	4.1 ppb
Lewiston High School	Serv Front Deli Sm Sink	1.8 ppb
Lewiston High School	Serv Kitchen Prep Sink	3.3 ppb
Lewiston High School	Serv. Back Deli Sm Sink	8.1 ppb
Lewiston High School	Serv. Small Sink Dishroom	2.4 ppb
Lewiston High School	V Wing Ground Fl Bottle Filler	0 ppb
Lewiston High School	V Wing Ground Fl Girls Rm Sink	0 ppb
Lewiston High School	V Wing Ground Fl Water Fountain	0 ppb
Lewiston High School	V1 Bottle Filler	2.7 ppb
Lewiston High School	V1 Sink	3.4 ppb
Lewiston High School	V1 Water Fountain	0 ppb
Lewiston High School	V103a Sink	1 ppb
Lewiston High School	V103b Sink	0 ppb
Lewiston High School	V106a Sink	3.6 ppb
Lewiston High School	V108 Sink	0 ppb
Lewiston High School	V10b Center	5.8 ppb
Lewiston High School	V11 Center	2.9 ppb
Lewiston High School	V110 Student A	6.3 ppb
Lewiston High School	V110 Student B	5.6 ppb
Lewiston High School	V110 Student C	15.6 ppb
Lewiston High School	V110 Student D	40.4 ppb
Lewiston High School	V110 Student E	7.3 ppb
Lewiston High School	V110 Teacher Sink	8.4 ppb

School Name	Sample Location	Lead Test Result
Lewiston High School	V114 Sink	14.6 ppb
Lewiston High School	V115 Sink	10 ppb
Lewiston High School	V115a Bath Sink	1.9 ppb
Lewiston High School	V12 Center	7.4 ppb
Lewiston High School	V121 Lrg Sink	6.9 ppb
Lewiston High School	V121 Small Sink	2.2 ppb
Lewiston High School	V123 Bath Sink	3 ppb
Lewiston High School	V123 Prep Sink	2.7 ppb
Lewiston High School	V123 Small Sink	4.7 ppb
Lewiston High School	V13 Center	9.8 ppb
Lewiston High School	V16 Center	2 ppb
Lewiston High School	V2 Sink	168 ppb
Lewiston High School	V204 Kitchen Sink	0 ppb
Lewiston High School	V204a Sink	2.3 ppb
Lewiston High School	V204c Sink	1.2 ppb
Lewiston High School	V206a Sink	3 ppb
Lewiston High School	V208 Bath Sink	2.5 ppb
Lewiston High School	V212 Sink	15.1 ppb
Lewiston High School	V216 Sink	112 ppb
Lewiston High School	V4 Sink	1.1 ppb
Lewiston High School	V7 Lh	27.8 ppb
Lewiston High School	V8a Center	1.3 ppb
Lewiston High School	Water Fountain By V105	0 ppb
Lewiston Middle School	110 Sink	4.2 ppb
Lewiston Middle School	112 Nurses Sink	0 ppb
Lewiston Middle School	113 Staff Bath Sink	0 ppb
Lewiston Middle School	119 Sink	0 ppb
Lewiston Middle School	130 Sink	10.5 ppb
Lewiston Middle School	138 Sink	36.5 ppb
Lewiston Middle School	144 Water Fountain	0 ppb
Lewiston Middle School	1st Fl Armory Side Bottle Filler	0 ppb
Lewiston Middle School	1st Fl Armory Side Water Fountain	0 ppb
Lewiston Middle School	1st Fl Bates Side Bottle Filler	0 ppb
Lewiston Middle School	1st Fl Bates Side Water Fountain	0 ppb
Lewiston Middle School	214 C Library Kitchen Sink	0 ppb
Lewiston Middle School	215a Library Bath	1.3 ppb
Lewiston Middle School	229 1st Staff Bath	0 ppb
Lewiston Middle School	2nd Fl Armonry Side Water Fountain	0 ppb
Lewiston Middle School	2nd Fl Armory Side Bottle Filler	0 ppb
Lewiston Middle School	2nd Fl Bates Side Bottle Filler	5.4 ppb
Lewiston Middle School	2nd Fl Bathes Side Water Fountain	6.4 ppb
Lewiston Middle School	311 Sink	2.9 ppb
Lewiston Middle School	312 Sink	3 ppb
Lewiston Middle School	314 Center Sink	0 ppb
Lewiston Middle School	314 Rh Sink	1.2 ppb
Lewiston Middle School	317 Center Sink	0 ppb
Lewiston Middle School	318 Lh Sink	0 ppb

School Name	Sample Location	Lead Test Result
Lewiston Middle School	318 Rh Sink	0 ppb
Lewiston Middle School	329 Staff Bath Sink	1.2 ppb
Lewiston Middle School	3rd Fl Armory Side Bottle Filler	0 ppb
Lewiston Middle School	3rd Fl Armory Side Water Fountain	0 ppb
Lewiston Middle School	3rd Fl Bates Side Bottle Filler	0 ppb
Lewiston Middle School	3rd Fl Bates Side Water Fountain	3.5 ppb
Lewiston Middle School	Boys Locker Room Sink	1.5 ppb
Lewiston Middle School	Boys Room Lh Sink	4.7 ppb
Lewiston Middle School	Cafe Amory Side Bottle Filler	0 ppb
Lewiston Middle School	Cafe Amory Side Water Fountain	0 ppb
Lewiston Middle School	Cafe Water Fountain	0 ppb
Lewiston Middle School	Cust Office Sink	0 ppb
Lewiston Middle School	Girl Room Rh Sink	298 ppb
Lewiston Middle School	Gym Lobby Bottle Filler	2.3 ppb
Lewiston Middle School	Gym Lobby Water Fountain	0 ppb
Lewiston Middle School	Kitchen Double Sink Lh	1.3 ppb
Lewiston Middle School	Kitchen Double Sink Rh	3 ppb
Lewiston Middle School	Kitchen Prep Sink	2.3 ppb
Lewiston Middle School	Kitchen Sm Sink	5.9 ppb
Lewiston Middle School	Kitchen Soup Kettle Lh	2.8 ppb
Lewiston Middle School	Kitchen Soup Kettle Rh	1.6 ppb
Lewiston Middle School	Kitchen Triple Sink Rh	1.7 ppb
Lewiston Middle School	Main Lobby Bottle Filler	0 ppb
Lewiston Middle School	Main Lobby Lh Water Fountain	0 ppb
Lewiston Middle School	Main Lobby Rh Water Fountain	0 ppb
Lewiston Middle School	Neutral Hall Bath Sink	0 ppb
Lewiston Middle School	Physed Hall Bottle Filler	0 ppb
Lewiston Middle School	Physed Hall Water Fountain	0 ppb
Lewiston Middle School	Stage Lh Bath Sink	0 ppb
Lewiston Middle School	Stage Rh Bath Sink	0 ppb
Lewiston Middle School	Stem Lab Sink	0 ppb
Lewiston Regional Technology Ctr	2 Bay Sink	0 ppb
Lewiston Regional Technology Ctr	3 Bay Sink	1.1 ppb
Lewiston Regional Technology Ctr	Dining Room Prep Sink	1.8 ppb
Lewiston Regional Technology Ctr	Prep Sink Lh	1.4 ppb
Lewiston Regional Technology Ctr	Prep Sink Rh	0 ppb
Lewiston Regional Technology Ctr	Soup Kettle	2.3 ppb
Lewiston Regional Technology Ctr	Steam Table	8.1 ppb
Libby-Tozier School	405 Ceramic Sink	0 ppb
Libby-Tozier School	413 Sink B	1.6 ppb
Libby-Tozier School	414 Sink B	1.5 ppb
Libby-Tozier School	Boys Bathroom Old Wing- Sink A	1.9 ppb
Libby-Tozier School	Boys Bathroom Old Wing- Sink B	1.6 ppb
Libby-Tozier School	Boys Bathroom On Fls- Sink A	13.2 ppb
Libby-Tozier School	Boys Bathroom On Fls- Sink B	1.5 ppb
Libby-Tozier School	Classroom 13 Df At Back Of Room	1.6 ppb
Libby-Tozier School	Classroom 14 Df At Back Of Room	1.3 ppb

School Name	Sample Location	Lead Test Result
Libby-Tozier School	Classroom 2 Df To Left Of Room	1.2 ppb
Libby-Tozier School	Classroom 3 Df At Back Of Room	0 ppb
Libby-Tozier School	Classroom 4 Df At Right Of Room	0 ppb
Libby-Tozier School	Classroom 409 Df To Left Of Room	2.1 ppb
Libby-Tozier School	Classroom 409a Df To Right Of Room	0 ppb
Libby-Tozier School	Classroom 7 Df To Left Of Room	0 ppb
Libby-Tozier School	Custodian Closet	5.7 ppb
Libby-Tozier School	Drinking Fountain By Classroom 12	7.6 ppb
Libby-Tozier School	Girls Bathroom New Wing- Red Doors Sink A	0 ppb
Libby-Tozier School	Girls Bathroom New Wing- Red Doors Sink B	2.1 ppb
Libby-Tozier School	Girls Bathroom On Fls- Sink A	11.6 ppb
Libby-Tozier School	Girls Bathroom On Fls- Sink B	1.1 ppb
Libby-Tozier School	Gym Office Bathroom- Sink	6.5 ppb
Libby-Tozier School	Kitchen Area 3 Bay Wash	30 ppb
Libby-Tozier School	Kitchen Area By Inter Gym Door	50.7 ppb
Libby-Tozier School	Kitchen Sink 1 - 3 Bay Right	6.1 ppb
Libby-Tozier School	Kitchen Sink 2 - Dishwasher Sink	5.5 ppb
Libby-Tozier School	Kitchen Sink 3 - Prep Sink Faucet	5.8 ppb
Libby-Tozier School	Kitchen Sink 4 - Prep Sink Spray	4.2 ppb
Libby-Tozier School	Misc Room Df To Left Of Room	23.8 ppb
Libby-Tozier School	Music Rm A	5.4 ppb
Libby-Tozier School	Music Rm B	0 ppb
Libby-Tozier School	Nurses Bathroom- Sink	0 ppb
Libby-Tozier School	Nurses Office- Sink	0 ppb
Libby-Tozier School	Rm 403- Sink	1.4 ppb
Libby-Tozier School	Rm 404- Sink	39.1 ppb
Libby-Tozier School	Rm 404a- Sink	1.5 ppb
Libby-Tozier School	Rm 405- Sink	2.3 ppb
Libby-Tozier School	Rm 405a- Sink	1.7 ppb
Libby-Tozier School	Rm 409- Sink	0 ppb
Libby-Tozier School	Rm 409a- Sink	0 ppb
Libby-Tozier School	Rm 411- Sink	3.3 ppb
Libby-Tozier School	Rm 413- Sink A	0 ppb
Libby-Tozier School	Rm 413a- Sink	1.2 ppb
Libby-Tozier School	Rm 414- Sink A	0 ppb
Libby-Tozier School	Rm 415 Side Room- Sink	1.5 ppb
Libby-Tozier School	Rm 416- Sink	4.9 ppb
Libby-Tozier School	Rm 421- Sink	37.9 ppb
Libby-Tozier School	Rm 422- Sink	0 ppb
Libby-Tozier School	Single Bathroom By Pre-k- Sink	0 ppb
Libby-Tozier School	Single Bathroom Old End- Sink	11.8 ppb
Libby-Tozier School	Single Bathroom Pre-k(adult)- Sink	1.1 ppb
Libby-Tozier School	Teachers Work Room- Sink	0 ppb
Libby-Tozier School	Water Fountain By Library	0 ppb
Lillian Parks Hussey School	3 Bay Sink Kitchen	1.2 ppb

School Name	Sample Location	Lead Test Result
Lillian Parks Hussey School	Bottle Fill Station By Room 4	0 ppb
Lillian Parks Hussey School	Bubbler Next To Room 7	3 ppb
Lillian Parks Hussey School	Classroom 10	0 ppb
Lillian Parks Hussey School	Classroom 12	0 ppb
Lillian Parks Hussey School	Classroom 13	0 ppb
Lillian Parks Hussey School	Classroom 14	0 ppb
Lillian Parks Hussey School	Classroom 15	0 ppb
Lillian Parks Hussey School	Classroom 16	3.5 ppb
Lillian Parks Hussey School	Classroom 4	0 ppb
Lillian Parks Hussey School	Classroom 6	4.2 ppb
Lillian Parks Hussey School	Classroom 8	1 ppb
Lillian Parks Hussey School	Classroom 9	0 ppb
Lillian Parks Hussey School	Single Bay Sink Kitchen	2.6 ppb
Lillian Parks Hussey School	Staff Lounge	1.2 ppb
Limestone Community School	A-wing Lower North	0 ppb
Limestone Community School	A-wing Lower South	1.5 ppb
Limestone Community School	A-wing Upper North	3.4 ppb
Limestone Community School	A-wing Upper South	5.3 ppb
Limestone Community School	B114 Wall Mount Sink	103 ppb
Limestone Community School	B207 Kitchen Sink	27.3 ppb
Limestone Community School	B211 Kitchen Sink	25.3 ppb
Limestone Community School	Boys Locker Room	239 ppb
Limestone Community School	B-wing Lower North	7.7 ppb
Limestone Community School	B-wing Lower South	8.9 ppb
Limestone Community School	B-wing Upper North	7 ppb
Limestone Community School	B-wing Upper South	8.1 ppb
Limestone Community School	Cafeteria Ice Machine	6.1 ppb
Limestone Community School	D640 Classroom	0 ppb
Limestone Community School	D640 Kitchen Sink	30 ppb
Limestone Community School	D645 Kitchen Sink	43.7 ppb
Limestone Community School	D654 Bathroom Sink 1	1.4 ppb
Limestone Community School	D654 Bathroom Sink 2	1.4 ppb
Limestone Community School	Girls Locker Room	16.6 ppb
Limestone Community School	Home Economics - Station 1	16.1 ppb
Limestone Community School	Home Economics - Station 2	11.5 ppb
Limestone Community School	Home Economics - Station 3	12 ppb
Limestone Community School	Home Economics - Station 4	18.7 ppb
Limestone Community School	Home Economics - Station 5	16.8 ppb
Limestone Community School	Kitchen 3 Bay Wash Sink	1.4 ppb
Limestone Community School	Kitchen Rinse/wash Sink	1.5 ppb
Limestone Community School	Lcs Main Office	8.8 ppb
Limestone Community School	Library Counter	15.9 ppb
Limestone Community School	Main Wing Lower East	0 ppb
Limestone Community School	Main Wing Lower West	1.2 ppb
Limestone Community School	Main Wing Upper East	0 ppb
Limestone Community School	Main Wing Upper West	0 ppb
Limestone Community School	Makerspace Classroom	658 ppb

School Name	Sample Location	Lead Test Result
Limestone Community School	Makerspace Workshop	1.5 ppb
Limestone Community School	Mssm Administration Office	1.1 ppb
Limestone Community School	Mssm Admissions Office	6.3 ppb
Limestone Community School	Nurses Office	14.3 ppb
Limestone Community School	Teacher Room Kitchen Sink	1.4 ppb
Limestone Community School	Teachers Room	18.9 ppb
Limestone Community School	Teachers Work Room	43.1 ppb
Lincoln Academy	1st Floor Kitchen Sink	0 ppb
Lincoln Academy	Blue Wing Water Fountain	0 ppb
Lincoln Academy	Common Room Fountain 1st Floor	0 ppb
Lincoln Academy	Fridge Water	0 ppb
Lincoln Academy	Green Wing Water Fountain	0 ppb
Lincoln Academy	Hh 1st Floor Water Fountain	0 ppb
Lincoln Academy	Hh 2 Floor Water Fountain	6.2 ppb
Lincoln Academy	Hh Apt 1 Kitchen Sink	1.2 ppb
Lincoln Academy	Hh Apt 2 Kitchen Sink	1.3 ppb
Lincoln Academy	Hh Basement Floor Water Fountain	0 ppb
Lincoln Academy	Hh Second Kitchen Sink	0 ppb
Lincoln Academy	Kitchen Faucet	0 ppb
Lincoln Academy	Lobby Drinking Fountain	0 ppb
Lincoln Academy	Mb Adc Hallway Fountain	0 ppb
Lincoln Academy	Mb Gym Ice Machine	1.9 ppb
Lincoln Academy	Mb Gym Water Fountain	3.3 ppb
Lincoln Academy	Mb Hand Sink	3.5 ppb
Lincoln Academy	Mb History Wing Hallway Water Fountain	4.9 ppb
Lincoln Academy	Mb Kitchen Basement	0 ppb
Lincoln Academy	Mb Kitchen Corner Sink	0 ppb
Lincoln Academy	Mb Kitchen Ice Machine	0 ppb
Lincoln Academy	Mb Kitchen Prep Sink	0 ppb
Lincoln Academy	Mb Kitchen Steamer	0 ppb
Lincoln Academy	Mb Mathwing Hallway Water Fountain	1.4 ppb
Lincoln Academy	Mb Room 131 Kitchen Sink	23.3 ppb
Lincoln Academy	Mb Teachers Room Kitchen Sink	4.4 ppb
Lincoln Academy	Orange Wing Water Fountain	0 ppb
Lincoln Academy	Pp Old Kitchen Sink	582 ppb
Lincoln Academy	Red Wing Water Fountain	0 ppb
Lincoln Academy	Yellow Wing Water Fountain	0 ppb
Lincoln Middle School	104-1	0 ppb
Lincoln Middle School	104-2	0 ppb
Lincoln Middle School	108-1	0 ppb
Lincoln Middle School	108-2	0 ppb
Lincoln Middle School	203-1	0 ppb
Lincoln Middle School	203-2	1.8 ppb
Lincoln Middle School	207 - Kitchen	1.3 ppb
Lincoln Middle School	210a Staff Kitchen	2.8 ppb
Lincoln Middle School	211-1	7.7 ppb
Lincoln Middle School	211-2	2.1 ppb

School Name	Sample Location	Lead Test Result
Lincoln Middle School	301-1	1.1 ppb
Lincoln Middle School	Bottle Filler - Hall By 103	0 ppb
Lincoln Middle School	Bottle Filler - Hall By 203	0 ppb
Lincoln Middle School	Bottle Filler - Hall By 209	0 ppb
Lincoln Middle School	Bottle Filler - Hall By 303	0 ppb
Lincoln Middle School	Bottle Filler - Hall By G3	0 ppb
Lincoln Middle School	Bottle Filler - Hall By Gym	0 ppb
Lincoln Middle School	Bottle Filler - Hall By Main Office	0 ppb
Lincoln Middle School	Bubbler-ground Floor Cafeteria	4.2 ppb
Lincoln Middle School	Food Service Kitchen-ground Floor In Cafeteria	3.5 ppb
Lincoln Middle School	G10 Food Prep Classroom (1st Left Side Sink)	2.5 ppb
Lincoln Middle School	G10 Food Prep Classroom (1st Right Side Sink)	2 ppb
Lincoln Middle School	G10 Food Prep Classroom (2nd Left Side Sink)	1.9 ppb
Lincoln Middle School	G10 Food Prep Classroom (2nd Right Side Sink)	1.9 ppb
Lincoln Middle School	G3-1	0 ppb
Lincoln Middle School	G3-2	1.1 ppb
Lincoln Middle School	G8 Nurse Office	5.2 ppb
Lincoln Middle School	Pos-1	2690 ppb
Lincoln Middle School	Staff Bathroom - 3rd Floor By 303	2 ppb
Lincoln Middle School	Staff Room - 1st Floor By Main Office	0 ppb
Lincoln Middle School	Staff Room - Ground Floor By G4	1.2 ppb
Lincoln Middle School	Stem-1	0 ppb
Lincoln School	2 Bay Sink Kitchen	0 ppb
Lincoln School	Bottle Fill Station By Gym	0 ppb
Lincoln School	Classroom 1	3.8 ppb
Lincoln School	Classroom 10	0 ppb
Lincoln School	Classroom 11	0 ppb
Lincoln School	Classroom 12	0 ppb
Lincoln School	Classroom 13	0 ppb
Lincoln School	Classroom 14	4.3 ppb
Lincoln School	Classroom 15	1.9 ppb
Lincoln School	Classroom 16	0 ppb
Lincoln School	Classroom 17	0 ppb
Lincoln School	Classroom 18	1.6 ppb
Lincoln School	Classroom 2	2 ppb
Lincoln School	Classroom 25	2 ppb
Lincoln School	Classroom 3	1.5 ppb
Lincoln School	Classroom 4	0 ppb
Lincoln School	Classroom 5	0 ppb
Lincoln School	Classroom 6	1.2 ppb
Lincoln School	Classroom 7	5.5 ppb
Lincoln School	Classroom 8	0 ppb

School Name	Sample Location	Lead Test Result
Lincoln School	Classroom 9	0 ppb
Lincoln School	Single Bay Sink Kitchen	0 ppb
Lincoln School	Teachers Lounge Sink	0 ppb
Lincoln School	Water Fountain By Men's Room	0 ppb
Lincoln School	Water Fountain By Women's Room	4.1 ppb
Lincolville Central School	1st Floor Boys Bathroom	3 ppb
Lincolville Central School	1st Floor Drinking Fountains	0 ppb
Lincolville Central School	1st Floor Girls Bathroom	3.3 ppb
Lincolville Central School	1st Floor Water Bottle Fill Station	0 ppb
Lincolville Central School	2nd Floor Drinking Fountain Lt (grade 3-5)	0 ppb
Lincolville Central School	2nd Floor Drinking Fountain Rt (grade 6-8)	0 ppb
Lincolville Central School	2nd Floor Water Bottle Fill Station (gr 3-5)	0 ppb
Lincolville Central School	2nd Floor Water Bottle Fill Station (gr 6-8)	0 ppb
Lincolville Central School	2nd Floor Work & Copier Room	2.2 ppb
Lincolville Central School	3rd Grade Classroom B4	1.5 ppb
Lincolville Central School	3rd Grade Classroom B5	0 ppb
Lincolville Central School	4th Grade Classroom	1.3 ppb
Lincolville Central School	5th Grade Classroom	2.5 ppb
Lincolville Central School	Art Room Sink 2 (deep Sink)	0 ppb
Lincolville Central School	Boys Locker Room-sink 1	2.4 ppb
Lincolville Central School	French Room	3.4 ppb
Lincolville Central School	Girls Locker Room-sink 1	1.8 ppb
Lincolville Central School	Kitchen- Food Prep Sink	2.9 ppb
Lincolville Central School	Kitchen- Mop Sink	79.4 ppb
Lincolville Central School	Kitchen- Pasta/bulk Food Cooking Vessel	53.8 ppb
Lincolville Central School	Locker Room (gym) Drinking Fountain	0 ppb
Lincolville Central School	Nurse's Office	0 ppb
Lincolville Central School	Room A-3 Kindergarten Fountain	0 ppb
Lincolville Central School	Room A-4 2nd Grade	1.7 ppb
Lincolville Central School	Staff Bathroom	2 ppb
Lincolville Central School	Teachers Lounge	0 ppb
Line Elementary	2nd Floor Elevator-drinking Fountain	2 ppb
Line Elementary	Bottle Filler-lobby	7.2 ppb
Line Elementary	Drinking Fountain Lobby	1.1 ppb
Line Elementary	Drinking Fountain-cafeteria	1.9 ppb
Line Elementary	Kitchen-3 Bay Sink (l)	9.1 ppb
Line Elementary	Kitchen-3 Bay Sink (r)	55.8 ppb
Line Elementary	Kitchen-kettle	4.8 ppb
Line Elementary	Kitchen-vegetable Sink	47.2 ppb
Line Elementary	Modular Bottle Filler	0 ppb
Line Elementary	Modular Drinking Fountain	0 ppb
Line Elementary	Nurse's Office-sink	11.6 ppb
Line Elementary	Room 110-drinking Fountain	51.4 ppb
Line Elementary	Room 110-sink	1.2 ppb
Line Elementary	Room 113-drinking Fountain	15.1 ppb
Line Elementary	Room 113-sink	106 ppb
Line Elementary	Room 117-drinking Fountain	7.8 ppb

School Name	Sample Location	Lead Test Result
Line Elementary	Room 117-sink	2.4 ppb
Line Elementary	Room 119-drinking Fountain	20.2 ppb
Line Elementary	Room 119-sink	325 ppb
Line Elementary	Room 120-drinking Fountain	8.2 ppb
Line Elementary	Room 120-sink	4.9 ppb
Line Elementary	Room 122-drinking Fountain	5.5 ppb
Line Elementary	Room 122-sink	4.4 ppb
Line Elementary	Room 125-drinking Fountain	99.3 ppb
Line Elementary	Room 125-sink	76.9 ppb
Line Elementary	Room 203-drinking Fountain	17.2 ppb
Line Elementary	Room 203-sink	2610 ppb
Line Elementary	Room 206-drinking Fountain	13.1 ppb
Line Elementary	Room 206-sink	114 ppb
Line Elementary	Room 213-sink	10 ppb
Line Elementary	Room 214-sink	31 ppb
Line Elementary	Room 215-sink	3.7 ppb
Line Elementary	Room 216-sink	5 ppb
Line Elementary	Room 218-sink	2 ppb
Line Elementary	Room 222-drinking Fountain	37.1 ppb
Line Elementary	Room 222-sink	4.1 ppb
Line Elementary	Speech-drinking Fountain	3.3 ppb
Line Elementary	Speech-sink	24.1 ppb
Line Elementary	Teacher's Room-sink	5.1 ppb
Lisbon Community School	100 Wing Teachers Room	18.7 ppb
Lisbon Community School	200 Wing Teachers Room	14.4 ppb
Lisbon Community School	300 Wing Teachers Room	6.9 ppb
Lisbon Community School	Cafeteria Bathroom	7.1 ppb
Lisbon Community School	Cafeteria Water Fountain	2.2 ppb
Lisbon Community School	Clinic	7.1 ppb
Lisbon Community School	Corner Sink A	1.7 ppb
Lisbon Community School	Corner Sink B	3.5 ppb
Lisbon Community School	Custodian Room A	35.8 ppb
Lisbon Community School	Gym Bathroom Mens	17.4 ppb
Lisbon Community School	Gym Bathroom Womans	21.1 ppb
Lisbon Community School	Gym Water Fountain A	5.5 ppb
Lisbon Community School	Gym Water Fountain B	0 ppb
Lisbon Community School	Hand Sink 1	1.4 ppb
Lisbon Community School	Hand Sink 2	4.5 ppb
Lisbon Community School	Hand Sink 3	4.5 ppb
Lisbon Community School	Kitchen Sink A	4.6 ppb
Lisbon Community School	Kitchen Sink B	4.2 ppb
Lisbon Community School	Library Bathroom	2.4 ppb
Lisbon Community School	Main Office Bathroom	4.2 ppb
Lisbon Community School	Restroom A	8.6 ppb
Lisbon Community School	Restroom B	3.6 ppb
Lisbon Community School	Room 1	2.6 ppb
Lisbon Community School	Room 10	4.1 ppb

School Name	Sample Location	Lead Test Result
Lisbon Community School	Room 103	4.1 ppb
Lisbon Community School	Room 104	2.8 ppb
Lisbon Community School	Room 105	9.6 ppb
Lisbon Community School	Room 106	1.9 ppb
Lisbon Community School	Room 107	8.8 ppb
Lisbon Community School	Room 108	4 ppb
Lisbon Community School	Room 109	8.4 ppb
Lisbon Community School	Room 11	1.1 ppb
Lisbon Community School	Room 110	2.9 ppb
Lisbon Community School	Room 111	8 ppb
Lisbon Community School	Room 112	3.1 ppb
Lisbon Community School	Room 113	2.5 ppb
Lisbon Community School	Room 114	9.7 ppb
Lisbon Community School	Room 12	7.6 ppb
Lisbon Community School	Room 16 A Faucet	9.1 ppb
Lisbon Community School	Room 16 B Faucet	8.2 ppb
Lisbon Community School	Room 16 C Faucet	9.5 ppb
Lisbon Community School	Room 16 D Faucet	9.2 ppb
Lisbon Community School	Room 16 E Faucet	6.5 ppb
Lisbon Community School	Room 2	4.7 ppb
Lisbon Community School	Room 203	0 ppb
Lisbon Community School	Room 204	6.9 ppb
Lisbon Community School	Room 205	10.7 ppb
Lisbon Community School	Room 206	3.4 ppb
Lisbon Community School	Room 207	8.9 ppb
Lisbon Community School	Room 208	4.2 ppb
Lisbon Community School	Room 209	6.4 ppb
Lisbon Community School	Room 210	3.8 ppb
Lisbon Community School	Room 211	4.6 ppb
Lisbon Community School	Room 212	14.6 ppb
Lisbon Community School	Room 213	6 ppb
Lisbon Community School	Room 214	6.4 ppb
Lisbon Community School	Room 3	11.2 ppb
Lisbon Community School	Room 30 A	11.1 ppb
Lisbon Community School	Room 30 B	8.8 ppb
Lisbon Community School	Room 303	7 ppb
Lisbon Community School	Room 304	5.2 ppb
Lisbon Community School	Room 305	7.8 ppb
Lisbon Community School	Room 306	4.7 ppb
Lisbon Community School	Room 307	5.1 ppb
Lisbon Community School	Room 308	2.3 ppb
Lisbon Community School	Room 309	3.3 ppb
Lisbon Community School	Room 310	3.4 ppb
Lisbon Community School	Room 311	6.1 ppb
Lisbon Community School	Room 312	8.5 ppb
Lisbon Community School	Room 313	7.3 ppb
Lisbon Community School	Room 314	6.1 ppb

School Name	Sample Location	Lead Test Result
Lisbon Community School	Room 32	5.8 ppb
Lisbon Community School	Room 36	7.4 ppb
Lisbon Community School	Room 4	2.5 ppb
Lisbon Community School	Room 42	6.2 ppb
Lisbon Community School	Room 42 Bathroom	3.5 ppb
Lisbon Community School	Room 8	2.7 ppb
Lisbon Community School	Room 9	3 ppb
Lisbon Community School	Staff Only Bathroom	7.6 ppb
Lisbon Community School	Teacher Room 8	6 ppb
Lisbon High School	100 Wing Boys Bathroom	10.1 ppb
Lisbon High School	100 Wing Girls Bathroom	1.8 ppb
Lisbon High School	100 Wing Water Fountain	3.2 ppb
Lisbon High School	200 Wing Boys Bathroom	10.2 ppb
Lisbon High School	200 Wing Custodial Closet	4.5 ppb
Lisbon High School	200 Wing Girls Bathroom	6.8 ppb
Lisbon High School	200 Wing Staff Bathroom Sink #1	25.9 ppb
Lisbon High School	200 Wing Staff Bathroom Sink #2	142 ppb
Lisbon High School	200 Wing Water Fountain	3.7 ppb
Lisbon High School	300 Wing Boys Bathroom	3.7 ppb
Lisbon High School	300 Wing Faucet #1	36.2 ppb
Lisbon High School	300 Wing Faucet #2	2330 ppb
Lisbon High School	300 Wing Girls Bathroom	2.6 ppb
Lisbon High School	300 Wing Staff Bathroom	5.1 ppb
Lisbon High School	300 Wing Water Fountain	1.8 ppb
Lisbon High School	Custodial Closet	2.2 ppb
Lisbon High School	Kitchen Bathroom Faucet	15.7 ppb
Lisbon High School	Kitchen Faucet #1	3 ppb
Lisbon High School	Kitchen Faucet #2	1.7 ppb
Lisbon High School	Kitchen Faucet #3	2.9 ppb
Lisbon High School	Kitchen Faucet #4	2.6 ppb
Lisbon High School	Kitchen Faucet #5	2 ppb
Lisbon High School	Kitchen Ice Machine	0 ppb
Lisbon High School	Library Bathroom #1	6.9 ppb
Lisbon High School	Library Bathroom #2	18.5 ppb
Lisbon High School	Library Wing Bathroom #1	3.4 ppb
Lisbon High School	Nurses Office	13.6 ppb
Lisbon High School	Room 104 Sink	24.7 ppb
Lisbon High School	Room 106 Sink	3 ppb
Lisbon High School	Room 108 Bathroom Sink	2 ppb
Lisbon High School	Room 108 Staff Sink	0 ppb
Lisbon High School	Room 301 Faucet #1	3.6 ppb
Lisbon High School	Room 301 Faucet #2	102 ppb
Lisbon High School	Room 302 Faucet #3	7.7 ppb
Lisbon High School	Room 302 Faucet #4	147 ppb
Lisbon High School	Room 302 Faucet #5	5.9 ppb
Lisbon High School	Room 303 Faucet #1	22.7 ppb
Lisbon High School	Room 303 Faucet #4	1240 ppb

School Name	Sample Location	Lead Test Result
Lisbon High School	Room 303 Faucet #5	7.6 ppb
Lisbon High School	Room 303 Faucet #6	1.9 ppb
Lisbon High School	Room 303 Faucet #7	6.7 ppb
Lisbon High School	Room 303 Faucet #2	41.9 ppb
Lisbon High School	Room 303 Faucet #3	607 ppb
Lisbon High School	Room 304 Faucet #2	217 ppb
Lisbon High School	Room 304 Faucet #3	47.7 ppb
Lisbon High School	Room 304 Faucet #4	32.1 ppb
Lisbon High School	Room 304 Faucet #1	15.1 ppb
Lisbon High School	Room 306 Faucet #2	2.2 ppb
Lisbon High School	Room 306 Faucet #1	3 ppb
Long Island Elementary School	Kitchen Sink	9.7 ppb
Long Island Elementary School	Water Fountain	4.2 ppb
Longfellow School-Portland	101	8 ppb
Longfellow School-Portland	102	5.7 ppb
Longfellow School-Portland	105	7.9 ppb
Longfellow School-Portland	106	11.9 ppb
Longfellow School-Portland	107	3.9 ppb
Longfellow School-Portland	112	6.2 ppb
Longfellow School-Portland	201	10.5 ppb
Longfellow School-Portland	202	24.1 ppb
Longfellow School-Portland	203	4.8 ppb
Longfellow School-Portland	204	8.5 ppb
Longfellow School-Portland	205	8.1 ppb
Longfellow School-Portland	206	17.2 ppb
Longfellow School-Portland	207	7.8 ppb
Longfellow School-Portland	208	9.2 ppb
Longfellow School-Portland	209	8 ppb
Longfellow School-Portland	210	5.1 ppb
Longfellow School-Portland	Library	49.1 ppb
Longfellow School-Portland	Pos-1	0 ppb
Longfellow School-Portland	Teachers Lounge	0 ppb
Loranger Memorial School	Bottle Fill Station Outside 12l	0 ppb
Loranger Memorial School	Bottle Fill Station Outside 4l	0 ppb
Loranger Memorial School	Bottle Fill Station Outside 7b	0 ppb
Loranger Memorial School	Bottle Fill Station Outside Cafe	0 ppb
Loranger Memorial School	Bottle Fill Station Outside Rm 4	0 ppb
Loranger Memorial School	Copy Room Sink	144 ppb
Loranger Memorial School	Fsa B Sink	164 ppb
Loranger Memorial School	Fsa Sink #1	30.7 ppb
Loranger Memorial School	Fsa Sink #2	28 ppb
Loranger Memorial School	Fsa Sink #3	20.8 ppb
Loranger Memorial School	Ice Machine Ad Office	166 ppb
Loranger Memorial School	Kitchen Double Sink #1	3 ppb
Loranger Memorial School	Kitchen Double Sink #2	4.1 ppb
Loranger Memorial School	Kitchen Ice Machine	0 ppb
Loranger Memorial School	Sink 10 B	80.1 ppb

School Name	Sample Location	Lead Test Result
Loranger Memorial School	Teachers Lounge Sink	3.2 ppb
Loranger Memorial School	Teachers Room Sink	96.7 ppb
Lubec Consolidated School	Bottle Fill Station By Gym	0 ppb
Lubec Consolidated School	Bottle Fill Station By Main Office	0 ppb
Lubec Consolidated School	Bottle Fill Station By Teacheræs Room	3.4 ppb
Lubec Consolidated School	Kitchen Double Sink	0 ppb
Lubec Consolidated School	Sink In Room 101	1.3 ppb
Lubec Consolidated School	Sink In Room 102	14.2 ppb
Lubec Consolidated School	Sink In Room 104	6.8 ppb
Lubec Consolidated School	Sink In Room 106	3.9 ppb
Lubec Consolidated School	Sink In Room 107	6.5 ppb
Lubec Consolidated School	Sink In Teacheræs Lounge	1.6 ppb
Lyman Elementary School	Art Room-drinking Fountain	10.9 ppb
Lyman Elementary School	Art Room-sink	2.4 ppb
Lyman Elementary School	Drinking Fountain Library-high	1 ppb
Lyman Elementary School	Drinking Fountain Library-low	0 ppb
Lyman Elementary School	Drinking Fountain Teacher's Lounge	3.4 ppb
Lyman Elementary School	Kitchen-3 Bay Sink (l)	6.8 ppb
Lyman Elementary School	Kitchen-3 Bay Sink (r)	3.4 ppb
Lyman Elementary School	Kitchen-combi Oven	7.5 ppb
Lyman Elementary School	Kitchen-skillet	1.1 ppb
Lyman Elementary School	Kitchen-vegetable Sink	3.3 ppb
Lyman Elementary School	Nurse's Office-sink	9 ppb
Lyman Elementary School	Room 10-drinking Fountain	7.8 ppb
Lyman Elementary School	Room 10-sink	3.7 ppb
Lyman Elementary School	Room 11-drinking Fountain	12.1 ppb
Lyman Elementary School	Room 11-sink	33.5 ppb
Lyman Elementary School	Room 12-drinking Fountain	14.7 ppb
Lyman Elementary School	Room 12-sink	5.3 ppb
Lyman Elementary School	Room 14-drinking Fountain	9.8 ppb
Lyman Elementary School	Room 14-sink	3.4 ppb
Lyman Elementary School	Room 15-drinking Fountain	9.1 ppb
Lyman Elementary School	Room 15-sink	4 ppb
Lyman Elementary School	Room 16-drinking Fountain	7.4 ppb
Lyman Elementary School	Room 16-sink	2.1 ppb
Lyman Elementary School	Room 17-drinking Fountain	4.6 ppb
Lyman Elementary School	Room 17-sink	6.7 ppb
Lyman Elementary School	Room 18-drinking Fountain	6.8 ppb
Lyman Elementary School	Room 18-sink	1.5 ppb
Lyman Elementary School	Room 19-drinking Fountain	4.3 ppb
Lyman Elementary School	Room 19-sink	1.3 ppb
Lyman Elementary School	Room 1-drinking Fountain	23 ppb
Lyman Elementary School	Room 1-sink	272 ppb
Lyman Elementary School	Room 20-drinking Fountain	3.3 ppb
Lyman Elementary School	Room 20-sink	2.4 ppb
Lyman Elementary School	Room 21-drinking Fountain	11.7 ppb
Lyman Elementary School	Room 21-sink	2.9 ppb

School Name	Sample Location	Lead Test Result
Lyman Elementary School	Room 2-drinking Fountain	13.7 ppb
Lyman Elementary School	Room 2-sink	8.2 ppb
Lyman Elementary School	Room 3-drinking Fountain	11.7 ppb
Lyman Elementary School	Room 3-sink	3.2 ppb
Lyman Elementary School	Room 4-drinking Fountain	8.3 ppb
Lyman Elementary School	Room 4-sink	6.1 ppb
Lyman Elementary School	Room 5-drinking Fountain	11.5 ppb
Lyman Elementary School	Room 5-sink	8.4 ppb
Lyman Elementary School	Room 6-drinking Fountain	7.5 ppb
Lyman Elementary School	Room 6-sink	4.3 ppb
Lyman Elementary School	Room 7-drinking Fountain	7.4 ppb
Lyman Elementary School	Room 7-sink	4.2 ppb
Lyman Elementary School	Room 8-drinking Fountain	17.5 ppb
Lyman Elementary School	Room 8-sink	14.2 ppb
Lyman Elementary School	Room 9-drinking Fountain	15.4 ppb
Lyman Elementary School	Room 9-sink	5.6 ppb
Lyman Elementary School	Teacher's Room-sink	2.9 ppb
Lyman Moore Middle School	107-1	0 ppb
Lyman Moore Middle School	107-2	1.2 ppb
Lyman Moore Middle School	109-1	2.2 ppb
Lyman Moore Middle School	109-2	1.2 ppb
Lyman Moore Middle School	110	0 ppb
Lyman Moore Middle School	111-01	0 ppb
Lyman Moore Middle School	114-1	0 ppb
Lyman Moore Middle School	114-2	0 ppb
Lyman Moore Middle School	126-01	1.2 ppb
Lyman Moore Middle School	132-01	1.1 ppb
Lyman Moore Middle School	143-1	0 ppb
Lyman Moore Middle School	143-2	6.8 ppb
Lyman Moore Middle School	145	15.6 ppb
Lyman Moore Middle School	151 - Left Sink	1.9 ppb
Lyman Moore Middle School	151 - Right Sink	1 ppb
Lyman Moore Middle School	155	2 ppb
Lyman Moore Middle School	156	7.2 ppb
Lyman Moore Middle School	214-1	0 ppb
Lyman Moore Middle School	214-2	6 ppb
Lyman Moore Middle School	223	2 ppb
Lyman Moore Middle School	224-1	0 ppb
Lyman Moore Middle School	224-2	0 ppb
Lyman Moore Middle School	228-1	0 ppb
Lyman Moore Middle School	228-2	0 ppb
Lyman Moore Middle School	Girls Locker Room	0 ppb
Lyman Moore Middle School	Hall - 2nd Floor Between The Bathrooms	0 ppb
Lyman Moore Middle School	Hall - Across From Room 103	0 ppb
Lyman Moore Middle School	Hall - By Gym 1	0 ppb
Lyman Moore Middle School	Hall - By Room 154	0 ppb
Lyman Moore Middle School	Hall - By Room 161	0 ppb

School Name	Sample Location	Lead Test Result
Lyman Moore Middle School	Kitchen - Left Sink	7.7 ppb
Lyman Moore Middle School	Kitchen - Right Sink	3.6 ppb
Lyman Moore Middle School	Library Back Room	1.8 ppb
Lyman Moore Middle School	Main Office	0 ppb
Lyman Moore Middle School	Pos-1	13.6 ppb
Mabel I Wilson School	3rd Floor Staff Restroom Sink	0 ppb
Mabel I Wilson School	Book Nook Sink With Fountain	2 ppb
Mabel I Wilson School	Boys Restroom B Wing Sink By Hallway	0 ppb
Mabel I Wilson School	Boys Restroom B Wing Sink By Urinal	2 ppb
Mabel I Wilson School	Boys Restroom Sink In Gym	1.4 ppb
Mabel I Wilson School	C Wing Boys Restroom Sink # By Urinal	1.1 ppb
Mabel I Wilson School	C Wing Boys Restroom Sink #2 Near Hallway	1.1 ppb
Mabel I Wilson School	C Wing Girls Restroom Sink #1 By Toilet	1.4 ppb
Mabel I Wilson School	C Wing Girls Restroom Sink #2 By Hallway	1.4 ppb
Mabel I Wilson School	Cafe Hallway Drinking Fountain	0 ppb
Mabel I Wilson School	Cafe Hallway Restroom Sink	0 ppb
Mabel I Wilson School	D Wing Boys Restroom Sink By Urinal	3.3 ppb
Mabel I Wilson School	D Wing Boys Restroom Sink Closest To Hall	1.2 ppb
Mabel I Wilson School	D Wing Girls Restroom Sink By Stall	1.8 ppb
Mabel I Wilson School	D Wing Girls Restroom Sink Closest To Hall	1.1 ppb
Mabel I Wilson School	Discovery Room Sink	0 ppb
Mabel I Wilson School	Drinking Fountain B-wing Hall	0 ppb
Mabel I Wilson School	Drinking Fountain Outside Of Gym	0 ppb
Mabel I Wilson School	Girls Restroom B-wing Sink By Hallways	1.8 ppb
Mabel I Wilson School	Girls Restroom B-wing Sink By Toilet	1.7 ppb
Mabel I Wilson School	Girls Restroom Sink In Gym	1.6 ppb
Mabel I Wilson School	Lg Artroom Sink #1 From Wall At Right Side	2.3 ppb
Mabel I Wilson School	Lg Artroom Sink #2 Next Sink	4.1 ppb
Mabel I Wilson School	Lg Artroom Sink #3 From Wall Left Sign	2.1 ppb
Mabel I Wilson School	Lg Artroom Sink #4 Next Sink	2.1 ppb
Mabel I Wilson School	Library Restroom Sink	0 ppb
Mabel I Wilson School	Main Hallway Boys Restroom Sink	3.3 ppb
Mabel I Wilson School	Main Hallway Drinking Fountain	0 ppb
Mabel I Wilson School	Main Hallway Girls Restroom Sink	2.3 ppb
Mabel I Wilson School	Main Kitchen 2 Basin Sink In Baking Area	1.9 ppb
Mabel I Wilson School	Main Kitchen 2 Basin Sink In Prep Area	1.7 ppb
Mabel I Wilson School	Main Kitchen Hand Sink	1.6 ppb
Mabel I Wilson School	Main Kitchen Ice Machine	1.2 ppb
Mabel I Wilson School	Main Kitchen Kettle By Steamer	5.7 ppb
Mabel I Wilson School	Main Kitchen Kettle By Tables	0 ppb
Mabel I Wilson School	Main Office Restroom Sink	0 ppb
Mabel I Wilson School	Modular Boys Restrm Sink #5(large Stall)	0 ppb
Mabel I Wilson School	Modular Boys Restrm Sink1 Closest To Hall	0 ppb
Mabel I Wilson School	Modular Boys Restroom Sink #2	0 ppb
Mabel I Wilson School	Modular Boys Restroom Sink #3	0 ppb
Mabel I Wilson School	Modular Boys Restroom Sink #4	0 ppb

School Name	Sample Location	Lead Test Result
Mabel I Wilson School	Modular Drinking Fountain #2	0 ppb
Mabel I Wilson School	Modular Drinking Fountain #3	0 ppb
Mabel I Wilson School	Modular Drinking Fountain Closest To School	0 ppb
Mabel I Wilson School	Modular Girls Restrm Sink #1 - Hall	0 ppb
Mabel I Wilson School	Modular Girls Restrm Sink #5 (large Stall)	0 ppb
Mabel I Wilson School	Modular Girls Restroom Sink #2	0 ppb
Mabel I Wilson School	Modular Girls Restroom Sink #3	0 ppb
Mabel I Wilson School	Modular Girls Restroom Sink #4	0 ppb
Mabel I Wilson School	Modular Staff Restroom Sink	0 ppb
Mabel I Wilson School	Mr Steven's Room Sink With Fountain	0 ppb
Mabel I Wilson School	Nurse's Office Restroom Sink	0 ppb
Mabel I Wilson School	Nurse's Office Sink	2.2 ppb
Mabel I Wilson School	Pre-k Restroom Sink	1.5 ppb
Mabel I Wilson School	Room A-2 Sink With Fountain	0 ppb
Mabel I Wilson School	Room A-3 Sink Wiyh Fountain	0 ppb
Mabel I Wilson School	Room A-4 Sink With Fountain	0 ppb
Mabel I Wilson School	Room A-5 Sink With Fountain	0 ppb
Mabel I Wilson School	Room A-6 Sink With Fountain	0 ppb
Mabel I Wilson School	Room A-7 Sink With Fountain	0 ppb
Mabel I Wilson School	Room B-1 Sink With Fountain	1.3 ppb
Mabel I Wilson School	Room B-2 Sink With Fountain	0 ppb
Mabel I Wilson School	Room B-3 Sink With Fountain	1.9 ppb
Mabel I Wilson School	Room B-4 Sink With Fountain	0 ppb
Mabel I Wilson School	Room B-5 Sink With Fountain	3.9 ppb
Mabel I Wilson School	Room B-6 Sinkwith Fountain	0 ppb
Mabel I Wilson School	Room B-7 Sink With Fountain	2.8 ppb
Mabel I Wilson School	Room B-8 Sink With Fountain	0 ppb
Mabel I Wilson School	Room C-1 Sink With Fountain	0 ppb
Mabel I Wilson School	Room C-2 Sink With Fountain	0 ppb
Mabel I Wilson School	Room C-3 Sink With Fountain	0 ppb
Mabel I Wilson School	Room C-4 Sink With Fountain	0 ppb
Mabel I Wilson School	Room C-5 Sink With Fountain	1.2 ppb
Mabel I Wilson School	Room C-6 Sink With Fountain	5.1 ppb
Mabel I Wilson School	Room C-7 Sink With Fountain	0 ppb
Mabel I Wilson School	Room C-8 Sink With Fountain	1.1 ppb
Mabel I Wilson School	Room D-1 Sink With Fountain	11.3 ppb
Mabel I Wilson School	Room D-2 Sink With Fountain	1.7 ppb
Mabel I Wilson School	Room D-3 Sink With Fountain	1.9 ppb
Mabel I Wilson School	Room D-4 Sink With Fountain	1.8 ppb
Mabel I Wilson School	Room D-5 Sink With Fountain	0 ppb
Mabel I Wilson School	Room D-6 Sink With Fountain	2.6 ppb
Mabel I Wilson School	Room D-7 Sink With Fountain	0 ppb
Mabel I Wilson School	Room D-8 Sink With Fountain	0 ppb
Mabel I Wilson School	Small Artroom Sink	0 ppb
Mabel I Wilson School	Teacher's Room Sink	0 ppb
Mabel I Wilson School	Upstairs Kitchen Sink In Dishroom	4.2 ppb

School Name	Sample Location	Lead Test Result
Machias Memorial High School	Boys Bathroom	7.4 ppb
Machias Memorial High School	Canteen Kitchen Sink Gym	0 ppb
Machias Memorial High School	Culinary Room 3 Bay Sink	0 ppb
Machias Memorial High School	Drinking Fountain Cafeteria	0 ppb
Machias Memorial High School	East Side Hall Drinking Fountain	0 ppb
Machias Memorial High School	Furnace Room Entry Point	0 ppb
Machias Memorial High School	Girls Bathroom	5.5 ppb
Machias Memorial High School	Gym Drinking Fountain	0 ppb
Machias Memorial High School	Kitchen 3 Bay Sink	6.7 ppb
Machias Memorial High School	Kitchen Prep Sink	1.7 ppb
Machias Memorial High School	Kitchen Wash Sink	3.5 ppb
Machias Memorial High School	Lunchroom Handwash Sink (previously Identified As Lunchroom Caft. Drinking Fountain)	51 ppb
Machias Memorial High School	Physic/chemistry Lab Row 1	45.5 ppb
Machias Memorial High School	Physic/chemistry Lab Row 2	75 ppb
Machias Memorial High School	Room 14 Biology Lab	1.2 ppb
Machias Memorial High School	Room 7 Art Sink	11.6 ppb
Machias Memorial High School	Room 8 Special Education Kitchen Sink	8.1 ppb
Machias Memorial High School	Teachers Room	12.7 ppb
Machias Memorial High School	West Side Hall Sink	18.3 ppb
Machias Memorial High School	West Wing Bathroom	4.6 ppb
Madawaska Elementary School	2-3 Wing Fountain/bottle Filler	2.3 ppb
Madawaska Elementary School	2nd Floor Wing Foutain/bottle Filler	0 ppb
Madawaska Elementary School	Kitchen Food Prep Sink	0 ppb
Madawaska Elementary School	Library Office Sink	2.9 ppb
Madawaska Elementary School	Music Room Sink	18.9 ppb
Madawaska Elementary School	Public Fountain/bottle Filler	0 ppb
Madawaska Elementary School	Room 100 Sink/fountain	0 ppb
Madawaska Elementary School	Room 101 Sink/fountain	3.7 ppb
Madawaska Elementary School	Room 102 Sink/fountain	1.3 ppb
Madawaska Elementary School	Room 103 Sink/fountain	1.2 ppb
Madawaska Elementary School	Room 104 Sink/fountain	5.2 ppb
Madawaska Elementary School	Room 105 Sink/fountain	9.9 ppb
Madawaska Elementary School	Room 106 Sink/fountain	5.6 ppb
Madawaska Elementary School	Room 111 Sink/fountain	4.2 ppb
Madawaska Elementary School	Room 112 Sink/fountain	2.4 ppb
Madawaska Elementary School	Room 113 Sink/fountain	2.7 ppb
Madawaska Elementary School	Room 114 Sink/fountain	2.3 ppb
Madawaska Elementary School	Room 115 Sink/fountain	1.9 ppb
Madawaska Elementary School	Room 116 Sink/fountain	1.5 ppb
Madawaska Elementary School	Room 117 Sink/fountain	1.7 ppb
Madawaska Elementary School	Room 118 Sink/fountain	3.2 ppb
Madawaska Elementary School	Room 119 Sink/fountain	1.5 ppb
Madawaska Elementary School	Room 210 Sink/fountain	2.6 ppb
Madawaska Elementary School	Room 212 Sink/fountain	71.6 ppb
Madawaska Elementary School	Room 213 Sink/fountain	4 ppb

School Name	Sample Location	Lead Test Result
Madawaska Elementary School	Room 214 Sink/fountain	2.4 ppb
Madawaska Elementary School	Room 215 Sink/fountain	1.9 ppb
Madawaska Elementary School	Room 216 Sink/fountain	3.8 ppb
Madawaska Elementary School	Room 217 Sink/fountain	4.3 ppb
Madawaska Elementary School	Room 218 Sink/fountain	4 ppb
Madawaska Elementary School	Room 219 Sink/fountain	2 ppb
Madawaska Elementary School	Teachers Room Sink	5.5 ppb
Madawaska Middle/High School	3rd Floor Fountain/bottle Filler	0 ppb
Madawaska Middle/High School	Adult Ed Fountain/bottle Filler	0 ppb
Madawaska Middle/High School	Boys Locker Room Fountain	0 ppb
Madawaska Middle/High School	Custodial Office Sink	1.1 ppb
Madawaska Middle/High School	Girls Locker Room Fountain	1.5 ppb
Madawaska Middle/High School	Green Wing Fountain (by Rm 203)	20.1 ppb
Madawaska Middle/High School	Green Wing Fountain (by Rm 210)	0 ppb
Madawaska Middle/High School	Industrial Arts Fountain	2.5 ppb
Madawaska Middle/High School	Kitchen Food Prep Sink	6.3 ppb
Madawaska Middle/High School	Library Office Sink	6.6 ppb
Madawaska Middle/High School	Lobby Fountain	0 ppb
Madawaska Middle/High School	Main Hall Fountain/bottle Filler	0 ppb
Madawaska Middle/High School	Office Restroom Sink	0 ppb
Madawaska Middle/High School	Room 212 Sink	1.4 ppb
Madawaska Middle/High School	Room 300 Sink	1.8 ppb
Madawaska Middle/High School	Science Wing Fountain/bottle Filler	0 ppb
Madison Area Memorial H S	Cafeteria Sink	1.3 ppb
Madison Area Memorial H S	Gym A	0 ppb
Madison Area Memorial H S	Gym B	0 ppb
Madison Area Memorial H S	Gym C	0 ppb
Madison Area Memorial H S	Kitchen Dishwasher	0 ppb
Madison Area Memorial H S	Kitchen Handwashing Station	1.8 ppb
Madison Area Memorial H S	Kitchen Ice Machine	0 ppb
Madison Area Memorial H S	Room 113	0 ppb
Madison Area Memorial H S	Room 166	0 ppb
Madison Area Memorial H S	Room 167	0 ppb
Madison Area Memorial H S	Room 211	0 ppb
Madison Area Memorial H S	Room 212	0 ppb
Madison Area Memorial H S	Storage Room	0 ppb
Madison Area Memorial H S	Training Room	0 ppb
Madison Area Memorial H S	Training Room Ice Machine	0 ppb
Madison Elementary School	3bay Sink	1.9 ppb
Madison Elementary School	Back Lob A	0 ppb
Madison Elementary School	Back Lob B	0 ppb
Madison Elementary School	Boiler	1.1 ppb
Madison Elementary School	Dsh Wsher	0 ppb
Madison Elementary School	Hand Sk A	1.1 ppb
Madison Elementary School	Hand Sk B	7.3 ppb
Madison Elementary School	Nurses Station	0 ppb
Madison Elementary School	Room 102	0 ppb

School Name	Sample Location	Lead Test Result
Madison Elementary School	Room 103	0 ppb
Madison Elementary School	Room 105	1.1 ppb
Madison Elementary School	Room 106	0 ppb
Madison Elementary School	Room 108	0 ppb
Madison Elementary School	Room 109	3.8 ppb
Madison Elementary School	Room 110	0 ppb
Madison Elementary School	Room 112	0 ppb
Madison Elementary School	Room 114	0 ppb
Madison Elementary School	Room 120	0 ppb
Madison Elementary School	Room 121	0 ppb
Madison Elementary School	Room 122	0 ppb
Madison Elementary School	Room 123	0 ppb
Madison Elementary School	Room 124	0 ppb
Madison Elementary School	Room 125	0 ppb
Madison Elementary School	Room 129	0 ppb
Madison Elementary School	Room 131	0 ppb
Madison Elementary School	Veg Sk	0 ppb
Madison Junior High School	2nd Floor Boys	0 ppb
Madison Junior High School	2nd Floor Girls	0 ppb
Madison Junior High School	Boys Locker A	5 ppb
Madison Junior High School	Boys Locker B	5.7 ppb
Madison Junior High School	Cafe Drink Stat	0 ppb
Madison Junior High School	Cafeteria Ice Machine	0 ppb
Madison Junior High School	Girls Locker A	1.9 ppb
Madison Junior High School	Girls Locker B	0 ppb
Madison Junior High School	Kitchen 3 Bay Sink	1 ppb
Madison Junior High School	Kitchen Dish Room	0 ppb
Madison Junior High School	Kitchen Handwashing Sink	1.2 ppb
Madison Junior High School	Kitchen Prep Sink	0 ppb
Madison Junior High School	Kitchen Steam Kettle	1.1 ppb
Madison Junior High School	Kvmpa Handwashing Sink	0 ppb
Madison Junior High School	Kvmpa Kitchen Dish Washing Sink	0 ppb
Madison Junior High School	Room 005	0 ppb
Madison Junior High School	Room 104 C	0 ppb
Madison Junior High School	Room 104 A	0 ppb
Madison Junior High School	Room 104 B	0 ppb
Madison Junior High School	Room 106	24.3 ppb
Madison Junior High School	Room 111	0 ppb
Madison Junior High School	Room 113	0 ppb
Madison Junior High School	Room 119a	2.2 ppb
Madison Junior High School	Room 119b	9.3 ppb
Madison Junior High School	Room 149	0 ppb
Madison Junior High School	Room 152	0 ppb
Madison Junior High School	Room 203	473 ppb
Madison Junior High School	Room 204	1.1 ppb
Madison Junior High School	Room 207	13.6 ppb
Madison Junior High School	Room 209	6.3 ppb

School Name	Sample Location	Lead Test Result
Madison Junior High School	Room 211	4 ppb
Madison Junior High School	Room 213	9.9 ppb
Madison Junior High School	Room 216	0 ppb
Madison Junior High School	Room 217	2.1 ppb
Madison Junior High School	Room 218	11 ppb
Madison Junior High School	Room 231	2.7 ppb
Madison Junior High School	Training Room Ice Machine	0 ppb
Maine Academy of Natural Sciences	Classroom A101 Sink	0 ppb
Maine Academy of Natural Sciences	Classroom M102 Sink	0 ppb
Maine Academy of Natural Sciences	Classroom M106 Sink	0 ppb
Maine Academy of Natural Sciences	Classroom M202 Sink	0 ppb
Maine Academy of Natural Sciences	First Floor Bathroom #m007 Sink	0 ppb
Maine Academy of Natural Sciences	First Floor Bathroom #m008	0 ppb
Maine Academy of Natural Sciences	First Floor Drinking Fountain #1	0 ppb
Maine Academy of Natural Sciences	First Floor Drinking Fountain #2	0 ppb
Maine Academy of Natural Sciences	Greenhouse #1 Sink	0 ppb
Maine Academy of Natural Sciences	Greenhouse #2 Hose Spigot	1.7 ppb
Maine Academy of Natural Sciences	M107 Bathroom Sink	0 ppb
Maine Academy of Natural Sciences	M109 Bathroom Sink	0 ppb
Maine Academy of Natural Sciences	M205 Bathroom Sink	0 ppb
Maine Academy of Natural Sciences	M207 Bathroom Sink	0 ppb
Maine Academy of Natural Sciences	Office A104c Sink	0 ppb
Maine Academy of Natural Sciences	Second Floor Drinking Fountain #1	0 ppb
Maine Academy of Natural Sciences	Second Floor Drinking Fountain #2	0 ppb
Maine Academy of Natural Sciences	Staff Bathroom M101b Sink	0 ppb
Maine Academy of Natural Sciences	Staff Bathroom M101c Sink	0 ppb
Maine Academy of Natural Sciences	Third Floor Drinking Fountain #1	0 ppb
Maine Academy of Natural Sciences	Third Floor Drinking Fountain #2	0 ppb
Maine Arts Academy School	Non-municipal/well	0 ppb
Maine Arts Academy School	Non-municipal/well	0 ppb
Maine Central Institute	Alumni 1st Floor Fountain	0 ppb
Maine Central Institute	Alumni 2e Bathroom Sink #1	0 ppb
Maine Central Institute	Alumni 2e Bathroom Sink #2	0 ppb
Maine Central Institute	Alumni 2w Bathroom Sink #1	0 ppb
Maine Central Institute	Alumni 2w Bathroom Sink #2	0 ppb
Maine Central Institute	Alumni 3e Bathroom Sink #2	0 ppb
Maine Central Institute	Alumni 3w Bathroom Sink #1	0 ppb
Maine Central Institute	Alumni 3w Bathroom Sink #2	0 ppb
Maine Central Institute	Alumni 4e Bathroom Sink #1	0 ppb
Maine Central Institute	Alumni 4e Bathroom Sink #2	0 ppb
Maine Central Institute	Alumni 5w Bathroom Sink #1	0 ppb
Maine Central Institute	Alumni 5w Bathroom Sink #2	0 ppb
Maine Central Institute	Alumni Apt 1 Bathroom #1	0 ppb
Maine Central Institute	Alumni Apt 1 Bathroom #2	0 ppb
Maine Central Institute	Alumni Apt 1 Kitchen	0 ppb
Maine Central Institute	Alumni Apt 2 Bathroom	0 ppb
Maine Central Institute	Alumni Apt 2 Kitchen	0 ppb

School Name	Sample Location	Lead Test Result
Maine Central Institute	Alumni Apt 3 Bathroom	0 ppb
Maine Central Institute	Alumni Apt 3 Kitchen	0 ppb
Maine Central Institute	Alumni Apt 4 Bathroom	0 ppb
Maine Central Institute	Alumni Apt 4 Kitchen	0 ppb
Maine Central Institute	Alumni Basement Kitchen	0 ppb
Maine Central Institute	Alumni Duty Room Bathroom Sink	0 ppb
Maine Central Institute	Cms 1st Floor Fountain	0 ppb
Maine Central Institute	Cms 2nd Floor Fountain	0 ppb
Maine Central Institute	Cms Basment Fountain	0 ppb
Maine Central Institute	Founders Fountain	0 ppb
Maine Central Institute	Hurd 1st Floor Apt Bathroom Sink	0 ppb
Maine Central Institute	Hurd 1st Floor Dorm Bathroom Sink #1	1.8 ppb
Maine Central Institute	Hurd 1st Floor Dorm Bathroom Sink #2	1.6 ppb
Maine Central Institute	Hurd 1st Floor Dorm Kitchen	1.6 ppb
Maine Central Institute	Hurd 2nd Floor Dorm Bathroom Sink #1	1.3 ppb
Maine Central Institute	Hurd 2nd Floor Dorm Bathroom Sink #2	1.1 ppb
Maine Central Institute	Jr Cianchette Boys Bathroom Sink #1	1.6 ppb
Maine Central Institute	Jr Cianchette Boys Bathroom Sink #2	19.2 ppb
Maine Central Institute	Jr Cianchette Boys Bathroom Sink #3	4.3 ppb
Maine Central Institute	Jr Cianchette Family Bathroom Sink	0 ppb
Maine Central Institute	Jr Cianchette Fountain	0 ppb
Maine Central Institute	Jr Cianchette Girls Bathroom Sink #1	2.2 ppb
Maine Central Institute	Jr Cianchette Girls Bathroom Sink #2	3.7 ppb
Maine Central Institute	Jr Cianchette Girls Bathroom Sink #3	2.4 ppb
Maine Central Institute	Kitchen Food Prep Sink	2.7 ppb
Maine Central Institute	Kitchen Ice Machine	0 ppb
Maine Central Institute	Kitchen Juice Machine	0 ppb
Maine Central Institute	Kitchen Soda Machine	0 ppb
Maine Central Institute	Manson 1st Floor Bathroom Sink #1	0 ppb
Maine Central Institute	Manson 1st Floor Bathroom Sink #2	0 ppb
Maine Central Institute	Manson 1st Floor Bathroom Sink #3	0 ppb
Maine Central Institute	Manson 2nd Floor Bathroom Sink #1	0 ppb
Maine Central Institute	Manson 2nd Floor Bathroom Sink #2	0 ppb
Maine Central Institute	Manson 2nd Floor Bathroom Sink #3	0 ppb
Maine Central Institute	Manson Apt 1 Bathroom	0 ppb
Maine Central Institute	Manson Apt 1 Kitchen	0 ppb
Maine Central Institute	Manson Apt 2 Bathroom	0 ppb
Maine Central Institute	Manson Apt 2 Kitchen	1.7 ppb
Maine Central Institute	Manson Apt 3 Bathroom	0 ppb
Maine Central Institute	Manson Apt 3 Kitchen	0 ppb
Maine Central Institute	Manson Apt 4 Bathroom	0 ppb
Maine Central Institute	Manson Apt 4 Kitchen	0 ppb
Maine Central Institute	Manson Apt 5 Bathroom	0 ppb
Maine Central Institute	Manson Apt 5 Kitchen	0 ppb
Maine Central Institute	Manson Basement Bathroom Sink #1	0 ppb
Maine Central Institute	Manson Basement Bathroom Sink #2	0 ppb
Maine Central Institute	Manson Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Maine Central Institute	Manson Kitchen	0 ppb
Maine Central Institute	Manson Studio Bathroom	2.1 ppb
Maine Central Institute	Parks Gym Fountain	0 ppb
Maine Central Institute	Parks Gym Ice Machine	0 ppb
Maine Central Institute	Powell Library 1st Floor Kitchen Faucet	3.9 ppb
Maine Central Institute	Powell Library Basement Kitchen Faucet	0 ppb
Maine Central Institute	Powell Library Fountain	0 ppb
Maine Central Institute	Rowe 1st Floor Bathroom Sink #1	0 ppb
Maine Central Institute	Rowe 1st Floor Bathroom Sink #2	0 ppb
Maine Central Institute	Rowe 1st Floor Bathroom Sink #3	16.5 ppb
Maine Central Institute	Rowe 2nd Floor Bathroom Sink #1	0 ppb
Maine Central Institute	Rowe 2nd Floor Bathroom Sink #2	0 ppb
Maine Central Institute	Rowe 2nd Floor Bathroom Sink #3	0 ppb
Maine Central Institute	Rowe Apt 1 Bathroom #1	1 ppb
Maine Central Institute	Rowe Apt 1 Bathroom #2	3.1 ppb
Maine Central Institute	Rowe Apt 1 Kitchen	0 ppb
Maine Central Institute	Rowe Apt 2 Bathroom	0 ppb
Maine Central Institute	Rowe Apt 2 Kitchen	0 ppb
Maine Central Institute	Rowe Apt 3 Bathroom	0 ppb
Maine Central Institute	Rowe Apt 3 Kitchen	0 ppb
Maine Central Institute	Rowe Apt 4 Bathroom	3.5 ppb
Maine Central Institute	Rowe Apt 4 Kitchen	1.5 ppb
Maine Central Institute	Rowe Apt 5 Bathroom	14.1 ppb
Maine Central Institute	Rowe Apt 5 Kitchen	0 ppb
Maine Central Institute	Rowe Fountain 1st Floor	0 ppb
Maine Central Institute	Rowe Fountain 2nd Floor	0 ppb
Maine Central Institute	Rowe Kitchen	0 ppb
Maine Central Institute	Rowe Suite Bathroom	0 ppb
Maine Central Institute	Weymouth Fountain	0 ppb
Maine Central Institute	Weymouth Infirmary Office	0 ppb
Maine Central Institute	Wright Gym Athletic Training Room Cooler Fill	4.5 ppb
Maine Central Institute	Wright Gym Basement Fountain	0 ppb
Maine Central Institute	Wright Gym Boys Locker 2nd Floor Sink	1.6 ppb
Maine Central Institute	Wright Gym Girls Locker 2nd Floor Sink	1.6 ppb
Maine Central Institute	Wright Gym Ice Machine	0 ppb
Maine Central Institute	Wright Gym Snack Shop	501 ppb
Maine Coast Semester at Chewonki	Allen Center- Advancement Bathroom Sink	8.1 ppb
Maine Coast Semester at Chewonki	Allen Center- Art Room Sink	3.9 ppb
Maine Coast Semester at Chewonki	Allen Center- Boys Bathroom Center Faucet	0 ppb
Maine Coast Semester at Chewonki	Allen Center- Boys Bathroom Left Faucet	0 ppb
Maine Coast Semester at Chewonki	Allen Center- Boys Bathroom Right Faucet	0 ppb
Maine Coast Semester at Chewonki	Allen Center- Ellis Room Waterbottle Filler	1.6 ppb

School Name	Sample Location	Lead Test Result
Maine Coast Semester at Chewonki	Allen Center- Grils Bathroom Center Faucet	0 ppb
Maine Coast Semester at Chewonki	Allen Center- Grils Bathroom Left Faucet	0 ppb
Maine Coast Semester at Chewonki	Allen Center- Grils Bathroom Right Faucet	0 ppb
Maine Coast Semester at Chewonki	Allen Center- Science Room Sink	32.2 ppb
Maine Coast Semester at Chewonki	Allen Center- Third Floor Bathroom Sink	3 ppb
Maine Coast Semester at Chewonki	Andrews- Downstairs Bathroom Sink	1.1 ppb
Maine Coast Semester at Chewonki	Andrews- Kitchen Sink	0 ppb
Maine Coast Semester at Chewonki	Andrews- Upstairs Bathroom Sink	0 ppb
Maine Coast Semester at Chewonki	Chateau- Downstairs Bathroom Sink	12.9 ppb
Maine Coast Semester at Chewonki	Chateau- Kitchen Sink	1.3 ppb
Maine Coast Semester at Chewonki	Chateau- Upstairs Bathroom Sink	4.5 ppb
Maine Coast Semester at Chewonki	Farmhouse- Apartment Bathroom Sink	0 ppb
Maine Coast Semester at Chewonki	Farmhouse- Apartment Kitchen Sink	1.4 ppb
Maine Coast Semester at Chewonki	Farmhouse- Bathroom Sink	0 ppb
Maine Coast Semester at Chewonki	Farm-milkroom Handsink	13.9 ppb
Maine Coast Semester at Chewonki	Gatehouse- Downstairs Bathroom Sink	42.9 ppb
Maine Coast Semester at Chewonki	Gatehouse- Kitchen Sink	2.5 ppb
Maine Coast Semester at Chewonki	Gatehouse- Upstairs Bathroom Sink	16.7 ppb
Maine Coast Semester at Chewonki	Hilltop Annex- Bathroom Sink Left	0 ppb
Maine Coast Semester at Chewonki	Hilltop Annex- Bathroom Sink Right	0 ppb
Maine Coast Semester at Chewonki	Hilltop Annex- Kitchen Sink	2.4 ppb
Maine Coast Semester at Chewonki	Hilltop Apartment- Downstairs Bathroom Sink	3.7 ppb
Maine Coast Semester at Chewonki	Hilltop Apartment- Kitchen Sink	0 ppb
Maine Coast Semester at Chewonki	Hilltop Apartment- Upstairs Bathroom Sink	1.5 ppb
Maine Coast Semester at Chewonki	Hilton- Eastside Center Sink	0 ppb
Maine Coast Semester at Chewonki	Hilton- Eastside Left Sink	0 ppb
Maine Coast Semester at Chewonki	Hilton- Eastside Right Sink	0 ppb
Maine Coast Semester at Chewonki	Hilton- Westside Center Sink	0 ppb
Maine Coast Semester at Chewonki	Hilton- Westside Left Sink	0 ppb
Maine Coast Semester at Chewonki	Hilton- Westside Right Sink	0 ppb
Maine Coast Semester at Chewonki	Hoyts- Bathroom Sink	0 ppb
Maine Coast Semester at Chewonki	Hoyts- Kitchen Sink	1 ppb
Maine Coast Semester at Chewonki	Hoyts Waterfront Fountain And Rinse Station	0 ppb
Maine Coast Semester at Chewonki	Jdell- Bathroom Sink	0 ppb
Maine Coast Semester at Chewonki	Jdell- Kitchen Sink	0 ppb
Maine Coast Semester at Chewonki	Last Resort- Bathroom Sink	0 ppb
Maine Coast Semester at Chewonki	Lower Field- Backstop Water Fountain	2.8 ppb
Maine Coast Semester at Chewonki	New Meadows- Bathroom Sink	3.6 ppb
Maine Coast Semester at Chewonki	Oxbow Waterfront Fountain And Rinse Station	1.4 ppb
Maine Coast Semester at Chewonki	Packout- Indoor Hand Sink	3 ppb
Maine Coast Semester at Chewonki	Packout- Kitchen Sink	14.9 ppb
Maine Coast Semester at Chewonki	Packout- Outdoor Hand Sink	2.4 ppb
Maine Coast Semester at Chewonki	Packout- Outdoor Water Jug Fill Station	2.4 ppb

School Name	Sample Location	Lead Test Result
Maine Coast Semester at Chewonki	Park Ave- Bathroom Sink	5.8 ppb
Maine Coast Semester at Chewonki	Park Ave- Kitchen Sink	0 ppb
Maine Coast Semester at Chewonki	Plaza- Center Faucet	0 ppb
Maine Coast Semester at Chewonki	Plaza- Left Faucet	0 ppb
Maine Coast Semester at Chewonki	Plaza- Right Faucet	0 ppb
Maine Coast Semester at Chewonki	Plaza- Water Fountain	10 ppb
Maine Coast Semester at Chewonki	Ritz- Center Faucet	0 ppb
Maine Coast Semester at Chewonki	Ritz- Left Faucet	0 ppb
Maine Coast Semester at Chewonki	Ritz- Right Faucet	0 ppb
Maine Coast Semester at Chewonki	Spruce Lodge- Bathroom Sink	0 ppb
Maine Coast Semester at Chewonki	Spruce Lodge- Kitchen Sink	1.5 ppb
Maine Coast Semester at Chewonki	Wallace- Barn Water Fountain	1.9 ppb
Maine Coast Semester at Chewonki	Wallace- Coffee Bar Sink	1.4 ppb
Maine Coast Semester at Chewonki	Wallace- Coffee Machine	0 ppb
Maine Coast Semester at Chewonki	Wallace- Dining Hand Sink	2 ppb
Maine Coast Semester at Chewonki	Wallace- Dining Pitcher Filler Left	1.2 ppb
Maine Coast Semester at Chewonki	Wallace- Dining Pitcher Filler Right	0 ppb
Maine Coast Semester at Chewonki	Wallace- Downstairs Bathroom Faucet Center	3.3 ppb
Maine Coast Semester at Chewonki	Wallace- Downstairs Bathroom Faucet Left	3.7 ppb
Maine Coast Semester at Chewonki	Wallace- Downstairs Bathroom Faucet Right	7.1 ppb
Maine Coast Semester at Chewonki	Wallace- Hand Sink By Veggie Prep Sink	4.1 ppb
Maine Coast Semester at Chewonki	Wallace- Healthcenter Bathroom Faucet Center	1.2 ppb
Maine Coast Semester at Chewonki	Wallace- Healthcenter Bathroom Faucet Left	3.2 ppb
Maine Coast Semester at Chewonki	Wallace- Healthcenter Bathroom Faucet Right	1.4 ppb
Maine Coast Semester at Chewonki	Wallace- Healthcenter Sick Room 1 Sink	7.5 ppb
Maine Coast Semester at Chewonki	Wallace- Healthcenter Sick Room 3 Sink	5.9 ppb
Maine Coast Semester at Chewonki	Wallace- Healthcenter Treatment Sink	11.9 ppb
Maine Coast Semester at Chewonki	Wallace- Healthcenter Triage Sink	4.8 ppb
Maine Coast Semester at Chewonki	Wallace- Kitchen Hand Sink By Printer	5.6 ppb
Maine Coast Semester at Chewonki	Wallace- Kitchen Ice Maker	0 ppb
Maine Coast Semester at Chewonki	Wallace- Kitchen Pot Sink - Right Faucet	1.6 ppb
Maine Coast Semester at Chewonki	Wallace- Kitchen Prep Sink With Pot Filler	2.7 ppb
Maine Coast Semester at Chewonki	Wallace- Kitchen Vegetable Rinse Sink	9.2 ppb
Maine Coast Semester at Chewonki	Wallace- Outdoor Bottle Filler Left	0 ppb
Maine Coast Semester at Chewonki	Wallace- Outdoor Bottle Filler Right	5.2 ppb
Maine Coast Semester at Chewonki	Wallace- Rodman Hall Bottle Filler	0 ppb
Maine Coast Semester at Chewonki	Wallace- Rodman Hall Handsink Left	2.3 ppb
Maine Coast Semester at Chewonki	Wallace- Rodman Hall Handsink Right	8.9 ppb
Maine Coast Semester at Chewonki	Warren- Bathroom Sink	1.1 ppb
Maine Coast Semester at Chewonki	Warren- Healthcenter Ada Bathroom Sink	1.1 ppb
Maine Coast Semester at Chewonki	Warren- Healthcenter Overnight Room Sink	2.1 ppb

School Name	Sample Location	Lead Test Result
Maine Coast Semester at Chewonki	Warren- Kitchen Sink	1.6 ppb
Maine Coast Semester at Chewonki	West- Downstairs Bathroom Sink	1.7 ppb
Maine Coast Semester at Chewonki	West- Kitchen Sink	0 ppb
Maine Coast Semester at Chewonki	West- Upstairs Bathroom Sink	0 ppb
Maine Coast Semester at Chewonki	Woodshop Sink	1.9 ppb
Maine Coast Waldorf School	1st Grade Sink	0 ppb
Maine Coast Waldorf School	2nd Grade Sink	0 ppb
Maine Coast Waldorf School	3rd Grade Sink	0 ppb
Maine Coast Waldorf School	4th Grade Sink	0 ppb
Maine Coast Waldorf School	5th Grade Sink	0 ppb
Maine Coast Waldorf School	6th Grade Sink	0 ppb
Maine Coast Waldorf School	7th Grade Sink	0 ppb
Maine Coast Waldorf School	8th Grade Sink	0 ppb
Maine Coast Waldorf School	Ch Kitchenette Drinking Fountain	0 ppb
Maine Coast Waldorf School	Ch Kitchenette Sink	0 ppb
Maine Coast Waldorf School	Ch Outside Drinking Fountain	0 ppb
Maine Coast Waldorf School	Ec Bluebell Room Sink	0 ppb
Maine Coast Waldorf School	Ec Buttercup Room Sink	0 ppb
Maine Coast Waldorf School	Ec Daisy Room Sink	0 ppb
Maine Coast Waldorf School	Ec Fiddlehead Room Sink	0 ppb
Maine Coast Waldorf School	Ec Sunflower Room Sink	0 ppb
Maine Coast Waldorf School	Farmhouse Kitchen Sink	0 ppb
Maine Coast Waldorf School	Handwork Room Sink	0 ppb
Maine Coast Waldorf School	Hs First Floor Bottle Filler	0 ppb
Maine Coast Waldorf School	Hs First Floor Left Drinking Fountain	0 ppb
Maine Coast Waldorf School	Hs First Floor Right Drinking Fountain	0 ppb
Maine Coast Waldorf School	Hs Second Floor Bottle Filler	0 ppb
Maine Coast Waldorf School	Hs Second Floor Left Drinking Fountain	0 ppb
Maine Coast Waldorf School	Hs Second Floor Right Drinking Fountain	0 ppb
Maine Coast Waldorf School	Hs Student Center Sink	0 ppb
Maine Coast Waldorf School	Kitchen 3 Bay Sink	0 ppb
Maine Coast Waldorf School	Kitchen Coffee Maker	0 ppb
Maine Coast Waldorf School	Kitchen Food Prep Sink	0 ppb
Maine Coast Waldorf School	M&m Room Sink	0 ppb
Maine Coast Waldorf School	Nurses Office Bathroom	0 ppb
Maine Coast Waldorf School	Woodwork Room Sink	0 ppb
Maine Connections Academy	Drinking Water Dispenser	0 ppb
Maine Connections Academy	Kitchen Sink	0 ppb
Maine Connections Academy	Laboratory Sink	0 ppb
Maine Region Ten Technical High Sch	Culinary Arts	0 ppb
Maine Region Ten Technical High Sch	Dirigo Diner	0 ppb
Maine Region Ten Technical High Sch	General Trades	0 ppb
Maine Region Ten Technical High Sch	Ice Machine	0 ppb
Maine Region Ten Technical High Sch	Main Hall	0 ppb
Maine Region Ten Technical High Sch	Nurse	12.8 ppb
Maine Region Ten Technical High Sch	Power Sports	0 ppb
Maine Region Ten Technical High Sch	Staff Kitchen	1.2 ppb

School Name	Sample Location	Lead Test Result
Maine Virtual Academy	2nd Wing Kf	5.8 ppb
Maine Virtual Academy	Br Faucet	0 ppb
Maine Virtual Academy	Dwf By Hr Office	18.9 ppb
Maine Virtual Academy	Main Wing Kf	0 ppb
Manchester Elementary School	1st Grade/miska Fountain	33.3 ppb
Manchester Elementary School	1st Grade/miska Sink	2 ppb
Manchester Elementary School	2nd Fountain Near Janitor	16.3 ppb
Manchester Elementary School	2nd Grade	11.3 ppb
Manchester Elementary School	3rd Grade	14.5 ppb
Manchester Elementary School	4th Grade	14 ppb
Manchester Elementary School	Art Room	1 ppb
Manchester Elementary School	Basement	23.8 ppb
Manchester Elementary School	Cafeteria	9 ppb
Manchester Elementary School	Computer Lab	16.9 ppb
Manchester Elementary School	Fountain Near Janitor Closet #1	12.4 ppb
Manchester Elementary School	Fountain Near Office #1	3.8 ppb
Manchester Elementary School	Fountain Near Office #2	0 ppb
Manchester Elementary School	Gifted Room Faucet	20.2 ppb
Manchester Elementary School	Gym Entrance Fountain	1.2 ppb
Manchester Elementary School	K/gross Fountain	12.3 ppb
Manchester Elementary School	K/gross Sink	3.2 ppb
Manchester Elementary School	K/sara Fountain	2.8 ppb
Manchester Elementary School	K/sara Sink	1.9 ppb
Manchester Elementary School	Kitchen Sink #1- Veg Prep	2.2 ppb
Manchester Elementary School	Kitchen Sink #2-dish Sink	7.2 ppb
Manchester Elementary School	Kitchen Sink #3- Dish Sink	8.6 ppb
Manchester Elementary School	Kitchen Sink #4- Spray Nozzle	7.4 ppb
Manchester Elementary School	Kitchen Sink #5- Hand Sink	2.3 ppb
Manchester Elementary School	Pre-k Fountain	6.3 ppb
Manchester Elementary School	Pre-k Sink	1.2 ppb
Manchester Elementary School	Special Ed Fountain	4.5 ppb
Manchester Elementary School	Special Ed Sink	3.8 ppb
Manchester Elementary School	Teachers Lounge	1.1 ppb
Manchester School	4th Grade Wf By Library- Bottle Fill	0 ppb
Manchester School	4th Grade Wf By Library- Water Fountain	0 ppb
Manchester School	5th Grade Wf By Library- Bottle Fill	0 ppb
Manchester School	5th Grade Wf By Library- Water Fountain	0 ppb
Manchester School	Art Room- Sink #1 Left	0 ppb
Manchester School	Back Hallway Bi-level Fountain- High Fountain	0 ppb
Manchester School	Back Hallway Bi-level Fountain- Low Fountain	0 ppb
Manchester School	Back Hallway Bi-level Fountain-bottle Fill	0 ppb
Manchester School	Back Hallway Single Fountain- Bottle Fill	0 ppb
Manchester School	Back Hallway Single Fountain- Fountain	0 ppb
Manchester School	Cafeterial Drinking Fountain- Bottle Fill	0 ppb

School Name	Sample Location	Lead Test Result
Manchester School	Cafeterial Drinking Fountain-high Fountain	0 ppb
Manchester School	Cafeterial Drinking Fountain-low Fountain	0 ppb
Manchester School	Classroom 177- Sink Faucet	2.4 ppb
Manchester School	Front Drinking Fountain- Bottle Fill	0 ppb
Manchester School	Front Drinking Fountain- High Fountain	0 ppb
Manchester School	Front Drinking Fountain- Low Fountain	0 ppb
Manchester School	Kettle- Kettle Fill Faucet	26 ppb
Manchester School	Kitchen Prep Sink- Faucet #2 On Right	0 ppb
Manchester School	Kitchen Prep Sink-faucet #1 On Left	1 ppb
Manchester School	Nurse Office- Sink Faucet	0 ppb
Manchester School	Teachers Break Room- Sink Faucet	0 ppb
Manson Park School	Bottle Fill Station Hallway	0 ppb
MapleStone School	Kitchen Sink At Cherrystone (dishwashing)	21.9 ppb
MapleStone School	Kitchen Sink At Cherrystone (handwashing)	0 ppb
Mapleton Elementary School	2nd Grade Hall	0 ppb
Mapleton Elementary School	5th Grade Hall	0 ppb
Mapleton Elementary School	Av Center East	8.5 ppb
Mapleton Elementary School	Av Center West	2.4 ppb
Mapleton Elementary School	Cafeteria	0 ppb
Mapleton Elementary School	Gymnasium	0 ppb
Mapleton Elementary School	Kitchen Sink #1	0 ppb
Mapleton Elementary School	Kitchen Sink #2	0 ppb
Mapleton Elementary School	Kitchen Sink #3	0 ppb
Mapleton Elementary School	Kitchen Sink #4	0 ppb
Mapleton Elementary School	Main Office Hall	0 ppb
Mapleton Elementary School	Room 1	5.6 ppb
Mapleton Elementary School	Room 10	2.2 ppb
Mapleton Elementary School	Room 11	20 ppb
Mapleton Elementary School	Room 12	3.8 ppb
Mapleton Elementary School	Room 13	3.2 ppb
Mapleton Elementary School	Room 14	34.8 ppb
Mapleton Elementary School	Room 15	16.1 ppb
Mapleton Elementary School	Room 3	8.8 ppb
Mapleton Elementary School	Room 4	1.7 ppb
Mapleton Elementary School	Room 5	5.9 ppb
Mapleton Elementary School	Room 6	92.2 ppb
Mapleton Elementary School	Room 7	7.9 ppb
Mapleton Elementary School	Room 8	3.3 ppb
Mapleton Elementary School	Room 9	129 ppb
Mapleton Elementary School	Teachers Lounge	0 ppb
Maranacook Community High Sch	Drinking Fountain By Gym #1 (bottle)	0 ppb
Maranacook Community High Sch	Drinking Fountain By Gym #2	0 ppb
Maranacook Community High Sch	Drinking Fountain Freshman Hall (bottle)	0 ppb
Maranacook Community High Sch	Drinking Fountain Ia Hall (bottle)	0 ppb
Maranacook Community High Sch	Drinking Fountain Media Hall (bottle)	0 ppb

School Name	Sample Location	Lead Test Result
Maranacook Community High Sch	Health Center 1 Sink	0 ppb
Maranacook Community High Sch	Kitchen Sink #1	0 ppb
Maranacook Community High Sch	Kitchen Sink #2	1.3 ppb
Maranacook Community High Sch	Kitchen Sink #3	2.3 ppb
Maranacook Community High Sch	Kitchen Sink #4	2.2 ppb
Maranacook Community High Sch	Rm 130 Sink #1	1.8 ppb
Maranacook Community High Sch	Rm 130 Sink #2	6 ppb
Maranacook Community High Sch	Rm 134 Sink	7.9 ppb
Maranacook Community High Sch	Rm 145 Sink	9.3 ppb
Maranacook Community High Sch	Rm 165 Sink	4.6 ppb
Maranacook Community High Sch	Rm 171 Sink	6.6 ppb
Maranacook Community High Sch	Rm 173 Sink #1	6.9 ppb
Maranacook Community High Sch	Rm 173 Sink #2	8.4 ppb
Maranacook Community High Sch	Rm 173 Sink #3	12.7 ppb
Maranacook Community High Sch	Rm 173 Sink #4	6 ppb
Maranacook Community High Sch	Rm 173 Sink #5	15.6 ppb
Maranacook Community High Sch	Rm 173 Sink #6	12.5 ppb
Maranacook Community High Sch	Rm 173 Sink #7	31.2 ppb
Maranacook Community High Sch	Rm 178 Sink #1	4.4 ppb
Maranacook Community High Sch	Rm 178 Sink #2	4.7 ppb
Maranacook Community High Sch	Rm 178 Sink #3	4.7 ppb
Maranacook Community High Sch	Rm 178 Sink #4	7.3 ppb
Maranacook Community High Sch	Rm 180 Sink #1	5.7 ppb
Maranacook Community High Sch	Rm 180 Sink #2	8.3 ppb
Maranacook Community High Sch	Rm 181 Sink #1	2.1 ppb
Maranacook Community High Sch	Rm 181 Sink #2	1.7 ppb
Maranacook Community High Sch	Rm 181 Sink #3	1.3 ppb
Maranacook Community High Sch	Rm 181 Sink #4	4.7 ppb
Maranacook Community High Sch	Rm 182 Sink #1	2.8 ppb
Maranacook Community High Sch	Rm 182 Sink #2	2.6 ppb
Maranacook Community High Sch	Rm 183 Sink # 1	2.1 ppb
Maranacook Community High Sch	Rm 183 Sink #2	3.4 ppb
Maranacook Community Middle Sch	Corridor 120	0 ppb
Maranacook Community Middle Sch	Corridor 22	0 ppb
Maranacook Community Middle Sch	Lower Lobby	0 ppb
Maranacook Community Middle Sch	Rm # 150	1.6 ppb
Maranacook Community Middle Sch	Rm # 155	0 ppb
Maranacook Community Middle Sch	Rm # 171	0 ppb
Maranacook Community Middle Sch	Rm # 175	2 ppb
Maranacook Community Middle Sch	Rm #117	1 ppb
Maranacook Community Middle Sch	Rm #123	1.3 ppb
Maranacook Community Middle Sch	Rm #125	1.3 ppb
Maranacook Community Middle Sch	Rm #126	0 ppb
Maranacook Community Middle Sch	Rm #146	0 ppb
Maranacook Community Middle Sch	Rm 145 Sink #1	0 ppb
Maranacook Community Middle Sch	Rm 145 Sink #2	1.1 ppb
Maranacook Community Middle Sch	Rm 145 Sink #3	2.2 ppb

School Name	Sample Location	Lead Test Result
Maranacook Community Middle Sch	Rm 18	2.9 ppb
Maranacook Community Middle Sch	Rm 2	2.6 ppb
Maranacook Community Middle Sch	Rm 21	1.7 ppb
Maranacook Community Middle Sch	Rm 26 #1	13.8 ppb
Maranacook Community Middle Sch	Rm 26 #2	7.1 ppb
Maranacook Community Middle Sch	Rm 26 #3	1.1 ppb
Maranacook Community Middle Sch	Rm 26 #4	3.4 ppb
Maranacook Community Middle Sch	Rm 26 #5	2.1 ppb
Maranacook Community Middle Sch	Rm 40 Sink #1	1.3 ppb
Maranacook Community Middle Sch	Rm 40 Sink #2	0 ppb
Maranacook Community Middle Sch	Rm 45 Sink #1	1 ppb
Maranacook Community Middle Sch	Rm 45 Sink #2	1.5 ppb
Marcia Buker School	Big Kids Wing- Water Fountain	0 ppb
Marcia Buker School	Boys Bathroom Hand Wash Sink- C	22.3 ppb
Marcia Buker School	Boys Bathroom Hand Wash Sink-a	0 ppb
Marcia Buker School	Boys Bathroom Hand Wash Sink-b	3 ppb
Marcia Buker School	Caf/ Gym Bathroom Sink	1.6 ppb
Marcia Buker School	Class Rm (Gardiner) Kitchen Sink A	5.9 ppb
Marcia Buker School	Class Rm 102 Drinking Fountain A	0 ppb
Marcia Buker School	Class Rm 102 Hand Wash B	1.3 ppb
Marcia Buker School	Class Rm 103 Drinking Fountain A	0 ppb
Marcia Buker School	Class Rm 103 Hand Wash B	2.9 ppb
Marcia Buker School	Class Rm 104 Drinking Fountain A	0 ppb
Marcia Buker School	Class Rm 104 Hand Wash B	2.2 ppb
Marcia Buker School	Class Rm 105 Drinking Fountain A	0 ppb
Marcia Buker School	Class Rm 105 Hand Wash B	0 ppb
Marcia Buker School	Class Rm 106 Drinking Fountain A	0 ppb
Marcia Buker School	Class Rm 106 Hand Wash B	4.3 ppb
Marcia Buker School	Class Rm 111 Drinking Fountain A	8.3 ppb
Marcia Buker School	Class Rm 111 Hand Wash B	5.5 ppb
Marcia Buker School	Class Rm 113 Drinking Fountain A	17.8 ppb
Marcia Buker School	Class Rm 113 Hand Wash B	4.3 ppb
Marcia Buker School	Class Rm 115 Drinking Fountain A	9 ppb
Marcia Buker School	Class Rm 115 Hand Wash B	17.3 ppb
Marcia Buker School	Class Rm 117 Fountain A	7 ppb
Marcia Buker School	Class Rm 117 Hand Wash B	3.5 ppb
Marcia Buker School	Girls Bathroom Hand Wash Sink- A	1.5 ppb
Marcia Buker School	Girls Bathroom Hand Wash Sink- B	1.4 ppb
Marcia Buker School	Girls Bathroom Hand Wash Sink- C	10.5 ppb
Marcia Buker School	Kitchen Hand Wash Sink	2.9 ppb
Marcia Buker School	Kitchen Sink	23.4 ppb
Marcia Buker School	Little Kids Wing- Big Fountain B	1.3 ppb
Marcia Buker School	Little Kids Wing- Little Fountain A	1 ppb
Marcia Buker School	Outside Water Spigot (boiler Room) D	38.8 ppb
Marcia Buker School	Outside Water Spigot(caterpillar Playground Ent)c	1400 ppb
Marcia Buker School	Outside Water Spigot(teachers Entrance) B	48.3 ppb

School Name	Sample Location	Lead Test Result
Marcia Buker School	Room 101 Drinking Water Fountain	0 ppb
Marcia Buker School	Room 101 Sink	1.6 ppb
Marcia Buker School	Room 102 Drinking Water Fountain	0 ppb
Marcia Buker School	Room 102 Sink	0 ppb
Marcia Buker School	Room 112 Sink	3.1 ppb
Marcia Buker School	Room 114 Sink	3.4 ppb
Marcia Buker School	Room 121nurses Room Bathroom Sink	0 ppb
Marcia Buker School	Room 124 Sink	5.1 ppb
Marcia Buker School	Room 132 Kitchen Sink A	3 ppb
Marcia Buker School	Teachers Bathroom A Sink	2.6 ppb
Margaret Chase Smith	Cafe Wtr Fountain	0 ppb
Margaret Chase Smith	Cafe Wtr Fountain W/bottle Fill	0 ppb
Margaret Chase Smith	Kitchen 3 Bay Sink	0 ppb
Margaret Chase Smith	Kitchen Kettle	27.7 ppb
Margaret Chase Smith	Kitchen Single Sink	0 ppb
Margaret Chase Smith	Wtr Fountain 1 2nd Fl Elv Door	0 ppb
Margaret Chase Smith	Wtr Fountain 1 Across Lib	0 ppb
Margaret Chase Smith	Wtr Fountain 1 By Gym	0 ppb
Margaret Chase Smith	Wtr Fountain 2 W/btl 2nd Flr Elv Dr	0 ppb
Margaret Chase Smith	Wtr Fountain 2 W/btl Fill Across Lib	0 ppb
Margaret Chase Smith	Wtr Fountain 2 W/btl Fill By Gym	0 ppb
Margaret Chase Smith	Wtr Fountain 3 2nd Flr Elv Door	0 ppb
Margaret Chase Smith	Wtr Fountain 3 Across Lib	0 ppb
Margaret Chase Smith	Wtr Fountain 3 By Gym	0 ppb
Margaret Chase Smith	Wtr Fountain By Rm 161	0 ppb
Margaret Chase Smith	Wtr Fountain Rm 101	0 ppb
Margaret Chase Smith	Wtr Fountain Rm 102	0 ppb
Margaret Chase Smith	Wtr Fountain Rm 105	0 ppb
Margaret Chase Smith	Wtr Fountain Rm 106	0 ppb
Margaret Chase Smith	Wtr Fountain Rm 107	1.1 ppb
Margaret Chase Smith	Wtr Fountain Rm 115	0 ppb
Margaret Chase Smith	Wtr Fountain Rm 118c	0 ppb
Margaret Chase Smith	Wtr Fountain Rm 121	0 ppb
Margaret Chase Smith	Wtr Fountain Rm 122	0 ppb
Margaret Chase Smith	Wtr Fountain Rm 123	0 ppb
Margaret Chase Smith	Wtr Fountain Rm 124	0 ppb
Margaret Chase Smith	Wtr Fountain Rm 125	0 ppb
Margaret Chase Smith	Wtr Fountain Rm 126	0 ppb
Margaret Chase Smith	Wtr Fountain Rm 127	0 ppb
Margaret Chase Smith	Wtr Fountain Rm 131 Tech Rm	0 ppb
Margaret Chase Smith	Wtr Fountain W/btl Fill By Rm 161	0 ppb
Margaret Chase Smith Sch - Skowhegan	Boys Restroom Wash Sink 2nd From Right	2 ppb
Margaret Chase Smith Sch - Skowhegan	Boys Restroom Wash Sink 3rd From Right	2.5 ppb
Margaret Chase Smith Sch - Skowhegan	Boys Restroom Wash Sink Far Right	2 ppb

School Name	Sample Location	Lead Test Result
Margaret Chase Smith Sch - Skowhegan	Closet Sink	1.3 ppb
Margaret Chase Smith Sch - Skowhegan	Girls Restroom Wash Sink 2nd From Left	2.7 ppb
Margaret Chase Smith Sch - Skowhegan	Girls Restroom Wash Sink 3rd From Left	5.2 ppb
Margaret Chase Smith Sch - Skowhegan	Girls Restroom Wash Sink Far Left	5.2 ppb
Margaret Chase Smith Sch - Skowhegan	Gym Bottle Fill Station	0 ppb
Margaret Chase Smith Sch - Skowhegan	Hall By Room 1 Bottle Fill Station	0 ppb
Margaret Chase Smith Sch - Skowhegan	Handicap Restroom Wash Sink	2.3 ppb
Margaret Chase Smith Sch - Skowhegan	Kitchen 1 Basin Sink By Door	11.6 ppb
Margaret Chase Smith Sch - Skowhegan	Kitchen 2 Basin Sink Left Of 1 Basin	6.1 ppb
Margaret Chase Smith Sch - Skowhegan	Kitchen Dishwasher	1.5 ppb
Margaret Chase Smith Sch - Skowhegan	Kitchen Sprayer By Dishwasher	1.4 ppb
Margaret Chase Smith Sch - Skowhegan	Kitchen Steamer	5.6 ppb
Margaret Chase Smith Sch - Skowhegan	Nurses Station Wash Sink	5.6 ppb
Margaret Chase Smith Sch - Skowhegan	Outside Room 12 Bottle Fill Station	7.8 ppb
Margaret Chase Smith Sch - Skowhegan	Restroom By Breakroom Wash Sink	2.9 ppb
Margaret Chase Smith Sch - Skowhegan	Room 1 Fountain	3.8 ppb
Margaret Chase Smith Sch - Skowhegan	Room 1 Restroom Wash Sink	5.1 ppb
Margaret Chase Smith Sch - Skowhegan	Room 1 Wash Sink	4.7 ppb
Margaret Chase Smith Sch - Skowhegan	Room 10 Fountain	10.2 ppb
Margaret Chase Smith Sch - Skowhegan	Room 10 Wash Sink	7.3 ppb
Margaret Chase Smith Sch - Skowhegan	Room 11 Fountain	11.7 ppb
Margaret Chase Smith Sch - Skowhegan	Room 11 Wash Sink	5.1 ppb
Margaret Chase Smith Sch - Skowhegan	Room 12 Fountain	8.5 ppb

School Name	Sample Location	Lead Test Result
Margaret Chase Smith Sch - Skowhegan	Room 12 Wash Sink	9.4 ppb
Margaret Chase Smith Sch - Skowhegan	Room 14 Fountain	1.2 ppb
Margaret Chase Smith Sch - Skowhegan	Room 14 Wash Sink	0 ppb
Margaret Chase Smith Sch - Skowhegan	Room 15 Fountain	0 ppb
Margaret Chase Smith Sch - Skowhegan	Room 15 Wash Sink	2.2 ppb
Margaret Chase Smith Sch - Skowhegan	Room 16/17 Fountain	0 ppb
Margaret Chase Smith Sch - Skowhegan	Room 16/17 Wash Sink	0 ppb
Margaret Chase Smith Sch - Skowhegan	Room 2 Fountain	7.9 ppb
Margaret Chase Smith Sch - Skowhegan	Room 2 Wash Sink	6.7 ppb
Margaret Chase Smith Sch - Skowhegan	Room 22 Wash Sink	10.4 ppb
Margaret Chase Smith Sch - Skowhegan	Room 23 Kitchen Sink	5.6 ppb
Margaret Chase Smith Sch - Skowhegan	Room 26 Wash Sink	38.6 ppb
Margaret Chase Smith Sch - Skowhegan	Room 3 Fountain	10.4 ppb
Margaret Chase Smith Sch - Skowhegan	Room 3 Wash Sink	3.9 ppb
Margaret Chase Smith Sch - Skowhegan	Room 4 Fountain	7 ppb
Margaret Chase Smith Sch - Skowhegan	Room 4 Wash Sink	6.4 ppb
Margaret Chase Smith Sch - Skowhegan	Room 5 Fountain	6.7 ppb
Margaret Chase Smith Sch - Skowhegan	Room 5 Wash Sink	14.4 ppb
Margaret Chase Smith Sch - Skowhegan	Room 6 Fountain	6.9 ppb
Margaret Chase Smith Sch - Skowhegan	Room 6 Wash Sink	3.2 ppb
Margaret Chase Smith Sch - Skowhegan	Room 7 Fountain	4.2 ppb
Margaret Chase Smith Sch - Skowhegan	Room 7 Wash Sink	2.5 ppb
Margaret Chase Smith Sch - Skowhegan	Room 8 Fountain	5.1 ppb

School Name	Sample Location	Lead Test Result
Margaret Chase Smith Sch - Skowhegan	Room 8 Wash Sink	11.9 ppb
Margaret Chase Smith Sch - Skowhegan	Room 9 Fountain	9.6 ppb
Margaret Chase Smith Sch - Skowhegan	Room 9 Hand Wash Sink	16.9 ppb
Marion C Cook School	Kitchen Sink	1.6 ppb
Marion C Cook School	Main Entry Hallway	0 ppb
Marion C Cook School	Main Office Area	5.8 ppb
Marshwood Great Works School	1st Floor Hallway Across From Rm. #8	1.7 ppb
Marshwood Great Works School	1st Floor Hallway Next To Rm. #22	0 ppb
Marshwood Great Works School	1st Floor Hallway Outside Main Office	1 ppb
Marshwood Great Works School	2nd Floor Hallway Across From Rm. #33	0 ppb
Marshwood Great Works School	Cafeteria	0 ppb
Marshwood Great Works School	Guidance Office	0 ppb
Marshwood Great Works School	Gymnasium	0 ppb
Marshwood Great Works School	Home Ec. Rm. #16 Left Of Refrigerator	0 ppb
Marshwood Great Works School	Home Ec. Rm. #16 Middle Of Room Hallway Side	0 ppb
Marshwood Great Works School	Home Ec. Rm. #16 Middle Of Room Rt. 236 Side	0 ppb
Marshwood Great Works School	Home Ec. Rm. #16 Right Of Refrigerator	0 ppb
Marshwood Great Works School	Kitchen 3-bay Sink Left Side	1 ppb
Marshwood Great Works School	Kitchen 3-bay Sink Right Side	0 ppb
Marshwood Great Works School	New Nurse Office (blue Room)	27.9 ppb
Marshwood Great Works School	Staff Work Room/coffee Between Rms #15 & #18	0 ppb
Marshwood High School	2nd Floor Hallway A-pod	0 ppb
Marshwood High School	2nd Floor Hallway B-pod	0 ppb
Marshwood High School	2nd Floor Hallway D-pod	2.8 ppb
Marshwood High School	2nd Floor Hallway E-pod	1.4 ppb
Marshwood High School	2nd Floor Hallway F-pod	0 ppb
Marshwood High School	2nd Floor Next To Elevator Left Unit	0 ppb
Marshwood High School	2nd Floor Next To Elevator Right Unit	0 ppb
Marshwood High School	Adult Ed. Rm. #c-110	0 ppb
Marshwood High School	Ath. Hallway Left Unit Backside Of Gym	0 ppb
Marshwood High School	Ath. Laundry Room Ice Machine	0 ppb
Marshwood High School	Band Room Rm. #228	0 ppb
Marshwood High School	Bottom Floor Hallway A-pod	0 ppb
Marshwood High School	Bottom Floor Hallway B-pod	2.3 ppb
Marshwood High School	Bottom Floor Hallway E-pod	0 ppb
Marshwood High School	Bottom Floor Hallway Outside Of Woodshop	0 ppb
Marshwood High School	Bottom Floor Lobby To Left Of Elevator	0 ppb
Marshwood High School	Boy's Lockerroom Rm. #g-220	1.3 ppb
Marshwood High School	Cafeteria	0 ppb
Marshwood High School	Fieldhouse Kitchen	4.7 ppb

School Name	Sample Location	Lead Test Result
Marshwood High School	Girls Ath. Team Room Rm. # G-240	0 ppb
Marshwood High School	Gymnasium Far End Opposite A.d.'s Office	0 ppb
Marshwood High School	Gymnasium To Right Of A.d.'s Office	0 ppb
Marshwood High School	Home Ec. 1st On Left Rm. #280	0 ppb
Marshwood High School	Home Ec. 1st On Right Rm. #280	0 ppb
Marshwood High School	Home Ec. 2nd On Left Moving Clockwise Rm. #280	0 ppb
Marshwood High School	Home Ec. 3rd On Left Moving Clockwise Rm. #280	2.6 ppb
Marshwood High School	H-pod Hallway Across From Rm. #243	0 ppb
Marshwood High School	Kitchen Coffee Station Sink	3.7 ppb
Marshwood High School	Kitchen Deep Sink Dishwashing Station Left Side	0 ppb
Marshwood High School	Kitchen Deep Sink Dishwashing Station Right Side	0 ppb
Marshwood High School	Kitchen Kettle Filling Station	0 ppb
Marshwood High School	Library Rm. #210 Next To Rm. #202	0 ppb
Marshwood High School	Main Office Bathroom	0 ppb
Marshwood High School	Nurses Office Rm. #232	1.6 ppb
Marshwood High School	Rm. C-203 Located In Library	0 ppb
Marshwood High School	Weight Room	0 ppb
Marshwood High School	Wrestling Room	0 ppb
Marshwood Middle School	1st Floor Next To Rm #113 Left Unit	0 ppb
Marshwood Middle School	1st Floor Next To Rm. #113 Right Unit	0 ppb
Marshwood Middle School	2nd Floor Across From Rm. #206	0 ppb
Marshwood Middle School	2nd Floor Next To Rm. #219 Left Unit	0 ppb
Marshwood Middle School	2nd Floor Next To Rm. #219 Right Unit	0 ppb
Marshwood Middle School	Across From Guidance Offices	0 ppb
Marshwood Middle School	Cafeteria	2.1 ppb
Marshwood Middle School	Central Office Kitchen	0 ppb
Marshwood Middle School	Home Ec. Rm. #410 1st Sink Next To Stove	3.8 ppb
Marshwood Middle School	Home Ec. Rm. #410 1st Sink On Left	1.9 ppb
Marshwood Middle School	Home Ec. Rm. #410 Right Of Refrigerator	2.7 ppb
Marshwood Middle School	Home Ec. Rm. #410 Sink Next To Washer/dryer	2.5 ppb
Marshwood Middle School	Kitchen 2-bay Sink To Right Of Store Room	0 ppb
Marshwood Middle School	Kitchen Prep Sink Left Of Store Room	0 ppb
Marshwood Middle School	Kitchen Sink In Center Of Kitchen	0 ppb
Marshwood Middle School	Kitchen Store Room Ice Machine	0 ppb
Marshwood Middle School	New Staff Lounge	0 ppb
Marshwood Middle School	Nurse Office (old Teacher Lounge)	0 ppb
Marti Stevens Learning Center	Camp David Kitchen Sink	2.7 ppb
Marti Stevens Learning Center	Camp David Restroom Sink	0 ppb
Marti Stevens Learning Center	Hallway By Rest Room 1 Bottle Fill Station	0 ppb
Marti Stevens Learning Center	Kitchen 2 Basin Sink	0 ppb
Marti Stevens Learning Center	Kitchen Hand Wash Sink	1.4 ppb
Marti Stevens Learning Center	Kitchen Sink	0 ppb

School Name	Sample Location	Lead Test Result
Marti Stevens Learning Center	Main Building: Restroom 1 Sink	2.7 ppb
Marti Stevens Learning Center	Main Building: Restroom 2 Sink	1.1 ppb
Marti Stevens Learning Center	Outdoor Spicket West End	0 ppb
Marti Stevens Learning Center	Portable: Hallway Bottle Fill Station	0 ppb
Marti Stevens Learning Center	Portable: Restroom Sink	0 ppb
Mary Snow School	Bottle Fill Station - Outside Room 15	0 ppb
Mary Snow School	Bottle Fill Station - Outside Room 17	0 ppb
Mary Snow School	Bottle Fill Station - Outside Room 5	1 ppb
Mary Snow School	Bottle Fill Station - Outside Room 6	1 ppb
Mary Snow School	Faucet - Teacher's Lounge	1 ppb
Mary Snow School	Kitchen - Double Basin - Right Faucet	3 ppb
Massabesic High School	East Drinking Fountain-gym	0 ppb
Massabesic High School	East Drinking Fountain-room 10	2.2 ppb
Massabesic High School	East Drinking Fountain-room 22	0 ppb
Massabesic High School	East Drinking Fountain-room 32	8.7 ppb
Massabesic High School	East Drinking Fountain-teacher's Room	1.8 ppb
Massabesic High School	East Nurse's Office-sink	21.9 ppb
Massabesic High School	East Room 20-sink	1.3 ppb
Massabesic High School	East Room 22-sink	3 ppb
Massabesic High School	East Room 28-dishwash Sink	6.9 ppb
Massabesic High School	East Room 28-left Sink	6.8 ppb
Massabesic High School	East Room 28-right Sink	7.4 ppb
Massabesic High School	East Teacher's Room-sink	5.3 ppb
Massabesic High School	West Bottle Filler Station-cafeteria	1.8 ppb
Massabesic High School	West Bottle Filler Station-corridor 2	0 ppb
Massabesic High School	West Concession Room-sink	43.6 ppb
Massabesic High School	West Drinking Fountain-art Room 1	0 ppb
Massabesic High School	West Drinking Fountain-art Room 44	2 ppb
Massabesic High School	West Drinking Fountain-corridor 1	0 ppb
Massabesic High School	West Drinking Fountain-corridor 3	1.1 ppb
Massabesic High School	West Drinking Fountain-gym	0 ppb
Massabesic High School	West Drinking Fountain-music Room	0 ppb
Massabesic High School	West Drinking Fountain-room 39	0 ppb
Massabesic High School	West Kitchen- 3 Bay Sink (l)	1.7 ppb
Massabesic High School	West Kitchen- 3 Bay Sink (r)	3 ppb
Massabesic High School	West Kitchen-dish Wash Sink	2 ppb
Massabesic High School	West Kitchen-kettle	1.3 ppb
Massabesic High School	West Kitchen-vegetable Sink (l)	5.2 ppb
Massabesic High School	West Kitchen-vegetable Sink (r)	2.4 ppb
Massabesic High School	West Library Office-sink	2.1 ppb
Massabesic High School	West Modular-sink In Kitchen	1.6 ppb
Massabesic High School	West Nurse's Office-sink	2.4 ppb
Massabesic High School	West Teacher's Room-sink	14.2 ppb
Massabesic High School	West Training Room-ice Machine	0 ppb
Massabesic High School	West Training Room-sink	29 ppb
Massabesic Middle School	Allagash Drinking Fountain-(l)	0 ppb
Massabesic Middle School	Allagash Drinking Fountain-(r)	0 ppb

School Name	Sample Location	Lead Test Result
Massabesic Middle School	Allagash Teacher's Room-sink	0 ppb
Massabesic Middle School	Aroostook Drinking Fountain (l)	0 ppb
Massabesic Middle School	Aroostook Drinking Fountain (r)	0 ppb
Massabesic Middle School	Aroostook Teacher's Room-sink	2.1 ppb
Massabesic Middle School	Bottle Filler Station-custodial Room	0 ppb
Massabesic Middle School	Carrabassett Drinking Fountain (l)	0 ppb
Massabesic Middle School	Carrabassett Drinking Fountain (r)	0 ppb
Massabesic Middle School	Carrabassett Teacher's Room-sink	0 ppb
Massabesic Middle School	Concessions-ice Machine	1 ppb
Massabesic Middle School	Drinking Fountain-cafe (high)	0 ppb
Massabesic Middle School	Drinking Fountain-cafe (low)	0 ppb
Massabesic Middle School	Drinking Fountain-gym (high)	0 ppb
Massabesic Middle School	Drinking Fountain-gym (low)	0 ppb
Massabesic Middle School	Kitchen- 3 Bay Sink (l)	3.1 ppb
Massabesic Middle School	Kitchen- 3 Bay Sink (r)	2.2 ppb
Massabesic Middle School	Kitchen-kettle	6.4 ppb
Massabesic Middle School	Kitchen-skillett	20.4 ppb
Massabesic Middle School	Kitchen-vegetable Sink	2.2 ppb
Massabesic Middle School	Nurse's Office-bathroom Sink	3.1 ppb
Massabesic Middle School	Nurse's Office-counter Sink	1.1 ppb
Massabesic Middle School	Nurse's Office-handwash Sink	3.8 ppb
Massabesic Middle School	Pemaquid Drinking Fountain-(l)	0 ppb
Massabesic Middle School	Pemaquid Drinking Fountain-(r)	0 ppb
Massabesic Middle School	Pemaquid Teacher's Room-sink	2.5 ppb
Massabesic Middle School	Room 235-corner Sink (l)	3.8 ppb
Massabesic Middle School	Room 235-corner Sink (r)	3 ppb
Massabesic Middle School	Room 235-sink Over Library (l)	2.7 ppb
Massabesic Middle School	Room 235-sink Over Library (r)	2.7 ppb
Massabesic Middle School	Room 60-sink	0 ppb
Massabesic Middle School	Teacher's Room Elevator 2nd Floor-sink	1 ppb
Mast Landing School	Entry Hall	0 ppb
Mast Landing School	Gym Entry	0 ppb
Mast Landing School	H2 Classroom Lower Level	1.4 ppb
Mast Landing School	H3 Classroom	0 ppb
Mast Landing School	H4 Classroom	6.5 ppb
Mast Landing School	H5 Classroom	0 ppb
Mast Landing School	H6 Classroom	0 ppb
Mast Landing School	H7 Classroom	0 ppb
Mast Landing School	Kitchen Sink Cooking	1 ppb
Mast Landing School	S1 Classroom Lower Level	1.1 ppb
Mast Landing School	S2 Classroom	0 ppb
Mast Landing School	S3 Classroom	2.5 ppb
Mast Landing School	S4 Classroom	1.2 ppb
Mast Landing School	S5 Classroom	1.8 ppb
Mast Landing School	S6 Classroom	0 ppb
Mast Landing School	S7 Classroom	0 ppb
Mast Landing School	Sh 4 Classroom	0 ppb

School Name	Sample Location	Lead Test Result
Mast Landing School	Sh 5 Classroom	1 ppb
Mast Landing School	Sh 6 Classroom	1.6 ppb
Mast Landing School	Sh 7 Classroom	0 ppb
Mast Landing School	Sh1 Classroom	1.3 ppb
Mast Landing School	Sh2 Classroom	0 ppb
Mast Landing School	Sh3 Classroom	0 ppb
Mattanawcook Academy	100 Wing Boys Br East Sink	2.5 ppb
Mattanawcook Academy	100 Wing Girls Br East Sink	3.8 ppb
Mattanawcook Academy	100 Wing South Drinking Fountain	0 ppb
Mattanawcook Academy	100 Wing South Drinking Fountain Bottle Filler	0 ppb
Mattanawcook Academy	1st Floor Library Drinking Ofuntain North	0 ppb
Mattanawcook Academy	1st Floor Teachers Room Mens Br Sink	2.1 ppb
Mattanawcook Academy	1st Floor Teachers Room Sink	4.3 ppb
Mattanawcook Academy	1st Floor Teachers Room Womens Br Sink	3.9 ppb
Mattanawcook Academy	200 Wing Boys Br East Sink	5.3 ppb
Mattanawcook Academy	200 Wing Girls Br East Sink	7.7 ppb
Mattanawcook Academy	200 Wing North Drinking Fountain	1 ppb
Mattanawcook Academy	200 Wing North Dwf Bottle Fill	1.1 ppb
Mattanawcook Academy	200 Wing North Dwf Right Side	2.8 ppb
Mattanawcook Academy	200 Wing North Faculty Br Sink	6.5 ppb
Mattanawcook Academy	200 Wing South Drinking Fountain	0 ppb
Mattanawcook Academy	200 Wing South Drinking Fountain Bottle Filler	0 ppb
Mattanawcook Academy	200 Wing South Faculty Bathroom Sink	3.6 ppb
Mattanawcook Academy	Adult Ed Room Sink	27.2 ppb
Mattanawcook Academy	Boys Pe Locker Room Sink	3.7 ppb
Mattanawcook Academy	Boys Team Locker Room Sink	3.9 ppb
Mattanawcook Academy	Cafeteria Concession Sink	2.5 ppb
Mattanawcook Academy	Cafeteria Drinking Fountain	1 ppb
Mattanawcook Academy	Field House Concession Area Sink	1.8 ppb
Mattanawcook Academy	Field House Mens Br Sink	3.1 ppb
Mattanawcook Academy	Field House Outside Spigot	2.6 ppb
Mattanawcook Academy	Field House Womens Br Sink	1.4 ppb
Mattanawcook Academy	Girls Pe Locker Room Sink	6.2 ppb
Mattanawcook Academy	Girls Team Locker Room Sink	6.2 ppb
Mattanawcook Academy	Gym East Drinking Fountain	1.3 ppb
Mattanawcook Academy	Gym West Drinking Fountain	1.4 ppb
Mattanawcook Academy	Ia Wing Boys Br Sink	2.1 ppb
Mattanawcook Academy	Ia Wing Girls Br Sink	2.5 ppb
Mattanawcook Academy	Irrigation Feed By Baseball	49.6 ppb
Mattanawcook Academy	Kitchen 3 Bay Sink East Faucet	83.5 ppb
Mattanawcook Academy	Kitchen 3 Bay Sink West Faucet	8.4 ppb
Mattanawcook Academy	Kitchen Bathroom Sink	53 ppb
Mattanawcook Academy	Kitchen Hand Wash Sink	5 ppb
Mattanawcook Academy	Kitchen Prep Area Sink	4.1 ppb

School Name	Sample Location	Lead Test Result
Mattanawcook Academy	Library North Drinking Fountain Bottle Filler	0 ppb
Mattanawcook Academy	Library Office Sink	13.8 ppb
Mattanawcook Academy	Library South Drinking Fountain	6 ppb
Mattanawcook Academy	Lms Bathroom Sink	6.6 ppb
Mattanawcook Academy	Lms Classroom Sink	27.3 ppb
Mattanawcook Academy	Lms Kitchen East Sink	2.2 ppb
Mattanawcook Academy	Lms Kitchen Island Sink	2.4 ppb
Mattanawcook Academy	Lms Kitchen Middle Sink	2.6 ppb
Mattanawcook Academy	Lms Kitchen West Sink	4.5 ppb
Mattanawcook Academy	Lms Sink By Washer	14.7 ppb
Mattanawcook Academy	Lobby Boys Br Sink 1	2.8 ppb
Mattanawcook Academy	Lobby Boys Br Sink 2	2.5 ppb
Mattanawcook Academy	Lobby Girls Br Sink 1	0 ppb
Mattanawcook Academy	Lobby Girls Br Sink 2	0 ppb
Mattanawcook Academy	Lobby North Drinking Fountain	0 ppb
Mattanawcook Academy	Lobby North Drinking Fountain Bottle Filler	0 ppb
Mattanawcook Academy	Lobby South Drinking Fountain	3 ppb
Mattanawcook Academy	Main Office Mens Br Sink	3.7 ppb
Mattanawcook Academy	Main Office Womens Br Sink	5.4 ppb
Mattanawcook Academy	Mens Pe Office Sink	13.7 ppb
Mattanawcook Academy	Missing Womens Pe Office Sink 1	168 ppb
Mattanawcook Academy	Nurses Room In Small Room	22.9 ppb
Mattanawcook Academy	Nurses Room Sink	11.9 ppb
Mattanawcook Academy	Room 15 Sink	1.4 ppb
Mattanawcook Academy	Room 205 East Sink	14.1 ppb
Mattanawcook Academy	Room 205 West Sink	5.7 ppb
Mattanawcook Academy	Room 206 Sink	256 ppb
Mattanawcook Academy	Room 3a Sink	2.9 ppb
Mattanawcook Academy	Training Room Ice Machine	0 ppb
Mattanawcook Academy	Training Room Sink	128 ppb
Mattanawcook Academy	Wood Shop Sink	5.7 ppb
Mattanawcook Jr High School	62 Wing Main Floor Boys Br West Sink	5.2 ppb
Mattanawcook Jr High School	62 Wing Top Floor Girls Br East Sink	2.9 ppb
Mattanawcook Jr High School	62 Wing Bottom Floor Df Bottle Filler	0 ppb
Mattanawcook Jr High School	62 Wing Bottom Floor Drinking Fountain	0 ppb
Mattanawcook Jr High School	62 Wing Boys Main Floor Br East Sink	3.7 ppb
Mattanawcook Jr High School	62 Wing Boys Top Floor Br East Sink	0 ppb
Mattanawcook Jr High School	62 Wing Girls Main Floor Br East Sink	1.4 ppb
Mattanawcook Jr High School	62 Wing Main Floor Df Bottle Filler	0 ppb
Mattanawcook Jr High School	62 Wing Main Floor Drinking Fountain	0 ppb
Mattanawcook Jr High School	62 Wing Main Floor Girls Br West Sink	1.2 ppb
Mattanawcook Jr High School	62 Wing Top Floor Boys Br West Sink	1.4 ppb
Mattanawcook Jr High School	62 Wing Top Floor Df Bottle Filler	0 ppb
Mattanawcook Jr High School	62 Wing Top Floor Drinking Fountain	0 ppb
Mattanawcook Jr High School	62 Wing Top Floor Girls Br West Sink	4.7 ppb

School Name	Sample Location	Lead Test Result
Mattanawcook Jr High School	Art Room Sink	1.6 ppb
Mattanawcook Jr High School	Bottom Floor Boys Br East Sink	1.2 ppb
Mattanawcook Jr High School	Bottom Floor Boys Br West Sink	0 ppb
Mattanawcook Jr High School	Bottom Floor Girls Br East Sink	0 ppb
Mattanawcook Jr High School	Bottom Floor Girls Br West Sink	5.5 ppb
Mattanawcook Jr High School	Bottom Floor Staff Bathroom Sink	0 ppb
Mattanawcook Jr High School	Bottom Floor Teachers Room Sink	1.7 ppb
Mattanawcook Jr High School	Boys Locker Room Sink	3.7 ppb
Mattanawcook Jr High School	Cafeteria Drinking Fountain	0 ppb
Mattanawcook Jr High School	Cafeteria Drinking Fountain Bottle Filler	0 ppb
Mattanawcook Jr High School	Conference Room Drinking Fountain	21 ppb
Mattanawcook Jr High School	Conference Room Sink	6.4 ppb
Mattanawcook Jr High School	Custodian Room Sink	1.1 ppb
Mattanawcook Jr High School	Garage Boys Br Sink	9.2 ppb
Mattanawcook Jr High School	Garage Girls Br Sink	4 ppb
Mattanawcook Jr High School	Garage South Wall Hose Spigot	10.5 ppb
Mattanawcook Jr High School	Garage West Wall Outside Spigot	406 ppb
Mattanawcook Jr High School	Girls Locker Room Sink	6.6 ppb
Mattanawcook Jr High School	Kitchen 2 Bay Sink	1.2 ppb
Mattanawcook Jr High School	Kitchen Dish Washer Room Sink	9.5 ppb
Mattanawcook Jr High School	Kitchen Hand Wash Sink By Pantry	1.5 ppb
Mattanawcook Jr High School	Library Drinking Fountain	2400 ppb
Mattanawcook Jr High School	Library Sink	2.5 ppb
Mattanawcook Jr High School	Lobby Boys Br North Sink	1.7 ppb
Mattanawcook Jr High School	Lobby Boys Br South Sink	5.9 ppb
Mattanawcook Jr High School	Lobby Drinking Fountain	0 ppb
Mattanawcook Jr High School	Lobby Drinking Fountain Bottle Filler	0 ppb
Mattanawcook Jr High School	Lobby Girls Br North Sink	3.5 ppb
Mattanawcook Jr High School	Lobby Girls Br South Sink	1.7 ppb
Mattanawcook Jr High School	Main Floor Br By Clinic Sink	2.2 ppb
Mattanawcook Jr High School	Main Floor South Drinking Fountain	0 ppb
Mattanawcook Jr High School	Main Floor South Drinking Fountain Bottle Filler	0 ppb
Mattanawcook Jr High School	Outside Drinking Fountain	36.1 ppb
Mattanawcook Jr High School	Room 1 Sink	5.5 ppb
Mattanawcook Jr High School	Room 10 Sink	6.6 ppb
Mattanawcook Jr High School	Room 10 Sink #2	62.6 ppb
Mattanawcook Jr High School	Room 15 Sink	135 ppb
Mattanawcook Jr High School	Room 2 Office Sink	63 ppb
Mattanawcook Jr High School	Room 2 Storage Room Sink	40.5 ppb
Mattanawcook Jr High School	Room 26 Sink	3.2 ppb
Mattanawcook Jr High School	Room 3 North Sink	219 ppb
Mattanawcook Jr High School	Room 3 South Sink	6.8 ppb
Mattanawcook Jr High School	Room 5 Sink	2.3 ppb
Mattanawcook Jr High School	Room 6 Sink	11.2 ppb
Mattanawcook Jr High School	Room 9 Sink	5.1 ppb
Mattanawcook Jr High School	Top Floor South Drinking Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Mattanawcook Jr High School	Top Floor South Drinking Fountain Bottle Filler	0 ppb
Mattanawcook Jr High School	Top Floor Staff Br Sink	4.4 ppb
ME Sch of Science & Mathematics	B Wing Apartment B 207	1.7 ppb
ME Sch of Science & Mathematics	B Wing Apartment B 219	0 ppb
ME Sch of Science & Mathematics	B Wing Outside Of B216	0 ppb
ME Sch of Science & Mathematics	C Wing Apartment C 201	0 ppb
ME Sch of Science & Mathematics	Lower A Wing Apartment A109	1.3 ppb
ME Sch of Science & Mathematics	Lower A Wing By Boiler Room Door	0 ppb
ME Sch of Science & Mathematics	Lower Lounge By Kitchen Entrance	0 ppb
ME Sch of Science & Mathematics	Students Kitchen Sink	1 ppb
ME Sch of Science & Mathematics	Upper A Wing Apartment A201	0 ppb
ME Sch of Science & Mathematics	Upper A Wing Outside A217	0 ppb
ME Sch of Science & Mathematics	Upper A Wing Apartment A 219	0 ppb
ME Sch of Science & Mathematics	Upper Lobby By Elevator	0 ppb
ME Sp. Ed./M.H. Collaborative	Ground Level Break Room	0 ppb
ME Sp. Ed./M.H. Collaborative	Intermediate Class Room 1st Floor	0 ppb
ME Sp. Ed./M.H. Collaborative	Primary Class Room 1st Floor	0 ppb
ME Sp. Ed./M.H. Collaborative	Room 201 Class Room Sink	0 ppb
ME Sp. Ed./M.H. Collaborative	Room 210 Kitchen	0 ppb
Medomak Valley High School	Art 2 Sinks & 3 Faucets	5.9 ppb
Medomak Valley High School	Art Bathroom Sink	1.8 ppb
Medomak Valley High School	Art Darkroom 2 Sinks & 3 Faucets	0 ppb
Medomak Valley High School	Bathrooms By Band Room X2	6.2 ppb
Medomak Valley High School	Boiler Room 1 Water Source	21.3 ppb
Medomak Valley High School	Bottle Fill Stations In Lobby	0 ppb
Medomak Valley High School	Bottle Fill Stations Outside Library	0 ppb
Medomak Valley High School	Bottle Fill Stations Outside Room #24	4.5 ppb
Medomak Valley High School	Bottle Fill Stations Outside Room #8	0 ppb
Medomak Valley High School	Bottle Fill Stations Outside Room Gym	0 ppb
Medomak Valley High School	Clay 2 Sinks	0 ppb
Medomak Valley High School	Clay Bathroom Sink	2.4 ppb
Medomak Valley High School	Custodial Closet Across From #10	6.6 ppb
Medomak Valley High School	Custodial Closet Across From #21	5 ppb
Medomak Valley High School	Custodial Closet Across From #33	0 ppb
Medomak Valley High School	Guidance - 2 Bathroom Sinks	3 ppb
Medomak Valley High School	Ice Machine	0 ppb
Medomak Valley High School	Ice Machine Sink	0 ppb
Medomak Valley High School	Jv Boys Locker Room Sink	3.3 ppb
Medomak Valley High School	Jv Girls Locker Room Sink	1.7 ppb
Medomak Valley High School	Kitchen 3 Bay Wash Sink 2 Faucets	3.4 ppb
Medomak Valley High School	Kitchen Bathroom Sink	17.6 ppb
Medomak Valley High School	Kitchen Hand Wash Sink	13.6 ppb
Medomak Valley High School	Library Bathroom Boys 3 Sinks	0 ppb
Medomak Valley High School	Library Bathroom Unisex 1 Sink	1.5 ppb
Medomak Valley High School	Library Sink	8.1 ppb
Medomak Valley High School	Lobby Boys Sink	2.3 ppb

School Name	Sample Location	Lead Test Result
Medomak Valley High School	Lobby Girls Sink	4.6 ppb
Medomak Valley High School	Maint Building 1 Sink	1.2 ppb
Medomak Valley High School	Matt Lash Office Sink/shower	3.6 ppb
Medomak Valley High School	Northwing Boys Bathroom 2 Sinks	0 ppb
Medomak Valley High School	Northwing Girls Bathroom 2 Sinks	0 ppb
Medomak Valley High School	Northwing Room #1 3 Sinks	3.6 ppb
Medomak Valley High School	Northwing Room #3 Bathroom Sink	1.3 ppb
Medomak Valley High School	Northwing Room #5 2 Sinks	1.3 ppb
Medomak Valley High School	Nurse Bathroom Sink	1.1 ppb
Medomak Valley High School	Nurse Sink	0 ppb
Medomak Valley High School	Ryan Dipompo Office Sink/shower	3.9 ppb
Medomak Valley High School	Southwing #19 20 Lab Faucets	9.4 ppb
Medomak Valley High School	Southwing #20 7 Lab Faucets	36.1 ppb
Medomak Valley High School	Southwing #21 6 Lab Faucets	10.4 ppb
Medomak Valley High School	Southwing #22 8 Lab Faucets	9.8 ppb
Medomak Valley High School	Southwing #23 5 Lab Faucets	5.5 ppb
Medomak Valley High School	Southwing Boys Bathroom 2 Sinks	0 ppb
Medomak Valley High School	Southwing Girls Bathroom 2 Sinks	3 ppb
Medomak Valley High School	Teachers Room Bathroom 2 Sinks	0 ppb
Medomak Valley High School	Teachers Room Sink	1.6 ppb
Medomak Valley High School	Varsity Boys Locker Room Sink	13.2 ppb
Medomak Valley High School	Varsity Girls Locker Room Sink	6.8 ppb
Medway Middle School	3 Sink Dishwasher Room Kitchen	1.8 ppb
Medway Middle School	5 Th + 6 Th Grades Hall Water Fountain	0 ppb
Medway Middle School	7 Th + 8th Grades Hall Water Fountain	1.8 ppb
Medway Middle School	Art Room Sink	4 ppb
Medway Middle School	Boy's Bathroom Hand Sink On Left Side	0 ppb
Medway Middle School	Boy's Bathroom Hand Sink On Right Side	0 ppb
Medway Middle School	Boy's Locker Hand Sink	4.1 ppb
Medway Middle School	Girl's Bathroom Hand Sink On Left Side	1.3 ppb
Medway Middle School	Girl's Bathroom Hand Sink On Right Side	1.7 ppb
Medway Middle School	Girl's Locker Hand Sink	1.8 ppb
Medway Middle School	Hand Sink	0 ppb
Medway Middle School	Ice Maker Gym	0 ppb
Medway Middle School	Kitchen Kettle	15.5 ppb
Medway Middle School	Lobby Water Fountain	0 ppb
Medway Middle School	Men's Lobby Bathroom Sink	3.9 ppb
Medway Middle School	Nurse's Room Bathroom Sink	2.8 ppb
Medway Middle School	Nurse's Room Sink	2.5 ppb
Medway Middle School	Outside Water Spigot North Side	377 ppb
Medway Middle School	Outside Water Spigot South Side	236 ppb
Medway Middle School	Payroll Office Sink	9.3 ppb
Medway Middle School	Salad Sink	3.7 ppb
Medway Middle School	Science Room 103 7th + 8th Grades	17.6 ppb
Medway Middle School	Science Room 111 5 Th + 6th Grades	15.9 ppb
Medway Middle School	Sink Dishwasher Room Kitchen	2.9 ppb
Medway Middle School	Teacher's Room Sink	3.9 ppb

School Name	Sample Location	Lead Test Result
Medway Middle School	Women's Lobby Bathroom Sink	1.4 ppb
Memorial Middle School	1st Flr...spec Ed Room 105	0 ppb
Memorial Middle School	2nd Flr...teacher Break Room	3.5 ppb
Memorial Middle School	Bottle Filler...near Gym...2nd Flr	0 ppb
Memorial Middle School	Bottle Fillerànear Gymà2nd Flr	0 ppb
Memorial Middle School	Central Office.2nd Flr...kitchen Sink	0 ppb
Memorial Middle School	Kitchen...2nd Flr....sink 1 Facing Window	0 ppb
Memorial Middle School	Kitchen...2nd Flr....sink 2 Facing Storage	0 ppb
Memorial School	Class Sink/ Bubbler Rm #140	0 ppb
Memorial School	Class Sink/ Bubbler Rm #141	0 ppb
Memorial School	Class Sink/ Bubbler Rm #145	0 ppb
Memorial School	Class Sink/ Bubbler Rm #146	0 ppb
Memorial School	Class Sink/ Bubbler Rm #147	0 ppb
Memorial School	Class Sink/ Bubbler Rm #148	0 ppb
Memorial School	Class Sink/ Bubbler Rm #150	0 ppb
Memorial School	Class Sink/ Bubbler Rm #151	0 ppb
Memorial School	Hall Bottle Filler #1	0 ppb
Memorial School	Hall Bottle Filler #2	0 ppb
Memorial School	Kitchen 3 Bay Sink	2.4 ppb
Memorial School	Kitchen Food Prep Sink	1.6 ppb
Memorial School	Nurse Sink Rm #113	0 ppb
Memorial School	Teachers Lounge Rm #116	0 ppb
Meroby Elementary School	201 - Drinking Fountain	1.4 ppb
Meroby Elementary School	201- Sink	0 ppb
Meroby Elementary School	202- Drinking Fountain	2.5 ppb
Meroby Elementary School	202- Sink	0 ppb
Meroby Elementary School	203- Bathroom Area Sink	1.7 ppb
Meroby Elementary School	203- Drinking Fountain	0 ppb
Meroby Elementary School	203- Sink	1.7 ppb
Meroby Elementary School	204- Drinking Fountain	2.2 ppb
Meroby Elementary School	204- Sink	1.7 ppb
Meroby Elementary School	205- Drinking Fountain	2.6 ppb
Meroby Elementary School	205- Sink	3.4 ppb
Meroby Elementary School	206- Drinking Fountain	1.8 ppb
Meroby Elementary School	206- Bathroom Area Sink	1.6 ppb
Meroby Elementary School	206- Sink	1.9 ppb
Meroby Elementary School	207- Drinking Fountain	1.9 ppb
Meroby Elementary School	207- Sink	1.3 ppb
Meroby Elementary School	208- Drinking Fountain	1.9 ppb
Meroby Elementary School	208- Sink	2.8 ppb
Meroby Elementary School	209- Bathroom Area Sink	2 ppb
Meroby Elementary School	209- Drinking Fountain	2.1 ppb
Meroby Elementary School	209- Sink	1.8 ppb
Meroby Elementary School	211- Drinking Fountain	0 ppb
Meroby Elementary School	211- Sink	1.5 ppb
Meroby Elementary School	258- Sink A	2.1 ppb
Meroby Elementary School	258- Sink B	1.8 ppb

School Name	Sample Location	Lead Test Result
Meroby Elementary School	258- Sink C	1.6 ppb
Meroby Elementary School	265- Bathroom Sink	0 ppb
Meroby Elementary School	265- Drinking Fountain	2.4 ppb
Meroby Elementary School	265- Sink	2.1 ppb
Meroby Elementary School	271- Bathroom Sink	1.9 ppb
Meroby Elementary School	274- Bathroom Sink	1.4 ppb
Meroby Elementary School	Between Room 274-271 Sink 1	2.1 ppb
Meroby Elementary School	Between Room 274-271 Sink 2	1.7 ppb
Meroby Elementary School	Boys Bathroom- First Floor (bbrff1)	0 ppb
Meroby Elementary School	Boys Bathroom- First Floor (bbrff2)	1.6 ppb
Meroby Elementary School	Boys Locker Room (blr1)	1.3 ppb
Meroby Elementary School	Boys Locker Room (blr2)	1.6 ppb
Meroby Elementary School	Girls Bathroom- First Floor (gbrff1)	1.7 ppb
Meroby Elementary School	Girls Bathroom- First Floor (gbrff2)	2.7 ppb
Meroby Elementary School	Girls Locker Room (glr1)	2.4 ppb
Meroby Elementary School	Girls Locker Room (glr2)	1.9 ppb
Meroby Elementary School	Gym Fountain (dwr1)	0 ppb
Meroby Elementary School	Hallway Infront Of Office Wf (dwf2)	0 ppb
Meroby Elementary School	Hallway Near Library Wf (dwf3)	2.2 ppb
Meroby Elementary School	Kitchen Bathroom (kb1)	4.9 ppb
Meroby Elementary School	Kitchen- Sink (kf1)	2.9 ppb
Meroby Elementary School	Library Bathroom- Sink	0 ppb
Meroby Elementary School	Library Office - Sink	21.8 ppb
Meroby Elementary School	Nurses Room (nurse1)	1 ppb
Meroby Elementary School	Room 101- Drinking Fountain	1.6 ppb
Meroby Elementary School	Room 101- Sink	5 ppb
Meroby Elementary School	Room 102- Sink	0 ppb
Meroby Elementary School	Room 103- Drinking Fountain	94.5 ppb
Meroby Elementary School	Room 103- Sink	9.9 ppb
Meroby Elementary School	Room 104- Drinking Fountain	12.9 ppb
Meroby Elementary School	Room 104- Sink	1.5 ppb
Meroby Elementary School	Room 105- Drinking Fountain	1.5 ppb
Meroby Elementary School	Room 105- Sink	1.1 ppb
Meroby Elementary School	Room 106- Drinking Fountain	0 ppb
Meroby Elementary School	Room 106- Sink	0 ppb
Meroby Elementary School	Room 107- Drinking Fountain	1.4 ppb
Meroby Elementary School	Room 107- Sink	1.8 ppb
Meroby Elementary School	Room 108- Drinking Fountain	2.2 ppb
Meroby Elementary School	Room 108- Sink	1.4 ppb
Meroby Elementary School	Room 166 Sink (r166)	1.9 ppb
Meroby Elementary School	Room 212- Drinking Fountain	0 ppb
Meroby Elementary School	Room 212- Sink	0 ppb
Meroby Elementary School	Room 242- Sink	6.4 ppb
Meroby Elementary School	Room 248- Art 1	2.6 ppb
Meroby Elementary School	Room 248- Art 2	2.4 ppb
Meroby Elementary School	Staff Bathroom- First Floor Hallways (stb1)	2 ppb
Meroby Elementary School	Upper Lobby- Bathroom Sink A (ulbra)	0 ppb

School Name	Sample Location	Lead Test Result
Meroby Elementary School	Upper Lobby- Bathroom Sink B (ulbrb)	1 ppb
Meroby Elementary School	Upper Lobby- Drinking Fountain (dwf4)	0 ppb
Messalonskee High School	100 Across From Main Office - Bot Fill A	0 ppb
Messalonskee High School	100 Across From Main Office - Dwf A	0 ppb
Messalonskee High School	100 Across From Main Office - Dwf B	0 ppb
Messalonskee High School	100 Wing - Bottle Fill	0 ppb
Messalonskee High School	100 Wing - Dwf	0 ppb
Messalonskee High School	101 Across From Main Office - Bot Fill B	0 ppb
Messalonskee High School	200 - Bottle Fill Station	0 ppb
Messalonskee High School	200 - Dwf	0 ppb
Messalonskee High School	200 Lib - Bathroom Sink	2.5 ppb
Messalonskee High School	204 Girls Bathroom - Sink A	0 ppb
Messalonskee High School	205 Girls Bathroom - Sink B	0 ppb
Messalonskee High School	300 Quad - Bottle Fill Station	0 ppb
Messalonskee High School	300 Quad - Dwf	0 ppb
Messalonskee High School	Between 309/311 - Bottle Fill Station	0 ppb
Messalonskee High School	Between 309/311 - Dwf	0 ppb
Messalonskee High School	Between 361-363 - Bottle Fill Station	0 ppb
Messalonskee High School	Between 361-363 - Dwf	0 ppb
Messalonskee High School	Brick Bldg Boys Bathroom - Sink	0 ppb
Messalonskee High School	Brick Bldg Girls Bathroom - Sink	0 ppb
Messalonskee High School	Brick Bldg Rm 1 - Sink A	2.9 ppb
Messalonskee High School	Brick Bldg Rm 1 - Sink B	2.2 ppb
Messalonskee High School	Brick Bldg Rm 2 - Sink A	0 ppb
Messalonskee High School	Brick Bldg Rm 2 - Sink B	3.6 ppb
Messalonskee High School	Brick Bldg Rm 2 - Sink C	2.3 ppb
Messalonskee High School	Kitchen Bathroom - Sink	0 ppb
Messalonskee High School	Kitchen Boiling Pot - Large	1 ppb
Messalonskee High School	Kitchen Boiling Pot - Small Line	26.5 ppb
Messalonskee High School	Kitchen Coffee - Sink	0 ppb
Messalonskee High School	Kitchen Dishwash - Sink	0 ppb
Messalonskee High School	Kitchen Garbage Disposal - Sink	0 ppb
Messalonskee High School	Kitchen Handwash - Sink A	0 ppb
Messalonskee High School	Kitchen Handwash - Sink B	0 ppb
Messalonskee High School	Kitchen Sanitize - Sink	0 ppb
Messalonskee High School	Kitchen Veggiewash - Sink	0 ppb
Messalonskee High School	Nurses Station - Bf (hot/cold)	0 ppb
Messalonskee High School	Nurses Station Bathroom - Sink	0 ppb
Messalonskee High School	Pac Boys Bathroom - Sink	0 ppb
Messalonskee High School	Pac Girls Bathroom - Sink	0 ppb
Messalonskee High School	Pac Room 156 Girl Dressing Room Sink A	3.3 ppb
Messalonskee High School	Pac Room 156 Girl Dressing Room Sink B	1.4 ppb
Messalonskee High School	Pac Room 158 Boy Dressing Room - Sink	13 ppb
Messalonskee High School	Rm 300 Science Lab - Sink A	19.3 ppb
Messalonskee High School	Rm 300 Science Lab - Sink B	74.9 ppb
Messalonskee High School	Rm 300 Science Lab - Sink C	31.9 ppb
Messalonskee High School	Rm 300 Science Lab - Sink D	41.6 ppb

School Name	Sample Location	Lead Test Result
Messalonskee High School	Rm 300 Science Lab - Sink E	13.4 ppb
Messalonskee High School	Rm 300 Science Lab - Sink F	50.4 ppb
Messalonskee High School	Rm 300 Science Lab - Sink G	75.9 ppb
Messalonskee High School	Rm 304 Teacher Lnge - Sink	0 ppb
Messalonskee High School	Rm 304 Teacher Lnge Boy Bath- Sink	0 ppb
Messalonskee High School	Rm 304 Teacher Lnge Girl Bath - Sink	1.8 ppb
Messalonskee High School	Rm 304 Teacher Lnge Water Cooler (h/c)	0 ppb
Messalonskee High School	Rm 309 Boy Bath - Sink A	8.2 ppb
Messalonskee High School	Rm 309 Boy Bath - Sink B	10.3 ppb
Messalonskee High School	Rm 309 Boy Bath - Sink C	9.5 ppb
Messalonskee High School	Rm 313 Girl Bathroom - Sink A	4.2 ppb
Messalonskee High School	Rm 313 Girl Bathroom - Sink B	4.4 ppb
Messalonskee High School	Rm 313 Girl Bathroom - Sink C	8.4 ppb
Messalonskee High School	Rm 350 Science - Sink A	2.7 ppb
Messalonskee High School	Rm 350 Science - Sink B	5 ppb
Messalonskee High School	Rm 350 Science - Sink C	6.4 ppb
Messalonskee High School	Rm 350 Science - Sink E	74.3 ppb
Messalonskee High School	Rm 350 Science - Sink F	5.4 ppb
Messalonskee High School	Rm 350 Science - Sink G	24.1 ppb
Messalonskee High School	Rm 350 Science - Sink H	3.7 ppb
Messalonskee High School	Rm 350 Science - Sink I	4.9 ppb
Messalonskee High School	Rm 350 Science - Sink J	5.3 ppb
Messalonskee High School	Rm 350 Science - Sink K	8.2 ppb
Messalonskee High School	Rm 352 Chem Science - Sink A	2.3 ppb
Messalonskee High School	Rm 352 Chem Science - Sink B	1.3 ppb
Messalonskee High School	Rm 352 Chem Science - Sink C	2.2 ppb
Messalonskee High School	Rm 352 Chem Science - Sink D	8.7 ppb
Messalonskee High School	Rm 352 Chem Science - Sink E	29.6 ppb
Messalonskee High School	Rm 352 Chem Science - Sink F	38 ppb
Messalonskee High School	Rm 352 Chem Science - Sink G	9.7 ppb
Messalonskee High School	Rm 352 Chem Science - Sink H	8.1 ppb
Messalonskee High School	Rm 352 Chem Science - Sink I	2.6 ppb
Messalonskee High School	Rm 352 Chem Science - Sink J	5.6 ppb
Messalonskee High School	Rm 361 Girls Bathroom - Sink A	8.3 ppb
Messalonskee High School	Rm 361 Girls Bathroom - Sink B	2.4 ppb
Messalonskee High School	Rm 361 Girls Bathroom - Sink C	41.1 ppb
Messalonskee High School	Rm 365 Boys Bathroom - Sink A	17.1 ppb
Messalonskee High School	Rm 365 Boys Bathroom - Sink B	5.7 ppb
Messalonskee High School	Rm 365 Boys Bathroom - Sink C	7.3 ppb
Messalonskee High School	Room 108 Boys B. Room - Sink A	0 ppb
Messalonskee High School	Room 108 Boys B. Room - Sink B	1.2 ppb
Messalonskee High School	Room 110 Girls B. Room - Sink A	1.1 ppb
Messalonskee High School	Room 110 Girls B. Room - Sink B	1.6 ppb
Messalonskee High School	Room 113 - Sink A	0 ppb
Messalonskee High School	Room 113 - Sink B	0 ppb
Messalonskee High School	Room 115 - Sink A	2.8 ppb
Messalonskee High School	Room 115 - Sink B	1.9 ppb

School Name	Sample Location	Lead Test Result
Messalonskee High School	Room 117 - Bathroom Sink	0 ppb
Messalonskee High School	Room 119 - Sink A	224 ppb
Messalonskee High School	Room 119 - Sink B	246 ppb
Messalonskee High School	Room 119 - Sink C	2.6 ppb
Messalonskee High School	Room 119 - Sink D	2.8 ppb
Messalonskee High School	Room 120 Girls L. Room - Sink A	0 ppb
Messalonskee High School	Room 120 Girls L. Room - Sink B	0 ppb
Messalonskee High School	Room 120 Girls L. Room - Sink C	0 ppb
Messalonskee High School	Room 121 - Sink	3.7 ppb
Messalonskee High School	Room 123 - Bathroom Sink	0 ppb
Messalonskee High School	Room 125 - Sink A	2.5 ppb
Messalonskee High School	Room 125 - Sink B	27.8 ppb
Messalonskee High School	Room 125 - Sink C	3.7 ppb
Messalonskee High School	Room 125 - Sink D	4 ppb
Messalonskee High School	Room 127 - Sink	3.2 ppb
Messalonskee High School	Room 131 - Ice Machine Fill	11 ppb
Messalonskee High School	Room 131 - Sink	0 ppb
Messalonskee High School	Room 133 - Sink A	0 ppb
Messalonskee High School	Room 172 Boys L. Room - Sink A	0 ppb
Messalonskee High School	Room 172 Boys L. Room - Sink C	0 ppb
Messalonskee High School	Room 202 Boys Bathroom - Sink A	0 ppb
Messalonskee High School	Room 202 Boys Bathroom - Sink B	0 ppb
Messalonskee High School	Room 305 - Sink A	10.5 ppb
Messalonskee High School	Room 305 - Sink C	9.2 ppb
Messalonskee Middle School	104/112 Outside - Water Bib	298 ppb
Messalonskee Middle School	107/100 Outside - Water Bib	8.4 ppb
Messalonskee Middle School	126/124 Outside - Water Bib	272 ppb
Messalonskee Middle School	133/125 Outside - Water Bib	368 ppb
Messalonskee Middle School	200 - Bf Station	0 ppb
Messalonskee Middle School	200 - Dwf #1	0 ppb
Messalonskee Middle School	200 - Dwf #2	0 ppb
Messalonskee Middle School	451 Physical Therapy - Sink A	8 ppb
Messalonskee Middle School	451 Physical Therapy - Sink B	0 ppb
Messalonskee Middle School	455 Us Wing - Water Bib	60.4 ppb
Messalonskee Middle School	Across Frm Nurse Bthrm - Bottle Fill	0 ppb
Messalonskee Middle School	Across Frm Nurse Bthrm - Dwf	0 ppb
Messalonskee Middle School	Across Frm Nurse Bthrm -dwf (stnd Alne)	0 ppb
Messalonskee Middle School	At House Storage (300)- Bathroom A Sink	2.8 ppb
Messalonskee Middle School	At House Storage (300) Bthrm B - Sink	2.8 ppb
Messalonskee Middle School	Bthrm Across Frm Fntn A - Sink	0 ppb
Messalonskee Middle School	Bthrm Across Frm Fntn B - Sink	1.2 ppb
Messalonskee Middle School	By 124 Bathroom A - Sink	3.1 ppb
Messalonskee Middle School	By 124 Bathroom B - Sink	1.2 ppb
Messalonskee Middle School	By 124 Bathroom C - Sink	0 ppb
Messalonskee Middle School	By 124 Bathroom D- Sink	1.3 ppb
Messalonskee Middle School	By 130 Bathroom A - Sink	0 ppb
Messalonskee Middle School	By 130 Bathroom B - Sink	0 ppb

School Name	Sample Location	Lead Test Result
Messalonskee Middle School	Caft Hall Boys Bathroom - Sink A	6.6 ppb
Messalonskee Middle School	Caft Hall Boys Bathroom - Sink B	5 ppb
Messalonskee Middle School	Caft Hall Girls Bathroom - Sink A	4.6 ppb
Messalonskee Middle School	Caft Hall Girls Bathroom - Sink B	2.9 ppb
Messalonskee Middle School	General Bathroom (next To 463) - Sink	0 ppb
Messalonskee Middle School	Gym - Dwf B	0 ppb
Messalonskee Middle School	Gym Boys Locker Room - Sink A	3.5 ppb
Messalonskee Middle School	Gym Boys Locker Room - Sink B	2.6 ppb
Messalonskee Middle School	Gym Girls Locker Room - Sink A	1.4 ppb
Messalonskee Middle School	Gym Girls Locker Room - Sink B	3.9 ppb
Messalonskee Middle School	Gym Hall - Bottle Fill Station	0 ppb
Messalonskee Middle School	Gym Hall - Dwf	0 ppb
Messalonskee Middle School	Gym Hall - Dwf Stand Alone	0 ppb
Messalonskee Middle School	Kitchen - Dishwash Station	1.9 ppb
Messalonskee Middle School	Kitchen - Kettle	5.1 ppb
Messalonskee Middle School	Kitchen - Tilt Skillet	74.2 ppb
Messalonskee Middle School	Kitchen Custodian - Deep Sink	3.9 ppb
Messalonskee Middle School	Kitchen Handwash Station - Sink B	2.6 ppb
Messalonskee Middle School	Kitchen Handwash Station Sink A	1.3 ppb
Messalonskee Middle School	Kitchen Restroom - Sink	2.4 ppb
Messalonskee Middle School	Kitchen Vegetable - Sink A	4.5 ppb
Messalonskee Middle School	Kitchen Vegetable - Sink B	5 ppb
Messalonskee Middle School	Library - Sink	0 ppb
Messalonskee Middle School	Mezz 200 Beside School - Hose Bib	5.6 ppb
Messalonskee Middle School	Mezz 200 Front Side School - Hose Bib	17.4 ppb
Messalonskee Middle School	Music/band - Sink	0 ppb
Messalonskee Middle School	Next 455 Bathroom - Sink	0 ppb
Messalonskee Middle School	Next To 106 Bathroom - Sink A	1.6 ppb
Messalonskee Middle School	Next To 106 Bathroom - Sink B	1.4 ppb
Messalonskee Middle School	Next To 230 Bathroom A - Sink	0 ppb
Messalonskee Middle School	Next To 230 Bathroom B - Sink	0 ppb
Messalonskee Middle School	Next To 326 Service Hub Bthrm A - Sink	0 ppb
Messalonskee Middle School	Next To 326 Service Hub Bthrm B - Sink	0 ppb
Messalonskee Middle School	Next To 326 Service Hub Bthrm C - Sink	1 ppb
Messalonskee Middle School	Next To 326 Service Hub Bthrm D - Sink	1.3 ppb
Messalonskee Middle School	Next To Custodial - Bthrm A	1.2 ppb
Messalonskee Middle School	Next To Custodial - Bthrm B	1.3 ppb
Messalonskee Middle School	Next To Custodial - Bthrm C	1.4 ppb
Messalonskee Middle School	Next To Custodial - Bthrm D	0 ppb
Messalonskee Middle School	Nurse Station Old Office - Bathroom Sink	2.3 ppb
Messalonskee Middle School	Nurse Station Old Office - Sink	0 ppb
Messalonskee Middle School	Nxt 2 House Storge(300)- Bottle Fill	0 ppb
Messalonskee Middle School	Nxt 2 House Storge(300)- Dwf Stand Alone	0 ppb
Messalonskee Middle School	Nxt To Gnrl Storge (300) Bthrm - Sink A	4.2 ppb
Messalonskee Middle School	Nxt To Gnrl Storge (300) Bthrm - Sink B	1.2 ppb
Messalonskee Middle School	Outside Caft - Bf	0 ppb
Messalonskee Middle School	Outside Caft - Dwf	0 ppb

School Name	Sample Location	Lead Test Result
Messalonskee Middle School	Outside Caft - Dwf Stand Alone	0 ppb
Messalonskee Middle School	Rm 104 Physical Therapy - Sink	1.1 ppb
Messalonskee Middle School	Rm 104 Physical Therapy Bathroom - Sink	2 ppb
Messalonskee Middle School	Room 106 Staff Lounge - Sink	3 ppb
Messalonskee Middle School	Room 106 Staff Lounge - Bathroom Sink	5.3 ppb
Messalonskee Middle School	Room 111 - Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 111 - Sink	8 ppb
Messalonskee Middle School	Room 112 - Sink	2.2 ppb
Messalonskee Middle School	Room 112- Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 113 - Dwf/sink Combo	4.9 ppb
Messalonskee Middle School	Room 113 - Sink	0 ppb
Messalonskee Middle School	Room 114 Nurse Station - Sink	2.2 ppb
Messalonskee Middle School	Room 114 Nurse Station-dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 115 - Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 115 - Sink	3.3 ppb
Messalonskee Middle School	Room 116 - Dwf	0 ppb
Messalonskee Middle School	Room 116 - Sink	4.1 ppb
Messalonskee Middle School	Room 117 - Sink B	5.1 ppb
Messalonskee Middle School	Room 117 - Sink C	4 ppb
Messalonskee Middle School	Room 117 - Sink D	1.7 ppb
Messalonskee Middle School	Room 117 - Sink E	4.1 ppb
Messalonskee Middle School	Room 118 - Sink A	4.4 ppb
Messalonskee Middle School	Room 118 - Sink B	7.5 ppb
Messalonskee Middle School	Room 118 - Sink C	6.6 ppb
Messalonskee Middle School	Room 118 - Sink D	2.7 ppb
Messalonskee Middle School	Room 118 - Sink F	16 ppb
Messalonskee Middle School	Room 133 - Dwf/sink Combo	1.3 ppb
Messalonskee Middle School	Room 133 - Sink	8.2 ppb
Messalonskee Middle School	Room 134 - Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 134 - Sink	2.2 ppb
Messalonskee Middle School	Room 135 - Sink A	6.7 ppb
Messalonskee Middle School	Room 135 - Sink B	3.1 ppb
Messalonskee Middle School	Room 135 - Sink C	7.1 ppb
Messalonskee Middle School	Room 135 - Sink D	2.8 ppb
Messalonskee Middle School	Room 135 - Sink E	2.2 ppb
Messalonskee Middle School	Room 136 - Sink	2.3 ppb
Messalonskee Middle School	Room 204 - Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 204 - Sink	8.7 ppb
Messalonskee Middle School	Room 207 - Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 207 - Sink	2.9 ppb
Messalonskee Middle School	Room 209 - Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 209 - Sink	2 ppb
Messalonskee Middle School	Room 211 - Dwf/sink Combo	3.3 ppb
Messalonskee Middle School	Room 211 - Sink	0 ppb
Messalonskee Middle School	Room 212 - Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 212 - Sink	13.2 ppb
Messalonskee Middle School	Room 213 - Sink B	4.2 ppb

School Name	Sample Location	Lead Test Result
Messalonskee Middle School	Room 213 - Sink C	4.3 ppb
Messalonskee Middle School	Room 213 - Sink D	3.6 ppb
Messalonskee Middle School	Room 213 - Sink E	2.7 ppb
Messalonskee Middle School	Room 214 - Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 214 - Sink	6.2 ppb
Messalonskee Middle School	Room 216 - Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 216 - Sink	2.4 ppb
Messalonskee Middle School	Room 218 - Sink A	3.9 ppb
Messalonskee Middle School	Room 218 - Sink B	5.6 ppb
Messalonskee Middle School	Room 218 - Sink C	3.9 ppb
Messalonskee Middle School	Room 218 - Sink D	2.7 ppb
Messalonskee Middle School	Room 218 - Sink E	20.2 ppb
Messalonskee Middle School	Room 229 - Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 229 - Sink	4.4 ppb
Messalonskee Middle School	Room 231 - Sink B	2.6 ppb
Messalonskee Middle School	Room 231 - Sink E	2.1 ppb
Messalonskee Middle School	Room 231 - Sink F	5.2 ppb
Messalonskee Middle School	Room 234 - Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 234 - Sink	2.9 ppb
Messalonskee Middle School	Room 236 - Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 236 - Sink	3.8 ppb
Messalonskee Middle School	Room 303 - Sink	0 ppb
Messalonskee Middle School	Room 303 - Sink	1.5 ppb
Messalonskee Middle School	Room 304 - Sink	3.3 ppb
Messalonskee Middle School	Room 305 - Sink	2.4 ppb
Messalonskee Middle School	Room 308 Staff Lounge - Bathroom Sink	2.5 ppb
Messalonskee Middle School	Room 308 Staff Lounge - Sink	1.9 ppb
Messalonskee Middle School	Room 313 - Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 313 - Sink	6.1 ppb
Messalonskee Middle School	Room 314 - Dwf	2.2 ppb
Messalonskee Middle School	Room 314 - Sink	4.1 ppb
Messalonskee Middle School	Room 315 - Dwf	0 ppb
Messalonskee Middle School	Room 315 - Sink	4.4 ppb
Messalonskee Middle School	Room 316 - Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 316 - Sink	4.4 ppb
Messalonskee Middle School	Room 317 - Sink E	3.5 ppb
Messalonskee Middle School	Room 317 Closet - Sink E	7.4 ppb
Messalonskee Middle School	Room 317 -sink A	2.2 ppb
Messalonskee Middle School	Room 317 -sink C	2.4 ppb
Messalonskee Middle School	Room 317 -sink D	3.5 ppb
Messalonskee Middle School	Room 318 - Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 318 - Sink	2.7 ppb
Messalonskee Middle School	Room 320 - Sink A	3.1 ppb
Messalonskee Middle School	Room 320 - Sink B	7.2 ppb
Messalonskee Middle School	Room 320 - Sink C	8 ppb
Messalonskee Middle School	Room 320 - Sink D	17.8 ppb
Messalonskee Middle School	Room 320 Closet - Sink E	1.9 ppb

School Name	Sample Location	Lead Test Result
Messalonskee Middle School	Room 333- Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 333- Sink A	3.4 ppb
Messalonskee Middle School	Room 335 - Sink B	3.5 ppb
Messalonskee Middle School	Room 335 - Sink C	2.8 ppb
Messalonskee Middle School	Room 335 - Sink D	2.2 ppb
Messalonskee Middle School	Room 335 - Sink E	2.9 ppb
Messalonskee Middle School	Room 335 Closet - Sink F	10.9 ppb
Messalonskee Middle School	Room 336 - Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 336 - Sink	4 ppb
Messalonskee Middle School	Room 338 - Dwf/sink Combo	0 ppb
Messalonskee Middle School	Room 338 - Sink	5 ppb
Messalonskee Middle School	Room 403 Pe Teacher Office - Sink	4 ppb
Messalonskee Middle School	Room 453 Health - Sink A	3 ppb
Messalonskee Middle School	Room 453 Health - Sink B	0 ppb
Messalonskee Middle School	Room 455 Art - Sink A	1.7 ppb
Messalonskee Middle School	Room 455 Art - Sink B	2.9 ppb
Messalonskee Middle School	Room 455 Art - Sink C	2.7 ppb
Messalonskee Middle School	Room 455 Art - Sink D	4 ppb
Messalonskee Middle School	Room 463 Art - Sink A	5.3 ppb
Messalonskee Middle School	Room 463 Art - Sink B	3.1 ppb
Messalonskee Middle School	Room 463 Art - Sink C	2.4 ppb
Messalonskee Middle School	Room 463 Art - Sink D	7.4 ppb
Messalonskee Middle School	Room 465 - Sink	4.3 ppb
Messalonskee Middle School	Staff Lounge - Water Cooler (hot/cold)	0 ppb
Messalonskee Middle School	Staff Lounge 200 - Bthrm Sink	2.4 ppb
Messalonskee Middle School	Staff Lounge 200 - Sink	1.1 ppb
Messalonskee Middle School	Staff Lounge Caft Hall - Sink	0 ppb
Messalonskee Middle School	Staff Room A 412 - Sink	1.3 ppb
Messalonskee Middle School	Ua Wing - Bottle Fill	0 ppb
Messalonskee Middle School	Ua Wing - Dwf	0 ppb
Messalonskee Middle School	Ua Wing - Dwf Stand Alone	0 ppb
Mid-Coast Sch of Tech-Region 8	3 Bay Sink Kitchen 108	0 ppb
Mid-Coast Sch of Tech-Region 8	Coffee Maker 223	18.1 ppb
Mid-Coast Sch of Tech-Region 8	Espresso Machine 223	6.6 ppb
Mid-Coast Sch of Tech-Region 8	Ice Machine Kitchen 223	0 ppb
Mid-Coast Sch of Tech-Region 8	Ice Machine Kitchen Storage 109	0 ppb
Mid-Coast Sch of Tech-Region 8	Kitchen Kettle 223	1.5 ppb
Mid-Coast Sch of Tech-Region 8	Nurse Sink 211	3.6 ppb
Mid-Coast Sch of Tech-Region 8	Prep Sink Kitchen 108	0 ppb
Mid-Coast Sch of Tech-Region 8	Sink Food Prep 222	0 ppb
Mid-Coast Sch of Tech-Region 8	Sink Food Prep 223	0 ppb
Mid-Coast Sch of Tech-Region 8	Sink Rm 201	0 ppb
Mid-Coast Sch of Tech-Region 8	Sink Rm 206	1.5 ppb
Mid-Coast Sch of Tech-Region 8	Sink Rm 212 Pathways	0 ppb
Mid-Coast Sch of Tech-Region 8	Sink Staff Rm 230	0 ppb
Mid-Coast Sch of Tech-Region 8	Water Bottle Fill Outside Rm 150	0 ppb
Mid-Coast Sch of Tech-Region 8	Water Bottle Fill Outside Rm 159	0 ppb

School Name	Sample Location	Lead Test Result
Mid-Coast Sch of Tech-Region 8	Water Bottle Fill Outside Rm 240	0 ppb
Mid-Coast Sch of Tech-Region 8	Water Bottle Fill Rm 110	0 ppb
Mid-Coast Sch of Tech-Region 8	Water Bottle Fill Rm 227	0 ppb
Middle School of the Kennebunks	502 #1	0 ppb
Middle School of the Kennebunks	503 #1	0 ppb
Middle School of the Kennebunks	503 #2	0 ppb
Middle School of the Kennebunks	503 #3	0 ppb
Middle School of the Kennebunks	503 #4	0 ppb
Middle School of the Kennebunks	503 #5	0 ppb
Middle School of the Kennebunks	504 #1	3.5 ppb
Middle School of the Kennebunks	504 #2	3.8 ppb
Middle School of the Kennebunks	504 #3	0 ppb
Middle School of the Kennebunks	504 #4	0 ppb
Middle School of the Kennebunks	504 #5	0 ppb
Middle School of the Kennebunks	505 #1	0 ppb
Middle School of the Kennebunks	506 #1	1.1 ppb
Middle School of the Kennebunks	506 #2	1.6 ppb
Middle School of the Kennebunks	609 #1	1.5 ppb
Middle School of the Kennebunks	609 #2	0 ppb
Middle School of the Kennebunks	6th Grade Bottle Filler By Staff Room	0 ppb
Middle School of the Kennebunks	709 #1	0 ppb
Middle School of the Kennebunks	709 #2	0 ppb
Middle School of the Kennebunks	709 #3	0 ppb
Middle School of the Kennebunks	7th Grade Bottle Filler	0 ppb
Middle School of the Kennebunks	810 #1	0 ppb
Middle School of the Kennebunks	810 #2	0 ppb
Middle School of the Kennebunks	812 #1	0 ppb
Middle School of the Kennebunks	812 #2	0 ppb
Middle School of the Kennebunks	Gym Bottle Filler	0 ppb
Middle School of the Kennebunks	Kitchen Basin Sink Enter The Kitchen	2.6 ppb
Middle School of the Kennebunks	Kitchen Sink By Dishwasher	32 ppb
Middle School of the Kennebunks	Kitchen Sink By Oven	0 ppb
Middle School of the Kennebunks	Kitchen Sink Prep Area	1.2 ppb
Middle School of the Kennebunks	Nurse Office	0 ppb
Middle School of the Kennebunks	Rm 501	0 ppb
Middle School of the Kennebunks	Teacher Break Room By Prep Area	0 ppb
Mid-Maine Technical Center	161 Hydro Station	0 ppb
Mid-Maine Technical Center	161 Sink 1	2 ppb
Mid-Maine Technical Center	161 Sink 2	3 ppb
Mid-Maine Technical Center	163 Hydro Station	0 ppb
Mid-Maine Technical Center	163 Sink 1	0 ppb
Mid-Maine Technical Center	163 Sink 2	0 ppb
Mid-Maine Technical Center	163 Sink 3	0 ppb
Mid-Maine Technical Center	164 Hydro System	0 ppb
Mid-Maine Technical Center	164 Sink 1	1 ppb
Mid-Maine Technical Center	164 Sink 2	2 ppb
Mid-Maine Technical Center	164 Sink 3	5 ppb

School Name	Sample Location	Lead Test Result
Mid-Maine Technical Center	166 Sink	0 ppb
Mid-Maine Technical Center	167 Hydro System	0 ppb
Mid-Maine Technical Center	167 Sink 1	6 ppb
Mid-Maine Technical Center	167 Sink 2	1 ppb
Mid-Maine Technical Center	167 Sink 3	0 ppb
Mid-Maine Technical Center	167 Sink 4	0 ppb
Mid-Maine Technical Center	167 Sink 5	0 ppb
Mid-Maine Technical Center	168 Hydro System	0 ppb
Mid-Maine Technical Center	168 Sink 1	2 ppb
Mid-Maine Technical Center	168 Sink 2	1 ppb
Mid-Maine Technical Center	168 Sink 3	4 ppb
Mid-Maine Technical Center	171 Hydro Station	0 ppb
Mid-Maine Technical Center	172 Hydro Station	0 ppb
Mid-Maine Technical Center	172 Sink	0 ppb
Mid-Maine Technical Center	173 Hydro Station	0 ppb
Mid-Maine Technical Center	173 Sink 1	0 ppb
Mid-Maine Technical Center	173 Sink 2	0 ppb
Mid-Maine Technical Center	174 Hydro Station	0 ppb
Mid-Maine Technical Center	174 Sink	0 ppb
Mid-Maine Technical Center	175 Hydro Station	0 ppb
Mid-Maine Technical Center	175 Sink 1	0 ppb
Mid-Maine Technical Center	175 Sink 2	0 ppb
Mid-Maine Technical Center	175 Sink 3	0 ppb
Mid-Maine Technical Center	176 Hydro Station	0 ppb
Mid-Maine Technical Center	176 Sink 1	4 ppb
Mid-Maine Technical Center	176 Sink 2	6 ppb
Mid-Maine Technical Center	176 Sink 3	1 ppb
Mid-Maine Technical Center	177 Sink 1	0 ppb
Mid-Maine Technical Center	177 Sink 2	0 ppb
Mid-Maine Technical Center	177 Sink 3	3 ppb
Mid-Maine Technical Center	178 Hydro Station	0 ppb
Mid-Maine Technical Center	178 Sink	0 ppb
Mid-Maine Technical Center	179 Sink 1	1 ppb
Mid-Maine Technical Center	179 Sink 2	0 ppb
Mid-Maine Technical Center	179 Sink 3	0 ppb
Mid-Maine Technical Center	179 Sink 4	0 ppb
Mid-Maine Technical Center	179 Sink 5	0 ppb
Mid-Maine Technical Center	179 Sink 6	0 ppb
Mid-Maine Technical Center	179 Sink 7	1 ppb
Mid-Maine Technical Center	180 Hydro Station	0 ppb
Mid-Maine Technical Center	180 Sink	21 ppb
Mid-Maine Technical Center	21 Sink 1	0 ppb
Mid-Maine Technical Center	21 Sink 2	0 ppb
Mid-Maine Technical Center	21 Sink 3	1 ppb
Mid-Maine Technical Center	21 Sink 4	1 ppb
Mid-Maine Technical Center	21 Sink 5	0 ppb
Mid-Maine Technical Center	22 Hydro Station	0 ppb

School Name	Sample Location	Lead Test Result
Mid-Maine Technical Center	22 Sink 1	2 ppb
Mid-Maine Technical Center	22 Sink 2	0 ppb
Mid-Maine Technical Center	22 Sink 3	0 ppb
Mid-Maine Technical Center	22 Sink 4	0 ppb
Mid-Maine Technical Center	22 Sink 5	0 ppb
Mid-Maine Technical Center	Hallway Closet	4 ppb
Mid-Maine Technical Center	Mens Room Sink Hallway	2 ppb
Mid-Maine Technical Center	Staff Room Hydro Station	0 ppb
Mid-Maine Technical Center	Staff Room Sink	0 ppb
Mid-Maine Technical Center	Womens Room Sink Hallway	6 ppb
Milbridge Elementary School	Gym Drinking Water Fountain	0 ppb
Milbridge Elementary School	Kitchen 3 Bay Sink	1.5 ppb
Milbridge Elementary School	West Wing 1 Drinking Water Fountain	0 ppb
Milbridge Elementary School	West Wing 2 Drinking Water Fountain	0 ppb
Mildred L Day School	Bottle Fill Station Gang Bathroom	0 ppb
Mildred L Day School	Rm 123	0 ppb
Mildred L Day School	Rm 126	0 ppb
Mildred L Day School	Rm 129	0 ppb
Mildred L Day School	Rm 134	0 ppb
Mildred L Day School	Rm 147	0 ppb
Mildred L Day School	Rm 155	0 ppb
Mildred L Day School	Rm120	0 ppb
Mildred L Day School	Sink Rm 105	0 ppb
Miles Lane School	East Fountain	0 ppb
Miles Lane School	Gym Lockers Mens	1.5 ppb
Miles Lane School	Gym Lockers Womens	0 ppb
Miles Lane School	Kitchen	4.8 ppb
Miles Lane School	Kitchen Kettle	8.7 ppb
Miles Lane School	Kitchen Vat	17.8 ppb
Miles Lane School	Media Center / Library	0 ppb
Miles Lane School	Rm. 119 W2	1.3 ppb
Miles Lane School	Rm. 123 W2	1 ppb
Miles Lane School	Rm. 127 W2	1.3 ppb
Miles Lane School	Rm. 130 W2	0 ppb
Miles Lane School	Rm. 134 W2	3.7 ppb
Miles Lane School	Rm. 138 W2 #1	6.7 ppb
Miles Lane School	Rm. 138 W2 #2	5.5 ppb
Miles Lane School	Rm. 146 W2	0 ppb
Miles Lane School	Rm. 150 W2	1.3 ppb
Miles Lane School	Rm. 154 W2	1.1 ppb
Miles Lane School	Rm. 157 W2	0 ppb
Miles Lane School	Rm. 166 W1	1.1 ppb
Miles Lane School	Rm. 169 W1	0 ppb
Miles Lane School	Rm. 174 W1	0 ppb
Miles Lane School	Rm. 180 W1	0 ppb
Miles Lane School	Rm. 182 W1	1.2 ppb
Miles Lane School	Rm. 194 W1	1.4 ppb

School Name	Sample Location	Lead Test Result
Miles Lane School	Rm. 197 W1	1.2 ppb
Miles Lane School	Rm. 202 W1	0 ppb
Miles Lane School	Rm. 204 W1	1.1 ppb
Miles Lane School	Rm. 207 W1	0 ppb
Miles Lane School	West Fountain	0 ppb
Mill Pond School	3bay Sink Kitchen Left Side 1	9.5 ppb
Mill Pond School	Art Room Sink Room 16	4.2 ppb
Mill Pond School	Bottle Fill Station Across From Rm 16	0 ppb
Mill Pond School	Bottle Fill Station Across From Rm 25	0 ppb
Mill Pond School	Bottle Fill Station Across From Rm 7	0 ppb
Mill Pond School	Bottle Fill Station Across From Speech Rm	0 ppb
Mill Pond School	Bottle Fill Station Beside Rm 11	0 ppb
Mill Pond School	Bottle Fill Station Main Hallway	0 ppb
Mill Pond School	Handwash Sink Boys Locker Room	2.6 ppb
Mill Pond School	Handwash Sink Copier Room	6.9 ppb
Mill Pond School	Handwash Sink Girls Locker Room	2.5 ppb
Mill Pond School	Handwash Sink Nurses Office	7.6 ppb
Mill Pond School	Handwash Sink Room 12	1.1 ppb
Mill Pond School	Handwash Sink Room 13	1.9 ppb
Mill Pond School	Handwash Sink Room 14	3.4 ppb
Mill Pond School	Handwash Sink Room 15	4 ppb
Mill Pond School	Handwash Sink Room 3	0 ppb
Mill Pond School	Handwash Sink Room 4	1.8 ppb
Mill Pond School	Handwash Sink Room 5	0 ppb
Mill Pond School	Handwash Sink Room 6	1.3 ppb
Mill Pond School	K1 Handwash Sink	4.1 ppb
Mill Pond School	K2 Handwash Sink	3.7 ppb
Mill Pond School	Kettle Filler Faucet	4.2 ppb
Mill Pond School	Kitchen Sink Teachers Room	4.3 ppb
Mill Pond School	Lab Table Faucet	10.7 ppb
Mill Pond School	Middle Bay 2	6.5 ppb
Mill Pond School	Pre K Sink Room 17	2.8 ppb
Mill Pond School	Right Bay 3	3.2 ppb
Mill Pond School	Sink Bus Room	4.7 ppb
Mill Pond School	Sink Vegetable Table	4.3 ppb
Mill Stream Elementary School	Alternative Room 2nd Sink From Right	1.7 ppb
Mill Stream Elementary School	Alternative Room 3rd Sink From Right	1.5 ppb
Mill Stream Elementary School	Alternative Room Eye Wash Station	3.9 ppb
Mill Stream Elementary School	Alternative Room Sink On Right	1.6 ppb
Mill Stream Elementary School	Belanger Room Sink	0 ppb
Mill Stream Elementary School	Bottle Fill Across Orange Lockers	0 ppb
Mill Stream Elementary School	Boys Lobby Restroom Sink 2nd From Left	1.4 ppb
Mill Stream Elementary School	Boys Lobby Restroom Sink 3rd From Left	1.7 ppb
Mill Stream Elementary School	Boys Lobby Restroom Sink Far Left	1.4 ppb
Mill Stream Elementary School	Boys Restroom Across From Green Lockers	2.1 ppb
Mill Stream Elementary School	Cafeteria Bottle Fill Station	0 ppb
Mill Stream Elementary School	Cafeteria Left Sink	1.9 ppb

School Name	Sample Location	Lead Test Result
Mill Stream Elementary School	Crowleys Room Sink	1.2 ppb
Mill Stream Elementary School	Custodian Closet 2nd Floor Eye Wash	57.9 ppb
Mill Stream Elementary School	Custodian Closet 2nd Floor Sink On Left	5.2 ppb
Mill Stream Elementary School	Custodian Closet 2nd Floor Sink On Right	30.2 ppb
Mill Stream Elementary School	Custodian Closet By Kitchen	3.6 ppb
Mill Stream Elementary School	Custodian Closet Sink On Left	66.8 ppb
Mill Stream Elementary School	Custodian Closet Sink On Right	1.2 ppb
Mill Stream Elementary School	Dorrs Room Sink	2.1 ppb
Mill Stream Elementary School	Fisette Restroom Sink	1.6 ppb
Mill Stream Elementary School	Girls Lobby Restroom Sink 2nd From Right	1.7 ppb
Mill Stream Elementary School	Girls Lobby Restroom Sink 3rd From Right	1.3 ppb
Mill Stream Elementary School	Girls Lobby Restroom Sink Far Right	1.5 ppb
Mill Stream Elementary School	Girls Restroom Across From Green Locker	2.6 ppb
Mill Stream Elementary School	Grays Room	2.3 ppb
Mill Stream Elementary School	Hall By 201 Bottle Fill On Left	8.6 ppb
Mill Stream Elementary School	Hall By Elevator Bottle Fill Station	0 ppb
Mill Stream Elementary School	Kitchen 2nd Right Sink	4.9 ppb
Mill Stream Elementary School	Kitchen 4th Right Sink	3.9 ppb
Mill Stream Elementary School	Kitchen 5th Right Sink	1.9 ppb
Mill Stream Elementary School	Kitchen 6th Right Sink	1.4 ppb
Mill Stream Elementary School	Kitchen 7th Right Sink	1.1 ppb
Mill Stream Elementary School	Kitchen Dishwasher	5.2 ppb
Mill Stream Elementary School	Kitchen Near Right Sink	2.4 ppb
Mill Stream Elementary School	Kitchen Restroom Sink	1.4 ppb
Mill Stream Elementary School	Kitchen Steamer	12.8 ppb
Mill Stream Elementary School	Leeman Room Fountain	1.5 ppb
Mill Stream Elementary School	Leonard Restroom Sink	1.7 ppb
Mill Stream Elementary School	Mcbreairty Restroom	1.2 ppb
Mill Stream Elementary School	Music Room Fountain	6.7 ppb
Mill Stream Elementary School	Music Room Sink	1.9 ppb
Mill Stream Elementary School	Nurse Station Sink	6.6 ppb
Mill Stream Elementary School	Office Sink	2.9 ppb
Mill Stream Elementary School	Ot/pt	3.1 ppb
Mill Stream Elementary School	Outdoor Spicket 1st On Right Main Door	4 ppb
Mill Stream Elementary School	Outdoor Spicket 2nd On Right Main Door	16.4 ppb
Mill Stream Elementary School	Outdoor Spicket 3rd On Right Main Door	32.4 ppb
Mill Stream Elementary School	Outdoor Spicket 4th On Right Main Door	10.1 ppb
Mill Stream Elementary School	Outdoor Spicket 5th On Right Main Door	4.8 ppb
Mill Stream Elementary School	Project Room Eye Wash Station	10 ppb
Mill Stream Elementary School	Project Room Sink 2nd From Right	5.7 ppb
Mill Stream Elementary School	Project Room Sink 3rd Fron Right	3.3 ppb
Mill Stream Elementary School	Project Room Sink 4th From Right	1.6 ppb
Mill Stream Elementary School	Project Room Sink On Right	2 ppb
Mill Stream Elementary School	Resource Room 1 Fountain	1 ppb
Mill Stream Elementary School	Resource Room 1 Sink	3 ppb
Mill Stream Elementary School	Resource Room 2 Fountain	8.3 ppb
Mill Stream Elementary School	Resource Room 2 Sink	3.8 ppb

School Name	Sample Location	Lead Test Result
Mill Stream Elementary School	Resource Room 3 Sink 2nd From Right	2.6 ppb
Mill Stream Elementary School	Resource Room 3 Sink 3rd From Right	6 ppb
Mill Stream Elementary School	Rest Room By Sped	1.5 ppb
Mill Stream Elementary School	Room 101 Fountain	2 ppb
Mill Stream Elementary School	Room 101 Restroom Sink	1.5 ppb
Mill Stream Elementary School	Room 101 Sink	3.1 ppb
Mill Stream Elementary School	Room 102 Fountain	1.9 ppb
Mill Stream Elementary School	Room 102 Restroom Sink	1.8 ppb
Mill Stream Elementary School	Room 102 Sink	2.8 ppb
Mill Stream Elementary School	Room 103 Fountain	2.5 ppb
Mill Stream Elementary School	Room 103 Restroom Sink	1.5 ppb
Mill Stream Elementary School	Room 103 Sink	1.9 ppb
Mill Stream Elementary School	Room 104 Fountain	3.4 ppb
Mill Stream Elementary School	Room 104 Restroom Sink	1.7 ppb
Mill Stream Elementary School	Room 104 Sink	5.9 ppb
Mill Stream Elementary School	Room 105 Fountain	3.3 ppb
Mill Stream Elementary School	Room 105 Restroom Sink	1.2 ppb
Mill Stream Elementary School	Room 105 Sink	2.5 ppb
Mill Stream Elementary School	Room 106 Fountain	4.3 ppb
Mill Stream Elementary School	Room 106 Restroom Sink	1.8 ppb
Mill Stream Elementary School	Room 106 Sink	2.9 ppb
Mill Stream Elementary School	Room 107 Fountain	3.3 ppb
Mill Stream Elementary School	Room 107 Restroom Sink	1.5 ppb
Mill Stream Elementary School	Room 107 Sink	3.4 ppb
Mill Stream Elementary School	Room 108 Fountain	4.4 ppb
Mill Stream Elementary School	Room 108 Restroom Sink	1.4 ppb
Mill Stream Elementary School	Room 108 Sink	1.5 ppb
Mill Stream Elementary School	Room 109 Fountain	10 ppb
Mill Stream Elementary School	Room 109 Restroom Sink	1.1 ppb
Mill Stream Elementary School	Room 109 Sink	3 ppb
Mill Stream Elementary School	Room 110 Fountain	3.7 ppb
Mill Stream Elementary School	Room 110 Restroom Sink	1.4 ppb
Mill Stream Elementary School	Room 110 Sink	3.5 ppb
Mill Stream Elementary School	Room 111 Fountain	3 ppb
Mill Stream Elementary School	Room 111 Restroom Sink	1.4 ppb
Mill Stream Elementary School	Room 111 Sink	3.4 ppb
Mill Stream Elementary School	Room 201 Fountain	2.3 ppb
Mill Stream Elementary School	Room 201 Restroom Sink	1.9 ppb
Mill Stream Elementary School	Room 201 Sink	1.3 ppb
Mill Stream Elementary School	Room 202 Fountain	7.6 ppb
Mill Stream Elementary School	Room 202 Sink	3.3 ppb
Mill Stream Elementary School	Room 203 Fountain	12.7 ppb
Mill Stream Elementary School	Room 203 Sink	2.8 ppb
Mill Stream Elementary School	Room 204 Fountain	5.1 ppb
Mill Stream Elementary School	Room 204 Sink	2.7 ppb
Mill Stream Elementary School	Room 205 Sink	3.2 ppb
Mill Stream Elementary School	Room 206 Fountain	2.4 ppb

School Name	Sample Location	Lead Test Result
Mill Stream Elementary School	Room 206 Sink	3.2 ppb
Mill Stream Elementary School	Room 207 Fountain	4.7 ppb
Mill Stream Elementary School	Room 207 Sink	2.8 ppb
Mill Stream Elementary School	Room 208 Fountain	4.1 ppb
Mill Stream Elementary School	Room 208 Sink	3 ppb
Mill Stream Elementary School	Room 209 Fountain	11.1 ppb
Mill Stream Elementary School	Room 209 Sink	2.2 ppb
Mill Stream Elementary School	Room 210 Fountain	1.2 ppb
Mill Stream Elementary School	Room 210 Sink	2.2 ppb
Mill Stream Elementary School	Room 211 Fountain	3.5 ppb
Mill Stream Elementary School	Room 211 Sink	3.3 ppb
Mill Stream Elementary School	Room 212 Fountain	7.1 ppb
Mill Stream Elementary School	Room 212 Sink	10.8 ppb
Mill Stream Elementary School	Staff Restroom 1	1.3 ppb
Mill Stream Elementary School	Staff Restroom 2	1.7 ppb
Mill Stream Elementary School	Staff Restroom 2nd Floor	3.1 ppb
Mill Stream Elementary School	Staff Room	1.6 ppb
Mill Stream Elementary School	Transistion Room By Shower	1.9 ppb
Mill Stream Elementary School	Transistion Room Sink Left	2 ppb
Mill Stream Elementary School	Transistion Room Sink Right	1.1 ppb
Mill Stream Elementary School	York Room	1.7 ppb
Miller School	3rd & 4th Wing 1 Sink	0 ppb
Miller School	5th & 6th Grade Boys Single Bathroom Sink	0 ppb
Miller School	5th & 6th Grade Girls2 Sinks	2.5 ppb
Miller School	Art Rm #1 1 Fountain & Sink Combo Non Drink	2 ppb
Miller School	Art Rm #35 4 Sinks	0 ppb
Miller School	Boiler Room Water Source	0 ppb
Miller School	Boys Bathroom Locker Room 2 Sinks	0 ppb
Miller School	Boys Bathroom Office Wing 2 Sinks	1.6 ppb
Miller School	Classroms 9-15 Sink & Fountain	0 ppb
Miller School	Custodial Closet Sink	0 ppb
Miller School	Exit C Closet Sink	2.1 ppb
Miller School	Exit C Rm Sink	1.1 ppb
Miller School	Filling Station Pre K - Broken	0 ppb
Miller School	Girls Bathroom Locker Room 2 Sinks	10.5 ppb
Miller School	Girls Bathroom Office Wing 2 Sinks	4.4 ppb
Miller School	Gym Drinking Fountain Next To Elevator	4.3 ppb
Miller School	Gym Teacher Bathroom 1 Sink	1.8 ppb
Miller School	Kitchen 3 Bay Sink	3.2 ppb
Miller School	Kitchen Dish Sink	13.1 ppb
Miller School	Kitchen Fruit Sink	0 ppb
Miller School	Kitchen Handwash Sink	1.9 ppb
Miller School	L39 1 Sink	0 ppb
Miller School	Nurse Office Dual Sink	0 ppb
Miller School	Nurses Office Single Bathroom	0 ppb
Miller School	Pre K Bath Sink	1.1 ppb

School Name	Sample Location	Lead Test Result
Miller School	Primary Wing Boys Bathroom 2 Sinks	1.6 ppb
Miller School	Primary Wing Fill Station	0 ppb
Miller School	Primary Wing Girls Bathroom 2 Sinks	1 ppb
Miller School	Primary Wing Staff Bathroom Sink	1.9 ppb
Miller School	Rm #18 Sink 1 With Fountain	0 ppb
Miller School	Rm #20 Dual Sink & Fountain	0 ppb
Miller School	Rm #23 Sink & Fountain	2.5 ppb
Miller School	Rm #24 Sink	4.9 ppb
Miller School	Rm #27 Sink & Fountain Combo	0 ppb
Miller School	Rm #28 Dual Sink	0 ppb
Miller School	Room #29 Bathroom 1 Sink	1.1 ppb
Miller School	Rooms 34-29 Sink/fountain Combo Non Drink	1.5 ppb
Miller School	Rose Office Sink	0 ppb
Miller School	Staff Bath 3rd & 4th Wing 1 Sink	0 ppb
Miller School	Staff Breakroom - Bathroom Sink	0 ppb
Miller School	Staff Breakroom - Sink/faucet	0 ppb
Milo Elementary School	Corridor Across From Mrs. Moeller's Rm	0 ppb
Milo Elementary School	Corridor Between Bathrooms	0 ppb
Milo Elementary School	Kitchen	22.4 ppb
Milo Elementary School	Lobby Entry	1.1 ppb
Milo Elementary School	Miss Amys Classroom	2.1 ppb
Milo Elementary School	Mr Perkins Classroom	3.8 ppb
Milo Elementary School	Mrs Chadwicks Classroom	2.6 ppb
Milo Elementary School	Mrs Guthries Classroom	1.8 ppb
Milo Elementary School	Mrs Howards Classroom	3.8 ppb
Milo Elementary School	Mrs Mcewens Classroom	3.7 ppb
Milo Elementary School	Mrs Moellers Classroom	2.4 ppb
Milo Elementary School	Mrs Moreys Classroom	75.6 ppb
Milo Elementary School	Mrs Notts Classroom	6.6 ppb
Milo Elementary School	Room 17	14.6 ppb
Milo Elementary School	Special Needs Room	136 ppb
Milo Elementary School	Teachers Breakroom Dwf	32.8 ppb
Milo Elementary School	Teachers Breakroom Kf	8.1 ppb
Minot Consolidated School	Adult Restroom Sink	0 ppb
Minot Consolidated School	Adult Restroom Sink (by Teachers Lounge)	0 ppb
Minot Consolidated School	Applied Academics Sink	0 ppb
Minot Consolidated School	Art Room Sink 1 (left)	0 ppb
Minot Consolidated School	Art Room Sink 2 (right)	0 ppb
Minot Consolidated School	Boy's Restroom (by Gym) Sink 1	2.6 ppb
Minot Consolidated School	Boy's Restroom (by Gym) Sink 2	0 ppb
Minot Consolidated School	Boy's Restroom (5-6) Sink 3	0 ppb
Minot Consolidated School	Boy's Restroom (by Gym) Sink 1	0 ppb
Minot Consolidated School	Boy's Restroom (by Gym) Sink 2	2.4 ppb
Minot Consolidated School	Boy's Restroom (by Gym) Sink 3	14.6 ppb
Minot Consolidated School	Boy's Restroom (by Nurse) Sink 1	1.2 ppb
Minot Consolidated School	Boy's Restroom (by Nurse) Sink 2	1.7 ppb

School Name	Sample Location	Lead Test Result
Minot Consolidated School	Entrance Water Fountain	0 ppb
Minot Consolidated School	Girl's Restroom (5-6) Sink 1	0 ppb
Minot Consolidated School	Girl's Restroom (5-6) Sink 2	0 ppb
Minot Consolidated School	Girl's Restroom (5-6) Sink 3	0 ppb
Minot Consolidated School	Girl's Restroom (by Gym) Sink 1	12.9 ppb
Minot Consolidated School	Girl's Restroom (by Gym) Sink 2	4.3 ppb
Minot Consolidated School	Girl's Restroom (by Gym) Sink 3	1.5 ppb
Minot Consolidated School	Girl's Restroom (by Nurse) Sink 1	4.2 ppb
Minot Consolidated School	Girl's Restroom (by Nurse) Sink 2	2.6 ppb
Minot Consolidated School	Girl's Shower (by Nurse)	702 ppb
Minot Consolidated School	Kindergarden Sink	0 ppb
Minot Consolidated School	Kitchen Hand Sink	13.9 ppb
Minot Consolidated School	Kitchen Pot Sink (by Stove)	5.4 ppb
Minot Consolidated School	Kitchen Wash Sink Left	2.5 ppb
Minot Consolidated School	Kitchen Wash Sink Right	2 ppb
Minot Consolidated School	Mop Sink Faucet (custodian Room)	0 ppb
Minot Consolidated School	Nurse's Sink 1	0 ppb
Minot Consolidated School	Nurse's Sink 2 (in Back Room)	3.7 ppb
Minot Consolidated School	Outside Hose Bib (by Garden)	0 ppb
Minot Consolidated School	Pre-k Sink	0 ppb
Minot Consolidated School	Teacher's Lounge Sink	0 ppb
Minot Consolidated School	Water Fountain (by Nurse)	0 ppb
Minot Consolidated School	Water Fountain W/ Bottle Filler (5-6)	0 ppb
Minot Consolidated School	Water Fountain W/bottle Filler (by Nurse)	0 ppb
MMCFC - Charles	Kf #1	0 ppb
MMCFC - Charles	Kf #2	1 ppb
MMCFC - Hotel	Handwashing Station	0 ppb
MMCFC - Hotel	Kitchen Sink	0 ppb
MMCFC - Main	Base Student Bathroom Sink	0 ppb
MMCFC - Main	Basement Staff Bathroom Sink	0 ppb
MMCFC - Main	Basement Water Cooler (glenrock)	0 ppb
MMCFC - Main	Main Floor Kitchen Sink	0 ppb
MMCFC - Main	Main Floor Staff Bathroom Sink	0 ppb
MMCFC - Main	Main Floor Student Bathroom Sink	0 ppb
MMCFC - Main	Main Floor Water Cooler (glenrock)	0 ppb
MMCFC - Main	Outdoor Hose Back Parking Lot Cold Water	58 ppb
MMCFC - Main	Outdoor Hose Back Parking Lot Hot Water	13.1 ppb
MMCFC - Main	Outdoor Hose Front Of Building By Garden	325 ppb
MMCFC - Main	Outdoor Hose Front Of Building By Ramp	252 ppb
MMCFC - Main	Outdoor Hose Garden Area By Gym	14.3 ppb
MMCFC - Main	Upstairs Staff Bathroom Sink	6.7 ppb
MMCFC - Memorial Ave	Big Kitchen Faucet	0 ppb
MMCFC - Memorial Ave	Boy's Stall Bathroom Faucet	0 ppb
MMCFC - Memorial Ave	Girl's Stall Bathroom Faucet	0 ppb
MMCFC - Memorial Ave	Little Kitchen Faucet	0 ppb
MMCFC - Memorial Ave	Nurse Faucet	0 ppb
MMCFC - Memorial Ave	Pod 2 Drinking Fountain	0 ppb

School Name	Sample Location	Lead Test Result
MMCFC - Memorial Ave	Pod 6 Drinking Fountain	0 ppb
MMCFC - Rodman	lpk Classroom	0 ppb
MMCFC - Rodman	Jungle Kitchen	0 ppb
MMCFC - Rodman	Nurse's Office	0 ppb
MMCFC - Rodman	Yellow Kitchen	0 ppb
MMCFC - Saco	Back Kitchen- Single Basin Sink	0 ppb
MMCFC - Saco	Main Kitchen- Double Basin Sink	0 ppb
MMCFC - Saco	Main Kitchen- Single Basin Sink	0 ppb
MMCFC - Saco	Staff Kitchen- Single Basin Sink	0 ppb
MMCFC - School St	Conference Room Water Fountain	0 ppb
MMCFC - School St	Cr2 Fountain/sink	2.4 ppb
MMCFC - School St	Cr3 Fountain/sink	0 ppb
MMCFC - School St	Downstairs Water Fountain	0 ppb
MMCFC - School St	Front Kitchen	1.2 ppb
MMCFC - School St	Girls Bathroom Water Fountain	0 ppb
MMCFC - School St	Nurses Station	1.1 ppb
MMCFC - School St	Staff Kitchen	1 ppb
Molly Ockett School	5th 6th Garde Fountain	0 ppb
Molly Ockett School	5th/6th Grade Bath Bottler Filler Fountai	0 ppb
Molly Ockett School	7th 8th Grade B/g Fountain	0 ppb
Molly Ockett School	C10 Hand Wash Sink Bubbler	0 ppb
Molly Ockett School	C33 Handwash Bubbler	0 ppb
Molly Ockett School	C4 Main Office Back Hall	0 ppb
Molly Ockett School	C4l Nurses Offcie By Entrance	0 ppb
Molly Ockett School	C4n Clinic Station To Left	0 ppb
Molly Ockett School	C5 Library Far Back Wall	1.4 ppb
Molly Ockett School	C6 Staff Breakroom Sink	0 ppb
Molly Ockett School	C8hand Wash Sink Bubbler To Left	0 ppb
Molly Ockett School	C9 Hand Wash Sink Buller Right	0 ppb
Molly Ockett School	Cafeteria Kitchen 3 Sink 1 To Far Left	0 ppb
Molly Ockett School	Cafeteria Kitchen Kettle	0 ppb
Molly Ockett School	Central Main Office D10 Staff Break	0 ppb
Molly Ockett School	Cross From Small Gym Bubbler Fountain	0 ppb
Molly Ockett School	Drink Water Fountain Bottler Filter Elem	0 ppb
Molly Ockett School	Drinkwater Fountain Bottler Main Lobby	0 ppb
Molly Ockett School	E10 Handwash Sink Bubbler	0 ppb
Molly Ockett School	E11 Handwash Sink Bubbler	0 ppb
Molly Ockett School	E12 Hand Wash Sink Bubbler	0 ppb
Molly Ockett School	E13 3 Handwash Sink With Bubbler	0 ppb
Molly Ockett School	E14 3 Hand Wash Sink Bubbler	0 ppb
Molly Ockett School	E15 Hand Wash Sink Bubbler	1.9 ppb
Molly Ockett School	E23 Hand Wash Sink Bubller	0 ppb
Molly Ockett School	E24 Handwash Sink Bubbler	0 ppb
Molly Ockett School	E25 Hand Wash Sink Bubbler	0 ppb
Molly Ockett School	E26 Handwash Sink Bubbler	0 ppb
Molly Ockett School	E27 Hand Wash Sink Bubbler	0 ppb
Molly Ockett School	E28 Hand Wash Sink Bubller	0 ppb

School Name	Sample Location	Lead Test Result
Molly Ockett School	E37 Hand Wash Sink Bubbler	0 ppb
Molly Ockett School	E7 Handwash Sink Bubbler	0 ppb
Molly Ockett School	E9 Handwash Sink Bubbler	0 ppb
Molly Ockett School	Essential Skill Kitchen Sink	0 ppb
Molly Ockett School	M12 Art Room Wash Sinks 1	0 ppb
Molly Ockett School	M12 Art Room Wash Sinks 2	1 ppb
Molly Ockett School	M12 Art Room Wash Sink 3	0 ppb
Molly Ockett School	M14 Bridge Program Wash Sink Bubbler	0 ppb
Molly Ockett School	M15 Wask Sink Left	0 ppb
Molly Ockett School	M2 Hand Wash Bubbler	2.8 ppb
Molly Ockett School	M22 Wash Sink Bubbler Left Of Door	0 ppb
Molly Ockett School	M23 Wash Sink Bubbler Right Of Door	3 ppb
Molly Ockett School	M24 Wash Sink Bubbler Left	0 ppb
Molly Ockett School	M25 Wash Sink Bubbler To Right Of Door	0 ppb
Molly Ockett School	M3 Tech Deptment	0 ppb
Molly Ockett School	M3 To The Right Behind Door	0 ppb
Molly Ockett School	M32 Wask Sink Bubbler To Left	0 ppb
Molly Ockett School	M37 8th Grade Science	2.9 ppb
Molly Ockett School	M43 7th Grade Sciene 1st Sink	12.2 ppb
Molly Ockett School	M43 7th Grade Sciene 2 Sink	14.9 ppb
Molly Ockett School	M43 7th Grade Sciene 3rd Sink	6.1 ppb
Molly Ockett School	M43 7th Grade Sciene 4th Sink	0 ppb
Molly Ockett School	M43 7th Grade Sciene 5th Sink	11.5 ppb
Molly Ockett School	M7 Mesa Foyer Kitchen	0 ppb
Molly Ockett School	Mesam7csceine 3 Sink To Left Back	0 ppb
Molly Ockett School	Outside Faucet Bridge	0 ppb
Molly Ockett School	Outside Faucet Elem Wing	0 ppb
Molly Ockett School	Outside Faucet Super	0 ppb
Molly Ockett School	Outside Mesa M7 Foutain Bottler Filler	0 ppb
Molly Ockett School	Super Bathroom 1 Sink	0 ppb
Molly Ockett School	Super Bathroom 2 Sink	0 ppb
Monhegan Island School	Has Water Brought In- No Water Is Served From Their Plumbing	
Monmouth Academy	1st Floor Conference Rm Sink 106	1.6 ppb
Monmouth Academy	1st Floor Gang Boys Rest Rm Sink Right	3.3 ppb
Monmouth Academy	1st Floor Gang Boys Rest Rm Sink Left	296 ppb
Monmouth Academy	1st Floor Gang Girls Rest Rm Sink Left	27.3 ppb
Monmouth Academy	1st Floor Gang Girls Rest Rm Sink Right	7.6 ppb
Monmouth Academy	1st Floor Nurse Sink	8 ppb
Monmouth Academy	1st Floor Water Fountain	0 ppb
Monmouth Academy	2nd Floor Drink Fountain- Hall	0 ppb
Monmouth Academy	2nd Floor Gang Rest Rm Boys Sink Left	3.4 ppb
Monmouth Academy	2nd Floor Gang Rest Rm Boys Sink Right	3.4 ppb
Monmouth Academy	2nd Floor Gang Rest Rm Girls Sink Left	3.4 ppb
Monmouth Academy	2nd Floor Gang Rest Rm Girls Sink Right	1.6 ppb
Monmouth Academy	2nd Floor Inner Wall Sink Front Rm201 A	7 ppb
Monmouth Academy	2nd Floor Rest Rm Staff Sink	1.6 ppb

School Name	Sample Location	Lead Test Result
Monmouth Academy	2nd Floor Rm 201 Front Desk Sink- Science Lab	1.6 ppb
Monmouth Academy	2nd Floor Rm 205 Front Desk Sink	3.8 ppb
Monmouth Academy	2nd Floor Rm 214 Sink	1.4 ppb
Monmouth Academy	Art Rm 01 Sink Back Wall	0 ppb
Monmouth Academy	Art Rm 01 Sink Outside Wall	1.9 ppb
Monmouth Academy	Athletic Trainers Rm Sink- Off Gym	0 ppb
Monmouth Academy	Back Wall Window Side Sink Rm 205	3.1 ppb
Monmouth Academy	Basement Conference Rm Kit Net Sink	5.4 ppb
Monmouth Academy	Basement Level Drinking Fountain	0 ppb
Monmouth Academy	Boy Trainers Rest Rm Sink- Boys Locker Rm	1.9 ppb
Monmouth Academy	Boys Locker Rm Sink Left	1.8 ppb
Monmouth Academy	Boys Locker Rm Sink Right	0 ppb
Monmouth Academy	Gang Rest Rm Boys Sink Left	0 ppb
Monmouth Academy	Gang Rest Rm Boys Sink Right	1.6 ppb
Monmouth Academy	Gang Rest Room Girls Sink Left	0 ppb
Monmouth Academy	Gang Rest Room Girls Sink Right	0 ppb
Monmouth Academy	Girls Locker Rm Sink Left	4.4 ppb
Monmouth Academy	Girls Locker Rm Sink Right	1.4 ppb
Monmouth Academy	Girls Trainers Rest Rm Sink-girls Locker Rm	3.1 ppb
Monmouth Academy	Gym Fountain	1.2 ppb
Monmouth Academy	Gym Teacher Rest Room Sink	0 ppb
Monmouth Academy	Haschs Rest Rm Sink	1.7 ppb
Monmouth Academy	Haschs Rm Sink- Special Ed Rm	3.3 ppb
Monmouth Academy	Inner Wall Back Side Sink Rm 205	9.1 ppb
Monmouth Academy	Inner Wall Front Sink Rm 205	11.8 ppb
Monmouth Academy	Inner Wall Middle Sink Rm 205	14.7 ppb
Monmouth Academy	Inner Wall Sink Rm 201 B	10.3 ppb
Monmouth Academy	Inner Wall Sink Rm 201 C	21.7 ppb
Monmouth Academy	Kitchen Far Left Sink	3.8 ppb
Monmouth Academy	Kitchen Far Right Sink	0 ppb
Monmouth Academy	Kitchen Middle Sink	1.2 ppb
Monmouth Academy	Nurse Rest Rm Sink	7.3 ppb
Monmouth Academy	Old Nurses Station Sink	8.7 ppb
Monmouth Academy	Rest Rm In Kitchen Sink	1 ppb
Monmouth Academy	Rm 216 Sink	22.2 ppb
Monmouth Academy	Window Side Sink Rm 205 A	0 ppb
Monmouth Academy	Window Side Sink Rm 205 B	0 ppb
Monmouth Academy	Window Side Sink Rm 205 C	26.8 ppb
Monmouth Academy	Window Side Sink Science Lab A	7.8 ppb
Monmouth Academy	Window Side Sink Science Lab B	10.4 ppb
Monmouth Academy	Window Side Sink Science Lab C	22.4 ppb
Monmouth Memorial School	A- Wing A005	0 ppb
Monmouth Memorial School	A- Wing A008	0 ppb
Monmouth Memorial School	A- Wing A009	0 ppb
Monmouth Memorial School	A- Wing A011	0 ppb
Monmouth Memorial School	A- Wing A012	0 ppb

School Name	Sample Location	Lead Test Result
Monmouth Memorial School	A- Wing A103 A	2.2 ppb
Monmouth Memorial School	A- Wing A103 B	0 ppb
Monmouth Memorial School	A- Wing A103 C	2.2 ppb
Monmouth Memorial School	A- Wing A109	0 ppb
Monmouth Memorial School	A- Wing A110	0 ppb
Monmouth Memorial School	A- Wing A111	0 ppb
Monmouth Memorial School	A- Wing A115 A	0 ppb
Monmouth Memorial School	A- Wing A116	0 ppb
Monmouth Memorial School	A- Wing A119	1.7 ppb
Monmouth Memorial School	A- Wing A202	0 ppb
Monmouth Memorial School	A- Wing A205	1.4 ppb
Monmouth Memorial School	A- Wing A206	0 ppb
Monmouth Memorial School	A- Wing A209	0 ppb
Monmouth Memorial School	A- Wing A211	0 ppb
Monmouth Memorial School	A- Wing A212	3.2 ppb
Monmouth Memorial School	A- Wing A217-a	1.5 ppb
Monmouth Memorial School	A- Wing A217-b	0 ppb
Monmouth Memorial School	A- Wing A217-c	0 ppb
Monmouth Memorial School	A- Wing A218-a	0 ppb
Monmouth Memorial School	A- Wing A218-b	0 ppb
Monmouth Memorial School	A- Wing A218-c	0 ppb
Monmouth Memorial School	A- Wing Lower Hallway Water Fountain	0 ppb
Monmouth Memorial School	A-wing A002	1.3 ppb
Monmouth Memorial School	A-wing A006	0 ppb
Monmouth Memorial School	A-wing A014	1.4 ppb
Monmouth Memorial School	A-wing A015	0 ppb
Monmouth Memorial School	A-wing A016	0 ppb
Monmouth Memorial School	A-wing A208	0 ppb
Monmouth Memorial School	A-wing A214	0 ppb
Monmouth Memorial School	A-wing Upper Level Water Fountain Btn A217 A218-a	0 ppb
Monmouth Memorial School	B- Wing 119- Side Wall Left	3.7 ppb
Monmouth Memorial School	B- Wing 119- Side Wall Middle	2.7 ppb
Monmouth Memorial School	B- Wing 119- Side Wall Right	5.7 ppb
Monmouth Memorial School	B- Wing B104 A	1 ppb
Monmouth Memorial School	B- Wing B104 B	0 ppb
Monmouth Memorial School	B- Wing B104 C	0 ppb
Monmouth Memorial School	B- Wing B105 B	0 ppb
Monmouth Memorial School	B- Wing B105 C	0 ppb
Monmouth Memorial School	B- Wing B107	0 ppb
Monmouth Memorial School	B- Wing B108	0 ppb
Monmouth Memorial School	B- Wing B109	0 ppb
Monmouth Memorial School	B- Wing B119- Outside Wall Right	5.9 ppb
Monmouth Memorial School	B- Wing B119-hallway Wall	5.5 ppb
Monmouth Memorial School	B- Wing B124 Left	1.2 ppb
Monmouth Memorial School	B- Wing B124 Middle	0 ppb
Monmouth Memorial School	B- Wing B124 Right	2.3 ppb

School Name	Sample Location	Lead Test Result
Monmouth Memorial School	B-wing B102	2.3 ppb
Monmouth Memorial School	B-wing B105 A	0 ppb
Monmouth Memorial School	B-wing B122- Hallway Wall	6.1 ppb
Monmouth Memorial School	B-wing Hallway Fountain Btw B104 And B105- A	0 ppb
Monmouth Memorial School	B-wing Hallway Fountain Btw B104 And B105- B	0 ppb
Monmouth Memorial School	C- Wing C101	1.9 ppb
Monmouth Memorial School	C- Wing C102	0 ppb
Monmouth Memorial School	C- Wing C103- Left	0 ppb
Monmouth Memorial School	C- Wing C103- Middle	0 ppb
Monmouth Memorial School	C- Wing C103- Right	0 ppb
Monmouth Memorial School	C- Wing C104- Left	0 ppb
Monmouth Memorial School	C- Wing C104- Middle	0 ppb
Monmouth Memorial School	C- Wing C104- Right	1.5 ppb
Monmouth Memorial School	C- Wing C105- Custodian	4.6 ppb
Monmouth Memorial School	C- Wing C106b	0 ppb
Monmouth Memorial School	C- Wing C106d	0 ppb
Monmouth Memorial School	C- Wing C106e	0 ppb
Monmouth Memorial School	C- Wing C107- Cafeteria Left	0 ppb
Monmouth Memorial School	C- Wing C107- Cafeteria Middle	1.3 ppb
Monmouth Memorial School	C- Wing C107- Cafeteria Right	0 ppb
Monmouth Memorial School	C- Wing C107- Left Fountain	0 ppb
Monmouth Memorial School	C- Wing C107- Right Fountain	0 ppb
Monmouth Memorial School	C- Wing C109b- Sink Next To Continental Fridge	2.3 ppb
Monmouth Memorial School	C- Wing C109b- Sink Next To Roll-up Door	1.3 ppb
Monmouth Memorial School	C- Wing C109b- Sink On Back Wall Parking Lot Side	0 ppb
Monmouth Memorial School	C- Wing C109b-kitchen Dishwash Rm- Right Sink	3.7 ppb
Monmouth Memorial School	C- Wing Hallway Left Fountain	0 ppb
Monmouth Memorial School	C- Wing Hallway Right Fountain	0 ppb
Monmouth Memorial School	C-wing C109b- Kitchen Dishwash Rm- Left Sink	0 ppb
Monmouth Memorial School	C-wing C109b- Kitchen Dishwash Rm- Middle Sink	0 ppb
Monmouth Memorial School	C-wing C112- Bathroom Sink	0 ppb
Monmouth Memorial School	C-wingc109b-sink Next To Stainless Utility Closet	3.1 ppb
Monmouth Memorial School	Spigot Next To Door #10	3.4 ppb
Monmouth Memorial School	Spigot Next To Door #2	116 ppb
Monmouth Memorial School	Spigot Next To Door #5	14.7 ppb
Monmouth Memorial School	Spigot Next To Door #7	0 ppb
Monmouth Memorial School	Spigot Next To Septic Pumps	10.9 ppb
Monroe Elementary School	Bottle Fill Station- Entrance	0 ppb

School Name	Sample Location	Lead Test Result
Monroe Elementary School	Boys Bathroom (entrance)- Handwash Sink #1	2.2 ppb
Monroe Elementary School	Boys Bathroom (entrance)- Handwash Sink #2	1.6 ppb
Monroe Elementary School	Downstairs Bathroom- Handwash Sink #1	0 ppb
Monroe Elementary School	Downstairs Bathroom- Handwash Sink #2	0 ppb
Monroe Elementary School	Downstairs- Bottle Fill Station	0 ppb
Monroe Elementary School	Downstairs- Fountain	0 ppb
Monroe Elementary School	Faculty Bathroom Sink	1.5 ppb
Monroe Elementary School	Fountain- Entrance	0 ppb
Monroe Elementary School	Girls Bathroom (entrance)- Handwash Sink #1	0 ppb
Monroe Elementary School	Girls Bathroom (entrance)- Handwash Sink #2	0 ppb
Monroe Elementary School	Grade 2/3- Fountain	0 ppb
Monroe Elementary School	Grade 2/3- Handwash Sink	0 ppb
Monroe Elementary School	Grade 4/5- Fountain	0 ppb
Monroe Elementary School	Grade 4/5- Handwash Sink #1	3.6 ppb
Monroe Elementary School	Grade 4/5- Handwash Sink #2	8.4 ppb
Monroe Elementary School	Grade 4/5- Handwash Sink #3	1.3 ppb
Monroe Elementary School	Gym- Fountain	0 ppb
Monroe Elementary School	Kindergarten/ Gi- Fountain	0 ppb
Monroe Elementary School	Kindergarten/ Gi- Handwash Sink	0 ppb
Monroe Elementary School	Kitchen- Dishwasher Spray Station	0 ppb
Monroe Elementary School	Kitchen- Handwash Sink	0 ppb
Monroe Elementary School	Kitchen- Single Prep Sink	0 ppb
Monroe Elementary School	Kitchen- Three Bay Fixture #1	0 ppb
Monroe Elementary School	Kitchen- Three Bay Fixture #2	0 ppb
Monroe Elementary School	Kitchen- Three Bay Sprayer	0 ppb
Monroe Elementary School	Library- Fountain	0 ppb
Monroe Elementary School	Library- Handwash Sink	6.3 ppb
Monroe Elementary School	Multipurpose Room- Fountain	0 ppb
Monroe Elementary School	Multipurpose Room- Handwash Sink	3 ppb
Monroe Elementary School	Pre-k- Fountain	0 ppb
Monroe Elementary School	Pre-k- Handwash Sink	0 ppb
Monroe Elementary School	Staff Bathroom (entrance)-handwash Sink	9 ppb
Monroe Elementary School	Title 1- Bathroom Handwash Sink	1.3 ppb
Monroe Elementary School	Title 1- Fountain	0 ppb
Monroe Elementary School	Title 1- Handwash Sink	1.1 ppb
Montello School	A102a Sink	7.3 ppb
Montello School	A102d Sink	15.8 ppb
Montello School	A103 Sink	115 ppb
Montello School	A106 Nurse Sink	12.8 ppb
Montello School	A106a Nurse Bath Sink	2.8 ppb
Montello School	A108d Bath Sink	5.5 ppb
Montello School	B Wing Hall Sink By Stairs 2nd	3.8 ppb
Montello School	B102 Sink	2.3 ppb

School Name	Sample Location	Lead Test Result
Montello School	B112 Girls Bath 1st Sink	1.2 ppb
Montello School	B114 Boys Bath 1st Sink	7.4 ppb
Montello School	B213 Girls Bath 1st Sink	2.3 ppb
Montello School	B214 Teachers Bath Sink	88 ppb
Montello School	B214a Staff Bath Sink	475 ppb
Montello School	B216 Boys Bath 1st Sink	21.9 ppb
Montello School	C Wing 2nd Fl Water Fountaing By Stairs	5.6 ppb
Montello School	C Wing Hall Bottle Filler	0 ppb
Montello School	C Wing Hall Water Fountain	0 ppb
Montello School	C101 Sink Rh	0 ppb
Montello School	C102 Bubbler	11.4 ppb
Montello School	C102 Sink	7.7 ppb
Montello School	C103 Sink	5.1 ppb
Montello School	C104 Sink	15.4 ppb
Montello School	C105 Sink Rh	18.9 ppb
Montello School	C106 Sink	1.2 ppb
Montello School	C201 Sink	4 ppb
Montello School	C202 Sink	9.5 ppb
Montello School	C203 Sink	10.8 ppb
Montello School	C205 Sink	33.2 ppb
Montello School	C206 Sink	11.3 ppb
Montello School	C207 Sink	7.8 ppb
Montello School	C208 Sink	9.2 ppb
Montello School	Cafe Bottle Filler	1.8 ppb
Montello School	Cafe Boys Sink 1st	12.6 ppb
Montello School	Cafe Girl Sink	3.4 ppb
Montello School	Cafe Water Fountain	1.8 ppb
Montello School	D102a Bath Sink	45.2 ppb
Montello School	D102b Bath Sink	69.4 ppb
Montello School	Hall Sink 1st Floor Rh	2.8 ppb
Montello School	Hall Sink Between Baths B Wing 2nd	6 ppb
Montello School	Hall Sink Bubber B Wing 2nd	8.1 ppb
Montello School	Hall Sink Bubbler	20.5 ppb
Montello School	Hall Sink End By Stairs B Wing 1st	3.2 ppb
Montello School	Kitchen 2 Bin Sink	1.5 ppb
Montello School	Kitchen Pot Sink	3.7 ppb
Montello School	Kitchen Soup Kettle	15.3 ppb
Montello School	Side Hall Bottle Filler	1.7 ppb
Montello School	Side Hall Water Fountain	0 ppb
Montello School	Staff Bath Lh Sink	3 ppb
Montello School	Staff Bath Rh Sink	1.8 ppb
Montello School	Staff Bath Sink C Wing 2nd	51.8 ppb
Montello School	Teachers Lougne Bottle Filler	8.1 ppb
Montello School	Teachers Lounge Sink	57 ppb
Montello School	Water Fountain By Cust Closet 2 Wing 2nd	5.8 ppb
Montello School	Water Fountain By Staff Bath B Wing 2nd	0 ppb
Montello School	Water Fountain C Wing 1st	0 ppb

School Name	Sample Location	Lead Test Result
Morrison Center - Scarborough	401 Bathroom Hallway Sink	1.2 ppb
Morrison Center - Scarborough	403 Bathroom Hallway Sink	0 ppb
Morrison Center - Scarborough	406 Area Kitchen Sink	1.6 ppb
Morrison Center - Scarborough	406 Area Room 1 Left Hand Sink	4.2 ppb
Morrison Center - Scarborough	406 Area Room 1 Right Hand Sink	0 ppb
Morrison Center - Scarborough	406 Area Room 2 Left Hand Sink	0 ppb
Morrison Center - Scarborough	406 Area Room 2 Right Hand Sink	0 ppb
Morrison Center - Scarborough	406 Area Room 3 Left Hand Sink	0 ppb
Morrison Center - Scarborough	406 Area Room 3 Right Hand Sink	0 ppb
Morrison Center - Scarborough	406 Area Utility Sink	0 ppb
Morrison Center - Scarborough	406a Bathroom Sink	0 ppb
Morrison Center - Scarborough	420 Bathroom Adult Area Sink	0 ppb
Morrison Center - Scarborough	Adult Area 500 Bm Bathroom Sink	0 ppb
Morrison Center - Scarborough	Adult Area 500a Bathroom Sink	0 ppb
Morrison Center - Scarborough	Adult Area Room 1 Sink	0 ppb
Morrison Center - Scarborough	Adult Area Room 2 Sink	0 ppb
Morrison Center - Scarborough	Adult Area Room 2 Utility Sink	0 ppb
Morrison Center - Scarborough	Davis Cottage 101r Bathroom Sink	3.4 ppb
Morrison Center - Scarborough	Davis Cottage 101r Kitchen Sink	0 ppb
Morrison Center - Scarborough	Davis Cottage 102r Br/laundry Sink	1.1 ppb
Morrison Center - Scarborough	Davis Cottage 106r Living Rm Bathrm Sink	0 ppb
Morrison Center - Scarborough	Davis Cottage 111r Living Rm Bathrm Sink	0 ppb
Morrison Center - Scarborough	Gym 002 Bathroom Sink	0 ppb
Morrison Center - Scarborough	Gym 003 Bathroom Sink	0 ppb
Morrison Center - Scarborough	High School Area Left Bathroom Sink	0 ppb
Morrison Center - Scarborough	High School Area Right Bathroom Sink	0 ppb
Morrison Center - Scarborough	High School Area Room 1 Left Hand Sink	0 ppb
Morrison Center - Scarborough	High School Area Room 1 Right Hand Sink	0 ppb
Morrison Center - Scarborough	High School Area Room 2 Left Hand Sink	23 ppb
Morrison Center - Scarborough	High School Area Room 2 Right Hand Sink	0 ppb
Morrison Center - Scarborough	High School Area Room 3 Left Hand Sink	0 ppb
Morrison Center - Scarborough	High School Area Room 3 Right Hand Sink	0 ppb
Morrison Center - Scarborough	Main Hallway 004 Bathroom Left Sink	0 ppb
Morrison Center - Scarborough	Main Hallway 004 Bathroom Right Sink	1.3 ppb
Morrison Center - Scarborough	Main Hallway 005 Bathroom Left Sink	0 ppb
Morrison Center - Scarborough	Main Hallway 005 Bathroom Right Sink	0 ppb
Morrison Center - Scarborough	Room 101 Sink	2.1 ppb
Morrison Center - Scarborough	Room 102 Sink	0 ppb
Morrison Center - Scarborough	Room 103 Sink	0 ppb
Morrison Center - Scarborough	Room 105 Sink	0 ppb
Morrison Center - Scarborough	Room 106 Sink	0 ppb
Morrison Center - Scarborough	Room 306 Nurses Sink	0 ppb
Morrison Center - Scarborough	Staff Kitchen Sink	0 ppb
Morrison Center - Wells	Blue Jay Room Sink	1.4 ppb
Morrison Center - Wells	Cardinal Room Sink	0 ppb
Morrison Center - Wells	Kitchen Bathroom Sink	0 ppb
Morrison Center - Wells	Kitchen Sink	0 ppb

School Name	Sample Location	Lead Test Result
Morrison Center - Wells	Nurses Room	1.6 ppb
Morrison Center - Wells	Staff Bathroom Sink	0 ppb
Morrison Center - Wells	Student's Bathroom Sink	0 ppb
Morrison Center - Wells	Turkey Room Bathroom Sink	0 ppb
Morse High School	Dish Pit Sink	2.4 ppb
Morse High School	First Floor To The Left Down Nurse Hallway	0 ppb
Morse High School	First Floor To The Right Near Cosmetology	0 ppb
Morse High School	Gym Bottle Filling Station	0 ppb
Morse High School	Gym Water Fountain Spicket	0 ppb
Morse High School	Near Classroom 615 Bottle Filler	0 ppb
Morse High School	Near Classroom 615 Water Fountain	0 ppb
Morse High School	Near Kitchen Area Student Side Under Red Sign	1.8 ppb
Morse High School	Sink Facing Classroom (prep Table)	2.9 ppb
Morse High School	Sink Near Spices	0 ppb
Morse High School	Sink With Sprayer	0 ppb
Morse High School	Small Sink Near Coffee Station	1.5 ppb
Morse High School	Three Bay Sink Near Dishwasher 2 Spicket	2.4 ppb
Morse High School	Three Bay Sink Near Dishwasher Spicket 2	0 ppb
Morse High School	Three Bay Sink Second Spicket	0 ppb
Morse High School	Three Bay Sink With With Two Spickets	1.1 ppb
Morse High School	Up Stairwell C 2nd Floor Near Elec Bottle	0 ppb
Morse High School	Up Stairwell C 2nd Floor Near Elec Foun	0 ppb
Morse High School	Up Stairwell C 3rd Floor Bottle	0 ppb
Morse High School	Up Stairwell C 3rd Floor Fountain	0 ppb
Morse Memorial School	Bottle Fill Station- Entrance	0 ppb
Morse Memorial School	Boys Bathroom- Handwash Sink (entrance)	4.1 ppb
Morse Memorial School	Boys Bathroom Next To Gym- Handwash Sink	8.9 ppb
Morse Memorial School	Classroom 4- Bathroom Handwash Sink	2.9 ppb
Morse Memorial School	Classroom 4- Handwash Sink	15.1 ppb
Morse Memorial School	Classroom 7- Handwash Sink	15.3 ppb
Morse Memorial School	Classroom 8- Handwash Sink	14.6 ppb
Morse Memorial School	Faculty Room- Handwash Sink	7 ppb
Morse Memorial School	Fountain- Entrance	0 ppb
Morse Memorial School	Girls Bathroom- Handwash Sink (entrance)	6.7 ppb
Morse Memorial School	Girls Bathroom Next To Gym-handwash Sink	3.9 ppb
Morse Memorial School	Kitchen- Dishwasher Rinse Station Sprayer	2.9 ppb
Morse Memorial School	Kitchen- Handwash Sink	6.5 ppb
Morse Memorial School	Kitchen- Three Bay Sink Fixture #1	323 ppb
Morse Memorial School	Kitchen- Three Bay Sink Fixture #2	6.8 ppb
Morse Memorial School	Upstairs- Bottle Fill Station	0 ppb
Morse Memorial School	Upstairs Boys Bathroom- Handwash Sink	3.4 ppb
Morse Memorial School	Upstairs- Fountain	0 ppb
Morse Memorial School	Upstairs Girls Bathroom- Handwash Sink	6.3 ppb

School Name	Sample Location	Lead Test Result
Morse Street School	A Wing Hall -a- At Girls	0 ppb
Morse Street School	A Wing Hall East End	1.5 ppb
Morse Street School	A Wing Hall Middle	0 ppb
Morse Street School	B Wing Hall	0 ppb
Morse Street School	C Wing Hall	9.2 ppb
Morse Street School	D Wing Hall	0 ppb
Morse Street School	Gym	0 ppb
Morse Street School	Kid's Kitchen	21.2 ppb
Morse Street School	Kitchen Sink Cooking	0 ppb
Moscow Elementary	Bottle Filler Gym Moscow	0 ppb
Moscow Elementary	Bottle Filler Main Hall Moscow	0 ppb
Moscow Elementary	Kitchen Sink Moscow	2.5 ppb
Moscow Elementary	Sink Teachers' Room Moscow	1.3 ppb
Mount Merici Academy	No Samples Yet Taken	
Mountain Valley High School	Booster Room- (br) A	7 ppb
Mountain Valley High School	Boys Locker Room- (blra)	2.3 ppb
Mountain Valley High School	Boys Locker Room- (blrb)	4.4 ppb
Mountain Valley High School	Boys Locker Room Entrance Fountain (blref) A	0 ppb
Mountain Valley High School	Bus Garage- Sink (bg1)	1.2 ppb
Mountain Valley High School	Central Office Bathroom- (cob) A	6.2 ppb
Mountain Valley High School	Central Office Breakroom- (cobr) A	2.6 ppb
Mountain Valley High School	Central Office Hallway Fountain- (cohf) A	0 ppb
Mountain Valley High School	Coaches Room 235- (cr235) A	1.4 ppb
Mountain Valley High School	First Floor Academic Wing Fountain- (ffawf) A	0 ppb
Mountain Valley High School	First Floor Boys Bathroom- (ffbba)	1.9 ppb
Mountain Valley High School	First Floor Boys Bathroom- (ffbbb)	1.9 ppb
Mountain Valley High School	First Floor Boys Bathroom- (ffbbc)	4.1 ppb
Mountain Valley High School	First Floor Girls Bathroom- (ffgba)	3.5 ppb
Mountain Valley High School	First Floor Girls Bathroom- (ffgbb)	3.5 ppb
Mountain Valley High School	First Floor Girls Bathroom- (ffgbc)	6.4 ppb
Mountain Valley High School	First Floor Girls Bathroom- (ffgbd)	2.6 ppb
Mountain Valley High School	First Floor Mens Staff Bathroom- (ffmsb) A	2.4 ppb
Mountain Valley High School	First Floor Womens Staff Bathroom- (ffwsb) A	5.5 ppb
Mountain Valley High School	Fitness Center - Bathroom (fc2)	1.4 ppb
Mountain Valley High School	Fitness Center- Water Fountain (fc1)	0 ppb
Mountain Valley High School	Girls Locker Room- (glra)	4.6 ppb
Mountain Valley High School	Girls Locker Room- (glrb)	2.8 ppb
Mountain Valley High School	Girls Locker Room- (glrc)	8.5 ppb
Mountain Valley High School	Girls Locker Room- (glrd)	5.7 ppb
Mountain Valley High School	Girls Locker Room Entrance Fountain (glref) A	0 ppb
Mountain Valley High School	Gym Entrance- Boys Bathroom A (gebba)	4.1 ppb
Mountain Valley High School	Gym Entrance- Boys Bathroom B (gebbb)	131 ppb
Mountain Valley High School	Gym Entrance- Girl Bathroom C (gegbc)	3 ppb

School Name	Sample Location	Lead Test Result
Mountain Valley High School	Gym Entrance- Girls Bathroom A (gegba)	7 ppb
Mountain Valley High School	Gym Entrance- Girls Bathroom B (gegbb)	2.6 ppb
Mountain Valley High School	Gym Entrance- Hallway Fountain (gehf) A	3.2 ppb
Mountain Valley High School	Kitchen- (ka)	12.3 ppb
Mountain Valley High School	Kitchen- (kb)	1.2 ppb
Mountain Valley High School	Kitchen- (kc)	1.9 ppb
Mountain Valley High School	Kitchen Bathroom- (kb)	2.4 ppb
Mountain Valley High School	Kitchen Closet- (kc)	0 ppb
Mountain Valley High School	Library Office- (lo) A	12.5 ppb
Mountain Valley High School	Main Office Bathroom- (mob) A	4.2 ppb
Mountain Valley High School	Phys Ed Office Bathroom- (peob)	3.4 ppb
Mountain Valley High School	Ramp Room 303- (rr303a)	1.5 ppb
Mountain Valley High School	Ramp Room 303- (rr303b)	0 ppb
Mountain Valley High School	Ramp Room 303- (rr303c)	0 ppb
Mountain Valley High School	Ramp Room 303- (rr303d)	5.6 ppb
Mountain Valley High School	Ramp Room 304- (rr304) A	1.6 ppb
Mountain Valley High School	Ramp Room 306- Art A (rr306a)	3.9 ppb
Mountain Valley High School	Ramp Room 306- Art B (rr306b)	4.8 ppb
Mountain Valley High School	Room 243 Physiotherapy Bathroom- (r243pb) A	76.5 ppb
Mountain Valley High School	Science Wing 201- (sw201a)	3.3 ppb
Mountain Valley High School	Science Wing 201- (sw201b)	2.9 ppb
Mountain Valley High School	Science Wing 201- (sw201c)	8.2 ppb
Mountain Valley High School	Science Wing 201- (sw201d)	11.8 ppb
Mountain Valley High School	Science Wing 201- (sw201e)	3.2 ppb
Mountain Valley High School	Science Wing 201- (sw201f)	3.8 ppb
Mountain Valley High School	Science Wing 201b- (sw201b/i)	16.7 ppb
Mountain Valley High School	Science Wing 202b- (sw202b/f)	33 ppb
Mountain Valley High School	Science Wing 202b- Closet A (sw202bc)	3.9 ppb
Mountain Valley High School	Science Wing 203- (sw203a)	3.5 ppb
Mountain Valley High School	Science Wing 203- (sw203b)	8.6 ppb
Mountain Valley High School	Science Wing 203- (sw203c)	7.1 ppb
Mountain Valley High School	Science Wing 203- (sw203d)	93.7 ppb
Mountain Valley High School	Science Wing 203- (sw203f)	48.1 ppb
Mountain Valley High School	Science Wing 203- (sw203g)	38.6 ppb
Mountain Valley High School	Science Wing 203- (sw203h)	14.1 ppb
Mountain Valley High School	Science Wing 204- (sw204)	59.9 ppb
Mountain Valley High School	Science Wing 204 Closet- (sw204c) A	863 ppb
Mountain Valley High School	Science Wing 204 Hallway- (sw204h) A	241 ppb
Mountain Valley High School	Science Wing 205- (sw205a)	85.8 ppb
Mountain Valley High School	Science Wing 205- (sw205c)	4.5 ppb
Mountain Valley High School	Science Wing 205- (sw205d)	8.6 ppb
Mountain Valley High School	Science Wing 205- (sw205e)	38.1 ppb
Mountain Valley High School	Science Wing 205- (sw205f)	5.9 ppb
Mountain Valley High School	Science Wing 205- (sw205g)	13.5 ppb
Mountain Valley High School	Science Wing 205- (sw205h)	18 ppb
Mountain Valley High School	Science Wing 206- (sw206b)	13.2 ppb

School Name	Sample Location	Lead Test Result
Mountain Valley High School	Science Wing 206- (sw206c)	24.2 ppb
Mountain Valley High School	Science Wing 206- (sw206d)	29.9 ppb
Mountain Valley High School	Science Wing 206- (sw206e)	62.3 ppb
Mountain Valley High School	Science Wing 206- (sw206f)	79.2 ppb
Mountain Valley High School	Science Wing 206- (sw206g)	46.6 ppb
Mountain Valley High School	Science Wing 206- (sw206h)	32.3 ppb
Mountain Valley High School	Science Wing Hallway Faucet- (swhf) A	0 ppb
Mountain Valley High School	Second Floor Academic Wing- Fountain A (sfawfa)	0 ppb
Mountain Valley High School	Second Floor Academic Wing- Fountain B (sfawfb)	0 ppb
Mountain Valley High School	Second Floor Boys Bathroom A- (sfbba)	9.5 ppb
Mountain Valley High School	Second Floor Boys Bathroom B- (sfbbb)	1.8 ppb
Mountain Valley High School	Second Floor Girls Bathroom A- (sfgba)	2.7 ppb
Mountain Valley High School	Second Floor Girls Bathroom B - (sfgbb)	3.3 ppb
Mountain Valley High School	Second Floor Girls Bathroom C- (sfgbc)	1.5 ppb
Mountain Valley High School	Second Floor Girls Bathroom D (sfgbd)	4.2 ppb
Mountain Valley High School	Special Services- (ss) A	322 ppb
Mountain Valley High School	Storage Room By Music Room- (srbmr) A	0 ppb
Mountain Valley High School	Teachers Lounge- (tl) A	1.9 ppb
Mountain Valley High School	Tech Wing Bathroom- Mens (twbm1)	2.3 ppb
Mountain Valley High School	Tech Wing Bathroom- Womens (twbw1)	2.8 ppb
Mountain Valley High School	Tech Wing Room 189- (twr189) A	3.9 ppb
Mountain Valley High School	Visitors Locker Room- (vlr) A	14.7 ppb
Mountain Valley High School	Visitors Locker Room- (vlr) B	30.6 ppb
Mountain Valley Middle School	Art Room Sink Rm 4	1.9 ppb
Mountain Valley Middle School	Boys Bathroom Sink 1	2.5 ppb
Mountain Valley Middle School	Boys Bathroom Sink 2	1.6 ppb
Mountain Valley Middle School	Boys Locker Room Drinking Fountain	0 ppb
Mountain Valley Middle School	Boys Locker Room Sink 1	0 ppb
Mountain Valley Middle School	Boys Locker Room Sink 2	1.9 ppb
Mountain Valley Middle School	Cafeteria Drinking Fountain	0 ppb
Mountain Valley Middle School	Fitness Room Drinking Fountain	9 ppb
Mountain Valley Middle School	Fitness Room Sink	3.6 ppb
Mountain Valley Middle School	Girls Bathroom Sink 1	3.4 ppb
Mountain Valley Middle School	Girls Bathroom Sink 2	1.9 ppb
Mountain Valley Middle School	Girls Bathroom Sink 3	9.1 ppb
Mountain Valley Middle School	Girls Coach Room Sink	1.3 ppb
Mountain Valley Middle School	Girls Locker Room Drinking Fountain	0 ppb
Mountain Valley Middle School	Girls Locker Room Sink 1	5.7 ppb
Mountain Valley Middle School	Girls Locker Room Sink 2	2.8 ppb
Mountain Valley Middle School	Gym Drinking Fountain	0 ppb
Mountain Valley Middle School	Hall Ramp Drinking Fountain	0 ppb
Mountain Valley Middle School	Kitchen Bathroom Sink	10.5 ppb
Mountain Valley Middle School	Kitchen Sink 1	0 ppb
Mountain Valley Middle School	Kitchen Sink 2	1.4 ppb
Mountain Valley Middle School	Kitchen Sink 3	11 ppb

School Name	Sample Location	Lead Test Result
Mountain Valley Middle School	Kitchen Sink 4	4.6 ppb
Mountain Valley Middle School	Kitchen Sink 5	2.5 ppb
Mountain Valley Middle School	Kitchen Sink 6	3.9 ppb
Mountain Valley Middle School	Lower Wing Boys Bathroom Sink 1	0 ppb
Mountain Valley Middle School	Lower Wing Boys Bathroom Sink 2	0 ppb
Mountain Valley Middle School	Lower Wing Girls Sink 1- Bathroom	0 ppb
Mountain Valley Middle School	Lower Wing Girls Sink 2- Bathroom	0 ppb
Mountain Valley Middle School	Lower Wing Girls Sink 3- Bathroom	0 ppb
Mountain Valley Middle School	Mens Bathroom Sink	0 ppb
Mountain Valley Middle School	Office Bathroom Sink	2.1 ppb
Mountain Valley Middle School	Room 1 Sink 1	1.5 ppb
Mountain Valley Middle School	Room 1 Sink 2	5.9 ppb
Mountain Valley Middle School	Room 1 Sink 3	6.2 ppb
Mountain Valley Middle School	Room 1 Sink 4	308 ppb
Mountain Valley Middle School	Room 10 Sink	2.3 ppb
Mountain Valley Middle School	Room 14 Sink	9.7 ppb
Mountain Valley Middle School	Room 18- Media Center Bathroom Sink	4 ppb
Mountain Valley Middle School	Room 19- Faculty Lounge Sink	0 ppb
Mountain Valley Middle School	Room 33- Sink	4.4 ppb
Mountain Valley Middle School	Room 34- Sink 1	18 ppb
Mountain Valley Middle School	Room 34- Sink 2	6.8 ppb
Mountain Valley Middle School	Room 34- Sink 3	13.3 ppb
Mountain Valley Middle School	Room 34- Sink 4	82.4 ppb
Mountain Valley Middle School	Room 34- Sink 6	18.1 ppb
Mountain Valley Middle School	Room 6 Sink	3.2 ppb
Mountain Valley Middle School	Room 66/32- Sink	9.4 ppb
Mountain Valley Middle School	Room 7 Sink	2.1 ppb
Mountain Valley Middle School	Room 9 Sink	4.8 ppb
Mountain Valley Middle School	Shop Bathroom Sink	1.5 ppb
Mountain Valley Middle School	Shop Sink	5 ppb
Mountain Valley Middle School	Snack Shack Sink	9.4 ppb
Mountain Valley Middle School	Staff Bathroom- Upper Wing Sink	11.8 ppb
Mountain Valley Middle School	Upper Wing Drinking Fountain 1	0 ppb
Mountain Valley Middle School	Upper Wing Drinking Fountain 2	0 ppb
Mountain Valley Middle School	Womens Bathroom Sink	1.5 ppb
Mountain View School	Drinking Fountain 3-5 Wing By 3-5 Bathroom	0 ppb
Mountain View School	Drinking Fountain 3-5 Wing By 6-8 Bathroom	0 ppb
Mountain View School	Drinking Fountain Main Hallway	0 ppb
Mountain View School	Ice Machine In Maintenance Room	450 ppb
Mountain View School	Kitchen Outside Wall	12.7 ppb
Mountain View School	Kitchen Steam Kettle Faucet	41 ppb
Mountain View School	Small Sink In Nurses Office	1.9 ppb
Mountain View School	Teachers Room #14 Kitchen Sink	7.7 ppb
MSAD 52 Adult & Community Education	Downstairs Kitchen Sink Faucet	1.7 ppb
MSAD 52 Adult & Community Education	Mens Room Sink Left Faucet	0 ppb

School Name	Sample Location	Lead Test Result
MSAD 52 Adult & Community Education	Mens Room Sink Right Faucet	0 ppb
MSAD 52 Adult & Community Education	Womens Room Sink Faucet	0 ppb
Mt Abram Regional High School	Art/math Wing Hall Water Cooler	0 ppb
Mt Abram Regional High School	Cafeteria Water Cooler	1.6 ppb
Mt Abram Regional High School	English Wing Hall Water Cooler	0 ppb
Mt Abram Regional High School	Gym Water Cooler	0 ppb
Mt Abram Regional High School	Gym/ Ice Machine	0 ppb
Mt Abram Regional High School	Kitchen 3 Bay Sink	0 ppb
Mt Abram Regional High School	Kitchen Kettle	2.7 ppb
Mt Abram Regional High School	Kitchen Prep Sink	13.4 ppb
Mt Abram Regional High School	Nurses Station	2 ppb
Mt Abram Regional High School	Room 19	2.6 ppb
Mt Abram Regional High School	Science Wing Hall Water Cooler	0 ppb
Mt Abram Regional High School	Special Ed Room 21/kitchen Area	0 ppb
Mt Ararat High School	104 Water Fountain	0 ppb
Mt Ararat High School	105 Water Fountain	0 ppb
Mt Ararat High School	106 Kitchen Sink	0 ppb
Mt Ararat High School	110 Lab Sink	2.5 ppb
Mt Ararat High School	111 Lab Sink	3.5 ppb
Mt Ararat High School	112 Lab Sink	2 ppb
Mt Ararat High School	114 Lab Sink	2.1 ppb
Mt Ararat High School	115 Lab Sink	2.5 ppb
Mt Ararat High School	116 Lab Sink	1.7 ppb
Mt Ararat High School	117 Lab Sink	2.3 ppb
Mt Ararat High School	118 Lab Sink	1.8 ppb
Mt Ararat High School	119 Water Fountain	0 ppb
Mt Ararat High School	12 Ice Machine	0 ppb
Mt Ararat High School	120 Water Fountain	0 ppb
Mt Ararat High School	121 Lab Sink	2 ppb
Mt Ararat High School	122 Lab Sink	3.6 ppb
Mt Ararat High School	123 Lab Sink	3 ppb
Mt Ararat High School	124 Lab Sink	4.6 ppb
Mt Ararat High School	13 Hand Wash Sink	2.3 ppb
Mt Ararat High School	134 Lab Sink	2.3 ppb
Mt Ararat High School	135 Water Fountain	0 ppb
Mt Ararat High School	136 Water Fountain	0 ppb
Mt Ararat High School	14 Water Fountain	0 ppb
Mt Ararat High School	145 Kitchen Sink	0 ppb
Mt Ararat High School	146 Lab Sink	3 ppb
Mt Ararat High School	147 Lab Sink	4.4 ppb
Mt Ararat High School	148 Lab Sink	1.9 ppb
Mt Ararat High School	149 Lab Sink	1.7 ppb
Mt Ararat High School	15 Water Fountain	0 ppb
Mt Ararat High School	150 Lab Sink	1.5 ppb
Mt Ararat High School	151 Lab Sink	1.6 ppb
Mt Ararat High School	152 Lab Sink	3.1 ppb
Mt Ararat High School	153 Lab Sink	1.8 ppb

School Name	Sample Location	Lead Test Result
Mt Ararat High School	154 Lab Sink	2.4 ppb
Mt Ararat High School	155 Lab Sink	2.9 ppb
Mt Ararat High School	156 Lab Sink	2.2 ppb
Mt Ararat High School	157 Lab Sink	1.7 ppb
Mt Ararat High School	158 Lab Sink	3.4 ppb
Mt Ararat High School	159 Lab Sink	3.2 ppb
Mt Ararat High School	16 Kitchen Sink	0 ppb
Mt Ararat High School	160 Lab Sink	3.4 ppb
Mt Ararat High School	161 Lab Sink	2.9 ppb
Mt Ararat High School	162 Lab Sink	2.4 ppb
Mt Ararat High School	163 Lab Sink	2.7 ppb
Mt Ararat High School	164 Lab Sink	9.4 ppb
Mt Ararat High School	165 Lab Sink	11.7 ppb
Mt Ararat High School	17 Kitchen Sink	0 ppb
Mt Ararat High School	18 Kitchen Sink	0 ppb
Mt Ararat High School	19 Kitchen Sink	0 ppb
Mt Ararat High School	21 Kitchen Sink	0 ppb
Mt Ararat High School	35 Water Fountain	0 ppb
Mt Ararat High School	36 Water Fountain	0 ppb
Mt Ararat High School	37 Kitchen Sink	0 ppb
Mt Ararat High School	38 Kitchen Sink	0 ppb
Mt Ararat High School	41 Water Fountain	0 ppb
Mt Ararat High School	42 Water Fountain	0 ppb
Mt Ararat High School	47 Hand Wash Sink	2.3 ppb
Mt Ararat High School	48 Kitchen Sink	0 ppb
Mt Ararat High School	49 Kitchen Sink	0 ppb
Mt Ararat High School	50 Hand Wash Sink	0 ppb
Mt Ararat High School	51 Kitchen Sink	0 ppb
Mt Ararat High School	53 Hand Wash Sink	0 ppb
Mt Ararat High School	55 Hand Wash Sink	2.5 ppb
Mt Ararat High School	56 Hand Wash Sink	1.9 ppb
Mt Ararat High School	57 Hand Wash Sink	2.7 ppb
Mt Ararat High School	58 Kitchen Sink	0 ppb
Mt Ararat High School	59 Kitchen Sink	2.1 ppb
Mt Ararat High School	60 Medical Sink	1.7 ppb
Mt Ararat High School	62 Medical Sink	1.6 ppb
Mt Ararat High School	63 Medical Sink	0 ppb
Mt Ararat High School	65 Medical Sink	0 ppb
Mt Ararat High School	68 Water Fountain	0 ppb
Mt Ararat High School	69 Water Fountain	0 ppb
Mt Ararat High School	70 Kitchen Sink	0 ppb
Mt Ararat High School	72 Kitchen Sink	0 ppb
Mt Ararat High School	73 Water Fountain	0 ppb
Mt Ararat High School	75 Water Fountain	0 ppb
Mt Ararat High School	76 Water Fountain	0 ppb
Mt Ararat High School	78 Kitchen Sink	0 ppb
Mt Ararat High School	79 Kitchen Sink	0 ppb

School Name	Sample Location	Lead Test Result
Mt Ararat High School	86 Kitchen Sink	0 ppb
Mt Ararat High School	87 Kitchen Sink	0 ppb
Mt Ararat High School	88 Kitchen Sink	0 ppb
Mt Ararat High School	89 Kitchen Sink	0 ppb
Mt Ararat High School	90 Kitchen Sink	0 ppb
Mt Ararat High School	91 Kitchen Sink	0 ppb
Mt Ararat Middle School	10 Water Bottle Fill Station	0 ppb
Mt Ararat Middle School	100 Room 1230 Kitchen Faucet	1.1 ppb
Mt Ararat Middle School	107 Room 2727 Lab Sink	2.5 ppb
Mt Ararat Middle School	108 Room 2727 Lab Sink	4.3 ppb
Mt Ararat Middle School	109 Room 2727 Lab Sink	4 ppb
Mt Ararat Middle School	110 Room 2729 Prep Sink	19.5 ppb
Mt Ararat Middle School	111 Room 2729 Lab Sink	0 ppb
Mt Ararat Middle School	112 Room 2733 Lab Sink	2.1 ppb
Mt Ararat Middle School	113 Room 2733 Lab Sink	1.5 ppb
Mt Ararat Middle School	114 Room 2734 Lab Sink	31.9 ppb
Mt Ararat Middle School	115 Room 2735 Lab Sink	1.8 ppb
Mt Ararat Middle School	116 Room 2735 Lab Sink	3.4 ppb
Mt Ararat Middle School	117 Room 2735 Lab Sink	0 ppb
Mt Ararat Middle School	118 Room 2735 Lab Sink	0 ppb
Mt Ararat Middle School	12 Kitchen Faucet	1.3 ppb
Mt Ararat Middle School	123 Water Fountain	0 ppb
Mt Ararat Middle School	124 Water Fountain	0 ppb
Mt Ararat Middle School	126 Kitchen Faucet	4.4 ppb
Mt Ararat Middle School	129 Kitchen Faucet	1.3 ppb
Mt Ararat Middle School	13 Hand Wash Sink	12.9 ppb
Mt Ararat Middle School	132 Water Fountain	0 ppb
Mt Ararat Middle School	133 Water Fountain	0 ppb
Mt Ararat Middle School	135 Kitchen Faucet	1.1 ppb
Mt Ararat Middle School	138 Kitchen Faucet	1.5 ppb
Mt Ararat Middle School	139 Water Fountain	0 ppb
Mt Ararat Middle School	143 Lab Sink	1 ppb
Mt Ararat Middle School	144 Lab Sink	1.7 ppb
Mt Ararat Middle School	145 Lab Sink	1.5 ppb
Mt Ararat Middle School	146 Lab Sink	2.9 ppb
Mt Ararat Middle School	147 Lab Sink	4.8 ppb
Mt Ararat Middle School	148 Lab Sink	1.7 ppb
Mt Ararat Middle School	149 Lab Sink	3.1 ppb
Mt Ararat Middle School	151 Kitchen Faucet	1.8 ppb
Mt Ararat Middle School	153 Lab Sink	1.1 ppb
Mt Ararat Middle School	154 Lab Sink	3.3 ppb
Mt Ararat Middle School	155 Lab Sink	1.5 ppb
Mt Ararat Middle School	156 Lab Sink	2.2 ppb
Mt Ararat Middle School	157 Lab Sink	0 ppb
Mt Ararat Middle School	16 Kitchen Prep Sink	0 ppb
Mt Ararat Middle School	162 Water Fountain	0 ppb
Mt Ararat Middle School	164 Kitchen Fuacet	1.6 ppb

School Name	Sample Location	Lead Test Result
Mt Ararat Middle School	167 Kitchen Faucet	1.8 ppb
Mt Ararat Middle School	17 Kitchen Prep Sink	0 ppb
Mt Ararat Middle School	18 Kitchen Handwash	0 ppb
Mt Ararat Middle School	19 Kitchen Dish Wash Sprayer	8.3 ppb
Mt Ararat Middle School	2 Kitchen Faucet	0 ppb
Mt Ararat Middle School	20 Dishwash Sink	0 ppb
Mt Ararat Middle School	21 Dishwash Sink	20.3 ppb
Mt Ararat Middle School	22 Dishwash Sink	42.4 ppb
Mt Ararat Middle School	25 Room 1307 Kitchen Faucet	2 ppb
Mt Ararat Middle School	26 Water Fountain	0 ppb
Mt Ararat Middle School	27 Water Fountain	0 ppb
Mt Ararat Middle School	31 Lab Sink	0 ppb
Mt Ararat Middle School	32 Lab Sink	2.3 ppb
Mt Ararat Middle School	33 Lab Sink	4.4 ppb
Mt Ararat Middle School	34 Lab Sink	4.3 ppb
Mt Ararat Middle School	35 Lab Sink	2.3 ppb
Mt Ararat Middle School	36 Room 1329 Prep Faucet	5.5 ppb
Mt Ararat Middle School	37 Room 1329 Prep Faucet	1.3 ppb
Mt Ararat Middle School	38 Room 1333 Prep Facuet	1.1 ppb
Mt Ararat Middle School	39 Room 1333 Prep Facuet	1.1 ppb
Mt Ararat Middle School	40 Lab Sink	10.2 ppb
Mt Ararat Middle School	41 Lab Sink	3.2 ppb
Mt Ararat Middle School	42 Lab Sink	8.8 ppb
Mt Ararat Middle School	43 Lab Sink	4.8 ppb
Mt Ararat Middle School	44 Lab Sink	2.1 ppb
Mt Ararat Middle School	52 Room 1351 Kitchen Faucet	1.3 ppb
Mt Ararat Middle School	55 Room 1354 Kitchen Faucet	2.7 ppb
Mt Ararat Middle School	57 Kitchen Faucet	1 ppb
Mt Ararat Middle School	63 Water Fountain	0 ppb
Mt Ararat Middle School	69 Water Fountain	0 ppb
Mt Ararat Middle School	72 Water Fountain	0 ppb
Mt Ararat Middle School	73 Water Fountain	0 ppb
Mt Ararat Middle School	74 Water Fountain	0 ppb
Mt Ararat Middle School	75 Water Fountain	0 ppb
Mt Ararat Middle School	8 Water Fountain	0 ppb
Mt Ararat Middle School	80 Consessions Kitchen Faucet	17.9 ppb
Mt Ararat Middle School	82 Water Fountain	0 ppb
Mt Ararat Middle School	83 Water Fountain	0 ppb
Mt Ararat Middle School	88 Room 1402 Kitchen Faucet	1.7 ppb
Mt Ararat Middle School	89 Room 1403 Kitchen Faucet	2.7 ppb
Mt Ararat Middle School	9 Water Fountain	0 ppb
Mt Ararat Middle School	90 Room 1406 Kitchen Faucet	4.8 ppb
Mt Ararat Middle School	91 Room 1406 Kitchen Faucet	1.3 ppb
Mt Ararat Middle School	92 Room 1406 Kitchen Faucet	3.6 ppb
Mt Ararat Middle School	93 Room 1406 Kitchen Faucet	4 ppb
Mt Ararat Middle School	95 Room 1235 Kitchen Faucet	1.5 ppb
Mt Ararat Middle School	96 Room 1235 Kitchen Faucet	2.8 ppb

School Name	Sample Location	Lead Test Result
Mt Ararat Middle School	97 Room 1234 Kitchen Faucet	1.2 ppb
Mt Ararat Middle School	98 Room 1232 Kithcen Faucet	1.2 ppb
Mt Ararat Middle School	99 Room 1232 Kithcen Faucet	1.3 ppb
Mt Blue High School\Foster Regional Applied	Bottle Fill Outside A130	0 ppb
Mt Blue High School\Foster Regional Applied	Bottle Fill Outside B123	0 ppb
Mt Blue High School\Foster Regional Applied	Bottle Fill Outside B225	0 ppb
Mt Blue High School\Foster Regional Applied	Bottle Fill Outside B321	0 ppb
Mt Blue High School\Foster Regional Applied	Bottle Fill Outside D134	0 ppb
Mt Blue High School\Foster Regional Applied	Bottle Fill Outside E107	0 ppb
Mt Blue High School\Foster Regional Applied	Bottle Fill Outside F117	0 ppb
Mt Blue High School\Foster Regional Applied	Bottle Fill Outside F223	0 ppb
Mt Blue High School\Foster Regional Applied	Buisness Office Sink A234	2.3 ppb
Mt Blue High School\Foster Regional Applied	Coaches Sink C134	6.7 ppb
Mt Blue High School\Foster Regional Applied	Home Economics Sink #1 F110	3.7 ppb
Mt Blue High School\Foster Regional Applied	Home Economics Sink #2 F110	1.4 ppb
Mt Blue High School\Foster Regional Applied	Home Economics Sink #3 F110	1.8 ppb
Mt Blue High School\Foster Regional Applied	Kitchen Double Sink C101	2.2 ppb
Mt Blue High School\Foster Regional Applied	Kitchen Hand Sink #2 C101	4.4 ppb
Mt Blue High School\Foster Regional Applied	Kitchen Hand Sink C101	1.3 ppb
Mt Blue High School\Foster Regional Applied	Kitchen Kettle C101	6.6 ppb
Mt Blue High School\Foster Regional Applied	Nurse's Sink A156	2.5 ppb
Mt Blue High School\Foster Regional Applied	Sink Room E101	2.4 ppb
Mt Blue High School\Foster Regional Applied	Teachers Lounge Sink B303	3.2 ppb
Mt Blue High School\Foster Regional Applied	Teachers Lounge Sink F200	2.1 ppb
Mt Blue Middle School	Bottle Fill B-wing	0 ppb
Mt Blue Middle School	Bottle Fill Outside Cafe	0 ppb
Mt Blue Middle School	Bottle Fill Outside Gym	1.5 ppb
Mt Blue Middle School	Bottle Fill Outside Office	0 ppb
Mt Blue Middle School	Kitchen Dish Sink	2.6 ppb
Mt Blue Middle School	Kitchen Hand Sink #1	7.2 ppb
Mt Blue Middle School	Kitchen Hand Sink #2	5.6 ppb
Mt Blue Middle School	Kitchen Kettle	1.7 ppb
Mt Blue Middle School	Sink Nurse's Room	2.4 ppb
Mt Blue Middle School	Sink Room 9	2.4 ppb
Mt Blue Middle School	Sink Room W	3.8 ppb
Mt Blue Middle School	Sink Staff Lounge A-wing	2.3 ppb
Mt Blue Middle School	Sink Staff Room By Gym	12.8 ppb
Mt Blue Middle School	Water Fountain #1 Outside Gym	1.1 ppb
Mt Blue Middle School	Water Fountain #2 Outside Gym	1 ppb
Mt Blue Middle School	Waterfountain Outside Cafe	0 ppb
Mt Desert Elementary School	2 Bay Sink	4 ppb
Mt Desert Elementary School	3 Bay Sink	1 ppb
Mt Desert Elementary School	Ice Machine	0 ppb
Mt Desert Elementary School	Sink By Steamer	2 ppb
Mt Desert Elementary School	Water Bottle Filler In Forum	0 ppb
Mt Desert Elementary School	Water Bottle Filler In Hall	0 ppb
Mt Desert Island High School	Adult Ed Sink	1.6 ppb

School Name	Sample Location	Lead Test Result
Mt Desert Island High School	Boiler In Kitchen	6.9 ppb
Mt Desert Island High School	Cafe Fountain	0 ppb
Mt Desert Island High School	Gym Hallway	1.4 ppb
Mt Desert Island High School	Gym Lobby	4.2 ppb
Mt Desert Island High School	Ice Training Rm	0 ppb
Mt Desert Island High School	Kitchen Sink In District Office	5.3 ppb
Mt Desert Island High School	Room 121 (l)	54.2 ppb
Mt Desert Island High School	Room 121 (r)	4.5 ppb
Mt Desert Island High School	Sink 2 Bay In Kitchen Back Wall	6.2 ppb
Mt Desert Island High School	Sink 3 Bay In Kitchen Staff Room Side	15.8 ppb
Mt Desert Island High School	Sink In 134	5 ppb
Mt Desert Island High School	Staff By Kitchen	3.8 ppb
Mt Desert Island High School	Staff Room By Baby Room	12.5 ppb
Mt Desert Island High School	Wf Auditorium	0 ppb
Mt Desert Island High School	Wf By 134	0 ppb
Mt Desert Island High School	Wf By Haney's	0 ppb
Mt Desert Island High School	Wf By Music Rm	0 ppb
Mt Desert Island High School	Wf Upstairs	0 ppb
Mt Jefferson Jr High School	Boys Bathroom Sink # 1	3.8 ppb
Mt Jefferson Jr High School	Boys Bathroom Sink # 2	2.2 ppb
Mt Jefferson Jr High School	Boys Locker Room Sink	14.4 ppb
Mt Jefferson Jr High School	Dish Wash Sink - Kitchen	1.8 ppb
Mt Jefferson Jr High School	Girls Bathroom Sink # 1	0 ppb
Mt Jefferson Jr High School	Girls Bathroom Sink # 2	2.3 ppb
Mt Jefferson Jr High School	Girls Locker Room Sink	52.7 ppb
Mt Jefferson Jr High School	Hallway Fountain East End	0 ppb
Mt Jefferson Jr High School	Hallway Fountain Gym	0 ppb
Mt Jefferson Jr High School	Hand Wash Sink- Kitchen	3.2 ppb
Mt Jefferson Jr High School	La Boys Locker Room Bath Sink # 1	2.2 ppb
Mt Jefferson Jr High School	La Boys Locker Room Bath Sink # 2	1.8 ppb
Mt Jefferson Jr High School	La Girls Bath Sink # 1	0 ppb
Mt Jefferson Jr High School	La Girls Bath Sink # 2	1.7 ppb
Mt Jefferson Jr High School	La Girls Locker Room Bath Sink # 1	0 ppb
Mt Jefferson Jr High School	La Girls Locker Room Bath Sink # 2	0 ppb
Mt Jefferson Jr High School	La Gym Boys Bath Sink # 1	0 ppb
Mt Jefferson Jr High School	La Gym Boys Bath Sink # 2	1.9 ppb
Mt Jefferson Jr High School	La Water Fountain Lobby	2.1 ppb
Mt Jefferson Jr High School	Nurses Station Sink	0 ppb
Mt Jefferson Jr High School	Outside Spigot Boiler Room	0 ppb
Mt Jefferson Jr High School	Outside Spigot Office	10.7 ppb
Mt Jefferson Jr High School	Room 201- Sink Science Room	12.3 ppb
Mt Jefferson Jr High School	Teacher's Room Sink	5.3 ppb
Mt Vernon Elementary School	1st Grade Fountain	5.2 ppb
Mt Vernon Elementary School	1st Grade Sink	1.3 ppb
Mt Vernon Elementary School	2nd Grade Fountain	3.9 ppb
Mt Vernon Elementary School	2nd Grade Sink	2.3 ppb
Mt Vernon Elementary School	4th Grade Fountain	17.6 ppb

School Name	Sample Location	Lead Test Result
Mt Vernon Elementary School	4th Grade Rm Sink	11.3 ppb
Mt Vernon Elementary School	Art Rm Fountain	42.5 ppb
Mt Vernon Elementary School	Art Rm Sink	13.6 ppb
Mt Vernon Elementary School	Fountain Near Gym	0 ppb
Mt Vernon Elementary School	Kindergarten Rm Fountain	2.7 ppb
Mt Vernon Elementary School	Kindergarten Rm Sink	5.5 ppb
Mt Vernon Elementary School	Kitchen Sink #1	8.4 ppb
Mt Vernon Elementary School	Kitchen Sink #2	35.9 ppb
Mt Vernon Elementary School	Kitchen Sink #3	5.5 ppb
Mt Vernon Elementary School	Prek K Sink	2.4 ppb
Mt Vernon Elementary School	Special Needs Rm Sink	3.1 ppb
Mt Vernon Elementary School	Special Needs Rn Fountain	6.8 ppb
Mt Vernon Elementary School	Staff Breakroom 1 Sink	4.4 ppb
Mt Vernon Elementary School	Water Fountain Near Gym (bottle Fill)	0 ppb
Mt View Elementary School	E101- Fountain	0 ppb
Mt View Elementary School	E101- Handwash Sink	0 ppb
Mt View Elementary School	E102- Fountain	0 ppb
Mt View Elementary School	E102- Handwash Sink	0 ppb
Mt View Elementary School	E103- Fountain	0 ppb
Mt View Elementary School	E103- Handwash Sink	0 ppb
Mt View Elementary School	E105- Bathroom Sink	0 ppb
Mt View Elementary School	E105- Fountain	0 ppb
Mt View Elementary School	E105- Handwash Sink	0 ppb
Mt View Elementary School	E106- Fountain	0 ppb
Mt View Elementary School	E106- Handwash Sink	0 ppb
Mt View Elementary School	E107- Bathroom Sink	0 ppb
Mt View Elementary School	E108- Fountain	0 ppb
Mt View Elementary School	E108- Handwash Sink	0 ppb
Mt View Elementary School	E109- Handwash Sink	0 ppb
Mt View Elementary School	E109- Sink Sprayer	2.9 ppb
Mt View Elementary School	E110- Fountain	0 ppb
Mt View Elementary School	E110- Handwash Sink	0 ppb
Mt View Elementary School	E110- Utility Sink Fixture #1	3.5 ppb
Mt View Elementary School	E110- Utility Sink Fixture #2	3.9 ppb
Mt View Elementary School	E110- Utility Sprayer	12.9 ppb
Mt View Elementary School	E203- Handwash Sink	0 ppb
Mt View Elementary School	E204- Handwash Sink	0 ppb
Mt View Elementary School	E205- Handwash Sink	0 ppb
Mt View Elementary School	E206- Handwash Sink	0 ppb
Mt View Elementary School	E207- Handwash Sink	0 ppb
Mt View Elementary School	E208- Handwash Sink	0 ppb
Mt View Elementary School	E209- Handwash Sink	0 ppb
Mt View Elementary School	E210 Bathroom- Mens 3 Bay Handwash Sink #1	1.7 ppb
Mt View Elementary School	E210 Bathroom- Mens 3 Bay Handwash Sink #2	2.1 ppb

School Name	Sample Location	Lead Test Result
Mt View Elementary School	E210 Bathroom- Mens 3 Bay Handwash Sink #3	0 ppb
Mt View Elementary School	E210 Bathroom- Womens 3 Bay Handwash Sink #1	0 ppb
Mt View Elementary School	E210 Bathroom- Womens 3 Bay Handwash Sink #2	2.2 ppb
Mt View Elementary School	E210 Bathroom- Womens 3 Bay Handwash Sink #3	2.3 ppb
Mt View Elementary School	E210- Bottle Fill Station	0 ppb
Mt View Elementary School	E210- Bubbler/ Fountain	0 ppb
Mt View Elementary School	Elementary 1st Floor- Staff Bathroom	0 ppb
Mt View Elementary School	Elementary 1st Floor- Student Bathroom	0 ppb
Mt View Elementary School	Em112 Bathroom- Handwash Sink Boys	1.4 ppb
Mt View Elementary School	Em113 Bathroom- Handwash Sink Girls	1.2 ppb
Mt View Elementary School	Em114- Kitchen Handwash Sink	0 ppb
Mt View Elementary School	Em114- Kitchen Sprayer	0 ppb
Mt View Elementary School	Em118- Kitchen Handwash Sink	0 ppb
Mt View Elementary School	Em118- Kitchen Sprayer	0 ppb
Mt View Elementary School	Ice Machine (downstairs Boiler Room Door)	0 ppb
Mt View Elementary School	Library- Handwash Sink	0 ppb
Mt View Elementary School	Lobby Ele/mid Mens Br-handwash Sink 4 Bay #1	2 ppb
Mt View Elementary School	Lobby Ele/mid Mens Br-handwash Sink 4 Bay #2	2.8 ppb
Mt View Elementary School	Lobby Ele/mid Mens Br-handwash Sink 4 Bay #3	1.2 ppb
Mt View Elementary School	Lobby Ele/mid Mens Br-handwash Sink 4 Bay #4	1.9 ppb
Mt View Elementary School	Lobby Ele/mid Womens Br-handwash Sink 4 Bay #1	0 ppb
Mt View Elementary School	Lobby Ele/mid Womens Br-handwash Sink 4 Bay #2	1.5 ppb
Mt View Elementary School	Lobby Ele/mid Womens Br-handwash Sink 4 Bay #3	0 ppb
Mt View Elementary School	Lobby Ele/mid Womens Br-handwash Sink 4 Bay #4	1.5 ppb
Mt View Elementary School	Lobby Elementary/ Middl- Bottle Fill Station	0 ppb
Mt View Elementary School	Lobby Elementary/ Middle- Fountain	0 ppb
Mt View Elementary School	Locker Room Bathroom- Handwash Sink	2 ppb
Mt View High School	2nd H Nurse Station- Br Handwash Sink	0 ppb
Mt View High School	2nd H Nurse Station- Br Shower	360 ppb
Mt View High School	2nd H Nurse Station- Handwash Sink #1	0 ppb
Mt View High School	2nd H Nurse Station- Handwash Sink #2	0 ppb
Mt View High School	2nd H Nurse Station- Ice Machine	0 ppb
Mt View High School	2nd H Nurse Station- Sprayer	0 ppb

School Name	Sample Location	Lead Test Result
Mt View High School	Athletic Director Bathroom- Handwash Sink	1.9 ppb
Mt View High School	Athletic Director Bathroom- Shower	34.3 ppb
Mt View High School	Athletic Training Room- Handwash Sink	2.5 ppb
Mt View High School	Athletic Training Room- Ice Maker	0 ppb
Mt View High School	Guidence Room Bathroom- Handwash Sink	0 ppb
Mt View High School	H105 Changing Room- Handwash Sink	1.2 ppb
Mt View High School	H105- Fridge Ice Maker	0 ppb
Mt View High School	H105- Fridge Water	0 ppb
Mt View High School	H105- Kitchen Sink #1	0 ppb
Mt View High School	H105- Kitchen Sink #2	0 ppb
Mt View High School	H105- Kitchen Sprayer #1	2.1 ppb
Mt View High School	H105- Kitchen Sprayer #2	0 ppb
Mt View High School	H203 Science Room- Utility Sink #1	215 ppb
Mt View High School	H203 Science Room- Utility Sink #2	727 ppb
Mt View High School	H203 Science Room- Utility Sink #3	110 ppb
Mt View High School	H203 Science Room- Utility Sink #4	486 ppb
Mt View High School	H204 - Kitchen Sink	1.1 ppb
Mt View High School	H204- Sprayer	0 ppb
Mt View High School	H205 Science Room- Utility Sink #2	16.2 ppb
Mt View High School	H205 Science Room- Utility Sink #3	5.5 ppb
Mt View High School	H205 Science Room- Utility Sink #4	1.4 ppb
Mt View High School	H205 Science Room- Utility Sink #5	20.9 ppb
Mt View High School	H205 Science Room- Utility Sink #6	7.3 ppb
Mt View High School	H205 Science Room- Utility Sink #7	3.5 ppb
Mt View High School	H205 Science Room- Utility Sink #8	0 ppb
Mt View High School	H206 Science Room- Utility Sink #2	2 ppb
Mt View High School	H206 Science Room- Utility Sink #3	4.1 ppb
Mt View High School	H206 Science Room- Utility Sink #4	5.3 ppb
Mt View High School	H206 Science Room- Utility Sink #5	6.3 ppb
Mt View High School	H206 Science Room- Utility Sink #6	4.6 ppb
Mt View High School	H215- Kitchen Sink	0 ppb
Mt View High School	H215- Kitchen Sprayer	0 ppb
Mt View High School	High School 1st Floor- Bottle Fill Station	0 ppb
Mt View High School	High School 1st Floor- Fountain	0 ppb
Mt View High School	High School 1st Floor Mens Br- Handwash Sink #1	1.2 ppb
Mt View High School	High School 1st Floor Mens Br- Handwash Sink #2	1.2 ppb
Mt View High School	High School 1st Floor Mens Br- Handwash Sink #3	0 ppb
Mt View High School	High School 1st Floor Staff Br- Handwash Sink #1	2.1 ppb
Mt View High School	High School 1st Floor Staff Br- Handwash Sink #2	0 ppb
Mt View High School	High School 1st Floor Womens Br- Handwash Sink #1	1.1 ppb

School Name	Sample Location	Lead Test Result
Mt View High School	High School 1st Floor Womens Br- Handwash Sink #2	1.3 ppb
Mt View High School	High School 1st Floor Womens Br- Handwash Sink #3	1.4 ppb
Mt View High School	High School 2nd Floor Bathroom- Handwash Sink #1	1.4 ppb
Mt View High School	High School 2nd Floor Bathroom- Handwash Sink #2	1.4 ppb
Mt View High School	High School 2nd Floor Bathroom-handwash Sink #3 A	1.6 ppb
Mt View High School	High School 2nd Floor Bathroom-handwash Sink #3 B	1 ppb
Mt View High School	High School 2nd Floor Bathroom-handwash Sink #3 C	0 ppb
Mt View High School	High School 2nd Floor Bathroom-handwash Sink #4 A	1.4 ppb
Mt View High School	High School 2nd Floor Bathroom-handwash Sink #4 B	1.6 ppb
Mt View High School	High School 2nd Floor Bathroom-handwash Sink #4 C	1.6 ppb
Mt View High School	High School 2nd Floor- Bottle Fill Station	0 ppb
Mt View High School	High School 2nd Floor- Fountain	0 ppb
Mt View High School	High School Art Room- 1 Bay Utility Sink	0 ppb
Mt View High School	High School Art Room- Photeroom Sink #1	18.8 ppb
Mt View High School	High School Art Room- Photeroom Sink #2	6.9 ppb
Mt View High School	High School Art Room- Photeroom Sink #3	7.9 ppb
Mt View High School	High School Art Room- Sprayer #1	0 ppb
Mt View High School	High School Art Room- Sprayer #2	0 ppb
Mt View High School	High School Art Room-2 Bay Utility Sink #1	0 ppb
Mt View High School	High School Art Room-2 Bay Utility Sink #2	0 ppb
Mt View High School	High School Bandroom- Handwash Sink	0 ppb
Mt View High School	High School Bandroom- Sprayer	0 ppb
Mt View High School	High School Basement- Bottle Fill Station	0 ppb
Mt View High School	High School Basement- Fountain	0 ppb
Mt View High School	High School Basement Staff Br- Handwash Sink #1	1.9 ppb
Mt View High School	High School Basement Staff Br- Handwash Sink #2	1.2 ppb
Mt View High School	High School Library Workroom- Kitchen Sink	0 ppb
Mt View High School	High School Library Workroom- Sprayer	10.6 ppb
Mt View High School	High School Lobby- Bottle Fill Station #1	0 ppb
Mt View High School	High School Lobby- Bottle Fill Station#2	0 ppb
Mt View High School	High School Lobby- Fountain Next To Locker Room	0 ppb
Mt View High School	High School Lobby- High Fountain	0 ppb
Mt View High School	High School Lobby- Low Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Mt View High School	High School Lobby- Mens Bathroom Sink #1	2 ppb
Mt View High School	High School Lobby- Mens Bathroom Sink #3	2.2 ppb
Mt View High School	High School Lobby- Womens Bathroom Sink #1	2 ppb
Mt View High School	High School Lobby- Womens Bathroom Sink #2	1.8 ppb
Mt View High School	High School Lobby- Womens Bathroom Sink #3	2 ppb
Mt View High School	High School Locker Rm- Mens Handwash Sink #1	0 ppb
Mt View High School	High School Locker Rm- Mens Handwash Sink #2	1.2 ppb
Mt View High School	High School Locker Rm- Mens Shower #1	111 ppb
Mt View High School	High School Locker Rm- Mens Shower #2	30.7 ppb
Mt View High School	High School Locker Rm- Mens Shower #3	60.9 ppb
Mt View High School	High School Locker Rm- Mens Shower #4	31.5 ppb
Mt View High School	High School Locker Rm- Mens Shower #5	67.8 ppb
Mt View High School	High School Locker Rm- Womens Handwash Sink #1	1 ppb
Mt View High School	High School Locker Rm- Womens Handwash Sink #2	0 ppb
Mt View High School	High School Locker Rm- Womens Shower #1	43.2 ppb
Mt View High School	High School Locker Rm- Womens Shower #2	6.3 ppb
Mt View High School	High School Locker Rm- Womens Shower #3	53.3 ppb
Mt View High School	High School Locker Rm- Womens Shower #4	97.3 ppb
Mt View High School	High School Locker Rm- Womens Shower #5	46.9 ppb
Mt View High School	High School Office- Bathroom Handwash Sink #1	1.2 ppb
Mt View High School	High School Office- Bathroom Handwash Sink #2	2.2 ppb
Mt View High School	High School Office Breakroom- Kitchen Sink	0 ppb
Mt View High School	High School Office Breakroom- Sprayer	446 ppb
Mt View High School	M209 Art- 1 Bay Utility Sink	0 ppb
Mt View High School	M209 Art- 2 Bay Utility Sink #1	2 ppb
Mt View High School	M209 Art- 2 Bay Utility Sink #2	0 ppb
Mt View High School	Outdoor Hose Spigot #4 (designated Dwspigot)	1.3 ppb
Mt View High School	Room H013- Kitchen Sink	0 ppb
Mt View High School	Room H103- Kitchen Sprayer	1.2 ppb

School Name	Sample Location	Lead Test Result
Mt View High School	Room H128- Kitchen Sink	0 ppb
Mt View High School	Room H128- Kitchen Sprayer	0 ppb
Mt View High School	Room H132- Ice Maker	0 ppb
Mt View Middle School	1st Floor Middle- Bottle Fill Station	0 ppb
Mt View Middle School	1st Floor Middle- Fountain	0 ppb
Mt View Middle School	C107 Nurse Station Br- Handwash	6 ppb
Mt View Middle School	C107 Nurse Station Br- Shower	192 ppb
Mt View Middle School	C107 Nurse Station- Handwash Sink	0 ppb
Mt View Middle School	C107 Nurse Station- Sprayer	1.1 ppb
Mt View Middle School	Hall Off Kitchen C117- Coffee Maker	2.1 ppb
Mt View Middle School	Hall Off Kitchen C117- Fridge	0 ppb
Mt View Middle School	Hall Off Kitchen C117- Kitchen Sink	0 ppb
Mt View Middle School	Hall Off Kitchen- Fountain- Low	0 ppb
Mt View Middle School	Hall Off Kitchen Mens Br- Handwash Sink #1	1.1 ppb
Mt View Middle School	Hall Off Kitchen- Mens Br- Handwash Sink #3	0 ppb
Mt View Middle School	Hall Off Kitchen Nurse Station-mens Br Hw Sink	0 ppb
Mt View Middle School	Hall Off Kitchen Nurse Station-womens Br Hw Sink	0 ppb
Mt View Middle School	Hall Off Kitchen- Womens Br- Handwash Sink #2	0 ppb
Mt View Middle School	Hall Off Kitchen- Womens Br- Handwash Sink #3	0 ppb
Mt View Middle School	Hall Off Kitchen-bottle Fill Station	0 ppb
Mt View Middle School	Hall Off Kitchen-fountain- High	0 ppb
Mt View Middle School	Hall Off Kitchen-mens Br- Handwash Sink #2	1.2 ppb
Mt View Middle School	Hall Off Kitchen-womens Br- Handwash Sink#1	0 ppb
Mt View Middle School	Kitchen- Dishwash 2 Bay Sink #1	0 ppb
Mt View Middle School	Kitchen- Dishwash 2 Bay Sink #2	0 ppb
Mt View Middle School	Kitchen- Dishwash Sprayer #1	0 ppb
Mt View Middle School	Kitchen- Dishwash Sprayer #2	0 ppb
Mt View Middle School	Kitchen- Handwash Sink #1	0 ppb
Mt View Middle School	Kitchen- Handwash Sink #2	0 ppb
Mt View Middle School	Kitchen- Handwash Sink #3	0 ppb
Mt View Middle School	Kitchen- Handwash Sink #4	0 ppb
Mt View Middle School	Kitchen- Handwash Sink #5	0 ppb
Mt View Middle School	Kitchen- Market Force Cooker Fill	0 ppb
Mt View Middle School	Kitchen- Prep Sink #1	1.4 ppb
Mt View Middle School	Kitchen- Prep Sink #2	1.4 ppb
Mt View Middle School	Kitchen- Prep Sink #3	5.1 ppb
Mt View Middle School	Kitchen- Sprayer #1	0 ppb
Mt View Middle School	Kitchen- Sprayer #2	0 ppb
Mt View Middle School	Kitchen- Sprayer #3	1.1 ppb

School Name	Sample Location	Lead Test Result
Mt View Middle School	M104- Science Utility Sink #1	56.4 ppb
Mt View Middle School	M104- Science Utility Sink #2	0 ppb
Mt View Middle School	M104- Science Utility Sink #3	2.3 ppb
Mt View Middle School	M104- Science Utility Sink #4	1.7 ppb
Mt View Middle School	M104- Science Utility Sink #5	3 ppb
Mt View Middle School	M104- Science Utility Sink #6	2.4 ppb
Mt View Middle School	M104- Science Utility Sink #7	1.4 ppb
Mt View Middle School	M108- Kitchen Bathroom Handwash Sink	0 ppb
Mt View Middle School	M108- Kitchen Sink #1	0 ppb
Mt View Middle School	M108- Kitchen Sink #2	0 ppb
Mt View Middle School	M108- Kitchen Sprayer #1	0 ppb
Mt View Middle School	M108- Kitchen Sprayer #2	0 ppb
Mt View Middle School	M204- Science Utility Sink #1	21.6 ppb
Mt View Middle School	M204- Science Utility Sink #2	1.2 ppb
Mt View Middle School	M204- Science Utility Sink #3	3.1 ppb
Mt View Middle School	M204- Science Utility Sink #4	2.5 ppb
Mt View Middle School	M204- Science Utility Sink #5	889 ppb
Mt View Middle School	M204- Science Utility Sink #6	2.8 ppb
Mt View Middle School	M204- Science Utility Sink #7	4.7 ppb
Mt View Middle School	M215/ 216- Bottle Fill Station	0 ppb
Mt View Middle School	M215/ 216- Fountain	0 ppb
Mt View Middle School	M215-womens Bathroom Handwash Sink 3 Bay #2	2.5 ppb
Mt View Middle School	M215-womens Bathroom Handwash Sink 3 Bay #3	2.1 ppb
Mt View Middle School	M216- Mens Bathroom Handwash Sink 3 Bay #1	2 ppb
Mt View Middle School	M216- Mens Bathroom Handwash Sink 3 Bay #3	2.4 ppb
Mt View Middle School	M222- Kitchen Sink	0 ppb
Mt View Middle School	M222- Sprayer	1.5 ppb
Mt View Middle School	M223- Mens Bathroom Handwash Sink 2 Bay #1	0 ppb
Mt View Middle School	M223- Mens Bathroom Handwash Sink 2 Bay #2	0 ppb
Mt View Middle School	M224- Womens Bathroom Handwash Sink 2 Bay #1	0 ppb
Mt View Middle School	M224- Womens Bathroom Handwash Sink 2 Bay #2	1.8 ppb
Mt View Middle School	M304- Science Utility Sink #1	928 ppb
Mt View Middle School	M304- Science Utility Sink #2	0 ppb
Mt View Middle School	M304- Science Utility Sink #3	3.7 ppb
Mt View Middle School	M304- Science Utility Sink #4	1.4 ppb
Mt View Middle School	M304- Science Utility Sink #5	12.9 ppb
Mt View Middle School	M304- Science Utility Sink #6	1.1 ppb
Mt View Middle School	M304- Science Utility Sink #7	0 ppb
Mt View Middle School	Mid 3rd Floor- Bottle Fill Station	0 ppb

School Name	Sample Location	Lead Test Result
Mt View Middle School	Mid 3rd Floor- Fountain	0 ppb
Mt View Middle School	Mid 3rd Floor- Womens Br Handwash Sink 3 Bay #1	2.4 ppb
Mt View Middle School	Mid 3rd Floor- Womens Br Handwash Sink 3 Bay #2	2 ppb
Mt View Middle School	Mid 3rd Floor- Womens Br Handwash Sink 3 Bay #3	1.9 ppb
Mt View Middle School	Mid 3rd Floor-mens Br Handwash Sink 3 Bay #1	1.4 ppb
Mt View Middle School	Mid 3rd Floor-mens Br Handwash Sink 3 Bay #2	2.2 ppb
Mt View Middle School	Mid 3rd Floor-mens Br Handwash Sink 3 Bay #3	1.7 ppb
Mt View Middle School	Mid/ Ele- Cafeteria Handwash #1	0 ppb
Mt View Middle School	Mid/ Ele- Cafeteria Handwash #2	0 ppb
Mt View Middle School	Middle Gym Mens Locker Room- Handwash Sink #1	0 ppb
Mt View Middle School	Middle Gym Mens Locker Room- Handwash Sink #2	0 ppb
Mt View Middle School	Middle Gym Mens Locker Room- Shower #1	96.4 ppb
Mt View Middle School	Middle Gym Mens Locker Room- Shower #2	33 ppb
Mt View Middle School	Middle Gym Mens Locker Room- Shower #3	27.2 ppb
Mt View Middle School	Middle Gym Womens Locker Room- Handwash #1	2.1 ppb
Mt View Middle School	Middle Gym Womens Locker Room- Handwash #2	1.4 ppb
Mt View Middle School	Middle Gym Womens Locker Room- Shower #1	464 ppb
Mt View Middle School	Middle Gym Womens Locker Room- Shower #2	28.4 ppb
Mt View Middle School	Middle Gym Womens Locker Room- Shower #3	222 ppb
Narragansett Elementary School	Across From Room 15a	1.7 ppb
Narragansett Elementary School	Cafe Water Cooler Bottle Filler	20.5 ppb
Narragansett Elementary School	Corridor Near Room 10b	0 ppb
Narragansett Elementary School	Entry Corridor To North Wing 4	0 ppb
Narragansett Elementary School	Entry Corridor To North Wing A	1.7 ppb
Narragansett Elementary School	Entry Corridor To North Wing B	1.7 ppb
Narragansett Elementary School	Entry Corridor To North Wing C	0 ppb
Narragansett Elementary School	Kitchen	16.2 ppb
Narragansett Elementary School	Kitchen Prep Sink Near Cooler	40.9 ppb
Narragansett Elementary School	Kitchen Prep Sink Near Disposal	203 ppb
Narragansett Elementary School	Nurse Sink	1 ppb
Narragansett Elementary School	Room 1	15.8 ppb

School Name	Sample Location	Lead Test Result
Narragansett Elementary School	Room 10	1.4 ppb
Narragansett Elementary School	Room 11	2.4 ppb
Narragansett Elementary School	Room 14b	1.3 ppb
Narragansett Elementary School	Room 15	1.6 ppb
Narragansett Elementary School	Room 16	3.2 ppb
Narragansett Elementary School	Room 17	1.7 ppb
Narragansett Elementary School	Room 18	1.6 ppb
Narragansett Elementary School	Room 19	5.1 ppb
Narragansett Elementary School	Room 2	0 ppb
Narragansett Elementary School	Room 20	3 ppb
Narragansett Elementary School	Room 21	0 ppb
Narragansett Elementary School	Room 22	1.4 ppb
Narragansett Elementary School	Room 23	1.4 ppb
Narragansett Elementary School	Room 3	10.6 ppb
Narragansett Elementary School	Room 4	29.9 ppb
Narragansett Elementary School	Room 5	2.1 ppb
Narragansett Elementary School	Room 6	1.3 ppb
Narragansett Elementary School	Room 7	1.5 ppb
Narragansett Elementary School	Room 8	5.1 ppb
Narragansett Elementary School	Room 9	1.3 ppb
Narragansett Elementary School	Teachers Lounge Off Gym	3 ppb
Narraguagus High School	Kitchen 2 Bay Sink	12.8 ppb
Narraguagus High School	Kitchen 3 Bay Sink	6.4 ppb
Narraguagus High School	Lobby Drinking Water Fountain	1.3 ppb
Narraguagus High School	Middle Hall Drinking Water Fountain Left	2.6 ppb
Narraguagus High School	Middle Hall Drinking Water Fountain Right	5.1 ppb
Narraguagus High School	New Wing Drinking Fountain Left	1.7 ppb
Narraguagus High School	New Wing Drinking Fountain Right	1.5 ppb
Narraguagus High School	Teachers Room Sink	2.3 ppb
New Dike-Newell School	Boys Bathroom By Cafeteria	0 ppb
New Dike-Newell School	Boys Room 1st Floor Near Office	0 ppb
New Dike-Newell School	Girls Bathroom By Cafeteria	0 ppb
New Dike-Newell School	Girls Room 1st Floor Near Office	0 ppb
New Dike-Newell School	Kitchen Large Sink On Left	9 ppb
New Dike-Newell School	Kitchen Sink In Island Style Of Counter	12.1 ppb
New Suncook School	Cafeteria	0 ppb
New Suncook School	Gym	0 ppb
New Suncook School	Hallway By Cafeteria	0 ppb
New Suncook School	Kitchen #1	1.5 ppb
New Suncook School	Kitchen #2	1.3 ppb
New Suncook School	Room 101	0 ppb
New Suncook School	Room 102	1.3 ppb
New Suncook School	Room 121	1.6 ppb
New Suncook School	Room 127	2.6 ppb
New Suncook School	Room 137	0 ppb
New Suncook School	Room 138	0 ppb
New Suncook School	Room 139	0 ppb

School Name	Sample Location	Lead Test Result
New Suncook School	Room 142	1.2 ppb
New Suncook School	Room 143	1.5 ppb
New Suncook School	Room 144	1.3 ppb
New Suncook School	Room 151	0 ppb
New Suncook School	Teacher Room	0 ppb
Newburgh Elementary School	Kitchen Faucet At 3 Bay Sink	0 ppb
NFI Buxton-Beacon House	Dining Room Fountain	0 ppb
NFI Buxton-Beacon House	Dining Room Ice Machine	0 ppb
NFI Buxton-Beacon House	Kitchen Faucet	0 ppb
NFI Buxton-Beacon House	Kitchen Fountain	0 ppb
NFI Buxton-Beacon House	Kitchen Ice Machine	0 ppb
NFI Sidney Riverbend School	Kitchen Faucet	11.3 ppb
NFI-Stetson Ranch School	Coffee Pot	0 ppb
NFI-Stetson Ranch School	Kitchen Faucet	0 ppb
No Penobscot Tech-Region 3	Conference Room Sink	8.1 ppb
No Penobscot Tech-Region 3	Sink In Kitchen Left Wall	1.8 ppb
No Penobscot Tech-Region 3	Water Fountain 1st Floor	0 ppb
No Penobscot Tech-Region 3	Water Fountain 2nd Floor	0 ppb
No Penobscot Tech-Region 3	Water Fountain Automotive Shop	1.5 ppb
No Penobscot Tech-Region 3	Water Fountain Welding Shop	5.6 ppb
No Penobscot Tech-Region 3	Water Fountain Wood Shop	1.5 ppb
Noble High School	Food Court Kitchen Sink #1	3.6 ppb
Noble High School	Food Court Kitchen Sink #2	1 ppb
Noble High School	Hallway A158 Drinking Fountain	0 ppb
Noble High School	Hallway A177 Drinking Fountain	0 ppb
Noble High School	Hallway A601 Drinking Fountain	0 ppb
Noble High School	Hallway A656 Drinking Fountain	0 ppb
Noble High School	Hallway B231 Drinking Fountain	0 ppb
Noble High School	Hallway B752 Drinking Fountain	0 ppb
Noble High School	Hallway D428 Drinking Fountain	0 ppb
Noble High School	Hallway E510 Drinking Fountain	0 ppb
Noble High School	Handwash Sink #1	0 ppb
Noble High School	Handwash Sink #2	0 ppb
Noble High School	Handwash Sink #3	0 ppb
Noble High School	Kitchen Prep Sink #1	0 ppb
Noble High School	Kitchen Prep Sink #2	2.7 ppb
Noble High School	Kitchen Prep Sink #3	3 ppb
Noble High School	Kitchen Prep Sink #4	0 ppb
Noble High School	Kitchen Prep Sink #5	1.1 ppb
Noble High School	Kitchen Prep Sink #6	3.8 ppb
Noble High School	Room 101	0 ppb
Noble High School	Room 111a	0 ppb
Noble High School	Room 111b Sink #2	0 ppb
Noble High School	Room 111b Sink #1	0 ppb
Noble High School	Room 112 Sink	0 ppb
Noble High School	Room 113b Sink	0 ppb
Noble High School	Room 123 Sink	0 ppb

School Name	Sample Location	Lead Test Result
Noble High School	Room 125a Sink	0 ppb
Noble High School	Room 128 Sink	0 ppb
Noble High School	Room 133 Sink	0 ppb
Noble High School	Room 138 Sink	0 ppb
Noble High School	Room 143 Sink	0 ppb
Noble High School	Room 148 Sink	0 ppb
Noble High School	Room 153 Sink	0 ppb
Noble High School	Room 158 Sink	0 ppb
Noble High School	Room 159 Sink	0 ppb
Noble High School	Room 207 Sink	0 ppb
Noble High School	Room 208 Sink	0 ppb
Noble High School	Room 223 Sink #1	0 ppb
Noble High School	Room 223 Sink #2	0 ppb
Noble High School	Room 224 Sink	0 ppb
Noble High School	Room 228 Sink	0 ppb
Noble High School	Room 234 Sink	0 ppb
Noble High School	Room 238 Sink	0 ppb
Noble High School	Room 242 Sink	0 ppb
Noble High School	Room 248 Sink	0 ppb
Noble High School	Room 253 Sink	0 ppb
Noble High School	Room 258 Sink	0 ppb
Noble High School	Room 264 Sink	0 ppb
Noble High School	Room 271 Sink	0 ppb
Noble High School	Room 300 Sink	0 ppb
Noble High School	Room 302 Sink	0 ppb
Noble High School	Room 303 Sink	0 ppb
Noble High School	Room 311 Prep Sink #1	0 ppb
Noble High School	Room 311 Prep Sink #2	0 ppb
Noble High School	Room 311 Prep Sink #3	0 ppb
Noble High School	Room 312 Prep Sink #1	0 ppb
Noble High School	Room 312 Prep Sink #2	2.4 ppb
Noble High School	Room 312 Prep Sink #3	4.4 ppb
Noble High School	Room 312 Prep Sink #4	7.9 ppb
Noble High School	Room 313 Prep Sink #1	0 ppb
Noble High School	Room 313 Prep Sink #2	1.1 ppb
Noble High School	Room 313 Prep Sink #3	1.1 ppb
Noble High School	Room 313 Prep Sink #4	2 ppb
Noble High School	Room 313 Prep Sink #5	0 ppb
Noble High School	Room 313 Prep Sink #6	0 ppb
Noble High School	Room 313 Prep Sink #7	0 ppb
Noble High School	Room 313 Prep Sink #8	0 ppb
Noble High School	Room 314 Prep Sink #1	771 ppb
Noble High School	Room 314 Prep Sink #2	730 ppb
Noble High School	Room 314 Prep Sink #3	7830 ppb
Noble High School	Room 314 Prep Sink #4	3 ppb
Noble High School	Room 322 Sink	0 ppb
Noble High School	Room 323 Sink	0 ppb

School Name	Sample Location	Lead Test Result
Noble High School	Room 324 Sink	0 ppb
Noble High School	Room 331 Sink	1.8 ppb
Noble High School	Room 332 Sink	1.6 ppb
Noble High School	Room 334 Sink	2.6 ppb
Noble High School	Room 348 Sink	0 ppb
Noble High School	Room 350 Sink	0 ppb
Noble High School	Room 511 Sink	0 ppb
Noble High School	Room 512 Sink	0 ppb
Noble High School	Room 513 Sink	0 ppb
Noble High School	Room 514 Sink	1.2 ppb
Noble High School	Room 515 Sink	1.1 ppb
Noble High School	Room 520 Sink	0 ppb
Noble High School	Room 525 Ice Machine #1	0 ppb
Noble High School	Room 525 Ice Machine #2	0 ppb
Noble High School	Room 528 Sink	0 ppb
Noble High School	Steam Kettle #1	1.9 ppb
Noble High School	Steam Kettle #2	0 ppb
Noble High School	Town Square Drinking Fountain #1	0 ppb
Noble High School	Town Square Drinking Fountain #2	0 ppb
Noble Middle School	First Floor Hallway Drinking Fountain	0 ppb
Noble Middle School	Kitchen Hand Wash Sink	1.6 ppb
Noble Middle School	Kitchen Prep Sink #1	0 ppb
Noble Middle School	Kitchen Prep Sink #2	0 ppb
Noble Middle School	Kitchen Prep Sink #3	0 ppb
Noble Middle School	Main Hall Drinking Fountain	0 ppb
Noble Middle School	Main Office Drinking Fountain	0 ppb
Noble Middle School	Nurse Office Sink	1.8 ppb
Noble Middle School	Romm #210 Sink	1.6 ppb
Noble Middle School	Room #103 Sink #1	1.1 ppb
Noble Middle School	Room #103 Sink #2	1.1 ppb
Noble Middle School	Room #104 Sink	2.6 ppb
Noble Middle School	Room #110 Sink #1	2.3 ppb
Noble Middle School	Room #110 Sink #2	3.1 ppb
Noble Middle School	Room #110 Sink #3	1.7 ppb
Noble Middle School	Room #110 Sink #4	1.8 ppb
Noble Middle School	Room #202 Sink	4.5 ppb
Noble Middle School	Room #203 Sink	3 ppb
Noble Middle School	Room #212 Sink	0 ppb
Noble Middle School	Second Floor Hallway Drinking Fountain	0 ppb
Nobleboro Central School	1st Grade (e01) Fountain	2.3 ppb
Nobleboro Central School	1st Grade (e01) Sink	4.6 ppb
Nobleboro Central School	2nd Grade (e04) Sink	2.2 ppb
Nobleboro Central School	3rd Grade (a35) Sink	2.4 ppb
Nobleboro Central School	4th Grade (a36) Sink	3.8 ppb
Nobleboro Central School	7th Grade (a45) Eyewash Sink	8.2 ppb
Nobleboro Central School	7th Grd(a45) Lab Sink Right Closer To Back Wall A	34.4 ppb

School Name	Sample Location	Lead Test Result
Nobleboro Central School	7th Grd(a45)lab Sink Center Closer To Back Wall A	32 ppb
Nobleboro Central School	7th Grd(a45)lab Sink Center Closer To Back Wall B	30.6 ppb
Nobleboro Central School	7th Grd(a45)lab Sink Left Closer To Back Wall A	32.2 ppb
Nobleboro Central School	7th Grd(a45)lab Sink Left Closer To Back Wall B	38.2 ppb
Nobleboro Central School	7th Grd(a45)lab Sink Right Closer To Back Wall B	50.6 ppb
Nobleboro Central School	7th Grd(a45)lab Sink(lft Closest To Front Classa)	22 ppb
Nobleboro Central School	7th Grd(a45)lab Sink(lft Closest To Front Classb)	38.8 ppb
Nobleboro Central School	7th Grd(a45)lab Snk Cnter Closest To Front Classa	20.5 ppb
Nobleboro Central School	7th Grd(a45)lab Snk Cnter Closest To Front Classb	138 ppb
Nobleboro Central School	7th Grd(a45)lab Snk Right Closest To Front Classa	37.6 ppb
Nobleboro Central School	7th Grd(a45)lab Snk Right Closest To Front Classb	28.1 ppb
Nobleboro Central School	Art Room (a30) Sink Closest To Exit & Kiln	1.5 ppb
Nobleboro Central School	Art Room (a30) Sink For Eye Wash	17.7 ppb
Nobleboro Central School	Art Room (a30) Sink In Island	4.5 ppb
Nobleboro Central School	Art Room (a30) Sink Near Stove	7.1 ppb
Nobleboro Central School	Basement Bathroom Hand Sink	138 ppb
Nobleboro Central School	Boys Lockerroom (a27) Sink (left)	15.1 ppb
Nobleboro Central School	Boys Lockerroom (a27) Sink (right)	5.9 ppb
Nobleboro Central School	Cal (a39) Sink	6.2 ppb
Nobleboro Central School	Conference/ Technology Office (e19) Fountain	10.1 ppb
Nobleboro Central School	Conference/ Technology Office (e19) Sink	5.3 ppb
Nobleboro Central School	Girls Lockerroom (a26) Sink (left)	7.2 ppb
Nobleboro Central School	Girls Lockerroom (a26) Sink (right)	5.2 ppb
Nobleboro Central School	Jr. High Boys Bathroom (a32) Sink	2 ppb
Nobleboro Central School	Jr. High Girls Bathroom (a31) Sink (left)	2.1 ppb
Nobleboro Central School	Jr. High Girls Bathroom (a31) Sink (right)	1.7 ppb
Nobleboro Central School	Jr. High Wing Bottle Fill	1.2 ppb
Nobleboro Central School	Jr. High Wing Fountain	1.1 ppb
Nobleboro Central School	Kindergarten (e03) Fountain	4.3 ppb
Nobleboro Central School	Kindergarten (e03) Sink	1.7 ppb
Nobleboro Central School	Kitchen 2-bay Pot Sink (a13) (left Side)	19.4 ppb
Nobleboro Central School	Kitchen 2-bay Pot Sink (a13) (right Side)	202 ppb
Nobleboro Central School	Kitchen 2-bay Vegetable Sink (a13)	2.5 ppb
Nobleboro Central School	Kitchen Dishwasher Sprayer (a13)	2.2 ppb
Nobleboro Central School	Kitchen Handwashing Sink (a13)	34.9 ppb

School Name	Sample Location	Lead Test Result
Nobleboro Central School	Library (a05) Sink (office)	6.9 ppb
Nobleboro Central School	Locker Hallway Bottle Fill	0 ppb
Nobleboro Central School	Locker Hallway Fountain	0 ppb
Nobleboro Central School	Lower Lobby Boys Bathroom (a23) Sink	2.3 ppb
Nobleboro Central School	Lower Lobby Girls Bathroom (a12) Sink (left)	2.6 ppb
Nobleboro Central School	Lower Lobby Girls Bathroom (a21) Sink (right)	3.4 ppb
Nobleboro Central School	Main Office Bathroom Sink (e12)	3.4 ppb
Nobleboro Central School	Nurses Office Sink (e09)	3 ppb
Nobleboro Central School	Outside Spigot	244 ppb
Nobleboro Central School	P.e Office (a18) Bathroom Sink	4.2 ppb
Nobleboro Central School	Resource-/ Special Ed (a38) Sink	5.6 ppb
Nobleboro Central School	Teachers Room Sink (a28)	4 ppb
Nobleboro Central School	Title 1 (e02) Sink	3.5 ppb
Nokomis Regional High School	C002 Sink 1	0 ppb
Nokomis Regional High School	C002 Sink 2	0 ppb
Nokomis Regional High School	C005 Sink	0 ppb
Nokomis Regional High School	C008 Sink 1	0 ppb
Nokomis Regional High School	C008 Sink 2	0 ppb
Nokomis Regional High School	C008 Sink 3	0 ppb
Nokomis Regional High School	C008 Sink 4	4.6 ppb
Nokomis Regional High School	C010 Sink	4.3 ppb
Nokomis Regional High School	C106 Hall Bottle	0 ppb
Nokomis Regional High School	C106 Hall Fountain Down	0 ppb
Nokomis Regional High School	C106 Hall Fountain Up	0 ppb
Nokomis Regional High School	C106b Hall Bottle	0 ppb
Nokomis Regional High School	C106b Hall Fountain Down	0 ppb
Nokomis Regional High School	C106b Hall Fountain Up	0 ppb
Nokomis Regional High School	C113 Center Faucet	7.1 ppb
Nokomis Regional High School	C113 Dishwasher Faucet 1	1.2 ppb
Nokomis Regional High School	C113 Dishwasher Faucet 2	0 ppb
Nokomis Regional High School	C113 Hand Wash 1	4.7 ppb
Nokomis Regional High School	C113 Hand Wash 2	2.3 ppb
Nokomis Regional High School	C113 Hand Wash 3	0 ppb
Nokomis Regional High School	C113 Ice	0 ppb
Nokomis Regional High School	C113 Steamer	15.6 ppb
Nokomis Regional High School	H001 Fountain	1.8 ppb
Nokomis Regional High School	H001 Sink	0 ppb
Nokomis Regional High School	H001a Sink	0 ppb
Nokomis Regional High School	H001d Sink	0 ppb
Nokomis Regional High School	H002 Sink Left	0 ppb
Nokomis Regional High School	H002 Sink Right	1.2 ppb
Nokomis Regional High School	H003 Sink	1.3 ppb
Nokomis Regional High School	H004 Sink	0 ppb
Nokomis Regional High School	H005 Sink Left	1.5 ppb
Nokomis Regional High School	H005 Sink Middle	0 ppb

School Name	Sample Location	Lead Test Result
Nokomis Regional High School	H005 Sink Right	0 ppb
Nokomis Regional High School	H006 Hall Bottle	0 ppb
Nokomis Regional High School	H006 Hall Fountain Down	0 ppb
Nokomis Regional High School	H006 Hall Fountain Up	0 ppb
Nokomis Regional High School	H006 Sink Left	0 ppb
Nokomis Regional High School	H006 Sink Middle	0 ppb
Nokomis Regional High School	H006 Sink Right	0 ppb
Nokomis Regional High School	H007 Sink	0 ppb
Nokomis Regional High School	H011 Sink	1 ppb
Nokomis Regional High School	H012 Sink	0 ppb
Nokomis Regional High School	H013 Sink	2.3 ppb
Nokomis Regional High School	H014 Sink	0 ppb
Nokomis Regional High School	H102 Sink	0 ppb
Nokomis Regional High School	H111 Sink	0 ppb
Nokomis Regional High School	H119 Sink	0 ppb
Nokomis Regional High School	H120a Sink	0 ppb
Nokomis Regional High School	H120b Sink	1.2 ppb
Nokomis Regional High School	H133b Sink	1.4 ppb
Nokomis Regional High School	H133e Sink	0 ppb
Nokomis Regional High School	H135 Sink	0 ppb
Nokomis Regional High School	H142 Fountain Down	0 ppb
Nokomis Regional High School	H142 Fountain Up	0 ppb
Nokomis Regional High School	H145 Sink	0 ppb
Nokomis Regional High School	H146 Sink	0 ppb
Nokomis Regional High School	H147 Sink	0 ppb
Nokomis Regional High School	H148 Sink	0 ppb
Nokomis Regional High School	H151 Ice	0 ppb
Nokomis Regional High School	H151 Sink	0 ppb
Nokomis Regional High School	H155 Sink Center	0 ppb
Nokomis Regional High School	H155 Sink Left	0 ppb
Nokomis Regional High School	H155 Sink Right	0 ppb
Nokomis Regional High School	H156 Sink Center	0 ppb
Nokomis Regional High School	H156 Sink Left	0 ppb
Nokomis Regional High School	H156 Sink Right	0 ppb
Nokomis Regional High School	H156a Sink	0 ppb
Nokomis Regional High School	H157 Sink Center	0 ppb
Nokomis Regional High School	H157 Sink Left	0 ppb
Nokomis Regional High School	H157 Sink Right	0 ppb
Nokomis Regional High School	H157a Sink	0 ppb
Nokomis Regional High School	H161a Sink	0 ppb
Nokomis Regional High School	H165 Sink	0 ppb
Nokomis Regional High School	H170 Bottle Filler	0 ppb
Nokomis Regional High School	H170 Fountain Down	0 ppb
Nokomis Regional High School	H170 Fountain Up	0 ppb
Nokomis Regional High School	H170 Sink	0 ppb
Nokomis Regional High School	H171 Sink	0 ppb
Nokomis Regional High School	H215 Breakroom	0 ppb

School Name	Sample Location	Lead Test Result
Nokomis Regional High School	H222 Hall Bottle	0 ppb
Nokomis Regional High School	H222 Hall Fountain Down	0 ppb
Nokomis Regional High School	H222 Hall Fountain Up	0 ppb
Nokomis Regional High School	H225 Sink	0 ppb
Nokomis Regional High School	H226 Sink	0 ppb
Nokomis Regional High School	H227 Middle Girls	0 ppb
Nokomis Regional High School	H227 Sink Left	0 ppb
Nokomis Regional High School	H227 Sink Right	0 ppb
Nokomis Regional High School	H228 Middle Boys	0 ppb
Nokomis Regional High School	H228 Sink Left	1.4 ppb
Nokomis Regional High School	H228 Sink Right	0 ppb
Nokomis Regional High School	H234 Sink	0 ppb
Nokomis Regional High School	Kitchen Dw Hand Sink	0 ppb
Nokomis Regional Middle School	C007 Sink 1	0 ppb
Nokomis Regional Middle School	C007 Sink 2	1.5 ppb
Nokomis Regional Middle School	C007 Sink 3	2.1 ppb
Nokomis Regional Middle School	C007 Sink 4	0 ppb
Nokomis Regional Middle School	C103 Sink	0 ppb
Nokomis Regional Middle School	C204 Sink	0 ppb
Nokomis Regional Middle School	M007 Sink	0 ppb
Nokomis Regional Middle School	M012 Sink Left	0 ppb
Nokomis Regional Middle School	M012 Sink Right	0 ppb
Nokomis Regional Middle School	M013 Sink	0 ppb
Nokomis Regional Middle School	M014 Sink	0 ppb
Nokomis Regional Middle School	M015 Sink	0 ppb
Nokomis Regional Middle School	M017 Sink Left	0 ppb
Nokomis Regional Middle School	M017 Sink Right	0 ppb
Nokomis Regional Middle School	M018 Hall Bottle	0 ppb
Nokomis Regional Middle School	M018 Hall Fountain Down	0 ppb
Nokomis Regional Middle School	M018 Hall Fountain Up	0 ppb
Nokomis Regional Middle School	M123 Sink Left	0 ppb
Nokomis Regional Middle School	M123 Sink Right	0 ppb
Nokomis Regional Middle School	M123a Sink	1.1 ppb
Nokomis Regional Middle School	M125 Sink	0 ppb
Nokomis Regional Middle School	M127 Sink Left	0 ppb
Nokomis Regional Middle School	M127 Sink Right	0 ppb
Nokomis Regional Middle School	M128 Sink Left	0 ppb
Nokomis Regional Middle School	M128 Sink Right	0 ppb
Nokomis Regional Middle School	M130d Sink	0 ppb
Nokomis Regional Middle School	M131b Sink	1.4 ppb
Nokomis Regional Middle School	M132b Sink	1.5 ppb
Nokomis Regional Middle School	M147 Sink	0 ppb
Nokomis Regional Middle School	M152 Sink Left	0 ppb
Nokomis Regional Middle School	M152 Sink Right	0 ppb
Nokomis Regional Middle School	M153 Sink	0 ppb
Nokomis Regional Middle School	M154 Sink	0 ppb
Nokomis Regional Middle School	M155 Sink	0 ppb

School Name	Sample Location	Lead Test Result
Nokomis Regional Middle School	M157 Sink Left	0 ppb
Nokomis Regional Middle School	M157 Sink Right	0 ppb
Nokomis Regional Middle School	M158 Hall Bottle	0 ppb
Nokomis Regional Middle School	M158 Hall Fountain Down	0 ppb
Nokomis Regional Middle School	M158 Hall Fountain Up	0 ppb
Nokomis Regional Middle School	M205 Sink Left	1.2 ppb
Nokomis Regional Middle School	M205 Sink Right	1.6 ppb
Nokomis Regional Middle School	M206 Sink Left	0 ppb
Nokomis Regional Middle School	M206 Sink Right	1.4 ppb
Nokomis Regional Middle School	M213 Sink	0 ppb
Nokomis Regional Middle School	M218 Sink Left	0 ppb
Nokomis Regional Middle School	M218 Sink Right	0 ppb
Nokomis Regional Middle School	M219 Sink	0 ppb
Nokomis Regional Middle School	M222 Sink	0 ppb
Nokomis Regional Middle School	M223 Sink Left	1.8 ppb
Nokomis Regional Middle School	M223 Sink Right	0 ppb
Nokomis Regional Middle School	M224 Hall Bottle	0 ppb
Nokomis Regional Middle School	M224 Hall Fountain Down	0 ppb
Nokomis Regional Middle School	M224 Hall Fountain Up	0 ppb
North Berwick Elementary School	Classroom #10 Sink/bubbler	15.7 ppb
North Berwick Elementary School	Classroom #11 Sink/bubbler	12.1 ppb
North Berwick Elementary School	Classroom #12 Sink/bubbler	10.5 ppb
North Berwick Elementary School	Classroom #14 Sink/bubbler	17 ppb
North Berwick Elementary School	Classroom #15 Sink/bubbler	18.6 ppb
North Berwick Elementary School	Classroom #16 Sink/bubbler	9.8 ppb
North Berwick Elementary School	Classroom #17 Sink/bubbler	36.7 ppb
North Berwick Elementary School	Classroom #18 Sink/bubbler	9.5 ppb
North Berwick Elementary School	Classroom #19 Sink/bubbler	40.7 ppb
North Berwick Elementary School	Classroom #20 Sink/bubbler	22.5 ppb
North Berwick Elementary School	Classroom #21 Sink/bubbler	66.3 ppb
North Berwick Elementary School	Classroom #22 Sink/bubbler	13.6 ppb
North Berwick Elementary School	Classroom #23 Sink/bubbler	22.4 ppb
North Berwick Elementary School	Classroom #24 Sink/bubbler	155 ppb
North Berwick Elementary School	Classroom #25 Sink/bubbler	17.3 ppb
North Berwick Elementary School	Classroom #26 Sink/bubbler	82.8 ppb
North Berwick Elementary School	Kitchen Prep Sink #1	23.1 ppb
North Berwick Elementary School	Kitchen Prep Sink #2	10.9 ppb
North Berwick Elementary School	Kitchen Steam Kettle	16 ppb
North Berwick Elementary School	Main Lobby Drinking Fountain	0 ppb
North Berwick Elementary School	Nurse Office Sink	8.2 ppb
North Berwick Elementary School	Second Floor Hall Drinking Fountain	0 ppb
North Berwick Elementary School	Teachers Lounge Sink	9.8 ppb
North Elementary School	Boys Restroom Far Right	1.9 ppb
North Elementary School	Boys Restroom First	1.8 ppb
North Elementary School	Girls Restroom Far Left	2.5 ppb
North Elementary School	Girls Restroom First	2.6 ppb
North Elementary School	Gym: Bottle Fill Station	0 ppb

School Name	Sample Location	Lead Test Result
North Elementary School	Hallway By Room 9 Bottle Fill Station	0 ppb
North Elementary School	Kitchen 3 Basin Sink	6.9 ppb
North Elementary School	Kitchen Sprayer By Dishwasher	0 ppb
North Elementary School	Kitchen Wash Sink Right Of Dishwasher	1.3 ppb
North Elementary School	Kvcap Restroom	2.2 ppb
North Elementary School	Room 1 Wash Sink	3.5 ppb
North Elementary School	Room 10 Fountain	8 ppb
North Elementary School	Room 10 Wash Sink	10.3 ppb
North Elementary School	Room 11 Fountain	1.4 ppb
North Elementary School	Room 11 Wash Sink	1.6 ppb
North Elementary School	Room 12 Fountain	0 ppb
North Elementary School	Room 12 Wash Sink	1.4 ppb
North Elementary School	Room 14 Wash Sink	0 ppb
North Elementary School	Room 15 Wash Sink	1.3 ppb
North Elementary School	Room 16 Wash Sink	1.8 ppb
North Elementary School	Room 2 Wash Sink	2.1 ppb
North Elementary School	Room 3 Fountain	9 ppb
North Elementary School	Room 3 Wash Sink	2.4 ppb
North Elementary School	Room 4 Fountain	8.2 ppb
North Elementary School	Room 4 Wash Sink	3.8 ppb
North Elementary School	Room 5 Fountain	8.8 ppb
North Elementary School	Room 5 Wash Sink	3.4 ppb
North Elementary School	Room 6 Fountain	5 ppb
North Elementary School	Room 6 Restroom	1.8 ppb
North Elementary School	Room 6 Wash Sink	9 ppb
North Elementary School	Room 7 Fountain	11.5 ppb
North Elementary School	Room 7 Wash Sink	14.7 ppb
North Elementary School	Room 8 Fountain	7 ppb
North Elementary School	Room 8 Wash Sink	12.1 ppb
North Elementary School	Room 9 Fountain	10.1 ppb
North Elementary School	Room 9 Wash Sink	4.3 ppb
North Elementary School	Staff Restroom By Office	3.7 ppb
North Haven Community School	Art Classroom Sink	21.9 ppb
North Haven Community School	Aux Classroom Sink	106 ppb
North Haven Community School	Classroom Sink 1-2	52.3 ppb
North Haven Community School	Classroom Sink 21	4.9 ppb
North Haven Community School	Classroom Sink 22	8.7 ppb
North Haven Community School	Classroom Sink K	35.5 ppb
North Haven Community School	Common Bathroom Sink #1	27.3 ppb
North Haven Community School	Common Bathroom Sink #2	16.2 ppb
North Haven Community School	Custodial Sink #1	5.9 ppb
North Haven Community School	Custodial Sink #2	5.4 ppb
North Haven Community School	Gym Water Fountain #1	9.5 ppb
North Haven Community School	Gym Water Fountain #2	10.3 ppb
North Haven Community School	High School Bathroom #1	20.2 ppb
North Haven Community School	High School Bathroom #2	28.7 ppb
North Haven Community School	Kitchen Sink #1	10.3 ppb

School Name	Sample Location	Lead Test Result
North Haven Community School	Kitchen Sink #2	17.5 ppb
North Haven Community School	Kitchen Sink #3	23.4 ppb
North Haven Community School	Library Water Foundation #1	3.7 ppb
North Haven Community School	Library Water Foundation #2	4.2 ppb
North Haven Community School	Locker Room Sink #1	38.6 ppb
North Haven Community School	Locker Room Sink #2	13.3 ppb
North Haven Community School	Middle School Bathroom #1	14.3 ppb
North Haven Community School	Middle School Bathroom #2	13.2 ppb
North Haven Community School	Music Classroom Sink	6.9 ppb
North Haven Community School	Primary Bathroom #1	43.4 ppb
North Haven Community School	Primary Bathroom #2	26.6 ppb
North Haven Community School	Projects Building Bathroom Sink	4.8 ppb
North Haven Community School	Science Lab Sink	28.1 ppb
North Haven Community School	Staff Bathroom Sink	17.1 ppb
North Haven Community School	Weight Room Bathroom Sink	41.8 ppb
North Yarmouth Academy	24 Changing Room	1.9 ppb
North Yarmouth Academy	24 Kitchen Sink	2 ppb
North Yarmouth Academy	24 Staff Bath	9.2 ppb
North Yarmouth Academy	24 Toddler 1	2.5 ppb
North Yarmouth Academy	Arena Main Entrance Fountain	2 ppb
North Yarmouth Academy	Arena Warm Room Fountain	3.2 ppb
North Yarmouth Academy	Blc Filling Station	0 ppb
North Yarmouth Academy	Coffee Pot Line	2.7 ppb
North Yarmouth Academy	Dole Bathroom Sink	9.7 ppb
North Yarmouth Academy	Gym Spigot/ice Machine	14.4 ppb
North Yarmouth Academy	Gym Water Fountain	0 ppb
North Yarmouth Academy	Higgins Water Fountain	0 ppb
North Yarmouth Academy	Kitchen Food Washing Sink	2.9 ppb
North Yarmouth Academy	Kitchen Hand Washing Sink	2.3 ppb
North Yarmouth Academy	Ls Bottle Filling Station	0 ppb
North Yarmouth Academy	Ls First Room By Front Door	2.7 ppb
North Yarmouth Academy	Ls Kitchen Sink	0 ppb
North Yarmouth Academy	Ls Main Bath Left	2.1 ppb
North Yarmouth Academy	Ls Main Bath Right	2.2 ppb
North Yarmouth Academy	Ls Primary 1	1.8 ppb
North Yarmouth Academy	Ls Upstairs Bath Back	1.1 ppb
North Yarmouth Academy	Ls Upstairs Bath Front	11.1 ppb
North Yarmouth Academy	Ms Filling Station	0 ppb
North Yarmouth Academy	Ms South Water Fountain	0 ppb
North Yarmouth Academy	Ms Teacher Lounge Sink	6.3 ppb
North Yarmouth Academy	Public Room L	0 ppb
North Yarmouth Academy	Public Room R	1.3 ppb
North Yarmouth Academy	Russell 1l	1.6 ppb
North Yarmouth Academy	Russell 1r	1.7 ppb
North Yarmouth Academy	Russell 2l	1.9 ppb
North Yarmouth Academy	Russell 2r	1.7 ppb
North Yarmouth Academy	Russell 3l	1.7 ppb

School Name	Sample Location	Lead Test Result
North Yarmouth Academy	Russell 3r	1.7 ppb
North Yarmouth Academy	Russell 4l	24.2 ppb
North Yarmouth Academy	Russell 4r	19.9 ppb
North Yarmouth Academy	Safford Water Fountain	4.9 ppb
North Yarmouth Academy	Science 1st Floor Fountain L	0 ppb
North Yarmouth Academy	Science 1st Floor Fountain R	0 ppb
North Yarmouth Academy	Science 2nd Floor Fountain L	1.8 ppb
North Yarmouth Academy	Science 2nd Floor Fountain R	5.4 ppb
North Yarmouth Academy	Shop Bathroom Sink	27.3 ppb
North Yarmouth Academy	Shop Sink	14.6 ppb
North Yarmouth Academy	Upstairs Bath L	1.1 ppb
North Yarmouth Academy	Upstairs Bath R	2.1 ppb
North Yarmouth Academy	Varsity L	2.7 ppb
North Yarmouth Academy	Varsity R	1.4 ppb
North Yarmouth Academy	Yarmouth L	2.4 ppb
North Yarmouth Academy	Yarmouth R	0 ppb
Oak Hill High School	Bathroom Faucet Near Rm 135	2.4 ppb
Oak Hill High School	Bathroom Faucet Near Rm 138	2.2 ppb
Oak Hill High School	Boy Locker Room Sink Faucet	2 ppb
Oak Hill High School	Boys Bathroom Faucet Near Media A	0 ppb
Oak Hill High School	Boys Bathroom Faucet Near Media B	0 ppb
Oak Hill High School	Boys Bathrrom Faucet Near Media C	3.9 ppb
Oak Hill High School	Coaches Office-boys Locker Room Side-sink Faucet	24.1 ppb
Oak Hill High School	Drinking Fountain By Room 201	0 ppb
Oak Hill High School	Dwf Boys Locker Room	2.8 ppb
Oak Hill High School	Dwf Near Athletic Director Office	0 ppb
Oak Hill High School	Fountian By Media	0 ppb
Oak Hill High School	Girls Bathroom Faucet Near Media A	0 ppb
Oak Hill High School	Girls Bathroom Faucet Near Media B	0 ppb
Oak Hill High School	Girls Bathroom Faucet Near Media C	20.6 ppb
Oak Hill High School	Girls Bathroom Faucet Near Rm 201	1.3 ppb
Oak Hill High School	Girls Lockers Room Faucet A	1.8 ppb
Oak Hill High School	Girls Lockers Room Faucet B	15.7 ppb
Oak Hill High School	Girls Small Locker Room- Faucet	62.9 ppb
Oak Hill High School	Guidance Bathroom Sink- Old Boys	2.8 ppb
Oak Hill High School	Guidance Bathroom Sink- Old Girls	0 ppb
Oak Hill High School	Kitchen Faucet	12.3 ppb
Oak Hill High School	Kitchen Faucet A	16.6 ppb
Oak Hill High School	Kitchen Faucet B	5.5 ppb
Oak Hill High School	Kitchen Faucet C	6.9 ppb
Oak Hill High School	Kitchen Faucet D	28.3 ppb
Oak Hill High School	Kitchen Faucet E	10.5 ppb
Oak Hill High School	Kitchen Faucet F	4.9 ppb
Oak Hill High School	Main Office- Faucet A	9.4 ppb
Oak Hill High School	Main Office- Faucet B	2.5 ppb
Oak Hill High School	Media Faucet	18.9 ppb

School Name	Sample Location	Lead Test Result
Oak Hill High School	Nurses Office- Sink Faucet	3.8 ppb
Oak Hill High School	Rm 117 Faucet A	73 ppb
Oak Hill High School	Rm 117 Faucet B	8.5 ppb
Oak Hill High School	Rm 133 Faucet A	7.4 ppb
Oak Hill High School	Rm 133 Faucet B	9.6 ppb
Oak Hill High School	Rm 133 Faucet C	60.7 ppb
Oak Hill High School	Rm 134 Faucet	2 ppb
Oak Hill High School	Room 106- Faucet	0 ppb
Oak Hill High School	Room 106a- Faucet	6 ppb
Oak Hill High School	Room 112- Faucet A	6.9 ppb
Oak Hill High School	Room 112- Faucet B	171 ppb
Oak Hill High School	Room 113- Faucet A	2.1 ppb
Oak Hill High School	Room 113- Faucet C	78.3 ppb
Oak Hill High School	Room 113- Faucet D	27.4 ppb
Oak Hill High School	Room 113- Faucet F	127 ppb
Oak Hill High School	Room 114- Faucet	2.5 ppb
Oak Hill High School	Room 115- Faucet A	21.4 ppb
Oak Hill High School	Room 115- Faucet B	379 ppb
Oak Hill High School	Room 117- Faucet F	16.9 ppb
Oak Hill High School	Room 117- Faucet G	18.2 ppb
Oak Hill High School	Room 133	10 ppb
Oak Hill High School	Room 137- Shop	9.6 ppb
Oak Hill High School	Room 144 Sink Faucet	298 ppb
Oak Hill High School	Sink Faucet Boys Bathroom By Room 201 A	0 ppb
Oak Hill High School	Sink Faucet Boys Bathroom By Room 201 B	0 ppb
Oak Hill High School	Sink Faucet Boys Bathroom By Room 201 C	1.6 ppb
Oak Hill High School	Sink Faucet Boys Bathroom By Room 201 D	1.1 ppb
Oak Hill High School	Sink Faucet Girls Bathroom By Room 201 A	1.7 ppb
Oak Hill High School	Sink Faucet Girls Bathroom By Room 201 B	2.4 ppb
Oak Hill High School	Sink Faucet Girls Bathroom By Room 201 C	2.7 ppb
Oak Hill High School	Teachers Room Bathroom Sink Faucet	0 ppb
Oak Hill High School	Teachers Room Sink Faucet	1.8 ppb
Oak Hill High School	Trainers Office Faucet	1.9 ppb
Oak Hill Middle School	Bottle- Water Fountain	0 ppb
Oak Hill Middle School	Downstairs Bathroom In Hall 1	6.3 ppb
Oak Hill Middle School	Downstairs Bathroom In Hall 2	4 ppb
Oak Hill Middle School	Downstairs Bathroom In Hall 3	1.3 ppb
Oak Hill Middle School	Downstairs Bathroom In Hall 4	2.4 ppb
Oak Hill Middle School	Downstairs Bathroom In Hall 5	3.5 ppb
Oak Hill Middle School	Downstairs Bathroom In Hall 6	4.7 ppb
Oak Hill Middle School	Gym Boys Locker Room Sink A	5.2 ppb
Oak Hill Middle School	Gym Boys Locker Room Sink B	7.5 ppb
Oak Hill Middle School	Gym Girls Locker Room Sink A	4.4 ppb
Oak Hill Middle School	Gym Girls Locker Room Sink B	5.7 ppb
Oak Hill Middle School	Kitchen Bathroom Sink	4.2 ppb
Oak Hill Middle School	Kitchen Sink A	2.3 ppb
Oak Hill Middle School	Kitchen Sink B	7.9 ppb

School Name	Sample Location	Lead Test Result
Oak Hill Middle School	Kitchen Sink C	0 ppb
Oak Hill Middle School	Kitchen Sink D	1.5 ppb
Oak Hill Middle School	Library	2.9 ppb
Oak Hill Middle School	Lobby Boys Bathroom Sink A	5.1 ppb
Oak Hill Middle School	Lobby Boys Bathroom Sink B	3.4 ppb
Oak Hill Middle School	Lobby Fountain	0 ppb
Oak Hill Middle School	Lobby Girls Bathroom Sink A	3.5 ppb
Oak Hill Middle School	Lobby Girls Bathroom Sink B	2.7 ppb
Oak Hill Middle School	Nurse Room Bathroom Sink	5.6 ppb
Oak Hill Middle School	Nurse Room Sink	1.3 ppb
Oak Hill Middle School	Rm 103- Fls	1 ppb
Oak Hill Middle School	Room 101 Sink(music) A	2.4 ppb
Oak Hill Middle School	Room 101 Sink(music) B	9.6 ppb
Oak Hill Middle School	Room 102 Sink (art) A	3.1 ppb
Oak Hill Middle School	Room 102 Sink (art) B	1.7 ppb
Oak Hill Middle School	Room 102 Sink (art) C	2.2 ppb
Oak Hill Middle School	Room 102 Sink (art) D	1.9 ppb
Oak Hill Middle School	Room 103	0 ppb
Oak Hill Middle School	Room 103 Bathroom	5.2 ppb
Oak Hill Middle School	Room 104	1.9 ppb
Oak Hill Middle School	Room 105	3.5 ppb
Oak Hill Middle School	Room 106	2.1 ppb
Oak Hill Middle School	Room 107 A	1.6 ppb
Oak Hill Middle School	Room 107 B	1.4 ppb
Oak Hill Middle School	Room 107 C	1 ppb
Oak Hill Middle School	Room 107 D	0 ppb
Oak Hill Middle School	Room 107 E	0 ppb
Oak Hill Middle School	Room 108 B	0 ppb
Oak Hill Middle School	Room 108 C	1.4 ppb
Oak Hill Middle School	Room 108 D	0 ppb
Oak Hill Middle School	Room 108 E	1.6 ppb
Oak Hill Middle School	Room 108 F	0 ppb
Oak Hill Middle School	Room 109	1.6 ppb
Oak Hill Middle School	Room 110	1.7 ppb
Oak Hill Middle School	Room 111 A	0 ppb
Oak Hill Middle School	Room 111 B	1.5 ppb
Oak Hill Middle School	Room 111 D	1.2 ppb
Oak Hill Middle School	Room 111 E	1.2 ppb
Oak Hill Middle School	Room 111 F	1.4 ppb
Oak Hill Middle School	Room 112	1.4 ppb
Oak Hill Middle School	Room 113	1.2 ppb
Oak Hill Middle School	Room 202	1.3 ppb
Oak Hill Middle School	Room 203	3.4 ppb
Oak Hill Middle School	Room 204	1.7 ppb
Oak Hill Middle School	Room 206	9.1 ppb
Oak Hill Middle School	Room 208	2.5 ppb
Oak Hill Middle School	Room 209	2.4 ppb

School Name	Sample Location	Lead Test Result
Oak Hill Middle School	Room 210	2.8 ppb
Oak Hill Middle School	Room 211	2.6 ppb
Oak Hill Middle School	Room 212	2.4 ppb
Oak Hill Middle School	Room 213	1.4 ppb
Oak Hill Middle School	Room 214	2.7 ppb
Oak Hill Middle School	Room 215	1.4 ppb
Oak Hill Middle School	Room 216	2.3 ppb
Oak Hill Middle School	Room 217	0 ppb
Oak Hill Middle School	Room 218	1.8 ppb
Oak Hill Middle School	Staff Bathroom	20 ppb
Oak Hill Middle School	Tech Office	2.5 ppb
Oak Hill Middle School	Up Stairs Restroom In Hall 1	6.2 ppb
Oak Hill Middle School	Up Stairs Restroom In Hall 2	4.4 ppb
Oak Hill Middle School	Up Stairs Restroom In Hall 3	3.6 ppb
Oak Hill Middle School	Up Stairs Restroom In Hall 4	6.4 ppb
Oak Hill Middle School	Up Stairs Restroom In Hall 5	4.5 ppb
Oak Hill Middle School	Up Stairs Restroom In Hall 6	4.1 ppb
Ocean Avenue	100 Cafeteria - Left	3.9 ppb
Ocean Avenue	100 Cafeteria - Right	2 ppb
Ocean Avenue	102a Main Office	1.1 ppb
Ocean Avenue	111 Nurse	0 ppb
Ocean Avenue	117	2.7 ppb
Ocean Avenue	120	1.4 ppb
Ocean Avenue	123 #1	1.7 ppb
Ocean Avenue	124	7.4 ppb
Ocean Avenue	128	0 ppb
Ocean Avenue	133	4 ppb
Ocean Avenue	135	2.1 ppb
Ocean Avenue	136	1.5 ppb
Ocean Avenue	138	2.8 ppb
Ocean Avenue	139	1.9 ppb
Ocean Avenue	141	2 ppb
Ocean Avenue	150 - Left	2 ppb
Ocean Avenue	150 - Right	0 ppb
Ocean Avenue	153	1.6 ppb
Ocean Avenue	162 Kitchen - 3 Bay	0 ppb
Ocean Avenue	162 Kitchen - Prep	0 ppb
Ocean Avenue	206	2.4 ppb
Ocean Avenue	207	2 ppb
Ocean Avenue	209	2.6 ppb
Ocean Avenue	213	2.1 ppb
Ocean Avenue	215	1.6 ppb
Ocean Avenue	216	2.5 ppb
Ocean Avenue	218	1.9 ppb
Ocean Avenue	219	2.4 ppb
Ocean Avenue	221	1.8 ppb
Ocean Avenue	225	2.2 ppb

School Name	Sample Location	Lead Test Result
Ocean Avenue	227	1.5 ppb
Ocean Avenue	Front Lobby	0 ppb
Ocean Avenue	Pos-1	1870 ppb
Ocean Avenue	Teachers Lounge	0 ppb
Oceanside High School	Auditorium Custodial Sink	15.7 ppb
Oceanside High School	Basement Hall Fountain	0 ppb
Oceanside High School	Bathroom Next To Trainers Room Sink	0 ppb
Oceanside High School	Bathroom Shower	4 ppb
Oceanside High School	Bathroom Shower Next To Custodial Closet	0 ppb
Oceanside High School	Bathroom Sink Next To Custodial Closet	1 ppb
Oceanside High School	Bathroom With Baby Change Station Sink	1 ppb
Oceanside High School	Bottle Fill Station By Library	0 ppb
Oceanside High School	Boys Bathroom Sink A	3 ppb
Oceanside High School	Boys Bathroom Sink B	6 ppb
Oceanside High School	Boys Bathroom Sink C	10 ppb
Oceanside High School	Boys Bathroom Sink D	8 ppb
Oceanside High School	Boys Bathroom Sink E	14 ppb
Oceanside High School	Boys Bathroom Sink F	89 ppb
Oceanside High School	Boys Bathroom Sink Left	65 ppb
Oceanside High School	Boys Bathroom Sink Right	279 ppb
Oceanside High School	Boys Locker Room Handwashing Sink A	0 ppb
Oceanside High School	Boys Locker Room Handwashing Sink B	1 ppb
Oceanside High School	Boys Locker Room Handwashing Sink C	3 ppb
Oceanside High School	Boys Locker Room Handwashing Sink D	0 ppb
Oceanside High School	Boys Locker Room Shower 1	42 ppb
Oceanside High School	Boys Locker Room Shower 2	31 ppb
Oceanside High School	Boys Locker Room Shower 3	8 ppb
Oceanside High School	Boys Locker Room Shower 4	11 ppb
Oceanside High School	Boys Locker Room Shower 5	6 ppb
Oceanside High School	Boys Locker Room Shower 6	6 ppb
Oceanside High School	Boys Locker Room Shower 7	20 ppb
Oceanside High School	Boys Locker Room Shower 8	17 ppb
Oceanside High School	Boys Locker Room Shower 9	17 ppb
Oceanside High School	Cafeteria Fountain	0 ppb
Oceanside High School	Center Staff Bathroom Sink	9 ppb
Oceanside High School	Girls Bathroom Sink A	22 ppb
Oceanside High School	Girls Bathroom Sink B	18 ppb
Oceanside High School	Girls Bathroom Sink C	8 ppb
Oceanside High School	Girls Bathroom Sink D	5 ppb
Oceanside High School	Girls Bathroom Sink E	4 ppb
Oceanside High School	Girls Bathroom Sink F	11 ppb
Oceanside High School	Girls Bathroom Sink Left	237 ppb
Oceanside High School	Girls Bathroom Sink Right	583 ppb
Oceanside High School	Girls Locker Room Handwashing Sink A	2 ppb
Oceanside High School	Girls Locker Room Handwashing Sink B	1 ppb
Oceanside High School	Girls Locker Room Handwashing Sink C	2 ppb

School Name	Sample Location	Lead Test Result
Oceanside High School	Girls Locker Room Handwashing Sink D	3 ppb
Oceanside High School	Girls Locker Room Shower 1	254 ppb
Oceanside High School	Girls Locker Room Shower 2	7 ppb
Oceanside High School	Girls Locker Room Shower 3	38 ppb
Oceanside High School	Girls Locker Room Shower 4	57 ppb
Oceanside High School	Girls Locker Room Shower 5	2 ppb
Oceanside High School	Girls Locker Room Shower 6	31 ppb
Oceanside High School	Girls Locker Room Shower 7	49 ppb
Oceanside High School	Girls Locker Room Shower 8	39 ppb
Oceanside High School	Girls Locker Room Shower 9	33 ppb
Oceanside High School	Hall Fountain By Room 15	0 ppb
Oceanside High School	Hall Fountain Outside Gym	0 ppb
Oceanside High School	Hall Fountain By Room 34	0 ppb
Oceanside High School	Hand Wash Station Sink A	1 ppb
Oceanside High School	Hand Wash Station Sink B	1 ppb
Oceanside High School	Hand Wash Station Sink C	0 ppb
Oceanside High School	Hand Wash Station Sink D	1 ppb
Oceanside High School	Hand Wash Station Sink E	1 ppb
Oceanside High School	Kitchen Kettle Fill Left	2 ppb
Oceanside High School	Kitchen Kettle Fill Right	44 ppb
Oceanside High School	Kitchen Bathroom Sink	0 ppb
Oceanside High School	Kitchen Hand Wash Sink B	0 ppb
Oceanside High School	Kitchen Hand Wash Sink C	0 ppb
Oceanside High School	Kitchen Hand Wash Sink D	0 ppb
Oceanside High School	Kitchen Hand Wash Sink E	4 ppb
Oceanside High School	Kitchen Ice Machine	0 ppb
Oceanside High School	Kitchen Office Bathroom Sink	1 ppb
Oceanside High School	Kitchen Single Sink A	3 ppb
Oceanside High School	Kitchen Triple Sink Bay Left	2 ppb
Oceanside High School	Kitchen Triple Sink Right	0 ppb
Oceanside High School	Kitchen Double Bay Sink	0 ppb
Oceanside High School	Lockerroom Custodial Sink	0 ppb
Oceanside High School	Lower Staff Bathroom Sink	1 ppb
Oceanside High School	Nurses Office Hand Washing Sink	0 ppb
Oceanside High School	Off Stage Sink	10.7 ppb
Oceanside High School	Room 10 Sink	8 ppb
Oceanside High School	Room 104d Classroom Sink	1 ppb
Oceanside High School	Room 11a Sink	2 ppb
Oceanside High School	Room 11b Sink	2 ppb
Oceanside High School	Room 13a Sink	30 ppb
Oceanside High School	Room 20 Sink A	2 ppb
Oceanside High School	Room 20 Sink B	2 ppb
Oceanside High School	Room 20 Sink C	3 ppb
Oceanside High School	Room 20 Sink D	4 ppb
Oceanside High School	Room 20 Sink E	1 ppb
Oceanside High School	Room 20 Sink F	15 ppb
Oceanside High School	Room 20 Sink G	3 ppb

School Name	Sample Location	Lead Test Result
Oceanside High School	Room 20 Sink H	2 ppb
Oceanside High School	Room 20 Sink I	3 ppb
Oceanside High School	Room 20 Sink J	5 ppb
Oceanside High School	Room 20 Sink K	3 ppb
Oceanside High School	Room 20 Sink L	3 ppb
Oceanside High School	Room 20 Sink M	72 ppb
Oceanside High School	Room 21 Classroom Sink	8 ppb
Oceanside High School	Room 27 Classroom Sink A	3.7 ppb
Oceanside High School	Room 27 Sink B	3 ppb
Oceanside High School	Room 27 Sink C	12 ppb
Oceanside High School	Room 27 Sink D	3 ppb
Oceanside High School	Room 27 Sink E	6 ppb
Oceanside High School	Room 27 Sink F	3 ppb
Oceanside High School	Room 27 Sink G	4 ppb
Oceanside High School	Room 27 Sink H	5 ppb
Oceanside High School	Room 27 Sink I	6 ppb
Oceanside High School	Room 27 Sink J	4 ppb
Oceanside High School	Room 27 Sink K	2 ppb
Oceanside High School	Room 27 Sink L	4 ppb
Oceanside High School	Room 27 Sink M Closet	40 ppb
Oceanside High School	Room 27 Sink N Closet	1590 ppb
Oceanside High School	Room 28 Classroom Sink	7 ppb
Oceanside High School	Room 30 Classroom Sink B	1 ppb
Oceanside High School	Room 32 Classroom Sink A	10 ppb
Oceanside High School	Room 32 Classroom Sink B	1 ppb
Oceanside High School	Room 38 Classroom Sink	2 ppb
Oceanside High School	Room 44 Classroom Sink	22 ppb
Oceanside High School	Room 46 Sink A	4 ppb
Oceanside High School	Room 46 Sink B	17 ppb
Oceanside High School	Room 46 Sink C	8 ppb
Oceanside High School	Room 46 Sink D	60 ppb
Oceanside High School	Staff Room Sink	0 ppb
Oceanside High School	Storage Sink	2 ppb
Oceanside High School	Trainers Room Handwash Sink	0 ppb
Oceanside High School	Trainers Room Ice Machine	0 ppb
Oceanside Middle School	Bathroom Sink Back Of Gym A	1.4 ppb
Oceanside Middle School	Bathroom Sink Back Of Gym B	1 ppb
Oceanside Middle School	Bathroom Sink Next To Locker Room	1.1 ppb
Oceanside Middle School	Bottle Fill Station Across From Rm 15	0 ppb
Oceanside Middle School	Bottle Fill Station Near Main Office	0 ppb
Oceanside Middle School	Bottle Fill Station In Cafe	0 ppb
Oceanside Middle School	Bottle Fill Station Next To Room 36	0 ppb
Oceanside Middle School	Boys Bathroom Sink A	4.5 ppb
Oceanside Middle School	Boys Bathroom Sink B	3.2 ppb
Oceanside Middle School	Boys Bathroom Sink Beside Rm 15 A	2.9 ppb
Oceanside Middle School	Boys Bathroom Sink Beside Rm 15 B	1.5 ppb
Oceanside Middle School	Boys Bathroom Sink C	5.2 ppb

School Name	Sample Location	Lead Test Result
Oceanside Middle School	Girls Bathroom Sink A	2.4 ppb
Oceanside Middle School	Girls Bathroom Sink B	3.6 ppb
Oceanside Middle School	Girls Bathroom Sink Beside Rm 15 A	2.6 ppb
Oceanside Middle School	Girls Bathroom Sink Beside Rm 15 B	1.6 ppb
Oceanside Middle School	Girls Bathroom Sink C	3.7 ppb
Oceanside Middle School	Girls Locker Room Sink A	106 ppb
Oceanside Middle School	Girls Locker Room Sink B	5.6 ppb
Oceanside Middle School	Ice Machine	1.1 ppb
Oceanside Middle School	Kitchen Bathroom Sink	1.1 ppb
Oceanside Middle School	Kitchen Dishwasher	2.6 ppb
Oceanside Middle School	Kitchen Kettle Filler	14.9 ppb
Oceanside Middle School	Kitchen Sink Middle Wall	0 ppb
Oceanside Middle School	Kitchen Sink On East Wall A	1.9 ppb
Oceanside Middle School	Kitchen Sink On East Wall B	1.1 ppb
Oceanside Middle School	Kitchen Sink On West Wall A	1.2 ppb
Oceanside Middle School	Kitchen Sink On West Wall B	2.5 ppb
Oceanside Middle School	Kitchen Sink On West Wall C	1.1 ppb
Oceanside Middle School	Kitchen Skillet Filler	2.7 ppb
Oceanside Middle School	Nurse's Office Sink	17.5 ppb
Oceanside Middle School	Room 10 Sink	2.5 ppb
Oceanside Middle School	Room 15 Sink	1.9 ppb
Oceanside Middle School	Room 17 A	0 ppb
Oceanside Middle School	Room 17 B	0 ppb
Oceanside Middle School	Room 17 C	1.1 ppb
Oceanside Middle School	Room 19 Sink A	6.4 ppb
Oceanside Middle School	Room 19 Sink B	2.7 ppb
Oceanside Middle School	Room 19 Sink C	2.4 ppb
Oceanside Middle School	Room 19 Sink D	2.2 ppb
Oceanside Middle School	Room 19 Sink E	2.8 ppb
Oceanside Middle School	Room 19 Sink F	2.8 ppb
Oceanside Middle School	Room 21 Sink A	9.3 ppb
Oceanside Middle School	Room 21 Sink B	1.1 ppb
Oceanside Middle School	Room 21 Sink C	1.4 ppb
Oceanside Middle School	Room 21 Sink D	0 ppb
Oceanside Middle School	Room 21 Sink E	0 ppb
Oceanside Middle School	Room 21 Sink F	5.4 ppb
Oceanside Middle School	Room 26 Sink	2.5 ppb
Oceanside Middle School	Room 27 Sink	1.5 ppb
Oceanside Middle School	Room 28 Sink	2.9 ppb
Oceanside Middle School	Room 29 Sink	1.5 ppb
Oceanside Middle School	Room 36 Sink	3.1 ppb
Oceanside Middle School	Room 43 Sink	0 ppb
Oceanside Middle School	Room 43 Sink In Closet	11.8 ppb
Oceanside Middle School	Room 46 Sink	6.3 ppb
Oceanside Middle School	Room 63 Sink	0 ppb
Oceanside Middle School	Room 8 Sink	0 ppb
Oceanside Middle School	Serving Area Sink Kitchen/cafe A	1.1 ppb

School Name	Sample Location	Lead Test Result
Oceanside Middle School	Serving Area Sink Kitchen/cafe B	2.2 ppb
Oceanside Middle School	Sink In Old Boys Locker Room A	4.7 ppb
Oceanside Middle School	Sink In Old Boys Locker Room B	1.2 ppb
Oceanside Middle School	Sink In Room Above Stage	416 ppb
Oceanside Middle School	Staff Bathroom Sink A	1.9 ppb
Oceanside Middle School	Staff Bathroom Sink B	2.7 ppb
Old Orchard Beach High School	Bottle Fill Station Gym Hs	27.3 ppb
Old Orchard Beach High School	Bottle Fill Station Intersection Hs	0 ppb
Old Orchard Beach High School	Bottle Fill Station Main Office Hs	2.6 ppb
Old Orchard Beach High School	Bottle Fill Station Outside Rm 211	0 ppb
Old Orchard Beach High School	Double Basin Sink #1 Home Ec	4.4 ppb
Old Orchard Beach High School	Double Basin Sink #2 Home Ec	4.2 ppb
Old Orchard Beach High School	Double Basin Sink #3 Home Ec	6.2 ppb
Old Orchard Beach High School	Double Basin Sink #4 Home Ec	11.4 ppb
Old Orchard Beach High School	Ice Machine Gym Storage Hs	0 ppb
Old Orchard Beach High School	Kitchen Double Basin Sink Hs	3.6 ppb
Old Orchard Beach High School	Library Sink	31.9 ppb
Old Orchard Beach High School	Single Basin Sink Home Ec	21.6 ppb
Old Orchard Beach High School	Single Basin Sink Teacher Lounge	35.8 ppb
Old Orchard Beach High School	Sped Kitchen Sink	0 ppb
Old Orchard Beach High School	Tides Kitchen Sink	0 ppb
Old Orchard Beach High School	Water Fountain Gym Hs	0 ppb
Old Orchard Beach High School	Water Spigot Gym Storage Hs	2.8 ppb
Old Town Elementary School	2nd Floor Hallway Waterfountain	0 ppb
Old Town Elementary School	Gym Waterfountain 1	0 ppb
Old Town Elementary School	Gym Waterfountain 2	3.3 ppb
Old Town Elementary School	Kettle	4.3 ppb
Old Town Elementary School	Kitchen Sink 1	3.7 ppb
Old Town Elementary School	Kitchen Sink 2	4.8 ppb
Old Town Elementary School	Kitchen Sink 3	6.1 ppb
Old Town Elementary School	Library Sink	1.5 ppb
Old Town Elementary School	Office Kitchen Sink	0 ppb
Old Town Elementary School	Rear Main Entrance Waterfountain 1	0 ppb
Old Town Elementary School	Rear Main Entrance Waterfountain 2	0 ppb
Old Town Elementary School	Room A110 Sink	0 ppb
Old Town Elementary School	Room A111 Sink	1.6 ppb
Old Town Elementary School	Room A112 Sink	2.4 ppb
Old Town Elementary School	Room A113 Sink	2.1 ppb
Old Town Elementary School	Room A114 Sink	1 ppb
Old Town Elementary School	Room A115 Sink	1.5 ppb
Old Town Elementary School	Room A116 Sink	1.9 ppb
Old Town Elementary School	Room A123 Sink	0 ppb
Old Town Elementary School	Room A138 Sink	0 ppb
Old Town Elementary School	Room A145 Sink 1	3.3 ppb
Old Town Elementary School	Room A145 Sink 2	1.5 ppb
Old Town Elementary School	Room A145 Sink 3	3.7 ppb
Old Town Elementary School	Room A145 Sink 4	2.2 ppb

School Name	Sample Location	Lead Test Result
Old Town Elementary School	Room A150 Sink	2.7 ppb
Old Town Elementary School	Room A151 Sink	2.6 ppb
Old Town Elementary School	Room A152 Sink	3.5 ppb
Old Town Elementary School	Room A164 Sink	3 ppb
Old Town Elementary School	Room A165 Sink	2.5 ppb
Old Town Elementary School	Room A166 Sink	2.1 ppb
Old Town Elementary School	Room A167 Sink	2.1 ppb
Old Town Elementary School	Room A168 Sink	2.3 ppb
Old Town Elementary School	Room A169 Sink	2.1 ppb
Old Town Elementary School	Room A170 Sink	3.2 ppb
Old Town Elementary School	Room A171 Sink	3.1 ppb
Old Town Elementary School	Room A177 Sink	1.6 ppb
Old Town Elementary School	Room A204 Sink	1.2 ppb
Old Town Elementary School	Room A205 Sink	3 ppb
Old Town Elementary School	Room A206 Sink	0 ppb
Old Town Elementary School	Room A207 Sink	1.7 ppb
Old Town Elementary School	Room A208 Sink	1.6 ppb
Old Town Elementary School	Room A209 Sink	1.1 ppb
Old Town Elementary School	Room A210 Sink	3 ppb
Old Town Elementary School	Room A211 Sink	2.5 ppb
Old Town Elementary School	Room A218 Sink	1.8 ppb
Old Town Elementary School	Room A230 Sink	0 ppb
Old Town Elementary School	Room A240 Sink	3.5 ppb
Old Town Elementary School	Room A241 Sink	6 ppb
Old Town Elementary School	Room A242 Sink	2.8 ppb
Old Town Elementary School	Room A254 Sink	0 ppb
Old Town Elementary School	Room A255 Sink	1.7 ppb
Old Town Elementary School	Room A256 Sink	1.1 ppb
Old Town Elementary School	Room A257 Sink	0 ppb
Old Town Elementary School	Room A258 Sink	0 ppb
Old Town Elementary School	Room A259 Sink	0 ppb
Old Town Elementary School	Room A260 Sink	1.8 ppb
Old Town Elementary School	Room A261 Sink	0 ppb
Old Town Elementary School	Room A267 Sink	0 ppb
Old Town Elementary School	Room B117 Sink	3.6 ppb
Old Town Elementary School	Room B140 Sink	3.6 ppb
Old Town Elementary School	Room B144 Sink	0 ppb
Old Town High School	Business Wing Waterfountain	3.7 ppb
Old Town High School	Gym Waterfountain	1.2 ppb
Old Town High School	Home Ec Sink 1	5.3 ppb
Old Town High School	Home Ec Sink 2	3.3 ppb
Old Town High School	Kitchen Sink 1	8.5 ppb
Old Town High School	Kitchen Sink 2	4.5 ppb
Old Town High School	Kitchen Sink 3	11.5 ppb
Old Town High School	Kitchen Sink 4	63.4 ppb
Old Town High School	Main Lobby Waterfountain	0 ppb
Old Town High School	Pressure Vessel 1	180 ppb

School Name	Sample Location	Lead Test Result
Old Town High School	Pressure Vessel 2	90.1 ppb
Old Town High School	Science Wing 1 Floor Waterfountain	0 ppb
Old Town High School	Waterfountain By Room 12	4.4 ppb
Opal Myrick Elementary School and Schenck	Art Room Sink	3.5 ppb
Opal Myrick Elementary School and Schenck	Booster's Booth Sink	1.9 ppb
Opal Myrick Elementary School and Schenck	Bottle Filler - 400 Wing	0 ppb
Opal Myrick Elementary School and Schenck	Bottle Filler - 500 Wing	0 ppb
Opal Myrick Elementary School and Schenck	Bottle Filler - Admin. Hallway	0 ppb
Opal Myrick Elementary School and Schenck	Bottle Filler - Cafeteria	0 ppb
Opal Myrick Elementary School and Schenck	Bottle Filler - Main Lobby	0 ppb
Opal Myrick Elementary School and Schenck	Bottle Filler - Off Gym	0 ppb
Opal Myrick Elementary School and Schenck	Bottle Filler - Teacher's Room	0 ppb
Opal Myrick Elementary School and Schenck	Breakroom Library	7.6 ppb
Opal Myrick Elementary School and Schenck	Ice Machine - Gym	1.1 ppb
Opal Myrick Elementary School and Schenck	Kitchen Kettle - Cafeteria	3.6 ppb
Opal Myrick Elementary School and Schenck	Kitchen Sink - Cafeteria	2 ppb
Opal Myrick Elementary School and Schenck	Lucy's Room Sink	3.7 ppb
Opal Myrick Elementary School and Schenck	Nurse's Station Sink	7.5 ppb
Opal Myrick Elementary School and Schenck	Teacher's Room Sink	1.9 ppb
Opal Myrick Elementary School and Schenck	Wash Station - Cafeteria	0 ppb
Opportunity Training Center	Kitchen - Double Basin Sink	0 ppb
Opportunity Training Center	Kitchen - Single Basin Sink	0 ppb
Orono High School	Boys Gym Changing Room Fountain	3.6 ppb
Orono High School	Classroom 101a Left Side Of Room	11.8 ppb
Orono High School	Classroom 101a Right Side Of Room	13.3 ppb
Orono High School	Classroom 101b	1.6 ppb
Orono High School	Classroom 101c	6.9 ppb
Orono High School	Classroom 106	32.3 ppb
Orono High School	Fountain 2nd Floor Across From 202	4 ppb
Orono High School	Fountain By Cafeteria	0 ppb
Orono High School	Fountain In Gym Area By Consessions Stand	0 ppb
Orono High School	Girls Gym Changing Room Fountain	4.2 ppb
Orono High School	Kitchen 3 Bay Sink	0 ppb
Orono High School	Kitchen Vegetable Wash	0 ppb
Orono High School	Left Fountain 1st Floor Across From 101b	0 ppb
Orono High School	Library Fountain	10.9 ppb
Orono High School	Library Sink Backroom	10.9 ppb
Orono High School	Nurses Station	3.5 ppb
Orono High School	Right Fountain 1st Floor Across From 101b	0 ppb
Orono High School	Teachers Room	2.2 ppb
Orono Middle School	Band Room	4 ppb
Orono Middle School	Classroom 12	3 ppb
Orono Middle School	Classroom 20a	0 ppb
Orono Middle School	Fountain Across From Room 10	2.4 ppb
Orono Middle School	Fountain Between Rooms 14-16	0 ppb
Orono Middle School	Fountain By Principles Office	0 ppb

School Name	Sample Location	Lead Test Result
Orono Middle School	Fountain By Side Middle School Exit	11.8 ppb
Orono Middle School	Fountain In West Wing	0 ppb
Otisfield Community School	4th Grade	3.1 ppb
Otisfield Community School	6th Grade	3.4 ppb
Otisfield Community School	Front Hall Fountain 1	2.5 ppb
Otisfield Community School	Front Hall Fountain 2	2.5 ppb
Otisfield Community School	Kitchen	38 ppb
Otisfield Community School	Pre - K	2.8 ppb
Otisfield Community School	Staff Room	7.3 ppb
Overman Academy	Downstairs Water Bottle Filler	0 ppb
Overman Academy	Upstairs Kitchen 1	1.2 ppb
Overman Academy	Upstairs Kitchen 2	0 ppb
Overman Academy	Upstairs Kitchen 3	0 ppb
Overman Academy	Upstairs Water Bottle Filler	0 ppb
Oxford Elementary School	Cafeteria	2 ppb
Oxford Elementary School	Gym	0 ppb
Oxford Elementary School	Gym Lobby	2.4 ppb
Oxford Elementary School	Kitchen Dishwasher	0 ppb
Oxford Elementary School	Kitchen Sink	0 ppb
Oxford Elementary School	Library Lobby	2.5 ppb
Oxford Elementary School	Room 106	2.3 ppb
Oxford Elementary School	Room 108	20.5 ppb
Oxford Elementary School	Room 109	1.9 ppb
Oxford Elementary School	Room 110	2 ppb
Oxford Elementary School	Room 111	1.3 ppb
Oxford Elementary School	Room 112	1.7 ppb
Oxford Elementary School	Room 115	1.3 ppb
Oxford Elementary School	Room 116	1.3 ppb
Oxford Elementary School	Room 121	2.4 ppb
Oxford Elementary School	Room 122	2.8 ppb
Oxford Elementary School	Room 127	2.5 ppb
Oxford Elementary School	Room 133	6 ppb
Oxford Elementary School	Room 148	0 ppb
Oxford Elementary School	Room 152	3.2 ppb
Oxford Elementary School	Room 206	1.4 ppb
Oxford Elementary School	Room 207	1.6 ppb
Oxford Elementary School	Room 208	3.9 ppb
Oxford Elementary School	Room 209	1.9 ppb
Oxford Elementary School	Room 210	1.5 ppb
Oxford Elementary School	Room 213	4 ppb
Oxford Elementary School	Room 214	2.5 ppb
Oxford Elementary School	Room 217	2.5 ppb
Oxford Elementary School	Room 218	3 ppb
Oxford Elementary School	Room 220	4 ppb
Oxford Elementary School	Room 221	10.7 ppb
Oxford Elementary School	Staff Room 153 Icemaker	0 ppb
Oxford Hills Comprehensive H S\Tech region	A102	0 ppb

School Name	Sample Location	Lead Test Result
Oxford Hills Comprehensive H S\Tech region	A202	0 ppb
Oxford Hills Comprehensive H S\Tech region	Auto Collision	5.9 ppb
Oxford Hills Comprehensive H S\Tech region	Auto Tech	2 ppb
Oxford Hills Comprehensive H S\Tech region	B113	0 ppb
Oxford Hills Comprehensive H S\Tech region	B116	5.7 ppb
Oxford Hills Comprehensive H S\Tech region	B203	0 ppb
Oxford Hills Comprehensive H S\Tech region	B220 Closet Mens Bathroom	2.3 ppb
Oxford Hills Comprehensive H S\Tech region	B233	0 ppb
Oxford Hills Comprehensive H S\Tech region	B234	1.6 ppb
Oxford Hills Comprehensive H S\Tech region	Baseball Field	0 ppb
Oxford Hills Comprehensive H S\Tech region	Building Trades	2.6 ppb
Oxford Hills Comprehensive H S\Tech region	Culinary Arts	2.4 ppb
Oxford Hills Comprehensive H S\Tech region	Diversified Occ	3.7 ppb
Oxford Hills Comprehensive H S\Tech region	E208	0 ppb
Oxford Hills Comprehensive H S\Tech region	Ece	2.3 ppb
Oxford Hills Comprehensive H S\Tech region	Guidance Office C-117	4.9 ppb
Oxford Hills Comprehensive H S\Tech region	Locker Room 1	13.2 ppb
Oxford Hills Comprehensive H S\Tech region	Locker Room 2	4.2 ppb
Oxford Hills Comprehensive H S\Tech region	Locker Room 3	14 ppb
Oxford Hills Comprehensive H S\Tech region	Locker Room 4	4.7 ppb
Oxford Hills Comprehensive H S\Tech region	Locker Room 5	5.5 ppb
Oxford Hills Comprehensive H S\Tech region	Lower A Fountain Outside Body Shop	0 ppb
Oxford Hills Comprehensive H S\Tech region	Lower A/b Fountain #1	0 ppb
Oxford Hills Comprehensive H S\Tech region	Lower A/b Fountain #1 Office	1.1 ppb
Oxford Hills Comprehensive H S\Tech region	Lower C Fountain #2	0 ppb
Oxford Hills Comprehensive H S\Tech region	Main Kitchen	8.2 ppb
Oxford Hills Comprehensive H S\Tech region	Main Service	49.5 ppb
Oxford Hills Comprehensive H S\Tech region	Marketing E-103	0 ppb
Oxford Hills Comprehensive H S\Tech region	Near Kiosk	0 ppb
Oxford Hills Comprehensive H S\Tech region	Nursing School	1.8 ppb
Oxford Hills Comprehensive H S\Tech region	Phys Ed	0 ppb
Oxford Hills Comprehensive H S\Tech region	Rotunda	0 ppb
Oxford Hills Comprehensive H S\Tech region	Snack Shak	6.6 ppb
Oxford Hills Comprehensive H S\Tech region	Soccer Field	1.3 ppb
Oxford Hills Comprehensive H S\Tech region	Truck Driving	20.1 ppb
Oxford Hills Comprehensive H S\Tech region	Upper A/b	0 ppb
Oxford Hills Middle School	North-art Room	5.4 ppb
Oxford Hills Middle School	North-b-wing Science Lab	16.4 ppb
Oxford Hills Middle School	North-cafeteria Girls Bathroom	10.8 ppb
Oxford Hills Middle School	North-gym Hall Fountain	8.3 ppb
Oxford Hills Middle School	North-health Office	13.4 ppb
Oxford Hills Middle School	North-kitchen	10.3 ppb
Oxford Hills Middle School	North-main Hall Fountain	3.3 ppb
Oxford Hills Middle School	North-main Office	38.8 ppb
Oxford Hills Middle School	North-reflection Room	21.8 ppb
Oxford Hills Middle School	North-room 20	4.8 ppb
Oxford Hills Middle School	North-room 21	23.9 ppb

School Name	Sample Location	Lead Test Result
Oxford Hills Middle School	North-shaw Wing Fountain	44 ppb
Oxford Hills Middle School	North-staff Lounge	1.7 ppb
Oxford Hills Middle School	North-teachers Work Room	9.8 ppb
Oxford Hills Middle School	South-art Room	0 ppb
Oxford Hills Middle School	South-fountain New Area	0 ppb
Oxford Hills Middle School	South-gym Fountain	0 ppb
Oxford-Cumberland Canal School	Hall Art Fountain	1.4 ppb
Oxford-Cumberland Canal School	Hall Gym Fountain	0 ppb
Oxford-Cumberland Canal School	Hall Library Fountain	0 ppb
Oxford-Cumberland Canal School	Kitchen Prep Sink	2.8 ppb
Oxford-Cumberland Canal School	Nurse Sink	0 ppb
Oxford-Cumberland Canal School	Room 10 Fountain	4.9 ppb
Oxford-Cumberland Canal School	Room 11 Fountain	4.1 ppb
Oxford-Cumberland Canal School	Room 12 Fountain	11.2 ppb
Oxford-Cumberland Canal School	Room 13 Fountain	3.7 ppb
Oxford-Cumberland Canal School	Room 15 Fountain	9 ppb
Oxford-Cumberland Canal School	Room 16 Fountain	4.8 ppb
Oxford-Cumberland Canal School	Room 17 Fountain	3.1 ppb
Oxford-Cumberland Canal School	Room 18 Fountain	8.2 ppb
Oxford-Cumberland Canal School	Room 19 Fountain	3.5 ppb
Oxford-Cumberland Canal School	Room 26 Fountain	0 ppb
Oxford-Cumberland Canal School	Room 27 Fountain	2.6 ppb
Oxford-Cumberland Canal School	Room 28 Fountain	4.8 ppb
Oxford-Cumberland Canal School	Room 32 Fountain	2.6 ppb
Oxford-Cumberland Canal School	Room 33 Fountain	4.6 ppb
Oxford-Cumberland Canal School	Room 34 Fountain	3.6 ppb
Oxford-Cumberland Canal School	Room 35 Fountain	8 ppb
Palermo Consolidated School	Back Building (rm #3)	0 ppb
Palermo Consolidated School	Back Building (rm #4)	1.5 ppb
Palermo Consolidated School	Back Building Bottle Fill Between Restrooms	0 ppb
Palermo Consolidated School	Bottle Fill Across From Rm #211 Upstairs	0 ppb
Palermo Consolidated School	Bside Gym Entrance Bottle Fill	0 ppb
Palermo Consolidated School	Kitchen Sink #1	0 ppb
Palermo Consolidated School	Kitchen Sink #2	0 ppb
Palermo Consolidated School	Main Office (bubbler Poland Spring)	0 ppb
Palermo Consolidated School	Rm Across Boys Restroom Downstairs	12.2 ppb
Palermo Consolidated School	Upstairs Rm #204	15 ppb
Palermo Consolidated School	Upstairs Rm #210	38 ppb
Palermo Consolidated School	Upstairs Rm #211	3.1 ppb
Palermo Consolidated School	Upstairs Rm #212	3.1 ppb
Palermo Consolidated School	Upstairs Rm #213	5.5 ppb
Paris Elementary School	Pre K	0 ppb
Paris Elementary School	Room 238	1.9 ppb
Paris Elementary School	Room 312	2 ppb
Paris Elementary School	Room 315	2.7 ppb
Paris Elementary School	Room 318	2.1 ppb

School Name	Sample Location	Lead Test Result
Paris Elementary School	Room 320	2.5 ppb
Paris Elementary School	Room 321	2.7 ppb
Paris Elementary School	Room 324	3.1 ppb
Paris Elementary School	Room 325	2.3 ppb
Paris Elementary School	Room 327	2.9 ppb
Paris Elementary School	Room 413	2.1 ppb
Paris Elementary School	Room 417	2.1 ppb
Paris Elementary School	Room 420room 418	2.4 ppb
Paris Elementary School	Room 421	2.5 ppb
Paris Elementary School	Room 422	2.1 ppb
Paris Elementary School	Room 425	2 ppb
Park Avenue Elementary School	Bottle Filler By Room 169	0 ppb
Park Avenue Elementary School	Bottle Filler By Room 238	0 ppb
Park Avenue Elementary School	Bubbler By Room 169	0 ppb
Park Avenue Elementary School	Bubbler By Room 238	0 ppb
Park Avenue Elementary School	Bubbler On Right By Room 169	0 ppb
Park Avenue Elementary School	Cafeteria Dish Room Left Faucet	1.8 ppb
Park Avenue Elementary School	Cafeteria Dish Room Right Faucet	10.3 ppb
Park Avenue Elementary School	Cafeteria Handwash Faucet	2.1 ppb
Park Avenue Elementary School	Cafeteria Kitchen Handwash Faucet	1.2 ppb
Park Avenue Elementary School	Cafeteria Kitchen Handwash Faucet By Dry Goods	32.5 ppb
Park Avenue Elementary School	Cafeteria Kitchen Kettle Faucet	3.6 ppb
Park Avenue Elementary School	Cafeteria Kitchen Sink Faucet	2.8 ppb
Park Avenue Elementary School	Gym Boys Shower Room Sink Faucet	3.7 ppb
Park Avenue Elementary School	Gym Girls Shower Room Sink Faucet	1.7 ppb
Park Avenue Elementary School	Hall Restroom By Room 231 Faucet	1.4 ppb
Park Avenue Elementary School	Hall Restroom Next To Room 206 Faucet	0 ppb
Park Avenue Elementary School	Hall Restroom Next To Room 209 Faucet	1 ppb
Park Avenue Elementary School	Hall Restroom On Corner By 231 Faucet	0 ppb
Park Avenue Elementary School	Hallway Bathroom By Room 215 Faucet	1.4 ppb
Park Avenue Elementary School	Hallway Bathroom By Room 218 Faucet	1.5 ppb
Park Avenue Elementary School	Hallway Bubblers By Room 202 Left	0 ppb
Park Avenue Elementary School	Hallway Bubblers By Room 202 Right	0 ppb
Park Avenue Elementary School	Hallway By Cafe Boys Bathroom L Faucet	0 ppb
Park Avenue Elementary School	Hallway By Cafe Boys Bathroom R Faucet	2 ppb
Park Avenue Elementary School	Hallway By Cafe Bubbler	0 ppb
Park Avenue Elementary School	Hallway By Cafe Girls Bathroom L Faucet	0 ppb
Park Avenue Elementary School	Hallway By Cafe Girls Bathroom R Faucet	1.2 ppb
Park Avenue Elementary School	Hallway By Cafe Left Sink Faucet	0 ppb
Park Avenue Elementary School	Hallway By Cafe R Sink Faucet	0 ppb
Park Avenue Elementary School	Hallway By Cafe Right Bubbler	0 ppb
Park Avenue Elementary School	Restroom By Room 175 Faucet	1.1 ppb
Park Avenue Elementary School	Restroom Next To Room 224 Faucet	1.1 ppb
Park Avenue Elementary School	Restroom Next To Room 233 Faucet	3.4 ppb
Park Avenue Elementary School	Restroom On Left Faucet 1	1.9 ppb
Park Avenue Elementary School	Restroom On Left Faucet 2	3 ppb

School Name	Sample Location	Lead Test Result
Park Avenue Elementary School	Restroom On Left Faucet 3	1.2 ppb
Park Avenue Elementary School	Restroom Sink Faucet By Room 110	0 ppb
Park Avenue Elementary School	Room 110 Nurses Sink Faucet	0 ppb
Park Avenue Elementary School	Room 116 Library Sink Faucet	0 ppb
Park Avenue Elementary School	Room 143 Bubblers	0 ppb
Park Avenue Elementary School	Room 143 Faucet	1 ppb
Park Avenue Elementary School	Room 146 Bubblers	0 ppb
Park Avenue Elementary School	Room 146 Faucet	1 ppb
Park Avenue Elementary School	Room 146 Restroom Faucet	2.4 ppb
Park Avenue Elementary School	Room 150 Bubblers	0 ppb
Park Avenue Elementary School	Room 150 Faucet	0 ppb
Park Avenue Elementary School	Room 150 Restroom Faucet	2 ppb
Park Avenue Elementary School	Room 152 Bubblers	0 ppb
Park Avenue Elementary School	Room 152 Faucet	1.2 ppb
Park Avenue Elementary School	Room 152 Restroom Faucet	1.7 ppb
Park Avenue Elementary School	Room 155 Bubblers	1.4 ppb
Park Avenue Elementary School	Room 155 Faucet	0 ppb
Park Avenue Elementary School	Room 155 Restroom Faucet	2.7 ppb
Park Avenue Elementary School	Room 162/163 Bubblers	10.5 ppb
Park Avenue Elementary School	Room 162/163 Faucet	8.4 ppb
Park Avenue Elementary School	Room 164 Bubblers	1.4 ppb
Park Avenue Elementary School	Room 164 Faucet	3.8 ppb
Park Avenue Elementary School	Room 169 Faucet	0 ppb
Park Avenue Elementary School	Room 175 Bubblers	1.5 ppb
Park Avenue Elementary School	Room 175 Faucet	0 ppb
Park Avenue Elementary School	Room 177 Bubblers	0 ppb
Park Avenue Elementary School	Room 177 Faucet	2 ppb
Park Avenue Elementary School	Room 177 Restroom Faucet	1.6 ppb
Park Avenue Elementary School	Room 179 Bubblers	0 ppb
Park Avenue Elementary School	Room 179 Faucet	0 ppb
Park Avenue Elementary School	Room 179 Restroom Faucet	1 ppb
Park Avenue Elementary School	Room 181 Bubblers	0 ppb
Park Avenue Elementary School	Room 181 Faucet	0 ppb
Park Avenue Elementary School	Room 181 Restroom Faucet	1.2 ppb
Park Avenue Elementary School	Room 183 Bubblers	0 ppb
Park Avenue Elementary School	Room 183 Faucet	1.9 ppb
Park Avenue Elementary School	Room 184 Bubblers	0 ppb
Park Avenue Elementary School	Room 184 Faucet	1.4 ppb
Park Avenue Elementary School	Room 206 Bubblers	0 ppb
Park Avenue Elementary School	Room 206 Faucet	0 ppb
Park Avenue Elementary School	Room 209 Bubblers	0 ppb
Park Avenue Elementary School	Room 209 Faucet	1.2 ppb
Park Avenue Elementary School	Room 211 Bubblers	0 ppb
Park Avenue Elementary School	Room 211 Faucet	0 ppb
Park Avenue Elementary School	Room 213 Bubblers	0 ppb
Park Avenue Elementary School	Room 213 Faucet	0 ppb
Park Avenue Elementary School	Room 215 Bubblers	0 ppb

School Name	Sample Location	Lead Test Result
Park Avenue Elementary School	Room 215 Faucet	0 ppb
Park Avenue Elementary School	Room 223 Bubblers	0 ppb
Park Avenue Elementary School	Room 223 Faucet	0 ppb
Park Avenue Elementary School	Room 224 Staff Bathroom Faucet	1.4 ppb
Park Avenue Elementary School	Room 231 Bubblers	0 ppb
Park Avenue Elementary School	Room 231 Faucet	0 ppb
Park Avenue Elementary School	Room 232 A Bubblers	31 ppb
Park Avenue Elementary School	Room 232 A Faucet	1.7 ppb
Park Avenue Elementary School	Room 232 C Bubblers	5 ppb
Park Avenue Elementary School	Room 232 C Faucet	1.3 ppb
Park Avenue Elementary School	Room 233 Bubblers	0 ppb
Park Avenue Elementary School	Room 233 Faucet	0 ppb
Park Avenue Elementary School	Room 235 Bubblers	0 ppb
Park Avenue Elementary School	Room 235 Faucet	3.3 ppb
Park Avenue Elementary School	Room 236 Bubblers	0 ppb
Park Avenue Elementary School	Room 236 Faucet	0 ppb
Park Avenue Elementary School	Room 238 Bubblers	0 ppb
Park Avenue Elementary School	Room 238 Faucet	6.3 ppb
Park Avenue Elementary School	Room L 11 Center Sink Left Faucet	0 ppb
Park Avenue Elementary School	Room L 11 Center Sink Right Faucet	0 ppb
Park Avenue Elementary School	Room L 11 Left Sink Left Faucet	1.2 ppb
Park Avenue Elementary School	Room L 11 Left Sink Right Faucet	0 ppb
Park Avenue Elementary School	Room L 11 Right Sink Left Faucet	0 ppb
Park Avenue Elementary School	Room L 11 Right Sink Right Faucet	1.1 ppb
Park Avenue Elementary School	Room L 14 Left Center Faucet	0 ppb
Park Avenue Elementary School	Room L 14 Left Faucet	3.5 ppb
Park Avenue Elementary School	Room L 14 Right Center Faucet	0 ppb
Park Avenue Elementary School	Room L 14 Right Faucet	0 ppb
Park Avenue Elementary School	Room L 19 Left Bubblers	1.5 ppb
Park Avenue Elementary School	Room L 19 Left Faucet	4.4 ppb
Park Avenue Elementary School	Room L 19 Right Bubblers	1.8 ppb
Park Avenue Elementary School	Room L 19 Right Sink Faucet	12.7 ppb
Park Avenue Elementary School	Sink Across From Nurses Room Faucet	0 ppb
Park Avenue Elementary School	Staff Bathroom By Gym Faucet	0 ppb
Pathways Merrymeeting Center	Drinking Water Fountain- Admin	0 ppb
Pathways Merrymeeting Center	Drinking Water Fountain- Gym (admin)	0 ppb
Pathways Merrymeeting Center	Kitchenette-admin Building Sink	0 ppb
Pathways Merrymeeting Center	Pelc Sink- Blue Room (admin)	0 ppb
Pathways Merrymeeting Center	Pelc Sink Red Room (admin)	1.1 ppb
Pathways Merrymeeting Center	Pelc Sink Teacher Room (admin)	0 ppb
Pathways Merrymeeting Center	Pelc Sink- Yellow Room (admin)	1.4 ppb
Pathways Merrymeeting Center	Pmc- Functional Life Skills Room	0 ppb
Pathways Merrymeeting Center	Pmc Water Fountains (2) Rm 143	0 ppb
Pathways Merrymeeting Center	Rm 218 Water Fountains (2)- Pmc	0 ppb
Pathways Merrymeeting Center	Rm 238 Staff Lounge-pmc	0 ppb
Patricia A Duran School	Bottle Fill Station #1 By Rm #41	0 ppb
Patricia A Duran School	Bottle Fill Station #2 By Rm #41	0 ppb

School Name	Sample Location	Lead Test Result
Patricia A Duran School	Bottle Fill Station By Rm #14	0 ppb
Patricia A Duran School	Bottle Fill Station By Rm #20	0 ppb
Patricia A Duran School	Bottle Fill Station By Rm #5	4.4 ppb
Patricia A Duran School	Gym Lobby Bottle Fill Station	0 ppb
Patricia A Duran School	Kitchen Dish Sink	0 ppb
Patricia A Duran School	Kitchen Prep Sink	0 ppb
Patricia A Duran School	Kitchen Prep Sink By Eye Station	0 ppb
Patricia A Duran School	Nurse Office Hand Wash Sink	0 ppb
Peaks Island School	Gym	0 ppb
Peaks Island School	Hall Main Entrance	1.1 ppb
Peaks Island School	Hall Middle Entrance By 2	0 ppb
Peaks Island School	Kitchen - In Gym	2.7 ppb
Peaks Island School	Principal's Office	7.8 ppb
Pembroke Elementary School	Kitchen 3 Bay Sink	0 ppb
Pembroke Elementary School	Kitchen Food Prep Sink	2.5 ppb
Pembroke Elementary School	Lobby Drink Fountain	0 ppb
Pembroke Elementary School	Teachers Room	0 ppb
Pemetic Elementary School	107 Kindergarten - Mrs. Null	4.4 ppb
Pemetic Elementary School	4th Bathroom - Sink #1	2.7 ppb
Pemetic Elementary School	4th Bathroom -sink #2	1.8 ppb
Pemetic Elementary School	5th Bathroom - Sink #1	3.2 ppb
Pemetic Elementary School	5th Bathroom - Sink #2	2.9 ppb
Pemetic Elementary School	Bathroom 107	3.1 ppb
Pemetic Elementary School	Boys Bathroom - Sink #1	1.9 ppb
Pemetic Elementary School	Boys Bathroom - Sink #2	2.5 ppb
Pemetic Elementary School	Boys Bathroom 1st & 2nd Grades - Sink #1	2.5 ppb
Pemetic Elementary School	Boys Bathroom 1st & 2nd Grades - Sink #2	2.9 ppb
Pemetic Elementary School	Boy's Bathroom By Gym Sink #1	2 ppb
Pemetic Elementary School	Cafeteria - Fountain #5	0 ppb
Pemetic Elementary School	Girls Bathroom 1st & 2nd Grades - Sink #1	6.3 ppb
Pemetic Elementary School	Girls Bathroom 1st & 2nd Grades - Sink #2	8 ppb
Pemetic Elementary School	Girl's Bathroom By Gym Sink #1	1.9 ppb
Pemetic Elementary School	Girl's Bathroom Ms - Sink #1	3.1 ppb
Pemetic Elementary School	Girl's Bathroom Ms - Sink #2	3.3 ppb
Pemetic Elementary School	Girls Locker Room - Sink #1	4.9 ppb
Pemetic Elementary School	Girls Locker Room - Sink #2	12.6 ppb
Pemetic Elementary School	Hall Bathrooms Adult Only #1	2.6 ppb
Pemetic Elementary School	Hall Bathrooms Adult Only #2	2.5 ppb
Pemetic Elementary School	Hall Fountain #2	0 ppb
Pemetic Elementary School	Hall Water Fountain/main Office Room 137 #4	0 ppb
Pemetic Elementary School	Hand Sink #4	8.8 ppb
Pemetic Elementary School	Locker Room Boys Sink #1	5.3 ppb
Pemetic Elementary School	Locker Room Boys Sink #2	2.7 ppb
Pemetic Elementary School	Nurse Office	1 ppb
Pemetic Elementary School	Room 105 Pre-k	4.7 ppb
Pemetic Elementary School	Room 109	375 ppb

School Name	Sample Location	Lead Test Result
Pemetic Elementary School	Room 115 2nd Grade	7.1 ppb
Pemetic Elementary School	Room 117 3rd Grade Mrs. Raven	7.6 ppb
Pemetic Elementary School	Room 125	3.4 ppb
Pemetic Elementary School	Room 130 Library Office	33.6 ppb
Pemetic Elementary School	Room 133 Art Room - Sink #1	6.6 ppb
Pemetic Elementary School	Room 133 Art Room - Sink #2	3.2 ppb
Pemetic Elementary School	Room 135 Kitchen Double Faucet #1	6.7 ppb
Pemetic Elementary School	Room 135 Kitchen Double Faucet #2	10.1 ppb
Pemetic Elementary School	Room 136 Hand Sink	2 ppb
Pemetic Elementary School	Room 145 Nurse Bathroom	3.2 ppb
Pemetic Elementary School	Room 154 Music Room Hand Sink	9.8 ppb
Pemetic Elementary School	Room 162 Gym Ad Office Bathroom Sink	2.8 ppb
Pemetic Elementary School	Room 201 Mr. M	7.3 ppb
Pemetic Elementary School	Room 202 Mr. Wood	5.6 ppb
Pemetic Elementary School	Room 206 Mrs. Mccurdy	15.4 ppb
Pemetic Elementary School	Room 207 Mrs. Reed	52.1 ppb
Pemetic Elementary School	Room 213 - Kim	6.1 ppb
Pemetic Elementary School	Room 215 - Lacey	5.6 ppb
Pemetic Elementary School	Room 220	2.2 ppb
Pemetic Elementary School	Room 223 Pt/ot	5.8 ppb
Pemetic Elementary School	Room 225	1.7 ppb
Pemetic Elementary School	Room 231 - Sun Room	2.7 ppb
Pemetic Elementary School	Room 233 - Mrs. Philbrook	10.9 ppb
Pemetic Elementary School	Room 234 - Teachers Room	1.8 ppb
Pemetic Elementary School	Room 237	12.2 ppb
Pemetic Elementary School	Single Sink #3	3 ppb
Pemetic Elementary School	Sink #1 - Room 210 Mrs. Norwood	87.2 ppb
Pemetic Elementary School	Sink #2 - Room 210 Mrs. Norwood	98.2 ppb
Pemetic Elementary School	Teachers Bathroom	1.5 ppb
Pemetic Elementary School	Teacher's Bathroom	1.8 ppb
Pemetic Elementary School	Water Fountain By Gym #6	0 ppb
Pemetic Elementary School	Wing Fountain #1	0 ppb
Pemetic Elementary School	Wing Fountain #2	0 ppb
Peninsula School	#1 Kitchen Sink	2.3 ppb
Peninsula School	#2 Kitchen Sink	7.1 ppb
Peninsula School	100 Sink	2.6 ppb
Peninsula School	110 Sink	1.7 ppb
Peninsula School	112 Art Sink 1	8.9 ppb
Peninsula School	119 Water Fountain	0 ppb
Peninsula School	121 Water Fountain	0 ppb
Peninsula School	123 Water Fountain	0 ppb
Peninsula School	125 Water Fountain	0 ppb
Peninsula School	127 Water Fountain	1.3 ppb
Peninsula School	128 Water Fountain	0 ppb
Peninsula School	157 Water Fountain	11 ppb
Peninsula School	169 Water Fountain	0 ppb
Peninsula School	171 Water Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Peninsula School	172 Water Fountain	0 ppb
Peninsula School	173 Water Fountain	0 ppb
Peninsula School	Gym Water Fountain	0 ppb
Peninsula School	Hall Water Fountain	1.2 ppb
Peninsula School	Kitchen Prep Sink	4.5 ppb
Peninsula School	Kitchen Sink	3.3 ppb
Peninsula School	Skillet	94.9 ppb
Peninsula School	Steamer	138 ppb
Penobscot Elementary School	Drinking Fountain Between Bathrooms	0 ppb
Penobscot Elementary School	Drinking Fountain Next To Kindergarden	0 ppb
Penobscot Elementary School	Drinking Fountain Next To Teachers Room	0 ppb
Penobscot Elementary School	Kitchen Food Prep Sink	0 ppb
Penobscot Elementary School	Teachers Room Sink	0 ppb
Penobscot Valley High School	Bathroom Sink In Portables 214/217	1.2 ppb
Penobscot Valley High School	Bottle Fill Outside Office	0 ppb
Penobscot Valley High School	Bottle Filler Outside Room 119	0 ppb
Penobscot Valley High School	Drinking Fountain In Gym	0 ppb
Penobscot Valley High School	Drinking Fountain Outside Office #1	0 ppb
Penobscot Valley High School	Drinking Fountain Outside Office #2	0 ppb
Penobscot Valley High School	Drinking Fountain Outside Room 119 #1	0 ppb
Penobscot Valley High School	Drinking Fountain Outside Room 119 #2	0 ppb
Penobscot Valley High School	Kitchen Sink # 1 Going Left To Right	0 ppb
Penobscot Valley High School	Kitchen Sink # 2 Going Left To Right	0 ppb
Penobscot Valley High School	Kitchen Sink # 3 Going Left To Right	0 ppb
Penobscot Valley High School	Kitchen Sink # 4 Going Left To Right	2.7 ppb
Penobscot Valley High School	Kitchen Sink # 5 Going Left To Right	2.5 ppb
Penobscot Valley High School	Nurse Room Sink	2.3 ppb
Penobscot Valley High School	Room 217 In Portables Sink	1.5 ppb
Penobscot Valley High School	Science Lab Sink Room 189 Teachers Desk	51.2 ppb
Penobscot Valley High School	Snack Shack Sink In Lobby	1.7 ppb
Penobscot Valley High School	Teachers Room Sink	0 ppb
Penquis Valley Middle/High School	High School Life Skills Room	15.5 ppb
Penquis Valley Middle/High School	High School Teachers Breakroom	33.1 ppb
Penquis Valley Middle/High School	Hs Corridor Between Bathrooms	0 ppb
Penquis Valley Middle/High School	Hs Corridor Next To Room 12	0 ppb
Penquis Valley Middle/High School	Hs Main Gym Next To Equip. Room	0 ppb
Penquis Valley Middle/High School	Hs Main Lobby Between Bathrooms	1.7 ppb
Penquis Valley Middle/High School	Hs/ms Cafeteria	0 ppb
Penquis Valley Middle/High School	Kitchen Food Prep Sink #1	3.1 ppb
Penquis Valley Middle/High School	Kitchen Food Prep Sink #2	11.1 ppb
Penquis Valley Middle/High School	Kitchen Food Prep Sink #3	6.6 ppb
Penquis Valley Middle/High School	Ms Lower Level Corridor Between Bathrooms	0 ppb
Penquis Valley Middle/High School	Ms Lower Level Teachers Room	2.7 ppb
Penquis Valley Middle/High School	Ms Upper Level Corridor Between Bathrooms	0 ppb
Perry Elementary School	1 & 2 Room	5.5 ppb

School Name	Sample Location	Lead Test Result
Perry Elementary School	3 & 4 Room	6 ppb
Perry Elementary School	Drinking Fountain East Side Hallway	0 ppb
Perry Elementary School	Kitchen Food Prep Sink	0 ppb
Perry Elementary School	Pre-k & K Room	2.9 ppb
Perry Elementary School	Teachers Room	2.5 ppb
Philip W Sugg Middle School	6th Grade Boys Bathroom	1.4 ppb
Philip W Sugg Middle School	6th Grade Drinking Fountain	1.3 ppb
Philip W Sugg Middle School	6th Grade Girls Bathroom	2.6 ppb
Philip W Sugg Middle School	7th Grade Boys Bathroom	2.5 ppb
Philip W Sugg Middle School	7th Grade Drinking Fountain	2.5 ppb
Philip W Sugg Middle School	7th Grade Girls Bathroom	2 ppb
Philip W Sugg Middle School	8th Grade Boys Bathroom	1.7 ppb
Philip W Sugg Middle School	8th Grade Drinking Fountain	0 ppb
Philip W Sugg Middle School	8th Grade Fls Kitchen	3.7 ppb
Philip W Sugg Middle School	8th Grade Girls Bathroom	2.6 ppb
Philip W Sugg Middle School	8th Grade Teachers Bathroom	1.5 ppb
Philip W Sugg Middle School	Boiler Room Spigot	2.9 ppb
Philip W Sugg Middle School	Gym Water Fountain	3.1 ppb
Philip W Sugg Middle School	Kitchen Sink #1	3.9 ppb
Philip W Sugg Middle School	Kitchen Sink #2	10.8 ppb
Philip W Sugg Middle School	Kitchen Sink #3	21 ppb
Philip W Sugg Middle School	Main Hallway Bathroom #1	5.4 ppb
Philip W Sugg Middle School	Main Hallway Bathroom #2	6.1 ppb
Philip W Sugg Middle School	Main Hallway Drinking Fountain	3.4 ppb
Philip W Sugg Middle School	Nurses Office Bathroom	8.4 ppb
Philip W Sugg Middle School	Nurses Office Breakroom	7.7 ppb
Phillips Elementary School	Downstairs Water Cooler	0 ppb
Phillips Elementary School	Gym/cafeteria Sink	1 ppb
Phillips Elementary School	Kitchen 3 Bay Sink	3.4 ppb
Phillips Elementary School	Nurses Station	0 ppb
Phillips Elementary School	Room 117	0 ppb
Phillips Elementary School	Room 119	0 ppb
Phillips Elementary School	Room 120	2.5 ppb
Phillips Elementary School	Room 122	1.4 ppb
Phillips Elementary School	Room 125	0 ppb
Phillips Elementary School	Room 127	0 ppb
Phillips Elementary School	Room 130	1.2 ppb
Phillips Elementary School	Staff Room 110	0 ppb
Phillips Elementary School	Upstairs Water Cooler	0 ppb
Phippsburg Elementary School	Drinking Fountain By Music Rm	0 ppb
Phippsburg Elementary School	Drinking Fountain By Rm 11	1 ppb
Phippsburg Elementary School	Drinking Fountain By Staff Rm	0 ppb
Phippsburg Elementary School	Kitchen Sink	2.7 ppb
Phippsburg Elementary School	Sink In Staff Rm	1.1 ppb
Pine Street Elementary School	Cafeteria	0 ppb
Pine Street Elementary School	Gymnasium	0 ppb
Pine Street Elementary School	Kitchen Sink #1	2.8 ppb

School Name	Sample Location	Lead Test Result
Pine Street Elementary School	Kitchen Sink #2	0 ppb
Pine Street Elementary School	Kitchen Sink #3	0 ppb
Pine Street Elementary School	Kitchen Sink #4	0 ppb
Pine Street Elementary School	Kitchen Tilt Skillet	0 ppb
Pine Street Elementary School	Room 1	1.2 ppb
Pine Street Elementary School	Room 11	2.2 ppb
Pine Street Elementary School	Room 16	13.5 ppb
Pine Street Elementary School	Room 18	1.8 ppb
Pine Street Elementary School	Room 23	0 ppb
Pine Street Elementary School	Room 25	0 ppb
Pine Street Elementary School	Room 27	5 ppb
Pine Street Elementary School	Room 29	0 ppb
Pine Street Elementary School	Room 3	4.7 ppb
Pine Street Elementary School	Room 31	1.9 ppb
Pine Street Elementary School	Room 32	3.4 ppb
Pine Street Elementary School	Room 33	2.9 ppb
Pine Street Elementary School	Room 34	5.6 ppb
Pine Street Elementary School	Room 35	1.5 ppb
Pine Street Elementary School	Room 36	2.1 ppb
Pine Street Elementary School	Room 37	2.7 ppb
Pine Street Elementary School	Room 39	593 ppb
Pine Street Elementary School	Room 5	9.8 ppb
Pine Street Elementary School	Room 7	0 ppb
Pine Street Elementary School	Room 9	5 ppb
Pine Tree Academy	Boys Locker Room (gym)	6.8 ppb
Pine Tree Academy	Drinking Fountain By Kitchen	2.3 ppb
Pine Tree Academy	Drinking Fountain Elementary Wing (lower)	1.1 ppb
Pine Tree Academy	Drinking Fountain Outside Main Office	1.9 ppb
Pine Tree Academy	Elementary Boys Bathroom Sink	3.6 ppb
Pine Tree Academy	Elementary Girls Bathroom Sink	3.4 ppb
Pine Tree Academy	Elementary Grades 1 & 2 Room Sink	4.9 ppb
Pine Tree Academy	Elementary Grades 3 & 4 Room Sink	7.1 ppb
Pine Tree Academy	Elementary Kindergarten Room Sink	3.7 ppb
Pine Tree Academy	Girls Locker Room (gym)	5.8 ppb
Pine Tree Academy	Grades 7 & 5 Room Sink	2.8 ppb
Pine Tree Academy	High School Faculty/handicapped Bathroom	1.3 ppb
Pine Tree Academy	Kitchen 1st Sink	3.4 ppb
Pine Tree Academy	Kitchen Hand Wash Sink	7.1 ppb
Pine Tree Academy	Music Room	3.6 ppb
Pineview Learning Center	Bathroom Sink 1 Gym	1 ppb
Pineview Learning Center	Bathroom Sink 2 Pre-k	0 ppb
Pineview Learning Center	Bathroom Sink 3 Pre-k	0 ppb
Pineview Learning Center	Bathroom Sink 4 K-6	1.2 ppb
Pineview Learning Center	Bathroom Sink 5 K-6	1.5 ppb
Pineview Learning Center	Bathroom Sink 6 K-6	1.6 ppb

School Name	Sample Location	Lead Test Result
Pineview Learning Center	Bathroom Sink 7 K-6	3.5 ppb
Pineview Learning Center	Bathroom Sink 8 K-6	1.7 ppb
Pineview Learning Center	Handwash 1	6.6 ppb
Pineview Learning Center	Handwash 2	13.2 ppb
Pineview Learning Center	Kitchen Faucet 1	3 ppb
Pineview Learning Center	Kitchen Faucet 2	11.4 ppb
Pineview Learning Center	Nurse's Sink	1.8 ppb
Pineview Learning Center	Staff Office	4.1 ppb
Piscataquis Community Elementary	108 Cafe Drink Fountain	0 ppb
Piscataquis Community Elementary	110 Big Sink Left	8.3 ppb
Piscataquis Community Elementary	110 Big Sink Right	2.3 ppb
Piscataquis Community Elementary	110 Dish Spray Sink	4.9 ppb
Piscataquis Community Elementary	110 Hand Wash Sink	25.8 ppb
Piscataquis Community Elementary	110 Kettle	4.4 ppb
Piscataquis Community Elementary	110 Veg Sink	6.4 ppb
Piscataquis Community Elementary	112 Sink	6 ppb
Piscataquis Community Elementary	113 Sink	5.1 ppb
Piscataquis Community Elementary	122 Lav Left	1.6 ppb
Piscataquis Community Elementary	122 Lav Right	2.5 ppb
Piscataquis Community Elementary	123 Lav Left	1.1 ppb
Piscataquis Community Elementary	123 Lav Right	2.9 ppb
Piscataquis Community Elementary	130 Sink	1.9 ppb
Piscataquis Community Elementary	130 Utility Sink	15 ppb
Piscataquis Community Elementary	133 Sink	1 ppb
Piscataquis Community Elementary	134 Sink	1.6 ppb
Piscataquis Community Elementary	135a Sink	1 ppb
Piscataquis Community Elementary	135b Sink	1.2 ppb
Piscataquis Community Elementary	148 Ice Machine	2.7 ppb
Piscataquis Community Elementary	148 Lav	5.3 ppb
Piscataquis Community Elementary	156 Fountain	2.1 ppb
Piscataquis Community Elementary	156 Lav	1.2 ppb
Piscataquis Community Elementary	156 Sink	1.1 ppb
Piscataquis Community Elementary	159 Drink Fountain	5.1 ppb
Piscataquis Community Elementary	159 Sink	2.5 ppb
Piscataquis Community Elementary	165 Sink	21.2 ppb
Piscataquis Community Elementary	168 Sink	25.7 ppb
Piscataquis Community Elementary	175 Sink	4.2 ppb
Piscataquis Community Elementary	177 Sink	3.4 ppb
Piscataquis Community Elementary	203 Sink	1.4 ppb
Piscataquis Community Elementary	205 Lav	2.6 ppb
Piscataquis Community Elementary	205 Sink	5.2 ppb
Piscataquis Community Elementary	212 Drink Fountain	1.3 ppb
Piscataquis Community Elementary	212 Sink	2.7 ppb
Piscataquis Community Elementary	213 Sink	1.4 ppb
Piscataquis Community Elementary	218 Sink A	1.3 ppb
Piscataquis Community Elementary	218 Sink B	4.8 ppb
Piscataquis Community Elementary	218 Sink C	3.8 ppb

School Name	Sample Location	Lead Test Result
Piscataquis Community Elementary	219 Sink	4.7 ppb
Piscataquis Community Elementary	220 Sink	4.3 ppb
Piscataquis Community Elementary	221 Sink	3.6 ppb
Piscataquis Community Elementary	222 Sink	3.9 ppb
Piscataquis Community Elementary	223 Sink	7.4 ppb
Piscataquis Community Elementary	224 Sink	3.9 ppb
Piscataquis Community Elementary	225 Drink Fountain	0 ppb
Piscataquis Community Elementary	225 Sink	1.1 ppb
Piscataquis Community Elementary	226 Drink Fountain	0 ppb
Piscataquis Community Elementary	226 Sink	3.1 ppb
Piscataquis Community Elementary	227 Lav	1.2 ppb
Piscataquis Community Elementary	228 Lav	1.2 ppb
Piscataquis Community Elementary	230 Sink	3.1 ppb
Piscataquis Community Elementary	234 Sink	2.4 ppb
Piscataquis Community Elementary	237 Drink Fountain	0 ppb
Piscataquis Community Elementary	237 Sink	4.9 ppb
Piscataquis Community Elementary	238 Drink Fountain	1 ppb
Piscataquis Community Elementary	238 Sink	3.6 ppb
Piscataquis Community Elementary	240 Drinking Fountain	6.7 ppb
Piscataquis Community Elementary	240 Sink	5.7 ppb
Piscataquis Community Elementary	243 Drink Fountain	1.6 ppb
Piscataquis Community Elementary	243 Sink	1.8 ppb
Piscataquis Community Elementary	244 Drink Fountain	1.1 ppb
Piscataquis Community Elementary	244 Sink	2.6 ppb
Piscataquis Community Elementary	249 Sink	4.9 ppb
Piscataquis Community Elementary	251 Janitor Sink	1.1 ppb
Piscataquis Community Elementary	252 Hall Drink Fountain	0 ppb
Piscataquis Community Elementary	252 Hand Sink	4.1 ppb
Piscataquis Community Elementary	253 Drink Fountain	3.8 ppb
Piscataquis Community Elementary	253 Sink	5.9 ppb
Piscataquis Community Elementary	254 Drink Fountain	1.8 ppb
Piscataquis Community Elementary	254 Sink	3.5 ppb
Piscataquis Community Elementary	7-8 Drink Fountain	0 ppb
Piscataquis Community Elementary	Band Hydrant	152 ppb
Piscataquis Community Elementary	Boiler Room Hose	16.5 ppb
Piscataquis Community Elementary	Boiler Room Hydrant	84.2 ppb
Piscataquis Community Elementary	Front Garden Hydrant	16.8 ppb
Piscataquis Community Elementary	Gym Lobby Drink Fountain	0 ppb
Piscataquis Community Elementary	Kitchen Hydrant	67.1 ppb
Piscataquis Community Elementary	Lobby Drinking Fountain	0 ppb
Piscataquis Community Elementary	Outside Faucet Mechanical Room	55.4 ppb
Piscataquis Community Elementary	Special Ed Drinking Fountain	0 ppb
Piscataquis Community Secondary School	103 Hydrant	35.1 ppb
Piscataquis Community Secondary School	103 Utility Sink	4.1 ppb
Piscataquis Community Secondary School	103a Sink	40.4 ppb
Piscataquis Community Secondary School	104 Lav	5.9 ppb
Piscataquis Community Secondary School	106 Sink	54.5 ppb

School Name	Sample Location	Lead Test Result
Piscataquis Community Secondary School	113 Sink	12.1 ppb
Piscataquis Community Secondary School	114 Drink Fountain	0 ppb
Piscataquis Community Secondary School	114 Hydrant	140 ppb
Piscataquis Community Secondary School	114 Lav 2	7.3 ppb
Piscataquis Community Secondary School	119 Utility Sink	153 ppb
Piscataquis Community Secondary School	122 Drink Fountain	13.7 ppb
Piscataquis Community Secondary School	122 Lav 1	3.8 ppb
Piscataquis Community Secondary School	122 Lav 2	10.4 ppb
Piscataquis Community Secondary School	123 Ice Maker	2 ppb
Piscataquis Community Secondary School	123 Lav	15 ppb
Piscataquis Community Secondary School	132 Hydrant	36.9 ppb
Piscataquis Community Secondary School	141 Hose	6 ppb
Piscataquis Community Secondary School	145 Lav	68.3 ppb
Piscataquis Community Secondary School	146 Dish Sink	7.5 ppb
Piscataquis Community Secondary School	146 Hand Sink	4.3 ppb
Piscataquis Community Secondary School	147 Hand Sink	89.8 ppb
Piscataquis Community Secondary School	147 Kettle	7.3 ppb
Piscataquis Community Secondary School	158 Hydrant	159 ppb
Piscataquis Community Secondary School	160 1st Faucet	20.6 ppb
Piscataquis Community Secondary School	160 2nd Faucet	20.2 ppb
Piscataquis Community Secondary School	160 3rd Faucet	19.5 ppb
Piscataquis Community Secondary School	160 4th Faucet	15.5 ppb
Piscataquis Community Secondary School	161 Sink	15.7 ppb
Piscataquis Community Secondary School	162 Sink 1	36.1 ppb
Piscataquis Community Secondary School	162 Sink 2	6.7 ppb
Piscataquis Community Secondary School	163 Lab Station 1	202 ppb
Piscataquis Community Secondary School	163 Lab Station 2	12.6 ppb
Piscataquis Community Secondary School	163 Lab Station 3	16.1 ppb
Piscataquis Community Secondary School	163 Lab Station 4	15.5 ppb
Piscataquis Community Secondary School	163 Lab Station 5	17.9 ppb
Piscataquis Community Secondary School	163 Lab Station 6	48.7 ppb
Piscataquis Community Secondary School	163 Lav 1	5 ppb
Piscataquis Community Secondary School	163 Lav 2	3.2 ppb
Piscataquis Community Secondary School	163 Lav 3	5 ppb
Piscataquis Community Secondary School	164 Lav	7.8 ppb
Piscataquis Community Secondary School	165 Back Sink	66.7 ppb
Piscataquis Community Secondary School	165 Left Sink	25 ppb
Piscataquis Community Secondary School	165 Right Sink	11.9 ppb
Piscataquis Community Secondary School	166 Sink	5.5 ppb
Piscataquis Community Secondary School	168 Sink	25.9 ppb
Piscataquis Community Secondary School	175 Sink	11.3 ppb
Piscataquis Community Secondary School	177 Sink	7.3 ppb
Piscataquis Community Secondary School	180 Hydrant	96.2 ppb
Piscataquis Community Secondary School	182 Sink	5.9 ppb
Piscataquis Community Secondary School	189 Lav 1	6.1 ppb
Piscataquis Community Secondary School	189 Lav 2	40.7 ppb
Piscataquis Community Secondary School	195 Sink	3.2 ppb

School Name	Sample Location	Lead Test Result
Piscataquis Community Secondary School	196 Sink	6.9 ppb
Piscataquis Community Secondary School	200 Sink	17.3 ppb
Piscataquis Community Secondary School	200a Utility Sink	0 ppb
Piscataquis Community Secondary School	201 Sink	13.1 ppb
Piscataquis Community Secondary School	202 Sink	15.4 ppb
Piscataquis Community Secondary School	203 Sink	9 ppb
Piscataquis Community Secondary School	7-8 Boys Lav	5 ppb
Piscataquis Community Secondary School	7-8 Girls Lav	3.4 ppb
Piscataquis Community Secondary School	Art Hall Drinking Fountain	1.9 ppb
Piscataquis Community Secondary School	Big Janitor Room Sink	10.4 ppb
Piscataquis Community Secondary School	Bus Hydrant	6.3 ppb
Piscataquis Community Secondary School	Bus Lav	6.2 ppb
Piscataquis Community Secondary School	Bus Sink	6.2 ppb
Piscataquis Community Secondary School	Bus Utility	3.2 ppb
Piscataquis Community Secondary School	Cafe Drink Fountain	0 ppb
Piscataquis Community Secondary School	Cafe Hall Drink Fountain	0 ppb
Piscataquis Community Secondary School	Drink Fountain By Front Hall Lavs	0 ppb
Piscataquis Community Secondary School	Kitchen Hydrant	10.4 ppb
Piscataquis Community Secondary School	Lab Hall Drink Fountain	0 ppb
Pittston-Randolph Consolidated School	Art Rm	0 ppb
Pittston-Randolph Consolidated School	Ciampa Rm	0 ppb
Pittston-Randolph Consolidated School	Damon Rm	0 ppb
Pittston-Randolph Consolidated School	Hilton Rm	0 ppb
Pittston-Randolph Consolidated School	Kitchen Sink	0 ppb
Pittston-Randolph Consolidated School	Main Office Sink	1 ppb
Pittston-Randolph Consolidated School	Modular Hallway Water Fountain	0 ppb
Pittston-Randolph Consolidated School	Old Wing Hallway Fountain	0 ppb
Pittston-Randolph Consolidated School	Prout Rm	0 ppb
Pittston-Randolph Consolidated School	Rowe Rm	1 ppb
Pittston-Randolph Consolidated School	Woodcock Rm	0 ppb
Pleasant Hill School	Clinic Sink	1.6 ppb
Pleasant Hill School	Gym Bathroom Sink	0 ppb
Pleasant Hill School	Gym Filler	0 ppb
Pleasant Hill School	Gym Fountain	0 ppb
Pleasant Hill School	Kitchen 3-bay Sink	2.4 ppb
Pleasant Hill School	Library Sink	7.3 ppb
Pleasant Hill School	Room 10 Fountain	2 ppb
Pleasant Hill School	Room 10 Sink	4 ppb
Pleasant Hill School	Room 11 Sink	4.3 ppb
Pleasant Hill School	Room 12 Fountain	0 ppb
Pleasant Hill School	Room 12 Sink	2.6 ppb
Pleasant Hill School	Room 13 Fountain	0 ppb
Pleasant Hill School	Room 13 Sink	3.2 ppb
Pleasant Hill School	Room 14 Fountain	2.2 ppb
Pleasant Hill School	Room 14 Sink	6 ppb
Pleasant Hill School	Room 15 Fountain	2 ppb
Pleasant Hill School	Room 15 Sink	0 ppb

School Name	Sample Location	Lead Test Result
Pleasant Hill School	Room 16 Bath Sink	0 ppb
Pleasant Hill School	Room 17 Bath Sink	0 ppb
Pleasant Hill School	Room 18 Bath Sink	0 ppb
Pleasant Hill School	Room 19 Bath Sink	0 ppb
Pleasant Hill School	Room 5 Fountain	0 ppb
Pleasant Hill School	Room 5 Sink	2.8 ppb
Pleasant Hill School	Room 6 Fountain	1 ppb
Pleasant Hill School	Room 6 Sink	2.6 ppb
Pleasant Hill School	Room 7 Fountain	0 ppb
Pleasant Hill School	Room 7 Sink	3.2 ppb
Pleasant Hill School	Room 8 Fountain	0 ppb
Pleasant Hill School	Room 8 Sink	3.3 ppb
Pleasant Hill School	Room 9 Fountain	0 ppb
Pleasant Hill School	Room 9 Sink	3.3 ppb
Pleasant Hill School	Room11 Fountain	0 ppb
Pleasant Hill School	Teacher Break Room Sink	0 ppb
Poland Community School	2nd Floor Adult Bathroom	2.5 ppb
Poland Community School	2nd Floor Fountain	0 ppb
Poland Community School	3rd Grade #2 Fountain	1 ppb
Poland Community School	3rd Grade Solo Fountain	3.5 ppb
Poland Community School	Adult Bathroom (by Pre-k)	1.3 ppb
Poland Community School	Adult Bathroom Sink	0 ppb
Poland Community School	Adult Bathroom Sink 1 (by Boiler Rm)	7.2 ppb
Poland Community School	Art Room Sink 1	0 ppb
Poland Community School	Art Room Sink 2	0 ppb
Poland Community School	Boy's Bathroom Sink 1 (by Boiler Rm)	0 ppb
Poland Community School	Boy's Bathroom Sink 1 (by Pre-k)	0 ppb
Poland Community School	Boy's Bathroom Sink 2 (by Boiler Rm)	0 ppb
Poland Community School	Boy's Bathroom Sink 2 (by Pre-k)	0 ppb
Poland Community School	Boy's Bathroom Sink 3 (by Boiler Rm)	0 ppb
Poland Community School	Boy's Bathroom Sink 3 (by Pre-k)	0 ppb
Poland Community School	Boy's Locker Room Shower 1	10.7 ppb
Poland Community School	Boy's Locker Room Shower 2	11.7 ppb
Poland Community School	Boy's Locker Room Shower 3	8.7 ppb
Poland Community School	Boy's Locker Room Shower 4	8.7 ppb
Poland Community School	Boy's Locker Room Shower 5	11.7 ppb
Poland Community School	Boy's Locker Room Shower 6	7.5 ppb
Poland Community School	Boy's Locker Room Shower 7	9.8 ppb
Poland Community School	Boy's Locker Room Shower 8	7.8 ppb
Poland Community School	Boy's Locker Room Sink	0 ppb
Poland Community School	Boy's Room Sink (bottom Of Staires)	1.3 ppb
Poland Community School	Boy's Room Sink 1 (2nd Floor)	3.2 ppb
Poland Community School	Boy's Room Sink 2 (2nd Floor)	2.4 ppb
Poland Community School	Custodian Sink	1.3 ppb
Poland Community School	Girl's Bathroom Sink 1 (by Boiler Rm)	1.1 ppb
Poland Community School	Girl's Bathroom Sink 1 (by Pre-k)	0 ppb
Poland Community School	Girl's Bathroom Sink 2 (by Boiler Rm)	0 ppb

School Name	Sample Location	Lead Test Result
Poland Community School	Girl's Bathroom Sink 2 (by Pre-k)	0 ppb
Poland Community School	Girl's Bathroom Sink 3 (by Boiler Rm)	0 ppb
Poland Community School	Girl's Locker Room Shower 1	4.3 ppb
Poland Community School	Girl's Locker Room Shower 2	10.7 ppb
Poland Community School	Girl's Locker Room Shower 3	5.9 ppb
Poland Community School	Girl's Locker Room Shower 4	9.5 ppb
Poland Community School	Girl's Locker Room Shower 5	10.7 ppb
Poland Community School	Girl's Locker Room Sink	0 ppb
Poland Community School	Girl's Room Sink (bottom Of Staires)	2.3 ppb
Poland Community School	Girl's Room Sink 1 (2nd Floor)	0 ppb
Poland Community School	Girl's Room Sink 2 (2nd Floor)	0 ppb
Poland Community School	Gym Water Fountain 1 (left)	0 ppb
Poland Community School	Gym Water Fountain 2 (right)	0 ppb
Poland Community School	Hose Bib By Dumpster	26.2 ppb
Poland Community School	Hose Bib By Main Entrance	46.1 ppb
Poland Community School	Hose Bib By Oil Tank	4.4 ppb
Poland Community School	Hose Bib In Courtyard	11.2 ppb
Poland Community School	Kitchen Bathroom Sink	1.2 ppb
Poland Community School	Kitchen Dish Sink 1	0 ppb
Poland Community School	Kitchen Dish Sink 2	0 ppb
Poland Community School	Kitchen Hand Sink	2.2 ppb
Poland Community School	Kitchen Pot Faucet At Stove	44.3 ppb
Poland Community School	Kitchen Sprayer	15.4 ppb
Poland Community School	Kitchen Wash Sink 1	5.8 ppb
Poland Community School	Kitchen Wash Sink 2	2.9 ppb
Poland Community School	Lit Lab Sink	1.4 ppb
Poland Community School	Nurse Sink 1	0 ppb
Poland Community School	Nurse Sink 2	0 ppb
Poland Community School	Pre-k #1 Water Fountain Bottle Filler	0 ppb
Poland Community School	Pre-k #2 Water Fountain	0 ppb
Poland Community School	Rm 203	15.9 ppb
Poland Community School	Room 112 Pre-k Sink	0 ppb
Poland Community School	Room 137 Sink	0 ppb
Poland Community School	Room 148 Sink	5.8 ppb
Poland Community School	Room 159 Sink	0 ppb
Poland Community School	Room 164 Sink	10.7 ppb
Poland Community School	Room 172 Sink	0 ppb
Poland Community School	Room 173 Sink	0 ppb
Poland Community School	Room 179 Sink	5 ppb
Poland Community School	Room 202 Sink	34.1 ppb
Poland Community School	Room 204 Sink	11.8 ppb
Poland Community School	Room 205 Sink	36.6 ppb
Poland Community School	Room 206 Sink	6.9 ppb
Poland Community School	Room 207 Sink	7.4 ppb
Poland Community School	Room 209 Sink	28.9 ppb
Poland Community School	Teacher's Room Sink 1	0 ppb
Poland Community School	Teacher's Room Sink 2	1.1 ppb

School Name	Sample Location	Lead Test Result
Poland Community School	Water Fountain By Room 180	0 ppb
Poland Regional H S	Art A115 Sink 79 R	0 ppb
Poland Regional H S	Art A115 Sink 80 R	0 ppb
Poland Regional H S	Art A115 Sink 81 R	15.7 ppb
Poland Regional H S	Art A117 Sink 82 L	0 ppb
Poland Regional H S	Art A117 Sink 83 L	0 ppb
Poland Regional H S	Back Of School O. Faucet 143	541 ppb
Poland Regional H S	Boy's A157 Sink 59 R	1.3 ppb
Poland Regional H S	Boy's A157 Sink 60 L	4.1 ppb
Poland Regional H S	Boy's A157 Sink 61 L	8.4 ppb
Poland Regional H S	Boy's D116 Sink 91 L	2.2 ppb
Poland Regional H S	Boy's D116 Sink 92 R	0 ppb
Poland Regional H S	Boy's D116 Sink 93 R	1.9 ppb
Poland Regional H S	Boy's D209 Sink 121 R	0 ppb
Poland Regional H S	Boy's D209 Sink 122 L	3.3 ppb
Poland Regional H S	Boy's D209 Sink 123 L	2.8 ppb
Poland Regional H S	Boy's L. A160 Sink 64 L	7.3 ppb
Poland Regional H S	Boy's L. A160 Sink 65 R	1.9 ppb
Poland Regional H S	Boy's L. A160 Sink 66 R	2.3 ppb
Poland Regional H S	Break Rm O. Faucet 140	27 ppb
Poland Regional H S	Com. A132 Dwf 54	0 ppb
Poland Regional H S	Com. A132 Dwf 55	0 ppb
Poland Regional H S	Concessions O. Faucet 154	7 ppb
Poland Regional H S	Concessions Sink 155	0 ppb
Poland Regional H S	Concessions Sink 156	0 ppb
Poland Regional H S	Corr. A118 Dwf 85 L	0 ppb
Poland Regional H S	Corr. A118 Dwf 86 R	0 ppb
Poland Regional H S	Corr. D107 Dwf 97 Lk	0 ppb
Poland Regional H S	Corr. D230 Dwf 119 L	0 ppb
Poland Regional H S	Corr. D230 Dwf 120 R	0 ppb
Poland Regional H S	D-path D117 Sink 89 L	2.3 ppb
Poland Regional H S	Field House O. Faucet 153	2.1 ppb
Poland Regional H S	Girl's A158 Sink 56 L	7.4 ppb
Poland Regional H S	Girl's A158 Sink 57 R	2.4 ppb
Poland Regional H S	Girl's A158 Sink 58 R	1.5 ppb
Poland Regional H S	Girl's D115 Sink 94 R	0 ppb
Poland Regional H S	Girl's D115 Sink 95 L	1.7 ppb
Poland Regional H S	Girl's D115 Sink 96 L	0 ppb
Poland Regional H S	Girl's D208 Sink 116 R	1.4 ppb
Poland Regional H S	Girl's D208 Sink 117 L	0 ppb
Poland Regional H S	Girl's D208 Sink 118 L	1.5 ppb
Poland Regional H S	Girl's L. A165 Sink 67 L	2.3 ppb
Poland Regional H S	Girl's L. A165 Sink 68 R	3.4 ppb
Poland Regional H S	Girl's L. A165 Sink 69 R	1.8 ppb
Poland Regional H S	Hs Gym A100 Dwf 62a	2.3 ppb
Poland Regional H S	Jan. A172 Sink 70 L	0 ppb
Poland Regional H S	Janitor D 118 Sink 90 L	0 ppb

School Name	Sample Location	Lead Test Result
Poland Regional H S	Janitor D211 Sink 132	2.5 ppb
Poland Regional H S	Kitchen A112 Sink 73 R	1.8 ppb
Poland Regional H S	Kitchen A112 Sink 74 R	31.3 ppb
Poland Regional H S	Kitchen A112 Sink 75 R	9.6 ppb
Poland Regional H S	Kitchen A112 Sink 76 L	1.1 ppb
Poland Regional H S	Kitchen A112 Sink 77 L	1.4 ppb
Poland Regional H S	Mechanical Rm. O. Faucet 149	255 ppb
Poland Regional H S	Media A120 Sink 84 R	0 ppb
Poland Regional H S	Multi A101 Sink 78 R	1.5 ppb
Poland Regional H S	Near Band O. Faucet 146	101 ppb
Poland Regional H S	Near Chorus O. Faucet 145	702 ppb
Poland Regional H S	Near D101 O. Faucet 144	221 ppb
Poland Regional H S	Near Garage O. Faucet 141	678 ppb
Poland Regional H S	Near Hs Gym O. Faucet 151	0 ppb
Poland Regional H S	Near Hs Gym O. Faucet 152	519 ppb
Poland Regional H S	Near Kitchen O. Faucet 142	20.2 ppb
Poland Regional H S	Near Tech. Ed. O. Faucet 148	1170 ppb
Poland Regional H S	Prep. D130 Sink 101 R	2.4 ppb
Poland Regional H S	S. Prep D222 Sink 139	9.5 ppb
Poland Regional H S	Science D128 Sink 102 R	32.2 ppb
Poland Regional H S	Science D128 Sink 103 L	35.9 ppb
Poland Regional H S	Science D128 Sink 104 L	15 ppb
Poland Regional H S	Science D128 Sink 105 L	13.1 ppb
Poland Regional H S	Science D128 Sink 107 L	38.6 ppb
Poland Regional H S	Science D206 Sink 108 L	4.7 ppb
Poland Regional H S	Science D206 Sink 109 R	2.2 ppb
Poland Regional H S	Science D206 Sink 110 R	23.3 ppb
Poland Regional H S	Science D206 Sink 111 R	9.4 ppb
Poland Regional H S	Science D206 Sink 112 R	2 ppb
Poland Regional H S	Science D206 Sink 113 R	3.5 ppb
Poland Regional H S	Science D206 Sink 114 R	2.8 ppb
Poland Regional H S	Science D212 Sink 124 R	7.1 ppb
Poland Regional H S	Science D212 Sink 125 R	6.8 ppb
Poland Regional H S	Science D212 Sink 126 R	26.6 ppb
Poland Regional H S	Science D212 Sink 127 R	54.8 ppb
Poland Regional H S	Science D212 Sink 128 R	18.1 ppb
Poland Regional H S	Science D212 Sink 129 R	10.4 ppb
Poland Regional H S	Science D212 Sink 130 R	18.7 ppb
Poland Regional H S	Science D221 Sink 133 L	16 ppb
Poland Regional H S	Science D221 Sink 134 R	31.6 ppb
Poland Regional H S	Science D221 Sink 135 R	23.8 ppb
Poland Regional H S	Science D221 Sink 137 R	25.7 ppb
Poland Regional H S	Science D221 Sink 138 R	44.6 ppb
Poland Regional H S	Sp. Ed D133 Sink 99 R	0 ppb
Poland Regional H S	Supply A173 Sink 71 L	2.1 ppb
Poland Regional H S	Toilet A135 Sink 48 L	0 ppb
Poland Regional H S	Toilet A161 Sink 62 L	4.4 ppb

School Name	Sample Location	Lead Test Result
Poland Regional H S	Toilet A164 Sink 63 R	0 ppb
Poland Regional H S	Toilet D108 Sink 88 L	5.1 ppb
Poland Regional H S	Toilet D109 Sink 87 R	0 ppb
Poland Regional H S	Toilet D134 Sink 100 L	1.9 ppb
Poland Regional H S	Toilet D229 Sink 131	0 ppb
Poland Regional H S	Toilet D233 Sink 115	1.2 ppb
Poland Regional H S	Train A171 Sink 72 R	9 ppb
Pond Cove Elementary	4th Grade Boys Restroom	1.3 ppb
Pond Cove Elementary	4th Grade Girls Restroom	1.4 ppb
Pond Cove Elementary	A113	0 ppb
Pond Cove Elementary	A119	3 ppb
Pond Cove Elementary	A120	0 ppb
Pond Cove Elementary	A122	0 ppb
Pond Cove Elementary	A123	0 ppb
Pond Cove Elementary	A126	0 ppb
Pond Cove Elementary	A127	3.7 ppb
Pond Cove Elementary	A128 L	2.4 ppb
Pond Cove Elementary	A128 R	3.8 ppb
Pond Cove Elementary	A129	2.2 ppb
Pond Cove Elementary	Allied Arts Restroom	0 ppb
Pond Cove Elementary	B101	5.1 ppb
Pond Cove Elementary	B102	2.2 ppb
Pond Cove Elementary	B103	4.3 ppb
Pond Cove Elementary	B104	3.6 ppb
Pond Cove Elementary	B114	5.8 ppb
Pond Cove Elementary	B115	0 ppb
Pond Cove Elementary	B117	19.9 ppb
Pond Cove Elementary	B118	2.5 ppb
Pond Cove Elementary	Boys Restroom 1st Grade L	1.3 ppb
Pond Cove Elementary	Boys Restroom 1st Grade R	5.2 ppb
Pond Cove Elementary	Boys Restroom 2nd Grade L	1.6 ppb
Pond Cove Elementary	Boys Restroom 2nd Grade R	1.7 ppb
Pond Cove Elementary	Boys Restroom 3rd Grade L	3.8 ppb
Pond Cove Elementary	Boys Restroom 3rd Grade R	2 ppb
Pond Cove Elementary	Boys Restroom K Wing L	0 ppb
Pond Cove Elementary	Boys Restroom K Wing R	0 ppb
Pond Cove Elementary	C103	4.8 ppb
Pond Cove Elementary	C104	2.6 ppb
Pond Cove Elementary	C105	5.4 ppb
Pond Cove Elementary	C123	2.7 ppb
Pond Cove Elementary	C128	6 ppb
Pond Cove Elementary	C129	4 ppb
Pond Cove Elementary	C202	6 ppb
Pond Cove Elementary	C203	3.8 ppb
Pond Cove Elementary	C204	4.6 ppb
Pond Cove Elementary	C205	3.1 ppb
Pond Cove Elementary	C217	2.2 ppb

School Name	Sample Location	Lead Test Result
Pond Cove Elementary	C218	10.5 ppb
Pond Cove Elementary	C219	4.1 ppb
Pond Cove Elementary	C220	3.7 ppb
Pond Cove Elementary	C302	1.2 ppb
Pond Cove Elementary	C303	0 ppb
Pond Cove Elementary	C305	0 ppb
Pond Cove Elementary	C306	0 ppb
Pond Cove Elementary	C307	0 ppb
Pond Cove Elementary	C307 Restroom	0 ppb
Pond Cove Elementary	Fountain - 4th Grade	0 ppb
Pond Cove Elementary	Fountain - Main Office	0 ppb
Pond Cove Elementary	Girls Restroom 1st Grade L	9 ppb
Pond Cove Elementary	Girls Restroom 1st Grade R	1 ppb
Pond Cove Elementary	Girls Restroom 2nd Grade L	4 ppb
Pond Cove Elementary	Girls Restroom 2nd Grade R	2.3 ppb
Pond Cove Elementary	Girls Restroom 3rd Grade L	0 ppb
Pond Cove Elementary	Girls Restroom 3rd Grade R	0 ppb
Pond Cove Elementary	Girls Restroom K Wing L	0 ppb
Pond Cove Elementary	Girls Restroom K Wing R	0 ppb
Pond Cove Elementary	Gym Boys Restroom L	0 ppb
Pond Cove Elementary	Gym Boys Restroom R	0 ppb
Pond Cove Elementary	Gym Girls Restroom L	0 ppb
Pond Cove Elementary	Gym Girls Restroom R	0 ppb
Pond Cove Elementary	Gym Staff Restroom	4.5 ppb
Pond Cove Elementary	Gym Water Fountain	0 ppb
Pond Cove Elementary	Media Center	1.1 ppb
Pond Cove Elementary	Nurses Office	1.2 ppb
Pond Cove Elementary	Nurses Restroom	0 ppb
Pond Cove Elementary	Staff Restroom 1st Grade	0 ppb
Pond Cove Elementary	Staff Restroom 3rd Grade 1st	0 ppb
Pond Cove Elementary	Staff Restroom 3rd Grade 2nd	0 ppb
Pond Cove Elementary	Staff Restroom 3rd Grade Solo	0 ppb
Pond Cove Elementary	Staff Restroom Main Office	0 ppb
Portland Arts & Technology H S/Casco Bay H	111 Cafe	2.5 ppb
Portland Arts & Technology H S/Casco Bay H	112 Kitchen	6.7 ppb
Portland Arts & Technology H S/Casco Bay H	130 Kitchen	2.5 ppb
Portland Arts & Technology H S/Casco Bay H	145 Clinic	16.4 ppb
Portland Arts & Technology H S/Casco Bay H	150 Health Sci	0 ppb
Portland Arts & Technology H S/Casco Bay H	160 Child Care	5.2 ppb
Portland Arts & Technology H S/Casco Bay H	173 Small Kitchen	10.4 ppb
Portland Arts & Technology H S/Casco Bay H	1st Floor Lobby	0 ppb
Portland Arts & Technology H S/Casco Bay H	200 Great Space Kitchen - A	1.6 ppb
Portland Arts & Technology H S/Casco Bay H	222 Lab	4.5 ppb
Portland Arts & Technology H S/Casco Bay H	232 Nurse	1.3 ppb
Portland Arts & Technology H S/Casco Bay H	235 Library	2.2 ppb
Portland Arts & Technology H S/Casco Bay H	316-1	0 ppb
Portland Arts & Technology H S/Casco Bay H	316-2	0 ppb

School Name	Sample Location	Lead Test Result
Portland Arts & Technology H S/Casco Bay H	316a-1	4.3 ppb
Portland Arts & Technology H S/Casco Bay H	370 Art	6.1 ppb
Portland Arts & Technology H S/Casco Bay H	Auto Colission	0 ppb
Portland Arts & Technology H S/Casco Bay H	Auto Shop	0 ppb
Portland Arts & Technology H S/Casco Bay H	Cbhs Kitchen - A	1.6 ppb
Portland Arts & Technology H S/Casco Bay H	Cbhs Kitchen - B	2.4 ppb
Portland Arts & Technology H S/Casco Bay H	Greenhouse Kitchen	4.2 ppb
Portland Arts & Technology H S/Casco Bay H	Masonry	0 ppb
Portland Arts & Technology H S/Casco Bay H	Pos-1	33.4 ppb
Portland Arts & Technology H S/Casco Bay H	Small Wood Shop	0 ppb
Portland Arts & Technology H S/Casco Bay H	Welding Shop	0 ppb
Portland Arts & Technology H S/Casco Bay H	Wood Working	0 ppb
Portland High School	305-1	7.7 ppb
Portland High School	305-2	3 ppb
Portland High School	306-1	1.2 ppb
Portland High School	306-2	39.3 ppb
Portland High School	307-1	448 ppb
Portland High School	330-1	800 ppb
Portland High School	330-2	9.3 ppb
Portland High School	331/332-1	3.1 ppb
Portland High School	331-1	8.1 ppb
Portland High School	331-2	2.4 ppb
Portland High School	332-1	13.6 ppb
Portland High School	332-2	22.8 ppb
Portland High School	334-1	487 ppb
Portland High School	334-2	1480 ppb
Portland High School	335/336-1	0 ppb
Portland High School	336-1	321 ppb
Portland High School	337/338-1	9.7 ppb
Portland High School	337-1	312 ppb
Portland High School	338-1	2.6 ppb
Portland High School	Basement Hall By Girls Locker Room Bubbler	2.6 ppb
Portland High School	Basin Sink In Media Room	1.9 ppb
Portland High School	Basin Sink In Room 201	3 ppb
Portland High School	Basin Sink In Room 320	25.8 ppb
Portland High School	Basin Sink In Room 324	8.7 ppb
Portland High School	Bottle Fill/bubbler By Lower Cafeteria	0 ppb
Portland High School	Bottle Fill/bubbler By Room 203	0 ppb
Portland High School	Bubbler In Hall By G35	0 ppb
Portland High School	Bubbler In Hall Near Room 134	1 ppb
Portland High School	Bubbler In The Auditorium Lobby	3.2 ppb
Portland High School	Bubbler In The Back Of The Library	2.2 ppb
Portland High School	Bubbler In The Hall Across From Room 310	19.1 ppb
Portland High School	Custodial Breakroom Basin Sink	0 ppb
Portland High School	G05 Next To Basin Sink Closest To The Entrance	2 ppb

School Name	Sample Location	Lead Test Result
Portland High School	G05 Basin Sink Closest To The Entrance	3.5 ppb
Portland High School	G05 Basin Sink Near Windows As You Enter Room	3.8 ppb
Portland High School	G05 By Basin Sink Near Windows As You Enter Room	3.6 ppb
Portland High School	G06 Basin Sink	0 ppb
Portland High School	Kitchen Basin Sink By The Ovens	0 ppb
Portland High School	Kitchen Double Basin Sink By Elevator	1.7 ppb
Portland High School	Kitchen Double Basin Sink With Sprayer	1.4 ppb
Portland High School	Kitchen Kettle	5.8 ppb
Portland High School	Main Office Basin Sink	1 ppb
Portland High School	Next To Gym Entrance On The Left	0 ppb
Portland High School	Next To Gym Entrance On The Right (bottle Fill)	0 ppb
Portland High School	Pos-1	329 ppb
Portland Kids Academy	Has Water Brought In- No Water Is Served From Their Plumbing	
Portland Public Schools Central Kitchen	No Samples Yet Taken	
Pownal Elementary School	Break Room Sink	0 ppb
Pownal Elementary School	Fountain Across Break Room	0 ppb
Pownal Elementary School	Fountain In Hall Across Room 16	11.1 ppb
Pownal Elementary School	Fountain Outside Kitchen	0 ppb
Pownal Elementary School	Kitchen Sink	1.1 ppb
Pownal Elementary School	Room 10 Fountain	3.9 ppb
Pownal Elementary School	Room 12 Fountain	3.6 ppb
Pownal Elementary School	Room 14 Fountain	5 ppb
Pownal Elementary School	Room 15 Fountain	3.5 ppb
Pownal Elementary School	Room 16 Fountain	3.7 ppb
Pownal Elementary School	Second Fountain Across Break Room	0 ppb
Prescott Memorial School	Art Room Sink	12.1 ppb
Prescott Memorial School	Bathroom Boys Sink Lower Level	0 ppb
Prescott Memorial School	Bathroom Boys Sink Upper Level	6.9 ppb
Prescott Memorial School	Bathroom Girls Sink Lower Level	2.7 ppb
Prescott Memorial School	Bathroom Girls Sink Upper Level	13.6 ppb
Prescott Memorial School	Bathroom Men Sink Lower Level	3.6 ppb
Prescott Memorial School	Bathroom Women Sink Lower Level	1.1 ppb
Prescott Memorial School	Bottle Filling Bubbler Gym	1.4 ppb
Prescott Memorial School	Bottle Filling Bubbler Upper Hallway	0 ppb
Prescott Memorial School	Bottle Filling Gym	1.9 ppb
Prescott Memorial School	Bottle Filling Upper Hallway	0 ppb
Prescott Memorial School	Custodial Closet Sink Lower Level	3.1 ppb
Prescott Memorial School	Custodial Closet Sink Upper Level	11.6 ppb
Prescott Memorial School	Kitchen Food Prep Sinks	3.8 ppb
Prescott Memorial School	Kitchen Handwash Station	6.8 ppb
Prescott Memorial School	Room 104 Bubblers	8.5 ppb
Prescott Memorial School	Room 104 Faucet	12.9 ppb
Prescott Memorial School	Room 105 Bubbler Teacher Lounge	4.7 ppb

School Name	Sample Location	Lead Test Result
Prescott Memorial School	Room 105 Facuet Teacher Lounge	4.9 ppb
Prescott Memorial School	Room 106 Bubbler 1st Grade	1.4 ppb
Prescott Memorial School	Room 106 Faucet 1st Grade	5.6 ppb
Prescott Memorial School	Room 107 Bubbler Kindergarten	3.4 ppb
Prescott Memorial School	Room 107 Faucet Kindergarten	0 ppb
Prescott Memorial School	Room 203 Bubbler 2nd Grade	2.2 ppb
Prescott Memorial School	Room 203 Faucet 2nd Grade	2.4 ppb
Prescott Memorial School	Room 207 Faucet 5th Grade	5.3 ppb
Prescott Memorial School	Room 212 Faucet 6th Grade	4.7 ppb
Prescott Memorial School	Room 214 Faucet Clinic	14.2 ppb
Presque Isle High School	Art Room	0 ppb
Presque Isle High School	Cafeteria	0 ppb
Presque Isle High School	Concessions Hall	2.2 ppb
Presque Isle High School	Junior Hall By Nurses Office	0 ppb
Presque Isle High School	Kitchen Ice Machine	0 ppb
Presque Isle High School	Kitchen Sink #1	0 ppb
Presque Isle High School	Kitchen Sink #2	0 ppb
Presque Isle High School	Kitchen Sink #3	0 ppb
Presque Isle High School	Kitchen Tilt Skillet	3.1 ppb
Presque Isle High School	Library Hall Teachers Lounge	2.2 ppb
Presque Isle High School	Lower Gym Phys Ed Office	0 ppb
Presque Isle High School	Main Office	2.1 ppb
Presque Isle High School	Nurses Office Sink #1	0 ppb
Presque Isle High School	Nurses Office Sink #2	112 ppb
Presque Isle High School	Room 128 Life Skills Kitchenette	0 ppb
Presque Isle High School	Room 223	6.1 ppb
Presque Isle High School	Room 226	3.6 ppb
Presque Isle High School	Room 228	0 ppb
Presque Isle High School	Room 230	9 ppb
Presque Isle High School	Room 300	3.5 ppb
Presque Isle High School	Senior Hall 100 Wing	0 ppb
Presque Isle High School	Senior Hall Teachers Lounge	1 ppb
Presque Isle High School	Sophomore Hall 200 Wing	0 ppb
Presque Isle High School	Superintendents Break Room	6.5 ppb
Presque Isle High School	Upper Gym Phys Ed Office	0 ppb
Presque Isle High School	Upper Gymnasium	0 ppb
Presque Isle Middle School	6th Grade Hall	0 ppb
Presque Isle Middle School	7th Grade Teachers Lounge	0 ppb
Presque Isle Middle School	8th Grade Hall	0 ppb
Presque Isle Middle School	8th Grade Teachers Lounge	0 ppb
Presque Isle Middle School	Cafeteria	1.4 ppb
Presque Isle Middle School	Fine Arts Hall	0 ppb
Presque Isle Middle School	Gymnasium	0 ppb
Presque Isle Middle School	Ice Machine	0 ppb
Presque Isle Middle School	Kitchen Sink #	0 ppb
Presque Isle Middle School	Kitchen Sink #2	0 ppb
Presque Isle Middle School	Kitchen Sink #3	0 ppb

School Name	Sample Location	Lead Test Result
Presque Isle Middle School	Kitchen Sink #4	0 ppb
Presque Isle Middle School	Kitchen Sink #5	0 ppb
Presque Isle Middle School	Main Hall Teachers Lounge	0 ppb
Presque Isle Middle School	Main Office Hall	0 ppb
Presque Isle Middle School	Room 1	0 ppb
Presque Isle Middle School	Room 14	5.6 ppb
Presque Isle Middle School	Room 201	0 ppb
Presque Isle Middle School	Room 202	0 ppb
Presque Isle Middle School	Room 218	1.1 ppb
Presque Isle Middle School	Room 29 Life Skills Kitchennette	5 ppb
Presque Isle Middle School	Room 6	0 ppb
Presque Isle Reg Career & Tech Ctr	Room 114	1.3 ppb
Presque Isle Reg Career & Tech Ctr	Room 302	3.1 ppb
Presque Isle Reg Career & Tech Ctr	Room 312	0 ppb
Presque Isle Reg Career & Tech Ctr	Room 409	38.6 ppb
Presque Isle Reg Career & Tech Ctr	Vegetable Wash Sink #1	0 ppb
Presque Isle Reg Career & Tech Ctr	Vegetable Wash Sink #3	0 ppb
Presque Isle Reg Career & Tech Ctr	Vegetable Wask Sink #2	0 ppb
Presque Isle Reg Career & Tech Ctr	Vocational Hall 300 Wing	0 ppb
Presque Isle Reg Career & Tech Ctr	Vocational Hall 400 Wing	0 ppb
Presque Isle Reg Career & Tech Ctr	Vocational Hall Teachers Lounge 300 Wing	0 ppb
Presumpscot School	Art Room	11.6 ppb
Presumpscot School	Bottle Filler In Lobby	0 ppb
Presumpscot School	Boys Bathroom	1 ppb
Presumpscot School	Boys Bathroom Sink 1	0 ppb
Presumpscot School	Boys Bathroom Sink 2	0 ppb
Presumpscot School	Boys Bathroom Sink 3	0 ppb
Presumpscot School	Copier Room	1.7 ppb
Presumpscot School	Girls Bathroom	1.5 ppb
Presumpscot School	Girls Bathroom Sink 1	0 ppb
Presumpscot School	Girls Bathroom Sink 2	0 ppb
Presumpscot School	Girls Bathroom Sink 3	0 ppb
Presumpscot School	Kitchen Sink	4.8 ppb
Presumpscot School	Nurses Office	4.5 ppb
Presumpscot School	Pos-1	2.6 ppb
Presumpscot School	Room 1 Sink	2.9 ppb
Presumpscot School	Room 141 Sink	0 ppb
Presumpscot School	Room 141fountain	0 ppb
Presumpscot School	Room 2	2.6 ppb
Presumpscot School	Room 3	2.9 ppb
Presumpscot School	Room 4	1.1 ppb
Presumpscot School	Room 5	2.2 ppb
Presumpscot School	Room 6	0 ppb
Presumpscot School	Rooms 9 10 11 12 And 13	7.4 ppb
Presumpscot School	Staff #1 Bathroom 1	0 ppb
Presumpscot School	Staff #1 Bathroom 2	0 ppb
Presumpscot School	Staff Bathroom	0 ppb

School Name	Sample Location	Lead Test Result
Presumpscot School	Teachers Lounge	0 ppb
Presumpscot School	Therapy Room	1 ppb
Princeton Elementary School	Boys Bathroom In Gym	2.8 ppb
Princeton Elementary School	Boys Upper Grade Bathroom	2.9 ppb
Princeton Elementary School	Dish Wash Sink In Kitchen	1.4 ppb
Princeton Elementary School	Eye/hand Wash Sink In Kitchen	6.8 ppb
Princeton Elementary School	Faucet A In Boiler Room	16.6 ppb
Princeton Elementary School	Faucet B In Boiler Room	136 ppb
Princeton Elementary School	Faucets- Teachers Desk- Science Lab	13.8 ppb
Princeton Elementary School	Fountain In Boys' Locker Room	0 ppb
Princeton Elementary School	Fountain In Girls Locker Room	0 ppb
Princeton Elementary School	Girls Bathroom In Gym	15.5 ppb
Princeton Elementary School	Girls Upper Grade Bathroom	3.4 ppb
Princeton Elementary School	Outside Faucet By Boiler Room	8.4 ppb
Princeton Elementary School	Outside Faucet By Kindergarten Room	4.5 ppb
Princeton Elementary School	Prep Sink In Kitchen	3 ppb
Princeton Elementary School	Project Room Sink	6.4 ppb
Princeton Elementary School	Sink In Grade 6	6 ppb
Princeton Elementary School	Sink In Bathroom (nurses Office)	3.4 ppb
Princeton Elementary School	Sink In Boys Locker Room	5.8 ppb
Princeton Elementary School	Sink In Girls Locker Room	15.1 ppb
Princeton Elementary School	Sink In Grade 1	0 ppb
Princeton Elementary School	Sink In Grade 2	0 ppb
Princeton Elementary School	Sink In Grade 3	4.2 ppb
Princeton Elementary School	Sink In Grade 4	8.5 ppb
Princeton Elementary School	Sink In Grade 7	2.8 ppb
Princeton Elementary School	Sink In Grade 8	3 ppb
Princeton Elementary School	Sink In Kindergarten	1.8 ppb
Princeton Elementary School	Sink In Library Back Room	29.1 ppb
Princeton Elementary School	Sink In Pre K	0 ppb
Princeton Elementary School	Sink In Spec Ed A (richard's Rm)	8.2 ppb
Princeton Elementary School	Sink In Spec Ed B (carle's Rm)	0 ppb
Princeton Elementary School	Sink In Teachers' Room	2 ppb
Princeton Elementary School	Sink In Title I Room 1	7.8 ppb
Princeton Elementary School	Sink In Title I Room 2	13.3 ppb
Princeton Elementary School	Water Fountain In Lobby	0 ppb
Ralph M Atwood Primary School	B. Room -hot Water Tank Top Hose Bib	1.7 ppb
Ralph M Atwood Primary School	B.room -hot Water Tank-bottom Bib	2.3 ppb
Ralph M Atwood Primary School	Boiler Room (At Door) Hose Bib	4.2 ppb
Ralph M Atwood Primary School	Boys Gang Bathroom-sink A	1.8 ppb
Ralph M Atwood Primary School	Boys Gang Bathroom-sink B	5.4 ppb
Ralph M Atwood Primary School	Boys Gang Bathroom-sink C	0 ppb
Ralph M Atwood Primary School	By Gym Bottle Fill Station	0 ppb
Ralph M Atwood Primary School	By Gym Drinking Water Fountain	0 ppb
Ralph M Atwood Primary School	Cafateria - Drinking Water Fountain	0 ppb
Ralph M Atwood Primary School	Cafateria- Bathroom -sink	1.5 ppb
Ralph M Atwood Primary School	Cafateria -bottle Fill Station	0 ppb

School Name	Sample Location	Lead Test Result
Ralph M Atwood Primary School	Front Hallway - Bottle Fill Station	0 ppb
Ralph M Atwood Primary School	Front Hallway - Drinking Water Fountain	0 ppb
Ralph M Atwood Primary School	Girls Gang Bathroom Sink A	1 ppb
Ralph M Atwood Primary School	Girls Gang Bathroom Sink B	1 ppb
Ralph M Atwood Primary School	Girls Gang Bathroom Sink C	2.1 ppb
Ralph M Atwood Primary School	Gym Storage Bathroom Sink	7 ppb
Ralph M Atwood Primary School	Kitchen - 2 Bay Sink	4.3 ppb
Ralph M Atwood Primary School	Kitchen - 3 Bay Sink	8.6 ppb
Ralph M Atwood Primary School	Kitchen - Bathroom - Sink	35.3 ppb
Ralph M Atwood Primary School	Kitchen -handwash Sink	8.5 ppb
Ralph M Atwood Primary School	Nurses Office- Bathroom Sink	1.6 ppb
Ralph M Atwood Primary School	Pre K Water Cooler	0 ppb
Ralph M Atwood Primary School	Pre K Left (a) Bathroom Sink	1.4 ppb
Ralph M Atwood Primary School	Pre K Right (b) Bathroom Sink	4.2 ppb
Ralph M Atwood Primary School	Pre K Right B- Bathroom - Sink B	0 ppb
Ralph M Atwood Primary School	Room 103-sink	3.7 ppb
Ralph M Atwood Primary School	Room 104 -sink	3.6 ppb
Ralph M Atwood Primary School	Room 105-bathroom -sink	5.1 ppb
Ralph M Atwood Primary School	Room 106 Bathroom -sink	1.8 ppb
Ralph M Atwood Primary School	Room 107- Bathroom Sink	5.3 ppb
Ralph M Atwood Primary School	Room 108- Bathroom Sink A	0 ppb
Ralph M Atwood Primary School	Room 108- Bathroom Sink B	0 ppb
Ralph M Atwood Primary School	Room 111 - Bathroom-sink	5.5 ppb
Ralph M Atwood Primary School	Room 112-bathroom-sink	6.5 ppb
Ralph M Atwood Primary School	Room 113 -bathroom -sink	5.8 ppb
Ralph M Atwood Primary School	Room 114-bathroom-sink	2.5 ppb
Ralph M Atwood Primary School	Teachers Lounge -sink	1.1 ppb
Ralph M Atwood Primary School	Teachers Lounge -water Cooler	0 ppb
Rangeley Lakes Regional School	Concession Stand	1.1 ppb
Rangeley Lakes Regional School	Gym Fill Station	0 ppb
Rangeley Lakes Regional School	High School Fill Station	0 ppb
Rangeley Lakes Regional School	K-5 Fill Station	0 ppb
Rangeley Lakes Regional School	Kitchen Sink Front (cafe)	2.1 ppb
Rangeley Lakes Regional School	Kitchen Sink Back	8.6 ppb
Rangeley Lakes Regional School	Upstairs Fill Station	0 ppb
Raymond A. Geiger Elementary School	A108 Sink	0 ppb
Raymond A. Geiger Elementary School	A120 Sink	5 ppb
Raymond A. Geiger Elementary School	A123 Sink	3 ppb
Raymond A. Geiger Elementary School	A130 1st Sink	1.9 ppb
Raymond A. Geiger Elementary School	A130 2nd Sink	1.8 ppb
Raymond A. Geiger Elementary School	B105 Sink	13.7 ppb
Raymond A. Geiger Elementary School	B106 Bubbler	0 ppb
Raymond A. Geiger Elementary School	B106 Sink	2.4 ppb
Raymond A. Geiger Elementary School	B107 Bubbler	0 ppb
Raymond A. Geiger Elementary School	B107 Sink	1.8 ppb
Raymond A. Geiger Elementary School	B108 Sink	2.4 ppb
Raymond A. Geiger Elementary School	B110 Sink	2.3 ppb

School Name	Sample Location	Lead Test Result
Raymond A. Geiger Elementary School	B112 Sbubble	0 ppb
Raymond A. Geiger Elementary School	B112 Sink	6.7 ppb
Raymond A. Geiger Elementary School	B113 Bubbler	2.4 ppb
Raymond A. Geiger Elementary School	B113 Sink	3 ppb
Raymond A. Geiger Elementary School	B116 Bubbler	2.2 ppb
Raymond A. Geiger Elementary School	B116 Sink	4.7 ppb
Raymond A. Geiger Elementary School	B117 Bubbler	0 ppb
Raymond A. Geiger Elementary School	B117 Sink	1.7 ppb
Raymond A. Geiger Elementary School	B119 Bubbler	0 ppb
Raymond A. Geiger Elementary School	B119 Sink	5.7 ppb
Raymond A. Geiger Elementary School	B120 Bubbler	0 ppb
Raymond A. Geiger Elementary School	B120 Sink	2.1 ppb
Raymond A. Geiger Elementary School	B121 Sink	29.6 ppb
Raymond A. Geiger Elementary School	B202 Sink	4.1 ppb
Raymond A. Geiger Elementary School	B203 Sink	5.6 ppb
Raymond A. Geiger Elementary School	B204 Sink	2.7 ppb
Raymond A. Geiger Elementary School	B205 Sink	11.8 ppb
Raymond A. Geiger Elementary School	B207 Sink	5.7 ppb
Raymond A. Geiger Elementary School	B209 Sink	3.1 ppb
Raymond A. Geiger Elementary School	B210 Sink	1.9 ppb
Raymond A. Geiger Elementary School	B213 Sink	2.6 ppb
Raymond A. Geiger Elementary School	B214 Sink	6.7 ppb
Raymond A. Geiger Elementary School	B217 Sink	4.2 ppb
Raymond A. Geiger Elementary School	B218 Sink	2.1 ppb
Raymond A. Geiger Elementary School	B219 Sink	3.7 ppb
Raymond A. Geiger Elementary School	Bottle Filler B Wing	0 ppb
Raymond A. Geiger Elementary School	C103 Sink	1.2 ppb
Raymond A. Geiger Elementary School	C104 Sink	6.7 ppb
Raymond A. Geiger Elementary School	C109 Sink	1.5 ppb
Raymond A. Geiger Elementary School	C111 Bubbler	0 ppb
Raymond A. Geiger Elementary School	C111 Sink	0 ppb
Raymond A. Geiger Elementary School	C112 Bubbler	0 ppb
Raymond A. Geiger Elementary School	C112 Sink	1.6 ppb
Raymond A. Geiger Elementary School	C115 Bubbler	0 ppb
Raymond A. Geiger Elementary School	C115 Sink	3.9 ppb
Raymond A. Geiger Elementary School	C116 Bubbler	0 ppb
Raymond A. Geiger Elementary School	C116 Sink	1.6 ppb
Raymond A. Geiger Elementary School	C117 Bubbler	4.1 ppb
Raymond A. Geiger Elementary School	C117 Sink	8 ppb
Raymond A. Geiger Elementary School	C118 Bubbler	0 ppb
Raymond A. Geiger Elementary School	C118 Sink	3.4 ppb
Raymond A. Geiger Elementary School	C119 Sink	4.4 ppb
Raymond A. Geiger Elementary School	C123 Sink	2.2 ppb
Raymond A. Geiger Elementary School	C203 Sink	5.7 ppb
Raymond A. Geiger Elementary School	C204 Sink	2.8 ppb
Raymond A. Geiger Elementary School	C205 Sink	2.5 ppb
Raymond A. Geiger Elementary School	C206 Sink	5.3 ppb

School Name	Sample Location	Lead Test Result
Raymond A. Geiger Elementary School	C209 Sink	2.5 ppb
Raymond A. Geiger Elementary School	C210 Sink	1.8 ppb
Raymond A. Geiger Elementary School	C213 Sink	9.5 ppb
Raymond A. Geiger Elementary School	C214 Sink	2 ppb
Raymond A. Geiger Elementary School	C215 Sink	8 ppb
Raymond A. Geiger Elementary School	C219 Sink	5.2 ppb
Raymond A. Geiger Elementary School	C220 Sink	2.3 ppb
Raymond A. Geiger Elementary School	C221 Sink	4.6 ppb
Raymond A. Geiger Elementary School	Fountain Left C Wing	0 ppb
Raymond A. Geiger Elementary School	Fountain Rh Bottle Filler C Wing	0 ppb
Raymond A. Geiger Elementary School	Fountain Rh C Wing	0 ppb
Raymond A. Geiger Elementary School	Hallway Water Fountain High	0 ppb
Raymond A. Geiger Elementary School	Hallway Water Fountain Low	0 ppb
Raymond A. Geiger Elementary School	Kitchen 2 Bay Sink	0 ppb
Raymond A. Geiger Elementary School	Kitchen Kettle	2.9 ppb
Raymond A. Geiger Elementary School	Prep Sink	0 ppb
Raymond A. Geiger Elementary School	Water Fountain High Cafeteria	0 ppb
Raymond A. Geiger Elementary School	Water Fountain Lh Bwing	0 ppb
Raymond A. Geiger Elementary School	Water Fountain Low Cafeteria	0 ppb
Raymond A. Geiger Elementary School	Water Fountain Rh Bwing	0 ppb
Raymond Elementary School	Res11-art Rm-f1 Wall By Storage Closest To Door	3 ppb
Raymond Elementary School	Res12-art Rm-f2 Wall By Storage Closest To Kiln	6.4 ppb
Raymond Elementary School	Res14-basement Fountain- Bottle Fill	0 ppb
Raymond Elementary School	Res15-basement Fountain- High Level	0 ppb
Raymond Elementary School	Res16-basement Fountain- Low Level	0 ppb
Raymond Elementary School	Res18-fountain By Gym- Bottle Fill	0 ppb
Raymond Elementary School	Res19-fountain By Gym- High Level	0 ppb
Raymond Elementary School	Res20-fountain By Gym- Low Level	0 ppb
Raymond Elementary School	Res23-b117- Sink	4.4 ppb
Raymond Elementary School	Res26-admin Wing Sink- Kitchenet Sink	3.6 ppb
Raymond Elementary School	Res28-nurse Sick Room- Sick Room Sink	6.6 ppb
Raymond Elementary School	Res29-fountain By Elevator- Bottle Fill	0 ppb
Raymond Elementary School	Res3- Basement Kitchen- Prep Sink	10.2 ppb
Raymond Elementary School	Res30-fountain By Elevator- High Level Fountain	0 ppb
Raymond Elementary School	Res31-fountain By Elevator-low Level Fountain	0 ppb
Raymond Elementary School	Res32-staff Work Rm- Kitchen Sink	4.5 ppb
Raymond Elementary School	Res36-classroomb105- Bubbler	6.3 ppb
Raymond Elementary School	Res38- Classroom B125- Bubbler	7.5 ppb
Raymond Elementary School	Res40- Classroom B104- Bubbler	4.2 ppb
Raymond Elementary School	Res42- Classroom B124- Bubbler	7.7 ppb
Raymond Elementary School	Res44- Classroom B103- Bubbler	6.3 ppb
Raymond Elementary School	Res46- Classroom B123- Bubbler	5.6 ppb
Raymond Elementary School	Res48- Classroom B102- Bubbler	7 ppb

School Name	Sample Location	Lead Test Result
Raymond Elementary School	Res5- Basement Kitchen- Dish Wash Sink-left	6.2 ppb
Raymond Elementary School	Res50- Classroom B122- Bubbler	5 ppb
Raymond Elementary School	Res52- Water Fountain By A109- Bottle Fill	0 ppb
Raymond Elementary School	Res53-water Fountain By A109- High Level	0 ppb
Raymond Elementary School	Res54- Water Fountain By A109- Low Level	0 ppb
Raymond Elementary School	Res56-staff Kitchen By A104- Kitchen Sink	4.1 ppb
Raymond Elementary School	Res58-classroom A104- Bubbler	5.3 ppb
Raymond Elementary School	Res6- Basement Kitchen- Dish Wash Sink-right	4.9 ppb
Raymond Elementary School	Res60-classroom A102- Bubbler	5.5 ppb
Raymond Elementary School	Res62- Classroom A103- Bubbler	5.7 ppb
Raymond Elementary School	Res64- Classroom A101- Bubbler	4.8 ppb
Raymond Elementary School	Res66- Classroom B216- Bubbler	3.6 ppb
Raymond Elementary School	Res68- Classroom B205- Bubbler	7.7 ppb
Raymond Elementary School	Res7- Cafeteria Sink	2.1 ppb
Raymond Elementary School	Res70- Classroom B215- Bubbler	2.3 ppb
Raymond Elementary School	Res72- Classroom B204- Bubbler	1.8 ppb
Raymond Elementary School	Res74- Classroom B214- Bubbler	10.6 ppb
Raymond Elementary School	Res76- Classroom B203- Bubbler	2.7 ppb
Raymond Elementary School	Res78- Classroom B213- Bubbler	4.8 ppb
Raymond Elementary School	Res80- Classroom B202- Bubbler	2.8 ppb
Raymond Elementary School	Res83-water Fountain By B201- Bottle Fill	0 ppb
Raymond Elementary School	Res84-water Fountain By B201- High Level	0 ppb
Raymond Elementary School	Res85-water Fountain By B201- Low Level	0 ppb
Readfield Elementary School	Art Rm Sink #1	3.3 ppb
Readfield Elementary School	Art Rm Sink #2	1.5 ppb
Readfield Elementary School	Bottle Filler By Office	0 ppb
Readfield Elementary School	Covid Rm Fountian	9.9 ppb
Readfield Elementary School	Double Fountian By Office	11.5 ppb
Readfield Elementary School	Kitchen 2 Bay Sink	4.3 ppb
Readfield Elementary School	Kitchen Hand Sink	2.3 ppb
Readfield Elementary School	Kitchen Prep Sink	2.2 ppb
Readfield Elementary School	Kitchen Sprayer Sink	29.8 ppb
Readfield Elementary School	Nurses/ Covid Rm Sink	16.4 ppb
Readfield Elementary School	Rm 10 Sink	4.9 ppb
Readfield Elementary School	Rm 11 Sink	32.8 ppb
Readfield Elementary School	Rm 26 Sink	0 ppb
Readfield Elementary School	Rm 27 Sink	0 ppb
Readfield Elementary School	Rm 31 Sink	2.3 ppb
Readfield Elementary School	Rm 33 Fountain	9.5 ppb
Readfield Elementary School	Rm 33 Sink	3.8 ppb
Readfield Elementary School	Rm 36 Sink	1.5 ppb
Readfield Elementary School	Rm 39 Sink	0 ppb
Readfield Elementary School	Rm 5 Fountian	6.1 ppb
Readfield Elementary School	Rm 5 Sink	4.9 ppb
Readfield Elementary School	Rm 6 Sink	3.8 ppb

School Name	Sample Location	Lead Test Result
Readfield Elementary School	Rm 7 Sink	6 ppb
Readfield Elementary School	Rm 8 Fountian	4.5 ppb
Readfield Elementary School	Rm 8 Sink	7 ppb
Readfield Elementary School	Rm 9 Fountian	9.1 ppb
Readfield Elementary School	Rm 9 Sink	3.7 ppb
Readfield Elementary School	Staff Fountian	6.7 ppb
Readfield Elementary School	Staff Kitchen Sink	2.1 ppb
Readfield Elementary School	Water Fountian North	0 ppb
Reeds Brook Middle School	Cafeteria Drinking Fountain	1 ppb
Reeds Brook Middle School	Classroom 211 Sink	0 ppb
Reeds Brook Middle School	Drinking Fountain - Across From Rm 162	0 ppb
Reeds Brook Middle School	Drinking Fountain - Across From Rm 229	0 ppb
Reeds Brook Middle School	Drinking Fountain Inside The Gymnasium	0 ppb
Reeds Brook Middle School	Drinking Fountain Outside Gymnasium	0 ppb
Reeds Brook Middle School	Kitchen - Single Bay Sink	0 ppb
Reeds Brook Middle School	Staff Lounge Sink - Rm 215	0 ppb
Region 9 Sch of Applied Technology	Adult Ed Bathroom Sink Blue	15 ppb
Region 9 Sch of Applied Technology	Adult Ed Bathroom Sink Pink	0 ppb
Region 9 Sch of Applied Technology	Adult Ed Staff Kitchen Sink	6.2 ppb
Region 9 Sch of Applied Technology	Automotive Shop Sink	4.3 ppb
Region 9 Sch of Applied Technology	Ba Sink On Left By Metal Trades	3.3 ppb
Region 9 Sch of Applied Technology	Br Sink On Left By Truck Driving	0 ppb
Region 9 Sch of Applied Technology	Br Sink On Right By Metal Trades	8.6 ppb
Region 9 Sch of Applied Technology	Br Sink On Right By Truck Driving	0 ppb
Region 9 Sch of Applied Technology	Building Construction Shop Sink	5.9 ppb
Region 9 Sch of Applied Technology	Building Construction Hose Spicket	11.4 ppb
Region 9 Sch of Applied Technology	C N A Bathroom Sink	8.3 ppb
Region 9 Sch of Applied Technology	Culinary 2 Bay Sink	0 ppb
Region 9 Sch of Applied Technology	Culinary Handwash Sink By Fridge	0 ppb
Region 9 Sch of Applied Technology	Culinary Handwash Sink By Ice Machine	1.3 ppb
Region 9 Sch of Applied Technology	Culinary Ice Machine	0 ppb
Region 9 Sch of Applied Technology	Early Childhood Bathroom Sink	0 ppb
Region 9 Sch of Applied Technology	Early Childhood Pre-school Sink	0 ppb
Region 9 Sch of Applied Technology	End Of Hallway Bathroom Sink	1.1 ppb
Region 9 Sch of Applied Technology	End Of Hallway Bottle Filler Station	0 ppb
Region 9 Sch of Applied Technology	Entance Hallway Fountain Bottle Filler	0 ppb
Region 9 Sch of Applied Technology	Exploratory Hose Spicket	4.6 ppb
Region 9 Sch of Applied Technology	Exploratory Shop Sink	1.5 ppb
Region 9 Sch of Applied Technology	Heavy Equip /small Engines Shop Sink	7.3 ppb
Region 9 Sch of Applied Technology	Metal Trades Hose Spicket	0 ppb
Region 9 Sch of Applied Technology	Metal Trades Shop Sink	4.3 ppb
Region 9 Sch of Applied Technology	Outdoor Skills Kitchen Sink	0 ppb
Region 9 Sch of Applied Technology	Outsidespicket A- Custodial Room	0 ppb
Region 9 Sch of Applied Technology	Outsidespicket B- Truck Driving Hallway	1.5 ppb
Region 9 Sch of Applied Technology	Outsidespicket C-culinary/caft Area	0 ppb
Region 9 Sch of Applied Technology	Small Kitchen 3 Bay Sink	5.9 ppb
Region 9 Sch of Applied Technology	Small Kitchen Dishwasher Sink	4.1 ppb

School Name	Sample Location	Lead Test Result
Region 9 Sch of Applied Technology	Small Kitchen Single Sink	4 ppb
Region 9 Sch of Applied Technology	Small Ktchen Hand Wash Sink	1.9 ppb
Region 9 Sch of Applied Technology	Staff Room Kitchen Sink	0 ppb
Region 9 Sch of Applied Technology	Truck Driving Green Bldg Hose Spicket	0 ppb
Region 9 Sch of Applied Technology	Upstairs Shower Room (left) Sink	0 ppb
Region 9 Sch of Applied Technology	Upstairs Shower Room (right) Sink	0 ppb
Region 9 Sch of Applied Technology	Upstairs Water Cooler Bottle Fill Station	0 ppb
Region Two Sch of Applied Tech	Admin	8.4 ppb
Region Two Sch of Applied Tech	Culinary 1	3.4 ppb
Region Two Sch of Applied Tech	Culinary 2	5.9 ppb
Region Two Sch of Applied Tech	Culinary 3	5.1 ppb
Region Two Sch of Applied Tech	Ece Kitch	0 ppb
Region Two Sch of Applied Tech	Forestry 1	2.6 ppb
Region Two Sch of Applied Tech	Health	49.8 ppb
Region Two Sch of Applied Tech	Ice Machine	0 ppb
Region Two Sch of Applied Tech	Law 1	1 ppb
Region Two Sch of Applied Tech	Main Hall	0 ppb
Renaissance School	Boys Room	1.7 ppb
Renaissance School	Db Room	2.4 ppb
Renaissance School	File Room	8.7 ppb
Renaissance School	Girls Room	9.7 ppb
Renaissance School	Intervention Room	6.4 ppb
Renaissance School	Kitchen / Caf Sink	1.2 ppb
Renaissance School	North Side Upstairs Office	79.1 ppb
Renaissance School	Ot Room	49.4 ppb
Renaissance School	Pt Room	4.2 ppb
Renaissance School	School Store	2.4 ppb
Renaissance School	South Side Upstairs Office	31.8 ppb
Renaissance School	Staff Mens Room	20.8 ppb
Renaissance School	Staff Womens Room	140 ppb
Renaissance School	Tc Room	2.6 ppb
Renaissance School	Teachers Room	743 ppb
Renaissance School	Ts Room	2 ppb
Renaissance School	Upstairs Boys Room	13.2 ppb
Renaissance School	Upstairs Conf	153 ppb
Renaissance School	Upstairs Girls Room	15.2 ppb
RETC and SOS	2nd Bathroom Faucet	1.9 ppb
RETC and SOS	3 Bay Sink Faucet Comm Kitchen	5.8 ppb
RETC and SOS	Bathroom By Water Fountain Faucet	2 ppb
RETC and SOS	Boiler Room Faucet	1.3 ppb
RETC and SOS	Bottle Filler 1st Floor	2.6 ppb
RETC and SOS	Boys Room Faucet	3 ppb
RETC and SOS	Bubbler 1st Floor	3.8 ppb
RETC and SOS	Cafeteria Bathroom Faucet	11.5 ppb
RETC and SOS	Cafeteria Bathroom W/shower	2530 ppb
RETC and SOS	Counter Top Sink Faucet Comm Kitchen	2.5 ppb
RETC and SOS	Custodial Closet Faucet	9.4 ppb

School Name	Sample Location	Lead Test Result
RETC and SOS	Girls Room Faucet	3.5 ppb
RETC and SOS	Hand Washing Sink Faucet Comm Kitchen	14.9 ppb
Richmond High and Middle School	Art Room Bathroom Hand Wash Sink 1	8.6 ppb
Richmond High and Middle School	Boys Locker Room Sink A	2.6 ppb
Richmond High and Middle School	Boys Locker Room Sink B	2.9 ppb
Richmond High and Middle School	Boys Locker Room Sink C	7.2 ppb
Richmond High and Middle School	Caf Fountain B	0 ppb
Richmond High and Middle School	Costodial Sink (Off Kitchen)	0 ppb
Richmond High and Middle School	Custodian Middle # 2 Sink	4.2 ppb
Richmond High and Middle School	Custodian Middle #3 Sink	303 ppb
Richmond High and Middle School	Girls Locker Room Sink A	4 ppb
Richmond High and Middle School	Girls Locker Room Sink B	4.6 ppb
Richmond High and Middle School	Girls Locker Room Sink C	6.8 ppb
Richmond High and Middle School	Gym Fountain C	0 ppb
Richmond High and Middle School	Gym Fountain D	0 ppb
Richmond High and Middle School	Highschool Boy Bathroom Handwash Sink A	3.9 ppb
Richmond High and Middle School	Highschool Boy Bathroom Handwash Sink B	2.5 ppb
Richmond High and Middle School	Highschool Boy Bathroom Handwash Sink C	3.4 ppb
Richmond High and Middle School	Highschool Girls Bathroom Handwash Sink D	1.9 ppb
Richmond High and Middle School	Highschool Girls Bathroom Handwash Sink E	1.6 ppb
Richmond High and Middle School	Highschool Girls Bathroom Handwash Sink F	2.3 ppb
Richmond High and Middle School	Highschool Office Bathroom Sink 2	1.2 ppb
Richmond High and Middle School	Kitchen #1 Hand Wash Sink	2.7 ppb
Richmond High and Middle School	Kitchen 1a 2 Bay Wash Sink	1.8 ppb
Richmond High and Middle School	Kitchen 1b Rinse Sink A 3 Bay Wash Sink	3.9 ppb
Richmond High and Middle School	Kitchen Bathroom # 2	10.3 ppb
Richmond High and Middle School	Library Hall Fountain E	0 ppb
Richmond High and Middle School	Library Media Room Sink	24.5 ppb
Richmond High and Middle School	Middle School Bathroom Hand Wash Sink- A	1.1 ppb
Richmond High and Middle School	Middle School Bathroom Hand Wash Sink- B	0 ppb
Richmond High and Middle School	Middle School Fountain F	0 ppb
Richmond High and Middle School	Middle School Science Sink A	25.8 ppb
Richmond High and Middle School	Nurses Office Kitchen Sink 3	2.9 ppb
Richmond High and Middle School	Nurses Rm Bathroom Sink 1	3 ppb
Richmond High and Middle School	Outside Water Spigot(by Highschool Garden) E	17.1 ppb
Richmond High and Middle School	Rhs Office Fountain A	0 ppb
Richmond High and Middle School	Room 115 Bathroom Sink	1.8 ppb
Richmond High and Middle School	Room 115 Sink A	4.4 ppb

School Name	Sample Location	Lead Test Result
Richmond High and Middle School	Room 115 Sink B	6.6 ppb
Richmond High and Middle School	Room 118 # C	1830 ppb
Richmond High and Middle School	Room 118 # D	73 ppb
Richmond High and Middle School	Room 118 Sink A	46 ppb
Richmond High and Middle School	Room 118 Sink B	41.5 ppb
Richmond High and Middle School	Room 121 Music Room Dwf	5.3 ppb
Richmond High and Middle School	Room 130 Sink A	1.5 ppb
Richmond High and Middle School	Room 130 Sink B	0 ppb
Richmond High and Middle School	Science Lab Rm 112 B	3.7 ppb
Richmond High and Middle School	Science Lab Rm 112 C	5 ppb
Richmond High and Middle School	Science Lab Rm 112 E	6.9 ppb
Richmond High and Middle School	Science Lab Rm 112 F	10.5 ppb
Richmond High and Middle School	Science Lab Rm 112 G	24.1 ppb
Richmond High and Middle School	Science Lab Rm 116 C	114 ppb
Richmond High and Middle School	Science Lab Rm 116 D	887 ppb
Richmond High and Middle School	Science Lab Rm 116 E	3480 ppb
Richmond High and Middle School	Science Lab Rm 116 F	262 ppb
Richmond High and Middle School	Science Lab Rm 116 G	51.9 ppb
Richmond High and Middle School	Science Lab Rm 116 O	535 ppb
Richmond High and Middle School	Science Lab Rm 116 P	727 ppb
Richmond High and Middle School	Science Lab Rm 116 Q	237 ppb
Richmond High and Middle School	Science Storage Kitchen Faucet A	126 ppb
Richmond High and Middle School	Soccer Field Outside Drink Source 1	4.8 ppb
Richmond High and Middle School	Teachers Lounge Bathroom Sink B	1.3 ppb
Richmond High and Middle School	Teachers Lounge Ladies Restroom Sink	1.5 ppb
Richmond High and Middle School	Teachers Lounge Sink 1	1.8 ppb
Ridge View Community School	1-2 Wing Fountain	0 ppb
Ridge View Community School	1-2 Wing Sp Ed Kitchen Sink	1.8 ppb
Ridge View Community School	3-5 Wing Fountain	0 ppb
Ridge View Community School	6-8 Wing Fountain	0 ppb
Ridge View Community School	6-8 Wing Jmg Sink	0 ppb
Ridge View Community School	6-8 Wing Sp Ed Kitchen	0 ppb
Ridge View Community School	Art Room Sink	1.3 ppb
Ridge View Community School	Boys Gang Bathroom	0 ppb
Ridge View Community School	Boys Locker Room	7.1 ppb
Ridge View Community School	Girls Gang Bathroom	0 ppb
Ridge View Community School	Girls Locker Room	1.7 ppb
Ridge View Community School	Gym Wing Fountain	0 ppb
Ridge View Community School	K Wing Fountain	0 ppb
Ridge View Community School	K Wing Teachers Room Sink	0 ppb
Ridge View Community School	Kitchen 3 Bay Sink	1.6 ppb
Ridge View Community School	Kitchen Prep Sink	2.7 ppb
Ridge View Community School	Main Office Sink	0 ppb
Riley School Inc	Library Bathroom	0 ppb
Riley School Inc	Main Building Art Room Bathroom	0 ppb
Riley School Inc	Main Building Art Room Sink	0 ppb
Riley School Inc	Main Building Bathroom	0 ppb

School Name	Sample Location	Lead Test Result
Riley School Inc	Main Building Kitchen	0 ppb
Riley School Inc	Theatre Building Bathroom	0 ppb
Riley School Inc	Theatre Building Kitchen	0 ppb
Riley School Inc	Theatre Building Math Bathroom	0 ppb
Riley School Inc	Wade Acres Juniper Bathroom	0 ppb
Riley School Inc	Wade Acres Juniper Kitchen	2.6 ppb
Riley School Inc	Wade Acres Magnolia Bathroom	5.6 ppb
Riley School Inc	Wade Acres Magnolia Kitchen	3.9 ppb
River View Community School	Bottle Fill 1st Floor	0 ppb
River View Community School	Bottle Fill 2nd Floor	0 ppb
River View Community School	Cafeteria Sink	3.7 ppb
River View Community School	Kitchen Prep Sink	1.7 ppb
River View Community School	Kitchen Prep Sink #2	0 ppb
River View Community School	Nurse Sink	0 ppb
River View Community School	Stars Room Sink	0 ppb
River View Community School	Teacher's Room Sink	1.3 ppb
Riverview Memorial School	Kitchen Fixture	2 ppb
Riverview Memorial School	Outside Fixture	3.2 ppb
Riverview Memorial School	Water Fountain	0 ppb
Robert V. Connors Elementary School	A103 Sink	0 ppb
Robert V. Connors Elementary School	A111 Rh Sink	0 ppb
Robert V. Connors Elementary School	A118 Bubbler	0 ppb
Robert V. Connors Elementary School	A118 Sink	0 ppb
Robert V. Connors Elementary School	A122 Bubbler	2.3 ppb
Robert V. Connors Elementary School	A122 Sink	4 ppb
Robert V. Connors Elementary School	B101 Bubbler	0 ppb
Robert V. Connors Elementary School	B101 Sink	0 ppb
Robert V. Connors Elementary School	B102 Bubbler	0 ppb
Robert V. Connors Elementary School	B102 Sink	0 ppb
Robert V. Connors Elementary School	B103 Bubbler	0 ppb
Robert V. Connors Elementary School	B103 Sink	0 ppb
Robert V. Connors Elementary School	B104 Bubbler	0 ppb
Robert V. Connors Elementary School	B104 Sink	0 ppb
Robert V. Connors Elementary School	B105 Bubbler	0 ppb
Robert V. Connors Elementary School	B105 Sink	0 ppb
Robert V. Connors Elementary School	B106 Bubbler	0 ppb
Robert V. Connors Elementary School	B106 Sink	0 ppb
Robert V. Connors Elementary School	B107 1st Sink	0 ppb
Robert V. Connors Elementary School	B107 2nd Sink	0 ppb
Robert V. Connors Elementary School	B116 Bubbler	0 ppb
Robert V. Connors Elementary School	B116 Sink	0 ppb
Robert V. Connors Elementary School	B117 Bubbler	0 ppb
Robert V. Connors Elementary School	B117 Sink	0 ppb
Robert V. Connors Elementary School	B118 Bubbler	0 ppb
Robert V. Connors Elementary School	B118 Sink	0 ppb
Robert V. Connors Elementary School	B119 Bubbler	0 ppb
Robert V. Connors Elementary School	B119 Sink	0 ppb

School Name	Sample Location	Lead Test Result
Robert V. Connors Elementary School	B120 Bubbler	0 ppb
Robert V. Connors Elementary School	B120 Sink	0 ppb
Robert V. Connors Elementary School	B121 Bubbler	0 ppb
Robert V. Connors Elementary School	B121 Sink	0 ppb
Robert V. Connors Elementary School	B201 Bubbler	0 ppb
Robert V. Connors Elementary School	B201 Sink	0 ppb
Robert V. Connors Elementary School	B202 Bubbler	0 ppb
Robert V. Connors Elementary School	B202 Sink	0 ppb
Robert V. Connors Elementary School	B203 Bubbler	0 ppb
Robert V. Connors Elementary School	B203 Sink	0 ppb
Robert V. Connors Elementary School	B204 Bubbler	0 ppb
Robert V. Connors Elementary School	B204 Sink	0 ppb
Robert V. Connors Elementary School	B205 Bubbler	0 ppb
Robert V. Connors Elementary School	B205 Sink	0 ppb
Robert V. Connors Elementary School	B206 Bubbler	0 ppb
Robert V. Connors Elementary School	B206 Sink	0 ppb
Robert V. Connors Elementary School	B214 Bubbler	0 ppb
Robert V. Connors Elementary School	B216 Bubbler	0 ppb
Robert V. Connors Elementary School	B216 Sink	0 ppb
Robert V. Connors Elementary School	B217 Bubbler	0 ppb
Robert V. Connors Elementary School	B217 Sink	0 ppb
Robert V. Connors Elementary School	B218 Bubbler	0 ppb
Robert V. Connors Elementary School	B218 Sink	0 ppb
Robert V. Connors Elementary School	B219 Bubbler	0 ppb
Robert V. Connors Elementary School	B219 Sink	0 ppb
Robert V. Connors Elementary School	B221 Bubbler	0 ppb
Robert V. Connors Elementary School	B221 Sink	0 ppb
Robert V. Connors Elementary School	C102 Sink	0 ppb
Robert V. Connors Elementary School	C108 Sink	0 ppb
Robert V. Connors Elementary School	C110 Sink	0 ppb
Robert V. Connors Elementary School	C118 Sink	0 ppb
Robert V. Connors Elementary School	C202 Sink	0 ppb
Robert V. Connors Elementary School	C208 Sink	0 ppb
Robert V. Connors Elementary School	C210 Sink	0 ppb
Robert V. Connors Elementary School	C212 Sink Lh	1.3 ppb
Robert V. Connors Elementary School	C212 Sink Rh	0 ppb
Robert V. Connors Elementary School	C218 Sink	0 ppb
Robert V. Connors Elementary School	Cafe Bottle Filler	0 ppb
Robert V. Connors Elementary School	Cafe Lh Water Fountain	0 ppb
Robert V. Connors Elementary School	Cafe Rh Water Fountain	0 ppb
Robert V. Connors Elementary School	D101 Bubbler	0 ppb
Robert V. Connors Elementary School	D101 Sink	0 ppb
Robert V. Connors Elementary School	D102 Bubbler	0 ppb
Robert V. Connors Elementary School	D102 Sink	0 ppb
Robert V. Connors Elementary School	D103 Bubbler	0 ppb
Robert V. Connors Elementary School	D103 Sink	0 ppb
Robert V. Connors Elementary School	D104 Bubbler	0 ppb

School Name	Sample Location	Lead Test Result
Robert V. Connors Elementary School	D104 Sink	0 ppb
Robert V. Connors Elementary School	D105 Bubbler	0 ppb
Robert V. Connors Elementary School	D106 Bubbler	0 ppb
Robert V. Connors Elementary School	D106 Sink	0 ppb
Robert V. Connors Elementary School	D112 Bubbler	0 ppb
Robert V. Connors Elementary School	D112 Sink	0 ppb
Robert V. Connors Elementary School	D114 Bubbler	0 ppb
Robert V. Connors Elementary School	D114 Sink	0 ppb
Robert V. Connors Elementary School	D115 Bubbler	0 ppb
Robert V. Connors Elementary School	D115 Sink	0 ppb
Robert V. Connors Elementary School	D116 Bubbler	0 ppb
Robert V. Connors Elementary School	D116 Sink	0 ppb
Robert V. Connors Elementary School	D117 Bubbler	0 ppb
Robert V. Connors Elementary School	D117 Sink	0 ppb
Robert V. Connors Elementary School	D118 Bubbler	1.3 ppb
Robert V. Connors Elementary School	D118 Sink	0 ppb
Robert V. Connors Elementary School	D121 Bubbler	0 ppb
Robert V. Connors Elementary School	D121 Sink	0 ppb
Robert V. Connors Elementary School	D201 Bubbler	0 ppb
Robert V. Connors Elementary School	D201 Sink	0 ppb
Robert V. Connors Elementary School	D202 Bubbler	0 ppb
Robert V. Connors Elementary School	D202 Sink	0 ppb
Robert V. Connors Elementary School	D203 Bubbler	0 ppb
Robert V. Connors Elementary School	D203 Sink	0 ppb
Robert V. Connors Elementary School	D204 Bubbler	0 ppb
Robert V. Connors Elementary School	D204 Sink	0 ppb
Robert V. Connors Elementary School	D205 Bubbler	0 ppb
Robert V. Connors Elementary School	D205 Sink	0 ppb
Robert V. Connors Elementary School	D206 Bubbler	0 ppb
Robert V. Connors Elementary School	D206 Sink	0 ppb
Robert V. Connors Elementary School	D207 Sink	0 ppb
Robert V. Connors Elementary School	D207 Sink Center	0 ppb
Robert V. Connors Elementary School	D212 Bubbler	0 ppb
Robert V. Connors Elementary School	D212 Sink	0 ppb
Robert V. Connors Elementary School	D213 Bubbler	0 ppb
Robert V. Connors Elementary School	D213 Sink	0 ppb
Robert V. Connors Elementary School	D214 Bubbler	0 ppb
Robert V. Connors Elementary School	D214 Sink	0 ppb
Robert V. Connors Elementary School	D215 Bubbler	0 ppb
Robert V. Connors Elementary School	D215 Sink	0 ppb
Robert V. Connors Elementary School	D216 Bubbler	0 ppb
Robert V. Connors Elementary School	D216 Sink	0 ppb
Robert V. Connors Elementary School	D218 Bubbler	0 ppb
Robert V. Connors Elementary School	D218 Sink	0 ppb
Robert V. Connors Elementary School	D219 Bubbler	0 ppb
Robert V. Connors Elementary School	D219 Sink	0 ppb
Robert V. Connors Elementary School	Gym Lh Water Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Robert V. Connors Elementary School	Gym Rh Bottle Filler	0 ppb
Robert V. Connors Elementary School	Gym Rh Water Fountain	0 ppb
Robert V. Connors Elementary School	Kitchen 1st Prep Sink	0 ppb
Robert V. Connors Elementary School	Kitchen 2nd Prep Sink	0 ppb
Robert V. Connors Elementary School	Kitchen 3b In Lh Side	1.3 ppb
Robert V. Connors Elementary School	Kitchen Soup Kettle	6.5 ppb
Robert V. Connors Elementary School	Kitchen Steamer Table	63.9 ppb
Robert V. Connors Elementary School	Main Gang Bath Bottle Filler	0 ppb
Robert V. Connors Elementary School	Main Gang Bath Lh Water Fountain	0 ppb
Robert V. Connors Elementary School	Main Gang Bath Rh Water Fountain	0 ppb
Robert W Traip Academy	Atrium Fountain	0 ppb
Robert W Traip Academy	Boys Locker Room	1.8 ppb
Robert W Traip Academy	Classroom C9	11.4 ppb
Robert W Traip Academy	Girls Locker Room	2.3 ppb
Robert W Traip Academy	Kitchen	0 ppb
Robert W Traip Academy	Lower Cook Fountain	0 ppb
Robert W Traip Academy	Lower Hall Fountain	0 ppb
Robert W Traip Academy	Office Faucet	14.2 ppb
Robert W Traip Academy	Science Lab M5	21.4 ppb
Robert W Traip Academy	Science Lab M6	2.5 ppb
Robert W Traip Academy	Science Lab M7	8.4 ppb
Robert W Traip Academy	Science Lab M8	6.8 ppb
Robert W Traip Academy	Science Lab M9	8.5 ppb
Robert W Traip Academy	Success Center	4 ppb
Robert W Traip Academy	Upper Cook Fountain	0 ppb
Robert W Traip Academy	Wildes Fountain	0 ppb
Rose M Gaffney School	2nd Floor Drinking Fountain	0 ppb
Rose M Gaffney School	2nd Kitchen Sink	1 ppb
Rose M Gaffney School	5/6 Drinking Water Fountain	0 ppb
Rose M Gaffney School	Gym Drinking Fountain	0 ppb
Rose M Gaffney School	Kindergarten Room	0 ppb
Rose M Gaffney School	Kitchen 3 Bay Sink	1 ppb
Rose M Gaffney School	Pre K Sink 1	0 ppb
Rose M Gaffney School	Pre K Sink 2	0 ppb
Rumford Elementary	1st Floor Boys Bathroom- Left 1b-a	9.3 ppb
Rumford Elementary	1st Floor Boys Bathroom- Middle 1b-b	6.9 ppb
Rumford Elementary	1st Floor Boys Bathroom- Right 1b-c	8.5 ppb
Rumford Elementary	1st Floor Girls Bathroom- 1g-a	8.1 ppb
Rumford Elementary	1st Floor Girls Bathroom- 1g-b	5.2 ppb
Rumford Elementary	1st Floor Girls Bathroom- 1g-c	17.3 ppb
Rumford Elementary	Art Room 113	4.2 ppb
Rumford Elementary	Bathroom In Room 117	11.8 ppb
Rumford Elementary	Boys Bathroom 203- Left Bb203-a	28.1 ppb
Rumford Elementary	Boys Bathroom 203- Middle Bb203-b	6.7 ppb
Rumford Elementary	Boys Bathroom 203- Right Bb203-c	4 ppb
Rumford Elementary	Boys Bathroom 2nd Floor- Left 2bb-a	14.8 ppb
Rumford Elementary	Boys Bathroom 2nd Floor- Middle 2bb-b	10 ppb

School Name	Sample Location	Lead Test Result
Rumford Elementary	Boys Bathroom 2nd Floor- Right 2bb-c	44 ppb
Rumford Elementary	Drinking Water Fountain By 101	0 ppb
Rumford Elementary	Drinking Water Fountain By 202	0 ppb
Rumford Elementary	Drinking Water Fountain By 224	0 ppb
Rumford Elementary	Girls Bathroom 201- Left Gb201-a	19.9 ppb
Rumford Elementary	Girls Bathroom 201- Right Gb201-c	17 ppb
Rumford Elementary	Girls Bathroom 2nd Floor- Left 2gb-a	13.3 ppb
Rumford Elementary	Girls Bathroom 2nd Floor- Middle 2gb-b	8.9 ppb
Rumford Elementary	Girls Bathroom 2nd Floor- Right 2gb-c	6.2 ppb
Rumford Elementary	Kitchen Faucet- Main Sink K-4	17.6 ppb
Rumford Elementary	Kitchen Faucet- Post Dish Wash 1 K-5	11.5 ppb
Rumford Elementary	Kitchen Faucet- Post Dish Wash 2 K-6	7.8 ppb
Rumford Elementary	Kitchen Faucet- Side Sink K-3	39 ppb
Rumford Elementary	Kitchen Faucet- Sink K-2	8.5 ppb
Rumford Elementary	Kitchen Faucet- White Sink K-1	6.5 ppb
Rumford Elementary	Nurse Office 215	11.5 ppb
Rumford Elementary	Room 101	7.6 ppb
Rumford Elementary	Room 102	2.6 ppb
Rumford Elementary	Room 105	32.9 ppb
Rumford Elementary	Room 109	9.2 ppb
Rumford Elementary	Room 205	3 ppb
Rumford Elementary	Room 224- Sarah Marshalls	38.4 ppb
Rumford Elementary	Room 225	2.3 ppb
Rumford Elementary	Room 231	6.4 ppb
Rumford Elementary	Staff Bathroom 216- Females 216-b	6.7 ppb
Rumford Elementary	Staff Bathroom 216- Mens 216-a	9 ppb
Rumford Elementary	Staff Bathroom 216-c	5.3 ppb
Russell School	Art Room Sink Rm #65	4.9 ppb
Russell School	Gym Water Bottle Filler Rm #28	2.4 ppb
Russell School	Kitchen 3 Bay Rm # 30	16.7 ppb
Russell School	Kitchen Food Prep Sink Rm # 30	10.6 ppb
Russell School	Library Sink Rm #19	11 ppb
Russell School	Sink / Bubblers Rm #21	33.1 ppb
Russell School	Sink / Bubblers Rm #22	13.1 ppb
Russell School	Sink / Bubblers Rm #23	3.9 ppb
Russell School	Sink / Bubblers Rm #24	20.6 ppb
Russell School	Sink / Bubblers Rm #25	12.3 ppb
Russell School	Sink / Bubblers Rm #26	4.1 ppb
Russell School	Sink Rm # 13	9.8 ppb
Russell School	Sink Rm# 60	9.8 ppb
Russell School	Sink Rm# 67	2.6 ppb
Russell School	Sink/bubbler Rm # 10	3.5 ppb
Russell School	Sink/bubbler Rm # 11	11.4 ppb
Russell School	Sink/bubbler Rm # 6	16.8 ppb
Russell School	Sink/bubbler Rm # 7	4.6 ppb
Russell School	Sink/bubbler Rm # 8	8.2 ppb
Russell School	Sink/bubbler Rm # 9	3.5 ppb

School Name	Sample Location	Lead Test Result
Russell School	Sink/bubbler Rm #20	13.2 ppb
Russell School	Teacher Lounge Sink Rm #27	3.3 ppb
Russell School	Water Bottle Bubble #2	3.1 ppb
Russell School	Water Bottle Bubbler	1.1 ppb
Sabattus Primary School	Back Lobby Bathroom	5.4 ppb
Sabattus Primary School	Custodian Office	2.9 ppb
Sabattus Primary School	Dishroom- Kitchen	135 ppb
Sabattus Primary School	Guidance- Office Area	3.1 ppb
Sabattus Primary School	Gym Boys Bathroom	4.2 ppb
Sabattus Primary School	Gym Girls Bathroom	3.7 ppb
Sabattus Primary School	Kitchen Bathroom	22.9 ppb
Sabattus Primary School	Kitchen Sink A	28.6 ppb
Sabattus Primary School	Kitchen Sink B	3.9 ppb
Sabattus Primary School	Kitchen Sink C	3.9 ppb
Sabattus Primary School	Kitchen Sink D	6.7 ppb
Sabattus Primary School	Nurses Station	2.2 ppb
Sabattus Primary School	Room 123	5.9 ppb
Sabattus Primary School	Room 124	3.7 ppb
Sabattus Primary School	Room 125	4.3 ppb
Sabattus Primary School	Room 127	3.3 ppb
Sabattus Primary School	Room 204	4.3 ppb
Sabattus Primary School	Room 205	5 ppb
Sabattus Primary School	Room 206	2.6 ppb
Sabattus Primary School	Room 207	3.8 ppb
Sabattus Primary School	Room 208	4.4 ppb
Sabattus Primary School	Room 209	3.3 ppb
Sabattus Primary School	Room 210	5.2 ppb
Sabattus Primary School	Room 211	4.1 ppb
Sabattus Primary School	Staff Bathroom- Office Area	5.4 ppb
Sabattus Primary School	Staff Room Sink- Office Area	4.9 ppb
Sabattus Primary School	Water Fountain- Back Lobby	2 ppb
Saccarappa School	10	5.7 ppb
Saccarappa School	11	0 ppb
Saccarappa School	13	0 ppb
Saccarappa School	15	0 ppb
Saccarappa School	16	0 ppb
Saccarappa School	17	0 ppb
Saccarappa School	18	0 ppb
Saccarappa School	19	0 ppb
Saccarappa School	1a	0 ppb
Saccarappa School	1j	0 ppb
Saccarappa School	2	1.1 ppb
Saccarappa School	24	0 ppb
Saccarappa School	25	2.2 ppb
Saccarappa School	26	1.6 ppb
Saccarappa School	27	0 ppb
Saccarappa School	28	1.8 ppb

School Name	Sample Location	Lead Test Result
Saccarappa School	29	0 ppb
Saccarappa School	30	0 ppb
Saccarappa School	37	0 ppb
Saccarappa School	38	0 ppb
Saccarappa School	41	0 ppb
Saccarappa School	42	1.7 ppb
Saccarappa School	43	6.2 ppb
Saccarappa School	44	0 ppb
Saccarappa School	45	0 ppb
Saccarappa School	46	0 ppb
Saccarappa School	47	0 ppb
Saccarappa School	48	1.2 ppb
Saccarappa School	49	1.2 ppb
Saccarappa School	54	1.1 ppb
Saccarappa School	56	1.4 ppb
Saccarappa School	57	1.3 ppb
Saccarappa School	6	0 ppb
Saccarappa School	7	1 ppb
Saccarappa School	8	0 ppb
Saccarappa School	9	0 ppb
Saccarappa School	Cafe Fountain	0 ppb
Saccarappa School	Hall Fountain Sprinkler	1.2 ppb
Saccarappa School	Kitch Prep 1	1.6 ppb
Saccarappa School	Kitch Prep 2	0 ppb
Saco Learning Center	Drinking Water Fountain Front Door	2.3 ppb
Saco Learning Center	Snk Kitchen	19.2 ppb
Saco Middle School	Cooler Fac Rm	0 ppb
Saco Middle School	Drinking Water Fountain Bubbler Outside Caf. A	6 ppb
Saco Middle School	Drinking Water Fountain Bubbler Winga A	0 ppb
Saco Middle School	Drinking Water Fountain Bubbler Wingb A	0 ppb
Saco Middle School	Drinking Water Fountain Bubbler Wingc A	0 ppb
Saco Middle School	Drinking Water Fountain Bubbler Wingd A	0 ppb
Saco Middle School	Drinking Water Fountain Outside Caf. B	0 ppb
Saco Middle School	Drinking Water Fountain Winga B	3 ppb
Saco Middle School	Drinking Water Fountain Wingb B	0 ppb
Saco Middle School	Drinking Water Fountain Wingc B	18.2 ppb
Saco Middle School	Drinking Water Fountain Wingd B	1.3 ppb
Saco Middle School	Dwf Ocaf A	1.7 ppb
Saco Middle School	Dwf Winga A	40.5 ppb
Saco Middle School	Dwf Wingb A	4.9 ppb
Saco Middle School	Dwf Wingc A	47.1 ppb
Saco Middle School	Dwf Wingd A	2.1 ppb
Saco Middle School	Fridge Rm F2	0 ppb
Saco Middle School	Sink Room F7	0 ppb
Saco Middle School	Snk Fac Rm	0 ppb
Saco Middle School	Snk Kitchen A	4 ppb

School Name	Sample Location	Lead Test Result
Saco Middle School	Snk Kitchen B	113 ppb
Saco Middle School	Snk Kitchen C	51.9 ppb
Saco Middle School	Snk Kitchen D	53.1 ppb
Saco Middle School	Snk Kitchen E	37.8 ppb
Saco Middle School	Snk Nurse Rm	2 ppb
Saco Middle School	Snk Rm F2 A	86.2 ppb
Saco Middle School	Snk Rm F2 B	143 ppb
Saco Middle School	Snk Rm F2 C	157 ppb
Saco Middle School	Snk Rm F2 D	210 ppb
Saco Middle School	Snk Rm F2 E	143 ppb
Saco Middle School	Snk Rm F2 F	85.9 ppb
Saco Pre-K	Snk Fac Rm	0 ppb
Saco Pre-K	Snk Nurse Rm	0 ppb
Saco Pre-K	Snk Rm1	0 ppb
Saco Pre-K	Snk Rm2	2.9 ppb
Saco Pre-K	Snk Rm3 A	1.5 ppb
Saco Pre-K	Snk Rm3 B	0 ppb
Saco Pre-K	Snk Rm4 A	0 ppb
Saco Pre-K	Snk Rm4 B	0 ppb
Saco Pre-K	Snk Rm5 A	1.4 ppb
Saco Pre-K	Snk Rm5 B	0 ppb
Saco Pre-K	Snk Rm6 A	0 ppb
Saco Pre-K	Snk Rm6 B	1.2 ppb
Saco Pre-K	Snk Rm7	0 ppb
Saco Pre-K	Snk Rm8 A	1.6 ppb
Saco Pre-K	Snk Rm8 B	0 ppb
Sacopee Valley Elementary School	First Floor Fountain/ Fill Station	0 ppb
Sacopee Valley Elementary School	First Floor Teachers Rm. Double Sink	0 ppb
Sacopee Valley Elementary School	Gym Drinking Fountain/ Fill Sation	43.2 ppb
Sacopee Valley Elementary School	Kitchen Three Basin Sink	2.1 ppb
Sacopee Valley Elementary School	Second Floor #1 Fountain/fill Station	0 ppb
Sacopee Valley Elementary School	Second Floor #2 Fountain/fill Station	0 ppb
Sacopee Valley High Sch	2nd Floor #1 Drinking Fountain	0 ppb
Sacopee Valley High Sch	2nd Floor #2 Drinking Fountain	0 ppb
Sacopee Valley High Sch	2nd Floor #3 Drinking Fountain/f.s.	0 ppb
Sacopee Valley High Sch	2nd Floor #4 Drinking Fountain/f.s.	0 ppb
Sacopee Valley High Sch	2nd Floor #5 Drinking Fountain/ F.s.	0 ppb
Sacopee Valley High Sch	3rd Floor Drinking Water Fountain F.s.	0 ppb
Sacopee Valley High Sch	Cafe Fountain/ Bottle Fill Sation	0 ppb
Sacopee Valley High Sch	First Floor Fountain/ Fill Station#3	0 ppb
Sacopee Valley High Sch	First Floor Fountain/fill Station#1	0 ppb
Sacopee Valley High Sch	First Floor Fountain/fill Station#2	0 ppb
Sacopee Valley High Sch	Kitchen Double Basin Sink	0 ppb
Sacopee Valley High Sch	Kitchen Kettle	2 ppb
Sacopee Valley Middle School	1st Floor 5th Gd.fountain/ B.f.	0 ppb
Sacopee Valley Middle School	1st Floor 6th Gd. Fountain/ B.f.	0 ppb
Sacopee Valley Middle School	2nd Floor 7th Gd. Fountain/b.f.	0 ppb

School Name	Sample Location	Lead Test Result
Sacopec Valley Middle School	2nd Floor 8th Gd. Fountain/b.f.	0 ppb
Sacopec Valley Middle School	Administration Kitchen Sink	0 ppb
Sacopec Valley Middle School	Gym Drinking Fountain/bottle Filler	0 ppb
Sacopec Valley Middle School	Kitchen Kettel	0 ppb
Sacopec Valley Middle School	Kitchen Triple Basin Sink	1.2 ppb
Sacopec Valley Middle School	Middle School Field Fountain	0 ppb
Sacopec Valley Middle School	Principal Kitchen Sink	0 ppb
Sacopec Valley Middle School	Teachers Room Lounge Sink 2nd Floor	0 ppb
Samuel L Wagner Middle School	Kitchen - Double Sink Faucet	1.3 ppb
Samuel L Wagner Middle School	Kitchen Single Sink Faucet	0 ppb
Samuel L Wagner Middle School	Life Skills Classroom Sink (n)	0 ppb
Samuel L Wagner Middle School	Life Skills Classroom Sink (s)	2.2 ppb
Samuel L Wagner Middle School	Teachers Lounge Room 115	0 ppb
Samuel L Wagner Middle School	Water Fountain @ Nurse's Office	0 ppb
Samuel L Wagner Middle School	Water Fountain Between Gym Locker Rms	0 ppb
Samuel L Wagner Middle School	Water Fountain In Classroom Wing	0 ppb
Sanford High School	A106 Sink	2.2 ppb
Sanford High School	A133 Sink	1.2 ppb
Sanford High School	A178 Concession Std	7 ppb
Sanford High School	A201 Sink	0 ppb
Sanford High School	B142 Wtr Fountain	0 ppb
Sanford High School	B142 Wtr Fountain W/bf	0 ppb
Sanford High School	B210 Sink	3.5 ppb
Sanford High School	C100a 2 Bay Sink By Freezer	1.4 ppb
Sanford High School	C100a Left 2 Bay Sink Under Clock	2.9 ppb
Sanford High School	C100a Left Kettle	12.9 ppb
Sanford High School	C100a Right Kettle	4.1 ppb
Sanford High School	C100a Single Island Sink	3 ppb
Sanford High School	D112 Kitchen 1	0 ppb
Sanford High School	D112 Kitchen 2	0 ppb
Sanford High School	D112 Kitchen 3	0 ppb
Sanford High School	D112 Kitchen 4	0 ppb
Sanford High School	D112 Kitchen 5	0 ppb
Sanford High School	D112 Teaching Island	1.1 ppb
Sanford High School	F127 Ice Machine	0 ppb
Sanford High School	F127 Sink	4.5 ppb
Sanford High School	Kitchen Sink Inside E150	1.5 ppb
Sanford High School	Kitchen Sink Inside E250	1.4 ppb
Sanford High School	Wtr Fountain Across A160	0 ppb
Sanford High School	Wtr Fountain Across A240	0 ppb
Sanford High School	Wtr Fountain Across B222	0 ppb
Sanford High School	Wtr Fountain Across D105	0 ppb
Sanford High School	Wtr Fountain Across E128	0 ppb
Sanford High School	Wtr Fountain Inside A237	0 ppb
Sanford High School	Wtr Fountain Inside D105	0 ppb
Sanford High School	Wtr Fountain Inside E150	0 ppb
Sanford High School	Wtr Fountain Inside E250	0 ppb

School Name	Sample Location	Lead Test Result
Sanford High School	Wtr Fountain Outside A191	0 ppb
Sanford High School	Wtr Fountain Outside C134	0 ppb
Sanford High School	Wtr Fountain Outside D225	0 ppb
Sanford High School	Wtr Fountain Outside E242	0 ppb
Sanford High School	Wtr Fountain Outside F116	0 ppb
Sanford High School	Wtr Fountain Outside F126	0 ppb
Sanford High School	Wtr Fountain W/ Bf Across A160	0 ppb
Sanford High School	Wtr Fountain W/ Bf Outside F126	0 ppb
Sanford High School	Wtr Fountain W/bf Across A240	0 ppb
Sanford High School	Wtr Fountain W/bf Across B222	0 ppb
Sanford High School	Wtr Fountain W/bf Across C214	0 ppb
Sanford High School	Wtr Fountain W/bf Across D105	0 ppb
Sanford High School	Wtr Fountain W/bf Across E128	0 ppb
Sanford High School	Wtr Fountain W/bf Inside A237	0 ppb
Sanford High School	Wtr Fountain W/bf Inside D105	0 ppb
Sanford High School	Wtr Fountain W/bf Inside E150	0 ppb
Sanford High School	Wtr Fountain W/bf Inside E250	0 ppb
Sanford High School	Wtr Fountain W/bf Outside A191	0 ppb
Sanford High School	Wtr Fountain W/bf Outside C134	0 ppb
Sanford High School	Wtr Fountain W/bf Outside D225	0 ppb
Sanford High School	Wtr Fountain W/bf Outside E242	0 ppb
Sanford High School	Wtr Fountain W/bf Outside F116	0 ppb
Sanford Middle School	7th Grd Hallway By Cust Closet (1)	0 ppb
Sanford Middle School	7th Grd Hallway By Cust Closet (2)	0 ppb
Sanford Middle School	By Rm 1218 Hallway (1)	0 ppb
Sanford Middle School	By Rm 1218 Hallway (2)	0 ppb
Sanford Middle School	Cafe	0 ppb
Sanford Middle School	Cafe	0 ppb
Sanford Middle School	Girls Locker Room Rm 171	0 ppb
Sanford Middle School	Hallway By Door #7 (1)	0 ppb
Sanford Middle School	Hallway By Door #7 (2)	0 ppb
Sanford Middle School	Hallway By Rm 1202	0 ppb
Sanford Middle School	Hallway By Rm 2247	0 ppb
Sanford Middle School	Hallway By Rm121 (1)	0 ppb
Sanford Middle School	Hallway By Rm121 (2)	0 ppb
Sanford Middle School	Hallway By Room 2215 (1)	0 ppb
Sanford Middle School	Hallway By Room 2215 (2)	0 ppb
Sanford Middle School	Hallway By Room 2233 (1)	0 ppb
Sanford Middle School	Hallway By Room 2233 (2)	0 ppb
Sanford Middle School	Kitchen Kettle	0 ppb
Sanford Middle School	Kitchen Prep Sink	1 ppb
Sanford Middle School	Kitchen Sink By Windows	1.1 ppb
Sanford Middle School	Rm 1234	1.1 ppb
Sanford Middle School	Rm 1238	0 ppb
Sanford Middle School	Rm 1242	4.4 ppb
Sanford Middle School	Rm 155 Teachers Room	0 ppb
Sanford Middle School	Rm 2220	1.2 ppb

School Name	Sample Location	Lead Test Result
Sanford Pride Elementary School	A113 Teacher Breakroom	2.2 ppb
Sanford Pride Elementary School	A113 Teacher Breakroom (2)	0 ppb
Sanford Pride Elementary School	C210	2 ppb
Sanford Pride Elementary School	C211	2.1 ppb
Sanford Pride Elementary School	C212	1.7 ppb
Sanford Pride Elementary School	C213	3 ppb
Sanford Pride Elementary School	C215 Teacher Room	1.4 ppb
Sanford Pride Elementary School	C217a	1.4 ppb
Sanford Pride Elementary School	D214	2.8 ppb
Sanford Pride Elementary School	D218	1.2 ppb
Sanford Pride Elementary School	D220	1.9 ppb
Sanford Pride Elementary School	D225b Kitchen Prep Sink	11.3 ppb
Sanford Pride Elementary School	E230e Staff Bathroom	1.7 ppb
Sanford Pride Elementary School	E234 Teachers Room	1.7 ppb
Sanford Pride Elementary School	E237	2 ppb
Sanford Pride Elementary School	E238	1.7 ppb
Sanford Pride Elementary School	E239	3.2 ppb
Sanford Pride Elementary School	E240	50.6 ppb
Sanford Pride Elementary School	E242	1.7 ppb
Sanford Pride Elementary School	E244	2.2 ppb
Sanford Pride Elementary School	E247	1.5 ppb
Sanford Pride Elementary School	E249	1.6 ppb
Sanford Pride Elementary School	E251	1.8 ppb
Sanford Pride Elementary School	Hallway By B131 (1)	0 ppb
Sanford Pride Elementary School	Hallway By B131 (2)	0 ppb
Sanford Pride Elementary School	Hallway By B131 (3)	0 ppb
Sanford Pride Elementary School	Hallway By C215 (1)	0 ppb
Sanford Pride Elementary School	Hallway By C215 (2)	0 ppb
Sanford Pride Elementary School	Hallway By C215 (3)	0 ppb
Sanford Pride Elementary School	Hallway By D221 (1)	0 ppb
Sanford Pride Elementary School	Hallway By D221 (2)	0 ppb
Sanford Pride Elementary School	Hallway By D221 (3)	0 ppb
Sanford Pride Elementary School	Hallway By E236 (1)	0 ppb
Sanford Pride Elementary School	Hallway By E236 (2)	0 ppb
Sanford Pride Elementary School	Hallway By E236 (3)	0 ppb
Sanford Regional Technical Center	A143a Two Bay Sink	10.6 ppb
Sanford Regional Technical Center	D123 2 Bay Sink By Door	0 ppb
Sanford Regional Technical Center	D123 Ice Machine	0 ppb
Sanford Regional Technical Center	D123 Kettle Fill	4.6 ppb
Sanford Regional Technical Center	D123 Sink By Mixers	1.6 ppb
Sanford Regional Technical Center	D151 Server Station	1.6 ppb
Scarborough High School	""e"" Hallway Bottle Filler"	0 ppb
Scarborough High School	""e"" Hallway Water Fountain"	0 ppb
Scarborough High School	A100 Hallway Bottle Filler	0 ppb
Scarborough High School	A100 Hallway Fountain (mid Hall)	0 ppb
Scarborough High School	A100/d100 Hallway Bottle Filler	0 ppb
Scarborough High School	A100/d100 Hallway Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Scarborough High School	A103a Teacher Prep Room Sink	4.3 ppb
Scarborough High School	A200 Hall Bottle Filler	0 ppb
Scarborough High School	A200 Hall Fountain (mid Hall)	0 ppb
Scarborough High School	A205a Teacher Prep Rm Sink	5.4 ppb
Scarborough High School	Auditorium Dressing Room A Sink	4.3 ppb
Scarborough High School	Auditorium Dressing Room B Sink	8.1 ppb
Scarborough High School	B105a Science Lab Prep Room Sink	0 ppb
Scarborough High School	B200 Filler	0 ppb
Scarborough High School	B200 Fountain	0 ppb
Scarborough High School	B202a Tecaher Lab Prep Rm Sink	1.8 ppb
Scarborough High School	C100 Hallway Bottle Filler	0 ppb
Scarborough High School	C100 Hallway Fountain	0 ppb
Scarborough High School	C100 Kitch Sink 1 (inside On R)	0 ppb
Scarborough High School	C100 Kitchen Sink #2 (left Of	0 ppb
Scarborough High School	C101 Library Fountain (high)	0 ppb
Scarborough High School	C101 Library Fountain (low)	0 ppb
Scarborough High School	C101 Library Fountain Bottle Filler	0 ppb
Scarborough High School	C106a Lab Workroom Sink	0 ppb
Scarborough High School	D100 Hall Fountain (near D114)	0 ppb
Scarborough High School	D100 Hallway Bottle Filler	0 ppb
Scarborough High School	D109a Science Lab Prep Room	4.6 ppb
Scarborough High School	D200/a200 Hall Bottle Filler	0 ppb
Scarborough High School	D200/a200 Hall Fountain	0 ppb
Scarborough High School	D206a Teacher Prep Rm Sink	11.2 ppb
Scarborough High School	E100a Library Workroom Sink	0 ppb
Scarborough High School	F Hall Filler (I Or Rm F105)	0 ppb
Scarborough High School	F Hall Fountain (I Of Rm F105)	0 ppb
Scarborough High School	F105 Sink	1.7 ppb
Scarborough High School	F107 Sink	3 ppb
Scarborough High School	F109g Music Teacher Office Sink	0 ppb
Scarborough High School	G000 Hall Filler Btwm G007 & G009	0 ppb
Scarborough High School	G011 Training Room Floor Sink	1.5 ppb
Scarborough High School	G011 Training Room Ice Machine	0 ppb
Scarborough High School	G020 Football Coach Office Sink	7.5 ppb
Scarborough High School	G101 Cafeteria Concession Stand	7.3 ppb
Scarborough High School	G102 Main Off Staff Work Rm Sink	0 ppb
Scarborough High School	G102 Main Off Work Rm Culligan	0 ppb
Scarborough High School	G118a Clinic Exam Rm Cullig Disp	0 ppb
Scarborough High School	G118a Clinic Exam Room Sink	0 ppb
Scarborough High School	G118c Clinic Sink	11.2 ppb
Scarborough High School	G118d Clinic Sink	0 ppb
Scarborough High School	G118f Clinic Bathroom Sink	0 ppb
Scarborough High School	G122 Ap Office Sink	4 ppb
Scarborough High School	G134a Admin li Bathroom Sink	0 ppb
Scarborough High School	G138 Faculty Room Sink	0 ppb
Scarborough High School	G200 Hallway Bottle Filler	0 ppb
Scarborough High School	G200 Hallway Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Scarborough High School	G200 Staff Break Room Sink Faucet	0 ppb
Scarborough High School	G203 Fls Sink 1 Left	0 ppb
Scarborough High School	G203 Fls Sink 2 Right	0 ppb
Scarborough High School	G205 Sink 1 Left	3.5 ppb
Scarborough High School	G205 Sink 2 Right	0 ppb
Scarborough High School	Hall Filler Near G146	0 ppb
Scarborough High School	Hall Fountain Near G146	0 ppb
Scarborough High School	Hall Old Fountain (near G030)	0 ppb
Scarborough High School	Hall Old Fountain (near G030) Low	0 ppb
Scarborough High School	Kitchen Baking Sink Faucet	1.9 ppb
Scarborough High School	Kitchen G105 Coffee Maker #1	3.9 ppb
Scarborough High School	Kitchen G105 Ice Machine	0 ppb
Scarborough High School	Kitchen G105 Keurig #1 (R)	0 ppb
Scarborough High School	Kitchen G105 Keurig #2 (L)	0 ppb
Scarborough High School	Kitchen G105 Steam Kettle Spigot	2.9 ppb
Scarborough High School	Kitchen Produce Sink	2.3 ppb
Scarborough High School	Lower Gym Lobby Filler	0 ppb
Scarborough High School	Lower Gym Lobby Fountain	0 ppb
Scarborough High School	Main Lobby Bottle Filler	0 ppb
Scarborough High School	Main Lobby Fountain (left)	0 ppb
Scarborough High School	Main Lobby Fountain (right)	0 ppb
Scarborough High School	Weight Room Fountain	0 ppb
Scarborough Middle School	2-bay Sink	0 ppb
Scarborough Middle School	6th Grade Lc Hall Bottle Filler	0 ppb
Scarborough Middle School	6th Grade Lc Hall Fountain	0 ppb
Scarborough Middle School	A Hall Filler	0 ppb
Scarborough Middle School	A Hall Fountain	0 ppb
Scarborough Middle School	A200 Hall Bottle Filler	0 ppb
Scarborough Middle School	A200 Hall Fountain	0 ppb
Scarborough Middle School	B Break Room Mlr	0 ppb
Scarborough Middle School	B Hall Filler	0 ppb
Scarborough Middle School	B Hall Fountain	0 ppb
Scarborough Middle School	B200 Hall Bottle Filler	0 ppb
Scarborough Middle School	B200 Hall Fountain	0 ppb
Scarborough Middle School	Band Room Fountain	0 ppb
Scarborough Middle School	Band Room Sink	0 ppb
Scarborough Middle School	Cafeteria Hall Filler	0 ppb
Scarborough Middle School	Cafeteria Hall Fountain	0 ppb
Scarborough Middle School	Clinic Bubbler	0 ppb
Scarborough Middle School	Clinic Sink	0 ppb
Scarborough Middle School	D100 Hall Fountain	0 ppb
Scarborough Middle School	G Sink Mlr	0 ppb
Scarborough Middle School	Gym Lobby Bottle Filler	0 ppb
Scarborough Middle School	Gym Lobby New Fountain	0 ppb
Scarborough Middle School	Gym Lobby Old Fountain	0 ppb
Scarborough Middle School	Kitchen Ice Machine	0 ppb
Scarborough Middle School	Main Lobby Bottle Filler	0 ppb

School Name	Sample Location	Lead Test Result
Scarborough Middle School	Main Lobby Fountain	0 ppb
Scarborough Middle School	Main Office Bubbler	0 ppb
Scarborough Middle School	Produce Wash Sink	0 ppb
Scarborough Middle School	Rm 150 Teacher Break Room Sink	0 ppb
Scarborough Middle School	Room 114 Guidance Fountain	0 ppb
Scarborough Middle School	Room 114 Guidance Sink	0 ppb
Scarborough Middle School	Room 122 Fountain	0 ppb
Scarborough Middle School	Room 122 Sink	0 ppb
Scarborough Middle School	Room 125 Fountain	0 ppb
Scarborough Middle School	Room 125 Sink	0 ppb
Scarborough Middle School	Room 126 Fountain	0 ppb
Scarborough Middle School	Room 126 Sink	0 ppb
Scarborough Middle School	Room 129 Fountain	0 ppb
Scarborough Middle School	Room 129 Sink	0 ppb
Scarborough Middle School	Room 135 Fountain	0 ppb
Scarborough Middle School	Room 135 Sink	0 ppb
Scarborough Middle School	Room 139 Sink	0 ppb
Scarborough Middle School	Room 156 Fountain	0 ppb
Scarborough Middle School	Room 156 Sink	0 ppb
Scarborough Middle School	Room 157 Fountain	0 ppb
Scarborough Middle School	Room 157 Sink	0 ppb
Scarborough Middle School	Room 158 Fountain	0 ppb
Scarborough Middle School	Room 158 Sink	0 ppb
Scarborough Middle School	Room 159 Fountain	0 ppb
Scarborough Middle School	Room 159 Sink	0 ppb
Scarborough Middle School	Room 162 Fountain	0 ppb
Scarborough Middle School	Room 162 Sink	0 ppb
Scarborough Middle School	Room 163 Fountain	0 ppb
Scarborough Middle School	Room 163 Sink	0 ppb
Scarborough Middle School	Room 164 Fountain	1.1 ppb
Scarborough Middle School	Room 164 Sink	0 ppb
Scarborough Middle School	Room 165 Fountain	0 ppb
Scarborough Middle School	Room 165 Sink	0 ppb
Scarborough Middle School	Room 166 Fountain	0 ppb
Scarborough Middle School	Room 166 Sink	0 ppb
Scarborough Middle School	Room 167 Fountain	0 ppb
Scarborough Middle School	Room 167 Sink	0 ppb
Scarborough Middle School	Room 175 Fountain	0 ppb
Scarborough Middle School	Room 175 Sink	0 ppb
Scarborough Middle School	Room 176 Fountain	0 ppb
Scarborough Middle School	Room 176 Sink	0 ppb
Scarborough Middle School	Room 177 Fountain	0 ppb
Scarborough Middle School	Room 177 Sink	0 ppb
Scarborough Middle School	Room 178 Fountain	0 ppb
Scarborough Middle School	Room 178 Sink	0 ppb
Scarborough Middle School	Room 181 Fountain	0 ppb
Scarborough Middle School	Room 181 Sink	0 ppb

School Name	Sample Location	Lead Test Result
Scarborough Middle School	Room 182 Fountain	0 ppb
Scarborough Middle School	Room 182 Sink	0 ppb
Scarborough Middle School	Room 183 Fountain	0 ppb
Scarborough Middle School	Room 183 Sink	0 ppb
Scarborough Middle School	Room 184 Fountain	0 ppb
Scarborough Middle School	Room 184 Sink	0 ppb
Scarborough Middle School	Room 194 Art Sink 1	0 ppb
Scarborough Middle School	Room 194 Art Sink 2	0 ppb
Scarborough Middle School	Room 194 Fountain 1	0 ppb
Scarborough Middle School	Room 194 Fountain 2	0 ppb
Scarborough Middle School	Room 194 Sink 1	0 ppb
Scarborough Middle School	Room 194 Sink 2	0 ppb
Scarborough Middle School	Room 196 Sink	0 ppb
Scarborough Middle School	Room 198 Sink	0 ppb
Scarborough Middle School	Room 246 Library Work Room Sink	0 ppb
Scarborough Middle School	Room 254 Teacher Break Room Sink	0 ppb
Scarborough Middle School	Room 256 Fountain	1.7 ppb
Scarborough Middle School	Room 256 Sink	0 ppb
Scarborough Middle School	Room 257 Fountain	0 ppb
Scarborough Middle School	Room 257 Sink	0 ppb
Scarborough Middle School	Room 258 Fountain	0 ppb
Scarborough Middle School	Room 258 Sink	0 ppb
Scarborough Middle School	Room 259 Fountain	0 ppb
Scarborough Middle School	Room 259 Sink	0 ppb
Scarborough Middle School	Room 262 Fountain	0 ppb
Scarborough Middle School	Room 262 Sink	0 ppb
Scarborough Middle School	Room 263 Fountain	0 ppb
Scarborough Middle School	Room 263 Sink	0 ppb
Scarborough Middle School	Room 264 Fountain	0 ppb
Scarborough Middle School	Room 264 Sink	0 ppb
Scarborough Middle School	Room 265 Fountain	0 ppb
Scarborough Middle School	Room 265 Sink	0 ppb
Scarborough Middle School	Room 266 Fountain	0 ppb
Scarborough Middle School	Room 266 Sink	0 ppb
Scarborough Middle School	Room 267 Fountain	0 ppb
Scarborough Middle School	Room 267 Sink	0 ppb
Scarborough Middle School	Room 275 Fountain	0 ppb
Scarborough Middle School	Room 275 Sink	0 ppb
Scarborough Middle School	Room 276 Fountain	0 ppb
Scarborough Middle School	Room 276 Sink	0 ppb
Scarborough Middle School	Room 277 Fountain	0 ppb
Scarborough Middle School	Room 277 Sink	0 ppb
Scarborough Middle School	Room 278 Fountain	0 ppb
Scarborough Middle School	Room 278 Sink	0 ppb
Scarborough Middle School	Room 281 Fountain	0 ppb
Scarborough Middle School	Room 281 Sink	0 ppb
Scarborough Middle School	Room 282 Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Scarborough Middle School	Room 282 Sink	0 ppb
Scarborough Middle School	Room 283 Fountain	0 ppb
Scarborough Middle School	Room 283 Sink	0 ppb
Scarborough Middle School	Room 284 Fountain	0 ppb
Scarborough Middle School	Room 284 Sink	0 ppb
Scarborough Middle School	Room 305 Main Counter Sink	0 ppb
Scarborough Middle School	Steam Kettle	9.7 ppb
School Around Us	Faucet In Art Room Of School	0 ppb
School Around Us	Faucet In Bathroom	0 ppb
School Around Us	Faucet In Kitchen Of School	2.5 ppb
Se Do Mo Cha Elementary School	Bottle Fill - Mpr Room 126s	0 ppb
Se Do Mo Cha Elementary School	Bottle Fill - Outside Room 178s	0 ppb
Se Do Mo Cha Elementary School	Bottle Fill - Outside Room 234s	0 ppb
Se Do Mo Cha Elementary School	Bottle Fill - Outside Room 235s	0 ppb
Se Do Mo Cha Elementary School	Kitchen - Double Sink Basin	2 ppb
Se Do Mo Cha Middle School	Bottle Fill - Fitness Center Room 153	1.3 ppb
Se Do Mo Cha Middle School	Bottle Fill Between Gym & Cafe	0 ppb
Se Do Mo Cha Middle School	Bottle Fill Outside 7/8 Bathroom	0 ppb
Se Do Mo Cha Middle School	Bottle Fill Outside Room 130	0 ppb
Se Do Mo Cha Middle School	Kitchen - Double Sink Basin	9.4 ppb
Se Do Mo Cha Middle School	Kitchen - Ice Machine	1.1 ppb
Se Do Mo Cha Middle School	Kitchen - Kettle	0 ppb
Se Do Mo Cha Middle School	Life Skill's Sink - Room 177	7.7 ppb
Se Do Mo Cha Middle School	Nurse's Office Sink	0 ppb
Sea Road School	117	0 ppb
Sea Road School	118	0 ppb
Sea Road School	122	0 ppb
Sea Road School	127	0 ppb
Sea Road School	139	0 ppb
Sea Road School	206	0 ppb
Sea Road School	209	0 ppb
Sea Road School	215	0 ppb
Sea Road School	218	0 ppb
Sea Road School	223	0 ppb
Sea Road School	237	0 ppb
Sea Road School	239	0 ppb
Sea Road School	242	1.1 ppb
Sea Road School	247	0 ppb
Sea Road School	249	0 ppb
Sea Road School	253	0 ppb
Sea Road School	75	0 ppb
Sea Road School	87	0 ppb
Sea Road School	89	0 ppb
Sea Road School	Art Room Sink #1	0 ppb
Sea Road School	Art Room Sink #2	0 ppb
Sea Road School	Art Room Sink Within 20 Ft #1	0 ppb
Sea Road School	Art Room Sink Within 20 Ft #2	0 ppb

School Name	Sample Location	Lead Test Result
Sea Road School	Classroom 132	0 ppb
Sea Road School	Classroom 205	0 ppb
Sea Road School	Fountain By Gym	0 ppb
Sea Road School	Kitchen Dishwasher Sink	1.4 ppb
Sea Road School	Kitchen Sink #1	1.2 ppb
Sea Road School	Kitchen Sink #2	3.9 ppb
Sea Road School	Kitchen Sink #3	0 ppb
Sea Road School	Library Sink	1.5 ppb
Sea Road School	Nurse Office	0 ppb
Sea Road School	Stem Room	5.5 ppb
Sea Road School	Upstairs Fill Station	0 ppb
Seacoast Waldorf School	Bottle Fill Station - Red Building	0 ppb
Seacoast Waldorf School	Boys Bathroom - Red Building	0 ppb
Seacoast Waldorf School	Drinking Water Fountain - Community Room	0 ppb
Seacoast Waldorf School	Drinking Water Fountain - Ec Hallway	0 ppb
Seacoast Waldorf School	Drinking Water Fountain - Red Building	0 ppb
Seacoast Waldorf School	Girls Bathroom - Red Building	0 ppb
Seacoast Waldorf School	Grade 4/5 Classroom - Red Building	0 ppb
Seacoast Waldorf School	Grade 6 Classroom - Red Building	0 ppb
Seacoast Waldorf School	Grade 7/8 Classroom - Red Building	0 ppb
Seacoast Waldorf School	Kitchen - Potable Water Faucet	1.1 ppb
Seacoast Waldorf School	Unisex Bathroom - Red Building	0 ppb
Searsport District High School	Gym Back Hallway	3.7 ppb
Searsport District High School	Gym Between Locker Rooms Lower	0 ppb
Searsport District High School	Gym Between Locker Rooms Upper	0 ppb
Searsport District High School	Handicap Bathroom By Gym Lobby	3.5 ppb
Searsport District High School	Hs Kitchen 3 Bay Sink	1.5 ppb
Searsport District High School	Hs Kitchen Food Prep Sink#1	1.9 ppb
Searsport District High School	Hs Kitchen Food Prep Sink#2	1.2 ppb
Searsport District High School	Hs Outside Library	0 ppb
Searsport District High School	Hs Valt Room Sink #1	4.6 ppb
Searsport District High School	Hs Valt Room Sink #2	3.8 ppb
Searsport District High School	Ice Machine In Sports Storage Room	0 ppb
Searsport District High School	Lower Hs Across From Guidance	1.5 ppb
Searsport District High School	Lower Hs Across From Room 8	0 ppb
Searsport District High School	Upper Hs Sped Room #25	3.9 ppb
Searsport District Middle School	Ms Across From Guidance Top Of Stairs	1.5 ppb
Searsport District Middle School	Ms Between Bathrooms By Nurse's Room	0 ppb
Searsport District Middle School	Ms Hallway Between Rooms 3&4	5.3 ppb
Searsport District Middle School	Ms Nurse's Station Exam Room	0 ppb
Searsport District Middle School	Ms Rise Room Sink #1	1.6 ppb
Searsport District Middle School	Ms Rise Room Sink #2	2.8 ppb
Searsport Elementary	Bishops Room	10.7 ppb
Searsport Elementary	Brassbridges Room	3.9 ppb
Searsport Elementary	Bucklins Room	5.7 ppb
Searsport Elementary	Bucks Room	12 ppb

School Name	Sample Location	Lead Test Result
Searsport Elementary	Coxs Room	6.6 ppb
Searsport Elementary	Estabrooks Room	2.2 ppb
Searsport Elementary	Gatcombs Room	1.8 ppb
Searsport Elementary	Givens Room	27.3 ppb
Searsport Elementary	Hartfords Room	9.4 ppb
Searsport Elementary	Herberts Room	7.1 ppb
Searsport Elementary	Jaques Room	2.8 ppb
Searsport Elementary	Legeres Room	7.7 ppb
Searsport Elementary	Praise Room	1.9 ppb
Searsport Elementary	Pre-k Room	0 ppb
Searsport Elementary	Resource Room	6.8 ppb
Searsport Elementary	Ses Fountain 2nd Floor	0 ppb
Searsport Elementary	Ses Fountain By Gym	0 ppb
Searsport Elementary	Ses Fountain Main Lobby By Bathrooms	0 ppb
Searsport Elementary	Ses Kitchen Prep Sink By Dishwasher	0 ppb
Searsport Elementary	Ses Kitchen Prep Sink By Dry Storage	4 ppb
Searsport Elementary	Ses Nurse's Station	3.2 ppb
Searsport Elementary	Stepping Stones Room	2 ppb
Searsport Elementary	Title 1 Room	14.4 ppb
Searsport Elementary	Woods Room	4.8 ppb
Sebago Elementary School	Cafeteria Kitchen Sink	1.6 ppb
Sebago Elementary School	Clinic Room Drinking Fountain	2.2 ppb
Sebago Elementary School	Drinking Fountain Outside Staff Room 2	0 ppb
Sebago Elementary School	Hallway Drinking Fountain	0 ppb
Sebago Elementary School	Kindergarten Drinking Fountain	2.9 ppb
Sebago Elementary School	Pre-k Drinking Fountain	3.2 ppb
Sebasticook Valley Elementary School	100 Bottle Filler	0 ppb
Sebasticook Valley Elementary School	100 Fountain	0 ppb
Sebasticook Valley Elementary School	100 Hallway Sink	1.6 ppb
Sebasticook Valley Elementary School	102 Fountain	2.2 ppb
Sebasticook Valley Elementary School	102 Sink	4 ppb
Sebasticook Valley Elementary School	103 Sink	0 ppb
Sebasticook Valley Elementary School	104 Sink	0 ppb
Sebasticook Valley Elementary School	105 Sink	0 ppb
Sebasticook Valley Elementary School	107 Fountain	0 ppb
Sebasticook Valley Elementary School	107 Sink	1.2 ppb
Sebasticook Valley Elementary School	111 Fountain	0 ppb
Sebasticook Valley Elementary School	111 Sink	1.1 ppb
Sebasticook Valley Elementary School	112 Fountain	0 ppb
Sebasticook Valley Elementary School	112 Sink	2.9 ppb
Sebasticook Valley Elementary School	113 Fountain	0 ppb
Sebasticook Valley Elementary School	113 Sink	1.1 ppb
Sebasticook Valley Elementary School	114 Fountain	0 ppb
Sebasticook Valley Elementary School	114 Sink	0 ppb
Sebasticook Valley Elementary School	115 Fountian	0 ppb
Sebasticook Valley Elementary School	115 Sink	4.6 ppb
Sebasticook Valley Elementary School	116 Sink	0 ppb

School Name	Sample Location	Lead Test Result
Sebasticook Valley Elementary School	117 Sink	0 ppb
Sebasticook Valley Elementary School	120 Sink	0 ppb
Sebasticook Valley Elementary School	121 Sink	0 ppb
Sebasticook Valley Elementary School	122 Sink	0 ppb
Sebasticook Valley Elementary School	123 Sink	0 ppb
Sebasticook Valley Elementary School	124 Fountain	0 ppb
Sebasticook Valley Elementary School	124 Sink	0 ppb
Sebasticook Valley Elementary School	125 Fountain	3.2 ppb
Sebasticook Valley Elementary School	125 Sink	0 ppb
Sebasticook Valley Elementary School	126 Fountain	0 ppb
Sebasticook Valley Elementary School	126 Sink	0 ppb
Sebasticook Valley Elementary School	127 Fountain	0 ppb
Sebasticook Valley Elementary School	127 Sink	0 ppb
Sebasticook Valley Elementary School	129 Sink	0 ppb
Sebasticook Valley Elementary School	130 Fountain	3.4 ppb
Sebasticook Valley Elementary School	130 Sink	0 ppb
Sebasticook Valley Elementary School	131 Fountain	2.3 ppb
Sebasticook Valley Elementary School	131 Sink	2 ppb
Sebasticook Valley Elementary School	133 Hand Sink	3.3 ppb
Sebasticook Valley Elementary School	134 Sink Left	0 ppb
Sebasticook Valley Elementary School	134 Sink Right	0 ppb
Sebasticook Valley Elementary School	135 Sink Left	0 ppb
Sebasticook Valley Elementary School	135 Sink Right	0 ppb
Sebasticook Valley Elementary School	137 Ice Machine	0 ppb
Sebasticook Valley Elementary School	139 Sink Left	0 ppb
Sebasticook Valley Elementary School	139 Sink Right	0 ppb
Sebasticook Valley Elementary School	140 Sink Left	0 ppb
Sebasticook Valley Elementary School	140 Sink Right	0 ppb
Sebasticook Valley Elementary School	143 Sink	0 ppb
Sebasticook Valley Elementary School	145 Hand Sink At Dishwasher	15.3 ppb
Sebasticook Valley Elementary School	145 Hand Sink Del Ent	6.3 ppb
Sebasticook Valley Elementary School	145 Pan Wash Left	4.6 ppb
Sebasticook Valley Elementary School	145 Pan Wash Right	5 ppb
Sebasticook Valley Elementary School	145 Prep Sink	1.2 ppb
Sebasticook Valley Elementary School	202 Fountain	0 ppb
Sebasticook Valley Elementary School	202 Sink	0 ppb
Sebasticook Valley Elementary School	205 Sink	1.4 ppb
Sebasticook Valley Elementary School	206 Sink	0 ppb
Sebasticook Valley Elementary School	208 Sink	0 ppb
Sebasticook Valley Elementary School	209 Fountain	0 ppb
Sebasticook Valley Elementary School	209 Sink	0 ppb
Sebasticook Valley Elementary School	210 Fountain	0 ppb
Sebasticook Valley Elementary School	210 Sink	0 ppb
Sebasticook Valley Elementary School	211 Fountain	4.2 ppb
Sebasticook Valley Elementary School	211 Sink	0 ppb
Sebasticook Valley Elementary School	212 Sink	0 ppb
Sebasticook Valley Elementary School	214 Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Sebasticook Valley Elementary School	214 Sink	1.6 ppb
Sebasticook Valley Elementary School	215 Sink	0 ppb
Sebasticook Valley Elementary School	216 Sink	0 ppb
Sebasticook Valley Elementary School	218 Sink	0 ppb
Sebasticook Valley Elementary School	219 Sink	0 ppb
Sebasticook Valley Elementary School	220 Fountain Down	0 ppb
Sebasticook Valley Elementary School	220 Fountain Up	0 ppb
Sebasticook Valley Elementary School	220 Sink	0 ppb
Sebasticook Valley Elementary School	221 Fountain Up	0 ppb
Sebasticook Valley Elementary School	221 Sink	0 ppb
Sebasticook Valley Elementary School	222 Fountain	0 ppb
Sebasticook Valley Elementary School	222 Sink	1.1 ppb
Sebasticook Valley Elementary School	223 Fountain	1.1 ppb
Sebasticook Valley Elementary School	223 Sink	0 ppb
Sebasticook Valley Elementary School	225 Fountain	1.6 ppb
Sebasticook Valley Elementary School	225 Sink	0 ppb
Sebasticook Valley Elementary School	226 Fountain	1.4 ppb
Sebasticook Valley Elementary School	226 Sink	0 ppb
Sebasticook Valley Elementary School	231 Sink	0 ppb
Sebasticook Valley Elementary School	233 Sink Left	0 ppb
Sebasticook Valley Elementary School	233 Sink Middle	1.6 ppb
Sebasticook Valley Elementary School	233 Sink Right	1.2 ppb
Sedgwick Elementary School	Art Room Kitchen Sink	1.1 ppb
Sedgwick Elementary School	Kitchen Prep Sink	7.9 ppb
Sedgwick Elementary School	Laundry Room Sink	4.5 ppb
Sedgwick Elementary School	Nurse's Office Sink	3.9 ppb
Sedgwick Elementary School	Room 10 Fountain	5.5 ppb
Sedgwick Elementary School	Room 10 Left Sink	4.6 ppb
Sedgwick Elementary School	Room 10 Right Sink	1.5 ppb
Sedgwick Elementary School	Room 11 Fountain	15.6 ppb
Sedgwick Elementary School	Room 11 Sink	5.2 ppb
Sedgwick Elementary School	Room 12 Fountain	7.2 ppb
Sedgwick Elementary School	Room 12 Sink	6.4 ppb
Sedgwick Elementary School	Room 13 Fountain	6.7 ppb
Sedgwick Elementary School	Room 13 Sink	7.4 ppb
Sedgwick Elementary School	Room 14 Fountain	17.5 ppb
Sedgwick Elementary School	Room 14 Sink	4.4 ppb
Sedgwick Elementary School	Science Right Sink	2.2 ppb
Sedgwick Elementary School	Science Room Left Sink	2.8 ppb
Sedgwick Elementary School	Staff Room Sink	2.5 ppb
Shapleigh Memorial School	Drinking Fountain- Old Wing (high)	0 ppb
Shapleigh Memorial School	Drinking Fountain -old Wing (low)	0 ppb
Shapleigh Memorial School	Drinking Fountain-cafe	0 ppb
Shapleigh Memorial School	Drinking Fountain-new Wing	0 ppb
Shapleigh Memorial School	Kitchen- 3 Bay Sink (l)	4.3 ppb
Shapleigh Memorial School	Kitchen-3 Bay Sink (r)	2.7 ppb
Shapleigh Memorial School	Kitchen-vegetable Sink	0 ppb

School Name	Sample Location	Lead Test Result
Shapleigh Memorial School	Nurse's Office-sink	2.2 ppb
Shapleigh Memorial School	Room 1-drinking Fountain	98.8 ppb
Shapleigh Memorial School	Room 1-sink	2 ppb
Shapleigh Memorial School	Room 2-drinking Fountain	668 ppb
Shapleigh Memorial School	Room 2-sink	2 ppb
Shapleigh Memorial School	Room 3-drinking Fountain	1610 ppb
Shapleigh Memorial School	Room 3-sink	2.5 ppb
Shapleigh Memorial School	Room 4-drinking Fountain	3.8 ppb
Shapleigh Memorial School	Room 4-sink	1.9 ppb
Shapleigh Memorial School	Room 5-drinking Fountain	8.1 ppb
Shapleigh Memorial School	Room 5-sink	1.5 ppb
Shapleigh Memorial School	Room 8-sink	7.1 ppb
Shapleigh Memorial School	Teacher's Room-sink	5.1 ppb
Shapleigh School	Art Room #1	0 ppb
Shapleigh School	Burns #1	0 ppb
Shapleigh School	Downstairs Teachers Room #1	0 ppb
Shapleigh School	Foyes #1	0 ppb
Shapleigh School	Gagnon	0 ppb
Shapleigh School	Gilpatrick #1	0 ppb
Shapleigh School	Grade 4 Fountain #1	0 ppb
Shapleigh School	Grade 4 Restroom	0 ppb
Shapleigh School	Grade 4 Wing	0 ppb
Shapleigh School	Grade 5 Fountain #1	0 ppb
Shapleigh School	Grade 5 Restroom	0 ppb
Shapleigh School	Grade 5 Wing	0 ppb
Shapleigh School	Grade 6 Boys Restroom #1	0 ppb
Shapleigh School	Grade 6 Fountain #1	0 ppb
Shapleigh School	Grade 6 Girls Restroom #1	0 ppb
Shapleigh School	Grade 6 Science	0 ppb
Shapleigh School	Grade 7 Boys Restroom #1	0 ppb
Shapleigh School	Grade 7 Girls Restroom #1	0 ppb
Shapleigh School	Grade 7 Science #1	0 ppb
Shapleigh School	Grade 8 Boys Restroom #1	0 ppb
Shapleigh School	Grade 8 Girls Restroom #1	0 ppb
Shapleigh School	Gym	0 ppb
Shapleigh School	Harris #1	0 ppb
Shapleigh School	Kitchen #1	3.1 ppb
Shapleigh School	Nurse #1	0 ppb
Shapleigh School	Office #1	0 ppb
Shapleigh School	Office Restroom #1	0 ppb
Shapleigh School	Pearl #1	0 ppb
Shapleigh School	Randall #1	0 ppb
Shapleigh School	Reeve #1	0 ppb
Shapleigh School	Second Floor Teachers Room #1	0 ppb
Shapleigh School	Sheldon #1	0 ppb
Shapleigh School	Staff Restroom Near Stage #1	0 ppb
Shapleigh School	Waters #1	0 ppb

School Name	Sample Location	Lead Test Result
Shapleigh School	Westman #1	0 ppb
Shead High School	1st Floor Hallway Water Fountain	0 ppb
Shead High School	2nd Floor Hallway Water Fountain	0 ppb
Shead High School	Concession Stand 1 Bay Sink	0 ppb
Shead High School	Front Office 2 Bay Sinks	9 ppb
Shead High School	Library 1 Bay Sink	2.2 ppb
Shead High School	Maine Indian Ed 1 Bay Sink	2.5 ppb
Shead High School	Rm Off Library 1 Bay Sink	7.9 ppb
Shead High School	Tech Office 1 Bay Sink	8.7 ppb
Shead High School	Water Fountain Gym	0 ppb
Sheepscot Valley Children's House	Kitchen- Infant Room	0 ppb
Sheepscot Valley Children's House	Kitchen- Library	0 ppb
Sheepscot Valley Children's House	Kitchen- Preschool	24 ppb
Sipayik Elementary School	Kettle Filler In Kitchen	5.8 ppb
Sipayik Elementary School	Pot Filler By Stove	3.5 ppb
Sipayik Elementary School	Pot Filler In Kitchen By Kitchen Serving Window	1.9 ppb
Sipayik Elementary School	Water Fountain/ Bottle Filler B Wing	0 ppb
Sipayik Elementary School	Water Fountain/ Bottle Filler C Wing	0 ppb
Sipayik Elementary School	Water Fountain/ Bottle Filler D Wing	0 ppb
Sipayik Elementary School	Water Fountain/ Bottle Filler Gym	0 ppb
Skowhegan Area High School/Somerset Care	2nd Floor Restroom	3.7 ppb
Skowhegan Area High School/Somerset Care	Automotive Eye Wash	4.9 ppb
Skowhegan Area High School/Somerset Care	Automotive Restroom Sink	2.6 ppb
Skowhegan Area High School/Somerset Care	Automotive Sink	1.2 ppb
Skowhegan Area High School/Somerset Care	Back Of Gym Bottle Fill Station	0 ppb
Skowhegan Area High School/Somerset Care	Cafeteria Bottle Fill Station On Left	0 ppb
Skowhegan Area High School/Somerset Care	Cafeteria Bottle Fill Station On Right	0 ppb
Skowhegan Area High School/Somerset Care	Culinary Arts Classroom Sink	9.7 ppb
Skowhegan Area High School/Somerset Care	Culinary Arts Lab Sink 2nd On Right	0 ppb
Skowhegan Area High School/Somerset Care	Culinary Arts Lab Sink 3rd On Right	1.3 ppb
Skowhegan Area High School/Somerset Care	Culinary Arts Lab Sink 4th On Right	4.4 ppb
Skowhegan Area High School/Somerset Care	Culinary Arts Lab Sink 5th On Right	0 ppb
Skowhegan Area High School/Somerset Care	Culinary Arts Lab Sink 6th On Right	1.8 ppb
Skowhegan Area High School/Somerset Care	Culinary Arts Lab Sink 7th On Right	2.9 ppb
Skowhegan Area High School/Somerset Care	Culinary Arts Lab Sink On Right	0 ppb
Skowhegan Area High School/Somerset Care	Culinary Arts Restroom	4.3 ppb
Skowhegan Area High School/Somerset Care	Engineering Sink On Left	0 ppb
Skowhegan Area High School/Somerset Care	English Conference Room Sink	109 ppb
Skowhegan Area High School/Somerset Care	Green Bottle Fill Station	0 ppb
Skowhegan Area High School/Somerset Care	Green Custodian Sink	6.9 ppb
Skowhegan Area High School/Somerset Care	Green Ladies Restroom Sink On Left	2.1 ppb
Skowhegan Area High School/Somerset Care	Green Ladies Restroom Sink On Right	1.9 ppb
Skowhegan Area High School/Somerset Care	Green Mens Restroom Sink On Left	2.3 ppb
Skowhegan Area High School/Somerset Care	Green Mens Restroom Sink On Right	2.2 ppb
Skowhegan Area High School/Somerset Care	Gym Teacher Restroom Sink	3 ppb
Skowhegan Area High School/Somerset Care	Hall By Engineering Bottle Fill Station	0 ppb

School Name	Sample Location	Lead Test Result
Skowhegan Area High School/Somerset Care	Hall By Residential Bottle Fill	0 ppb
Skowhegan Area High School/Somerset Care	Health Care Sink	0 ppb
Skowhegan Area High School/Somerset Care	Hs Green 10 Sink 2nd On Right	14.9 ppb
Skowhegan Area High School/Somerset Care	Hs Green 10 Sink 3rd On Right	8.8 ppb
Skowhegan Area High School/Somerset Care	Hs Green 10 Sink 4th On Right	36.9 ppb
Skowhegan Area High School/Somerset Care	Hs Green 10 Sink 5th On Right	12.4 ppb
Skowhegan Area High School/Somerset Care	Hs Green 10 Sink 6th On Right	6.7 ppb
Skowhegan Area High School/Somerset Care	Hs Green 10 Sink 7th On Right	9 ppb
Skowhegan Area High School/Somerset Care	Hs Green 10 Sink 8th On Right	13.2 ppb
Skowhegan Area High School/Somerset Care	Hs Green 10 Sink 9th On Right	6.5 ppb
Skowhegan Area High School/Somerset Care	Hs Green 11 Sink 10th On Right	6.7 ppb
Skowhegan Area High School/Somerset Care	Hs Green 11 Sink 2nd On Right	7.5 ppb
Skowhegan Area High School/Somerset Care	Hs Green 11 Sink 3rd On Right	17.9 ppb
Skowhegan Area High School/Somerset Care	Hs Green 11 Sink 4th On Right	17.4 ppb
Skowhegan Area High School/Somerset Care	Hs Green 11 Sink 5th On Right	22.7 ppb
Skowhegan Area High School/Somerset Care	Hs Green 11 Sink 6th On Right	298 ppb
Skowhegan Area High School/Somerset Care	Hs Green 11 Sink 7th On Right	42.8 ppb
Skowhegan Area High School/Somerset Care	Hs Green 11 Sink 8th On Right	18.4 ppb
Skowhegan Area High School/Somerset Care	Hs Green 11 Sink 9th On Right	25.9 ppb
Skowhegan Area High School/Somerset Care	Hs Green 12 Sink 2nd On Right	8 ppb
Skowhegan Area High School/Somerset Care	Hs Green 12 Sink 3rd On Right	18.4 ppb
Skowhegan Area High School/Somerset Care	Hs Green 12 Sink 4th On Right	4.2 ppb
Skowhegan Area High School/Somerset Care	Hs Green 12 Sink 5th On Right	8.6 ppb
Skowhegan Area High School/Somerset Care	Hs Green 12 Sink 6th On Right	9.4 ppb
Skowhegan Area High School/Somerset Care	Hs Green 12 Sink 7th On Right	9.4 ppb
Skowhegan Area High School/Somerset Care	Hs Green 12 Sink 8th On Right	3.6 ppb
Skowhegan Area High School/Somerset Care	Hs Green 12 Sink 9th On Right	6.1 ppb
Skowhegan Area High School/Somerset Care	Hs Green 12 Sink On Right	11.2 ppb
Skowhegan Area High School/Somerset Care	Hs Green 6 Sink 10th On Right	18.1 ppb
Skowhegan Area High School/Somerset Care	Hs Green 6 Sink 2nd On Right	8.9 ppb
Skowhegan Area High School/Somerset Care	Hs Green 6 Sink 3rd On Right	14.1 ppb
Skowhegan Area High School/Somerset Care	Hs Green 6 Sink 4th On Right	26.9 ppb
Skowhegan Area High School/Somerset Care	Hs Green 6 Sink 5th On Right	21.5 ppb
Skowhegan Area High School/Somerset Care	Hs Green 6 Sink 6th On Right	56 ppb
Skowhegan Area High School/Somerset Care	Hs Green 6 Sink 7th On Right	25.2 ppb
Skowhegan Area High School/Somerset Care	Hs Green 6 Sink 8th On Right	12.9 ppb
Skowhegan Area High School/Somerset Care	Hs Green 6 Sink 9th On Right	21.7 ppb
Skowhegan Area High School/Somerset Care	Hs Green 6 Sink On Right	91.1 ppb
Skowhegan Area High School/Somerset Care	Hs Green 8 Sink 2nd On Right	9.5 ppb
Skowhegan Area High School/Somerset Care	Hs Green 8 Sink 3rd On Right	5.9 ppb
Skowhegan Area High School/Somerset Care	Hs Green 8 Sink 4th On Right	13.5 ppb
Skowhegan Area High School/Somerset Care	Hs Green 8 Sink 5th On Right	47.2 ppb
Skowhegan Area High School/Somerset Care	Hs Green 8 Sink 6th On Right	66.5 ppb
Skowhegan Area High School/Somerset Care	Hs Green 8 Sink 7th On Right	144 ppb
Skowhegan Area High School/Somerset Care	Hs Green 8 Sink 8th On Right	34.5 ppb
Skowhegan Area High School/Somerset Care	Hs Green 8 Sink 9th On Right	25 ppb
Skowhegan Area High School/Somerset Care	Hs Green 8 Sink On Right	36.6 ppb

School Name	Sample Location	Lead Test Result
Skowhegan Area High School/Somerset Care	Hs Green 9 Sink 10th On Right	26.6 ppb
Skowhegan Area High School/Somerset Care	Hs Green 9 Sink 2nd On Right	17.5 ppb
Skowhegan Area High School/Somerset Care	Hs Green 9 Sink 3rd On Right	9.6 ppb
Skowhegan Area High School/Somerset Care	Hs Green 9 Sink 4th On Right	22.3 ppb
Skowhegan Area High School/Somerset Care	Hs Green 9 Sink 5th On Right	7.4 ppb
Skowhegan Area High School/Somerset Care	Hs Green 9 Sink 6th On Right	84.6 ppb
Skowhegan Area High School/Somerset Care	Hs Green 9 Sink 7th On Right	8 ppb
Skowhegan Area High School/Somerset Care	Hs Green 9 Sink 8th On Right	8 ppb
Skowhegan Area High School/Somerset Care	Hs Green 9 Sink 9th On Right	12 ppb
Skowhegan Area High School/Somerset Care	Hs Green 9 Sink On Right	20.8 ppb
Skowhegan Area High School/Somerset Care	Industrial Arts Sink	3.5 ppb
Skowhegan Area High School/Somerset Care	Kitchen Restroom Sink	5.2 ppb
Skowhegan Area High School/Somerset Care	Kitchen Sink 2nd On Right	2.7 ppb
Skowhegan Area High School/Somerset Care	Kitchen Sink 3rd On Right	1.6 ppb
Skowhegan Area High School/Somerset Care	Kitchen Sink 4th On Right	1.6 ppb
Skowhegan Area High School/Somerset Care	Kitchen Sink 5th On Right	1.5 ppb
Skowhegan Area High School/Somerset Care	Kitchen Sink 6th On Right	1.3 ppb
Skowhegan Area High School/Somerset Care	Kitchen Sink On Right	9.2 ppb
Skowhegan Area High School/Somerset Care	Kitchen Steamer	9.5 ppb
Skowhegan Area High School/Somerset Care	Ladies Locker Fountain	0 ppb
Skowhegan Area High School/Somerset Care	Ladies Locker Sink	1.3 ppb
Skowhegan Area High School/Somerset Care	Lobby Bottle Fill Station	0 ppb
Skowhegan Area High School/Somerset Care	Lobby Custodian Sink	2 ppb
Skowhegan Area High School/Somerset Care	Lobby Ladies Room Sink Center	4.2 ppb
Skowhegan Area High School/Somerset Care	Lobby Ladies Room Sink On Left	4.6 ppb
Skowhegan Area High School/Somerset Care	Lobby Ladies Room Sink On Right	3.3 ppb
Skowhegan Area High School/Somerset Care	Lobby Mens Room Sink Center	5.2 ppb
Skowhegan Area High School/Somerset Care	Lobby Mens Room Sink On Left	4.3 ppb
Skowhegan Area High School/Somerset Care	Lobby Mens Room Sink On Right	8.3 ppb
Skowhegan Area High School/Somerset Care	Lobby Single Restroom Sink	6.7 ppb
Skowhegan Area High School/Somerset Care	Main Office Restroom 1 Sink	1.8 ppb
Skowhegan Area High School/Somerset Care	Main Office Restroom 2 Sink	1.8 ppb
Skowhegan Area High School/Somerset Care	Main Office Restroom 3 Sink	1.8 ppb
Skowhegan Area High School/Somerset Care	Math Conference Rm Sink	3.6 ppb
Skowhegan Area High School/Somerset Care	Media Center Ladies Room Sink	1.5 ppb
Skowhegan Area High School/Somerset Care	Media Center Mens Room Sink	2 ppb
Skowhegan Area High School/Somerset Care	Mens Locker Fountain	0 ppb
Skowhegan Area High School/Somerset Care	Mens Locker Sink	3.7 ppb
Skowhegan Area High School/Somerset Care	Orange Bottle Fill Station	0 ppb
Skowhegan Area High School/Somerset Care	Orange Ladies Room Sink On Left	2 ppb
Skowhegan Area High School/Somerset Care	Orange Ladies Room Sink On Right	4.8 ppb
Skowhegan Area High School/Somerset Care	Orange Mens Room Sink On Left	3.5 ppb
Skowhegan Area High School/Somerset Care	Orange Mens Room Sink On Right	7 ppb
Skowhegan Area High School/Somerset Care	Orange Restroom Sink	0 ppb
Skowhegan Area High School/Somerset Care	Outdoor Leadership Restroom Sink	1.5 ppb
Skowhegan Area High School/Somerset Care	Outdoor Leadership Sink	1.9 ppb
Skowhegan Area High School/Somerset Care	Outdoor Spicket Main Door 6th On Right	43.9 ppb

School Name	Sample Location	Lead Test Result
Skowhegan Area High School/Somerset Care	Outdoor Spicket Main Door 8th On Right	1.2 ppb
Skowhegan Area High School/Somerset Care	Purple Custodian Sink	1.3 ppb
Skowhegan Area High School/Somerset Care	Purple Mens Room Sink On Left	1.5 ppb
Skowhegan Area High School/Somerset Care	Purple Mens Room Sink On Right	1.6 ppb
Skowhegan Area High School/Somerset Care	Purple Restroom On Left Sink	1.1 ppb
Skowhegan Area High School/Somerset Care	Purple Restroom On Right Sink	1.4 ppb
Skowhegan Area High School/Somerset Care	Residential Construction Fountain	1.1 ppb
Skowhegan Area High School/Somerset Care	Sctc Custodian Sink	5 ppb
Skowhegan Area High School/Somerset Care	Social Studies Conference Room	5.9 ppb
Skowhegan Area High School/Somerset Care	Therapy Room Sink	2.3 ppb
Skowhegan Area High School/Somerset Care	Training Room Ice Machine	1.8 ppb
Skowhegan Area High School/Somerset Care	Training Room Sink On Right 1	1.2 ppb
Skowhegan Area High School/Somerset Care	Training Room Sink On Right 2	0 ppb
Skowhegan Area High School/Somerset Care	Upstairs Locker Fountain	0 ppb
Skowhegan Area High School/Somerset Care	Upstairs Locker Sink	0 ppb
Skowhegan Area High School/Somerset Care	Welding Sink	9.2 ppb
Skowhegan Area High School/Somerset Care	Wellness Center Sink	1360 ppb
Skowhegan Area High School/Somerset Care	White 3 Sink On Left	20.9 ppb
Skowhegan Area High School/Somerset Care	White 3 Sink On Right	10 ppb
Skowhegan Area High School/Somerset Care	Yellow 2 Sink	5.4 ppb
Skowhegan Area High School/Somerset Care	Yellow 5 Sink On Left	1.7 ppb
Skowhegan Area High School/Somerset Care	Yellow 5 Sink On Right	1.2 ppb
Skowhegan Area High School/Somerset Care	Yellow 6 Sink On Left	1.1 ppb
Skowhegan Area High School/Somerset Care	Yellow 6 Sink On Right	2.8 ppb
Skowhegan Area High School/Somerset Care	Yellow 7 Sink On Left	1.3 ppb
Skowhegan Area High School/Somerset Care	Yellow 7 Sink On Right	4.5 ppb
Skowhegan Area High School/Somerset Care	Yellow 9 Sink 2nd On Right	19.7 ppb
Skowhegan Area High School/Somerset Care	Yellow 9 Sink 3rd On Right	2.2 ppb
Skowhegan Area High School/Somerset Care	Yellow 9 Sink 4th On Right	4.1 ppb
Skowhegan Area High School/Somerset Care	Yellow 9 Sink On Right	1.7 ppb
Skowhegan Area High School/Somerset Care	Yellow Ladies Room Sink On Left	6 ppb
Skowhegan Area High School/Somerset Care	Yellow Ladies Room Sink On Right	5.7 ppb
Skowhegan Area High School/Somerset Care	Yellow Restroom Sink	4.2 ppb
Skowhegan Area Middle School	Cafeteria Bottle Fill On Right	0 ppb
Skowhegan Area Middle School	Custodial 187 Sink	3.3 ppb
Skowhegan Area Middle School	Custodial Closet In Kitchen	4.3 ppb
Skowhegan Area Middle School	Hall By 168 Bottle Fill Station	0 ppb
Skowhegan Area Middle School	Hall By Media Center Bottle Fill Station	0 ppb
Skowhegan Area Middle School	Ice Machine By Room 117	353 ppb
Skowhegan Area Middle School	Kitchen Restroom Sink	1.1 ppb
Skowhegan Area Middle School	Kitchen Sink 2nd On Right	2.9 ppb
Skowhegan Area Middle School	Kitchen Sink 3rd On Right	1.1 ppb
Skowhegan Area Middle School	Kitchen Sink 4th On Right	1.7 ppb
Skowhegan Area Middle School	Kitchen Sink On Right	0 ppb
Skowhegan Area Middle School	Kitchen Steamer	10.7 ppb
Skowhegan Area Middle School	Library Fountain	6.2 ppb
Skowhegan Area Middle School	Library Sink	1.7 ppb

School Name	Sample Location	Lead Test Result
Skowhegan Area Middle School	Outdoor Spicket By Main Door 3rd On Right	3.7 ppb
Skowhegan Area Middle School	Outdoor Spicket By Main Door 4th On Right	364 ppb
Skowhegan Area Middle School	Outdoor Spicket By Main Door 5th On Right	335 ppb
Skowhegan Area Middle School	Outdoor Spicket By Main Door 6th On Right	1730 ppb
Skowhegan Area Middle School	Outdoor Spicket By Main Door 7th On Right	649 ppb
Skowhegan Area Middle School	Outdoor Spicket By Main Door 8th On Right	37.5 ppb
Skowhegan Area Middle School	Restroom By Gym Ladies Sink Left	0 ppb
Skowhegan Area Middle School	Restroom By Gym Ladies Sink Right	0 ppb
Skowhegan Area Middle School	Restroom By Gym Mens Sink Left	1.4 ppb
Skowhegan Area Middle School	Restroom By Gym Mens Sink Right	2 ppb
Skowhegan Area Middle School	Room 107 Nurse Sink	1.5 ppb
Skowhegan Area Middle School	Room 109 Restroom Sink	4.2 ppb
Skowhegan Area Middle School	Room 117 Sink	2.2 ppb
Skowhegan Area Middle School	Room 119 Restroom Sink	1.2 ppb
Skowhegan Area Middle School	Room 120 Rest Room Sink	0 ppb
Skowhegan Area Middle School	Room 123 Fountain	0 ppb
Skowhegan Area Middle School	Room 123 Sink	0 ppb
Skowhegan Area Middle School	Room 125 Fountain	0 ppb
Skowhegan Area Middle School	Room 125 Sink	0 ppb
Skowhegan Area Middle School	Room 127 Fountain	0 ppb
Skowhegan Area Middle School	Room 127 Nurse Eye Wash	8.5 ppb
Skowhegan Area Middle School	Room 127 Sink	0 ppb
Skowhegan Area Middle School	Room 128 Eye Wash	16.6 ppb
Skowhegan Area Middle School	Room 129 Restroom Sink	0 ppb
Skowhegan Area Middle School	Room 130 Restroom Sink	0 ppb
Skowhegan Area Middle School	Room 131 Restroom Sink	0 ppb
Skowhegan Area Middle School	Room 132 Restroom Sink	0 ppb
Skowhegan Area Middle School	Room 135 Fountain	0 ppb
Skowhegan Area Middle School	Room 135 Sink	0 ppb
Skowhegan Area Middle School	Room 137 Fountain	0 ppb
Skowhegan Area Middle School	Room 137 Sink	4.2 ppb
Skowhegan Area Middle School	Room 140 Eye Wash	1.5 ppb
Skowhegan Area Middle School	Room 140 Sink 2nd On Right	4.3 ppb
Skowhegan Area Middle School	Room 140 Sink 3rd On Right	0 ppb
Skowhegan Area Middle School	Room 140 Sink On Right	0 ppb
Skowhegan Area Middle School	Room 143 Restroom Sink	0 ppb
Skowhegan Area Middle School	Room 144 Restroom Sink	0 ppb
Skowhegan Area Middle School	Room 145 Rest Room Sink	1.9 ppb
Skowhegan Area Middle School	Room 146 Rest Room Sink	1.2 ppb
Skowhegan Area Middle School	Room 149 Eye Wash	13.5 ppb
Skowhegan Area Middle School	Room 149 Sink 2nd On Right	21.5 ppb

School Name	Sample Location	Lead Test Result
Skowhegan Area Middle School	Room 149 Sink 3rd On Right	0 ppb
Skowhegan Area Middle School	Room 149 Sink 4th On Right	0 ppb
Skowhegan Area Middle School	Room 149 Sink On Right	0 ppb
Skowhegan Area Middle School	Room 150 Fountain	1.7 ppb
Skowhegan Area Middle School	Room 150 Sink	0 ppb
Skowhegan Area Middle School	Room 152 Fountain	1.1 ppb
Skowhegan Area Middle School	Room 152 Sink	1.3 ppb
Skowhegan Area Middle School	Room 154 Fountain	1.1 ppb
Skowhegan Area Middle School	Room 154 Sink	0 ppb
Skowhegan Area Middle School	Room 155 Rest Room Sink	2.7 ppb
Skowhegan Area Middle School	Room 156 Rest Room Sink	1.2 ppb
Skowhegan Area Middle School	Room 157 Teachers Sink	0 ppb
Skowhegan Area Middle School	Room 158 Restroom Sink	0 ppb
Skowhegan Area Middle School	Room 166 Fountain	0 ppb
Skowhegan Area Middle School	Room 166 Sink	1 ppb
Skowhegan Area Middle School	Room 168 Fountain	0 ppb
Skowhegan Area Middle School	Room 168 Sink	0 ppb
Skowhegan Area Middle School	Room 172 Sink	0 ppb
Skowhegan Area Middle School	Room 194 Fountain	0 ppb
Skowhegan Area Middle School	Room 194 Sink	4.5 ppb
Skowhegan Area Middle School	Room 198 Fountain	0 ppb
Skowhegan Area Middle School	Room 198 Sink	0 ppb
Skowhegan Area Middle School	Room 205 Fountain	1.8 ppb
Skowhegan Area Middle School	Room 205 Sink	0 ppb
Skowhegan Area Middle School	Room 207 Fountain	2 ppb
Skowhegan Area Middle School	Room 207 Sink	1.2 ppb
Skowhegan Area Middle School	Room 209 Sink	4.7 ppb
Skowhegan Area Middle School	Room 211 Restroom Sink	2 ppb
Skowhegan Area Middle School	Room 212 Restroom Sink	2.5 ppb
Skowhegan Area Middle School	Room 215 Fountain	1.5 ppb
Skowhegan Area Middle School	Room 215 Sink	0 ppb
Skowhegan Area Middle School	Room 217 Fountain	0 ppb
Skowhegan Area Middle School	Room 217 Sink	1.3 ppb
Skowhegan Area Middle School	Room 219 Fountain	0 ppb
Skowhegan Area Middle School	Room 219 Sink	0 ppb
Skowhegan Area Middle School	Room 220 Sink 2nd On Right	5.7 ppb
Skowhegan Area Middle School	Room 220 Sink 3rd On Right	4.1 ppb
Skowhegan Area Middle School	Room 220 Sink 4th On Right	5.4 ppb
Skowhegan Area Middle School	Room 220 Sink On Right	4.2 ppb
Skowhegan Area Middle School	Room 223 Restroom Sink	1.3 ppb
Skowhegan Area Middle School	Room 224 Restroom Sink	0 ppb
Skowhegan Area Middle School	Room 225 Restroom Sink	1.2 ppb
Skowhegan Area Middle School	Room 226 Restroom Sink	1.4 ppb
Skowhegan Area Middle School	Room 229 Fountain	0 ppb
Skowhegan Area Middle School	Room 229 Sink	0 ppb
Skowhegan Area Middle School	Room 231 Fountain	0 ppb
Skowhegan Area Middle School	Room 231 Sink	1.7 ppb

School Name	Sample Location	Lead Test Result
Skowhegan Area Middle School	Room 233 Fountain	0 ppb
Skowhegan Area Middle School	Room 233 Sink	0 ppb
Skowhegan Area Middle School	Room 234 Sink 4th On Right	1.6 ppb
Skowhegan Area Middle School	Room 234 Sink On Right	1 ppb
Skowhegan Area Middle School	Room 237 Restroom Sink	1.2 ppb
Skowhegan Area Middle School	Room 238 Restroom Sink	0 ppb
Skowhegan Area Middle School	Room 239 Restroom	1.9 ppb
Skowhegan Area Middle School	Room 240 Restroom	0 ppb
Skowhegan Area Middle School	Room 243 Sink 2nd On Right	2.1 ppb
Skowhegan Area Middle School	Room 243 Sink 3rd On Right	0 ppb
Skowhegan Area Middle School	Room 243 Sink 4th On Right	3.8 ppb
Skowhegan Area Middle School	Room 243 Sink On Right	1.5 ppb
Skowhegan Area Middle School	Room 244 Fountain	0 ppb
Skowhegan Area Middle School	Room 244 Sink	0 ppb
Skowhegan Area Middle School	Room 246 Fountain	0 ppb
Skowhegan Area Middle School	Room 246 Sink	5 ppb
Skowhegan Area Middle School	Room 248 Fountain	0 ppb
Skowhegan Area Middle School	Room 248 Sink	1.3 ppb
Skowhegan Area Middle School	Room 249 Restroom	2 ppb
Skowhegan Area Middle School	Room 250 Restroom	2.3 ppb
Skowhegan Area Middle School	Room 251 Sink	3.4 ppb
Skowhegan Area Middle School	Room 252 Restroom Sink	0 ppb
Skowhegan Area Middle School	Room 258 Restroom Sink	1.1 ppb
Skowhegan Area Middle School	Room 264 Sink	0 ppb
Skowhegan Area Middle School	Room 265 Fountain	1.3 ppb
Skowhegan Area Middle School	Room 265 Sink 2nd On Right	5.7 ppb
Skowhegan Area Middle School	Room 265 Sink 3rd On Right	1.9 ppb
Skowhegan Area Middle School	Room 265 Sink On Right	1.6 ppb
Skowhegan Area Middle School	Room 267 Fountain	1.1 ppb
Skowhegan Area Middle School	Room 267 Sink	0 ppb
Skowhegan Area Middle School	Somerset Bottle Fill Station	0 ppb
So Aroostook School	3-5 Teachers Room Sink	2.1 ppb
So Aroostook School	3-5 Water Fountain	1.6 ppb
So Aroostook School	Drinking Fountain Public Restrooms	4.6 ppb
So Aroostook School	Gym Water Fountain 1	10.4 ppb
So Aroostook School	Gym Water Fountain 2	1.9 ppb
So Aroostook School	High School Water Fountain	1.2 ppb
So Aroostook School	Hs Room 301 Sink 1	2 ppb
So Aroostook School	Hs Room 301 Sink 2	1.7 ppb
So Aroostook School	Hs Room 302 Bathroom Sink	1.6 ppb
So Aroostook School	Hs Room 306 Counter Top 2	4.7 ppb
So Aroostook School	Hs Room 307 Counter Top 1	25.6 ppb
So Aroostook School	Hs Room 307 Lab Sink 1	1.8 ppb
So Aroostook School	Kitchen Dish Pig Sink	11.2 ppb
So Aroostook School	Kitchen Drain Sink	2.2 ppb
So Aroostook School	Kitchen Sink Wash Rinse	5.5 ppb
So Aroostook School	Ms Drinking Fountain	0 ppb

School Name	Sample Location	Lead Test Result
So Aroostook School	Ms Teachers Room Br Sink	7.8 ppb
So Aroostook School	Prek-2 Teachers Room Sink	1.9 ppb
So Aroostook School	Prek-2 Water Fountain	0 ppb
Solon Elementary School	Front Entrance Water Fountain	0 ppb
Solon Elementary School	Hand Sink By Oven	5.2 ppb
Solon Elementary School	Kindergarten Water Fountain	6.3 ppb
Solon Elementary School	Kitchen Sink By Dishwasher	0 ppb
Solon Elementary School	Title I Water Fountain	26 ppb
Solon Elementary School	Water Fountain 3rd Grade	9.2 ppb
Solon Elementary School	Water Fountain 4th Grade	7.5 ppb
Solon Elementary School	Water Fountain Music Room	1.9 ppb
Somerset Elementary School	100 Fountain Down	0 ppb
Somerset Elementary School	100 Hallway Sink	3.2 ppb
Somerset Elementary School	100 Lobby Bottle Filler	0 ppb
Somerset Elementary School	100 Lobby Fountain Up	0 ppb
Somerset Elementary School	102 Fountain	1.2 ppb
Somerset Elementary School	102 Sink	0 ppb
Somerset Elementary School	103 Sink	0 ppb
Somerset Elementary School	104 Sink	0 ppb
Somerset Elementary School	105 Sink	0 ppb
Somerset Elementary School	107 Sink	1.1 ppb
Somerset Elementary School	108 Sink	0 ppb
Somerset Elementary School	111 Fountain	1.7 ppb
Somerset Elementary School	111 Sink	1.4 ppb
Somerset Elementary School	112 Sink	0 ppb
Somerset Elementary School	113 Fountain	6.9 ppb
Somerset Elementary School	113 Sink	2.6 ppb
Somerset Elementary School	114 Fountain	2 ppb
Somerset Elementary School	114 Sink	2 ppb
Somerset Elementary School	115 Fountain	2.8 ppb
Somerset Elementary School	115 Sink	2.3 ppb
Somerset Elementary School	116 Sink	0 ppb
Somerset Elementary School	117 Sink	1.4 ppb
Somerset Elementary School	120 Sink	0 ppb
Somerset Elementary School	121 Sink	0 ppb
Somerset Elementary School	122 Fountain Down	7.7 ppb
Somerset Elementary School	122 Fountain Up	7.5 ppb
Somerset Elementary School	122 Sink	0 ppb
Somerset Elementary School	123 Fountain Down	3 ppb
Somerset Elementary School	123 Sink	1.3 ppb
Somerset Elementary School	124 Fountain	3 ppb
Somerset Elementary School	124 Sink	3 ppb
Somerset Elementary School	125 Fountain	3.3 ppb
Somerset Elementary School	125 Sink	2.3 ppb
Somerset Elementary School	126 Fountain	2 ppb
Somerset Elementary School	126 Sink	1.2 ppb
Somerset Elementary School	127 Fountain	2.1 ppb

School Name	Sample Location	Lead Test Result
Somerset Elementary School	127 Sink	0 ppb
Somerset Elementary School	129 Sink	2.3 ppb
Somerset Elementary School	131 Fountain	6.3 ppb
Somerset Elementary School	131 Sink	6.7 ppb
Somerset Elementary School	133 Hand Sink	17.1 ppb
Somerset Elementary School	134 Sink Left	1.9 ppb
Somerset Elementary School	134 Sink Right	0 ppb
Somerset Elementary School	135 Sink Left	0 ppb
Somerset Elementary School	135 Sink Right	1.4 ppb
Somerset Elementary School	139 Sink Left	0 ppb
Somerset Elementary School	139 Sink Right	3 ppb
Somerset Elementary School	140 Sink Left	0 ppb
Somerset Elementary School	140 Sink Right	1.1 ppb
Somerset Elementary School	143 Sink	2.8 ppb
Somerset Elementary School	145 Hand Sink At Dishwasher	179 ppb
Somerset Elementary School	145 Hand Sink Delivery Ent	24.9 ppb
Somerset Elementary School	145 Pan Wash Left	5.7 ppb
Somerset Elementary School	145 Pan Wash Right	84.3 ppb
Somerset Elementary School	145 Prep Sink	5.1 ppb
Somerset Elementary School	202 Fountain	1.5 ppb
Somerset Elementary School	202 Sink	2.2 ppb
Somerset Elementary School	205 Sink	1.2 ppb
Somerset Elementary School	206 Sink	0 ppb
Somerset Elementary School	208 Fountain	2.1 ppb
Somerset Elementary School	208 Sink	2.4 ppb
Somerset Elementary School	209 Fountain	1.3 ppb
Somerset Elementary School	209 Sink	1.7 ppb
Somerset Elementary School	210 Fountain	1.2 ppb
Somerset Elementary School	210 Sink	1.4 ppb
Somerset Elementary School	211 Fountain	1.3 ppb
Somerset Elementary School	211 Sink	1.3 ppb
Somerset Elementary School	212 Left Fountain	1.7 ppb
Somerset Elementary School	212 Left Sink	1.4 ppb
Somerset Elementary School	212 Middle Sink	22.8 ppb
Somerset Elementary School	212 Right Sink	55.2 ppb
Somerset Elementary School	214 Fountain	1.1 ppb
Somerset Elementary School	214 Sink	5.8 ppb
Somerset Elementary School	215 Sink	0 ppb
Somerset Elementary School	216 Sink	0 ppb
Somerset Elementary School	218 Sink	1.5 ppb
Somerset Elementary School	219 Sink	0 ppb
Somerset Elementary School	220 Fountain Down	0 ppb
Somerset Elementary School	220 Fountain Up	0 ppb
Somerset Elementary School	220 Sink	0 ppb
Somerset Elementary School	221 Fountain Down	0 ppb
Somerset Elementary School	221 Fountain Up	0 ppb
Somerset Elementary School	221 Sink	0 ppb

School Name	Sample Location	Lead Test Result
Somerset Elementary School	222 Fountain	1.5 ppb
Somerset Elementary School	222 Sink	1.7 ppb
Somerset Elementary School	223 Sink Middle	1.6 ppb
Somerset Elementary School	223 Sink Right	1.1 ppb
Somerset Elementary School	225 Sink	13.7 ppb
Somerset Elementary School	226 Fountain	2.1 ppb
Somerset Elementary School	226 Sink	1.3 ppb
Somerset Elementary School	233 Sink	3 ppb
Somerset Elementary School	233 Sink Left	1.1 ppb
Somerset Elementary School	233 Sink Middle	4.7 ppb
Somerset Elementary School	233 Sink Right	3.1 ppb
Somerville Elementary School	Break Room Ro Water Dispenser	0 ppb
Somerville Elementary School	Kitchen Sink	7.2 ppb
Somerville Elementary School	Main Lobby Water Fountain	9.5 ppb
Somerville Elementary School	Rm #5 Pre-k Office Ro Water Dispenser	0 ppb
Somerville Elementary School	Rm #6 Pre-k Sink #1	1.9 ppb
Somerville Elementary School	Rm #6 Pre-k Sink #2	5 ppb
Songo Locks School	Art Rm Sink/bubbler # A	3.6 ppb
Songo Locks School	Art Rm Sink/bubbler # B	2.9 ppb
Songo Locks School	Art Rm Sink/bubbler # C	0 ppb
Songo Locks School	Bottle Fill By Adult Br 1st Floor Hallway	0 ppb
Songo Locks School	Cafe Bottle Fill Dwf	0 ppb
Songo Locks School	Cafe Kitchette Sink	1.8 ppb
Songo Locks School	Conference Rm Sink/bubbler	31.8 ppb
Songo Locks School	Gym Hallway Bottle Fill	0 ppb
Songo Locks School	Gym Hallway Dwf	0 ppb
Songo Locks School	Hallway 2nd Floor Bottle Fill Dwf	0 ppb
Songo Locks School	Hallway Portable By Rm # 26 Sink # A	0 ppb
Songo Locks School	Hallway Portable By Rm # 26 Sink # B	0 ppb
Songo Locks School	Hallway Portable By Rm # 26 Sink Dwf	0 ppb
Songo Locks School	Library Office Sink	5.4 ppb
Songo Locks School	Main Kitchen Hand Sink	5.1 ppb
Songo Locks School	Main Kitchen Kettle	46.4 ppb
Songo Locks School	Main Kitchen Single Sink	6.7 ppb
Songo Locks School	Main Kitchen Three Bay Sink # A	1.9 ppb
Songo Locks School	Main Kitchen Three Bay Sink # B	4.4 ppb
Songo Locks School	Music Rm Sink/bubbler	4.6 ppb
Songo Locks School	Nurse Bubbler	5.2 ppb
Songo Locks School	Nurse Ice Machine	0 ppb
Songo Locks School	Nurse Sink	1 ppb
Songo Locks School	Project Rm Sink/bubbler	6.8 ppb
Songo Locks School	Rm # 1 Sink/bubbler	1.9 ppb
Songo Locks School	Rm # 10/12 Sink/bubbler # A	1.3 ppb
Songo Locks School	Rm # 10/12 Sink/bubbler # B	1.1 ppb
Songo Locks School	Rm # 11 Sink/bubbler	16.3 ppb
Songo Locks School	Rm # 13 Sink/bubbler	1.4 ppb
Songo Locks School	Rm # 14 Sink/bubbler	1.4 ppb

School Name	Sample Location	Lead Test Result
Songo Locks School	Rm # 15 Sink/bubbler	1.3 ppb
Songo Locks School	Rm # 16 Sink/bubbler	1.9 ppb
Songo Locks School	Rm # 17 Sink/bubbler	1.4 ppb
Songo Locks School	Rm # 18 Sink/bubbler	2.3 ppb
Songo Locks School	Rm # 19 Sink/bubbler	3.6 ppb
Songo Locks School	Rm # 20 Sink/bubbler	1.5 ppb
Songo Locks School	Rm # 21 Sink/bubbler	3.6 ppb
Songo Locks School	Rm # 22 Sink/bubbler	2.9 ppb
Songo Locks School	Rm # 23 Sink/bubbler	3.2 ppb
Songo Locks School	Rm # 4 Sink/bubbler	1.2 ppb
Songo Locks School	Rm # 5 Sink/bubbler	1.7 ppb
Songo Locks School	Rm # 6 Sink/bubbler	1.5 ppb
Songo Locks School	Rm # 7 Sink/bubbler	5.8 ppb
Songo Locks School	Rm # 8 Sink/bubbler	1.2 ppb
Songo Locks School	Rm # 9 Sink/bubbler	0 ppb
Songo Locks School	Rm F Sink/bubbler	0 ppb
Songo Locks School	Rm H Sink/bubbler	2 ppb
Songo Locks School	Rm# 3 Sink/bubbler	0 ppb
Songo Locks School	Teachers Room Sink/bubbler	23 ppb
Songo Locks School	Teachers Work Rm Sink	0 ppb
South Bristol Elementary School	Boys Bathroom- Front Entrance To Left	1.3 ppb
South Bristol Elementary School	Boys Locker Room A	1.4 ppb
South Bristol Elementary School	Boys Locker Room B	2.6 ppb
South Bristol Elementary School	Double Basin Large Wash Sink-a	1.4 ppb
South Bristol Elementary School	Double Basin Large Wash Sink-b	1.7 ppb
South Bristol Elementary School	Front Entry Spigot- Left Of Entrance	589 ppb
South Bristol Elementary School	Girls Bathroom- Front Entrance To Left	2 ppb
South Bristol Elementary School	Girls Locker Room A	2.7 ppb
South Bristol Elementary School	Girls Locker Room B	1.4 ppb
South Bristol Elementary School	Girls Locker Room C	2.4 ppb
South Bristol Elementary School	Gym Fountain/ Bottle Fill	0 ppb
South Bristol Elementary School	Kitchen Hand Sink-a	24.2 ppb
South Bristol Elementary School	Kitchen Prep Sink-a	5.1 ppb
South Bristol Elementary School	Kitchen Spray-a	7.9 ppb
South Bristol Elementary School	Media (learning) Center Fountain/ Bottle Fill	0 ppb
South Bristol Elementary School	Nurses Bathroom	7.9 ppb
South Bristol Elementary School	Room 10	2.3 ppb
South Bristol Elementary School	Room 17 (art)	1 ppb
South Bristol Elementary School	Room 26	7.9 ppb
South Bristol Elementary School	Room 27	7.6 ppb
South Bristol Elementary School	Room 7	4.3 ppb
South Bristol Elementary School	Room 8	5.7 ppb
South Bristol Elementary School	Salty's Restroom- Portable Building	4.4 ppb
South Bristol Elementary School	Teachers Bathroom	3.3 ppb
South Bristol Elementary School	Teachers Kitchen	2 ppb
South Portland High School	1st Flr..conference Room..main Off.	0 ppb

School Name	Sample Location	Lead Test Result
South Portland High School	1st Flr..main Office Kitchen	0 ppb
South Portland High School	1st Flr...main Off...conf Rm 126	0 ppb
South Portland High School	1st Flr-rear Gym	0 ppb
South Portland High School	1st Flr-rear Gym	0 ppb
South Portland High School	2nd Flr..room 221	0 ppb
South Portland High School	2nd Flr..room 250 Food Prep Sink	0 ppb
South Portland High School	2nd Flr..teacher Break Room	0 ppb
South Portland High School	2nd Flr....opposite Guidance	0 ppb
South Portland High School	2nd Flr...next To Chorus Room	0 ppb
South Portland High School	2nd Flr...room 265..life Skills Kitchen	0 ppb
South Portland High School	2nd Flr...top Of Center Stairs	0 ppb
South Portland High School	2nd Flr à opposite Guidance	0 ppb
South Portland High School	2nd Flr à next To Chorus Room	0 ppb
South Portland High School	2nd Flr à top Of Center Stairs	0 ppb
South Portland High School	3rd Flr..room 323	0 ppb
South Portland High School	3rd Flr...bottle Fill Station @ Top Of Stairs	0 ppb
South Portland High School	3rd Flr...teachers Break Room	0 ppb
South Portland High School	3rd Flr à bottle Fill Station @ Top Of Stairs	0 ppb
South Portland High School	Aud Lobby Restrooms...1st Flr	0 ppb
South Portland High School	Aud Lobby Restrooms à 1st Flr	0 ppb
South Portland High School	Cafeteria..1st Flr	0 ppb
South Portland High School	Concession Area...gym...1st Flr	0 ppb
South Portland High School	Entry To Restrooms Near Rm 169...1st Flr	0 ppb
South Portland High School	Entry To Restrooms Near Rm 169 à 1st Flr	0 ppb
South Portland High School	Ground Flr-locker Room-opp Trainer Rm	0 ppb
South Portland High School	Ground Flr-locker Room-opp Trainer Rm	0 ppb
South Portland High School	Kitchen ...1st Flr...sink 1	0 ppb
South Portland High School	Kitchen..ice Machine..1st Flr	0 ppb
South Portland High School	Kitchen....1st Fl...sink 2	0 ppb
South Portland High School	Next To Lecture Hall...1st Flr	0 ppb
South Portland High School	Next To Lecture Hall à 1st Flr	0 ppb
South Portland High School	Opposite Art Rooms..1st Flr	0 ppb
South Portland High School	Opposite Art Rooms..1st Flr	0 ppb
South School	Art Room Bathroom Sink	0 ppb
South School	Bathroom Sink Room 3	0 ppb
South School	Bathroom Sink Room 44	45 ppb
South School	Botte Fill Station By Girls Bathroom	0 ppb
South School	Bottle Fill Station 5 Grade Wing	0 ppb
South School	Bottle Fill Station By Office	0 ppb
South School	Bottle Fill Station Gym	0 ppb
South School	Bottle Fill Station K Wing	0 ppb
South School	Bottle Fill Station Outside Room 32	0 ppb
South School	Boys Bathroom Far Left Sink 2nd Grade Wing	0 ppb
South School	Boys Bathroom Far Left Sink 5th Grade Wing	0 ppb

School Name	Sample Location	Lead Test Result
South School	Boys Bathroom Far Right Sink 2nd Grade Wing	0 ppb
South School	Boys Bathroom Far Right Sink 5th Grade Wing	0 ppb
South School	Boys Bathroom Left Sink Near Office	2 ppb
South School	Boys Bathroom Right Sink Near Office	0 ppb
South School	Girls Bathroom Far Left Sink 2nd Grade Wing	0 ppb
South School	Girls Bathroom Far Left Sink 5th Grade Wing	0 ppb
South School	Girls Bathroom Far Right Sink 2nd Grade Wing	0 ppb
South School	Girls Bathroom Far Right Sink 5th Grade Wing	0 ppb
South School	Girls Bathroom Left Sink Near Office	0 ppb
South School	Girls Bathroom Right Sink Near Office	1 ppb
South School	Gym Fountain	1 ppb
South School	Kitchen Bathroom Sink	0 ppb
South School	Kitchen Dish Room Sink	0 ppb
South School	Kitchen Hand Wash Sink By Freezer	31 ppb
South School	Kitchen Sprayer Dishroom	2 ppb
South School	Kitchen Work Area Sink	1 ppb
South School	Kitchen Work Area Sink By Freezer	0 ppb
South School	Library Office Sink	0 ppb
South School	Locker Room Sink Room 51	0 ppb
South School	Necc Bathroom Sink Main St	0 ppb
South School	Nurses Office Sink In Main Office	1 ppb
South School	Nurses Station Bathroom Sink	0 ppb
South School	Nurses Station Sink	0 ppb
South School	Room 47 Sink #1	0 ppb
South School	Room 47 Sink #2	0 ppb
South School	Room 52 Sink	0 ppb
South School	Room 53 Sink	1 ppb
South School	Sink #1 Staff Bathroom Room 54	0 ppb
South School	Sink #2 Staff Bathroom Room 55	0 ppb
South School	Sink 1 Room 25 By Window	1 ppb
South School	Sink 2 Room 25 By Wall	0 ppb
South School	Sink Boys Bathroom By Room 48b	0 ppb
South School	Sink Boys Bathroom Far Left By Mp Room	0 ppb
South School	Sink Boys Bathroom Far Left K Wing	0 ppb
South School	Sink Boys Bathroom Far Right By Mp Room	2 ppb
South School	Sink Boys Bathroom Far Right K Wing	0 ppb
South School	Sink Girls Bathroom By Room 48b	0 ppb
South School	Sink Girls Bathroom Far Left Near Room 23	1 ppb
South School	Sink Girls Bathroom Far Right Near Room 23	0 ppb
South School	Sink Girs Bathroom Far Left K Wing	0 ppb

School Name	Sample Location	Lead Test Result
South School	Sink Girs Bathroom Far Right K Wing	0 ppb
South School	Sink Room 11 K Wing	0 ppb
South School	Sink Room 12 K Wing	0 ppb
South School	Sink Room 13 K Wing	0 ppb
South School	Sink Room 14 K Wing	1 ppb
South School	Sink Room 15 K Wing	0 ppb
South School	Sink Room 16 K Wing	0 ppb
South School	Sink Room 24	0 ppb
South School	Sink Room 25	2 ppb
South School	Sink Room 26	2 ppb
South School	Sink Room 27	0 ppb
South School	Sink Room 3	1 ppb
South School	Sink Room 44	0 ppb
South School	Staff Bathroom Next To Elevator	0 ppb
South School	Staff Bathroom Sink By Staff Room	0 ppb
South School	Staff Bathroom Sink In Office	1 ppb
South School	Staff Bathroom Sink Main St	0 ppb
South School	Staff Room Sink By Office	0 ppb
South School	Staff Room Sink Room 15	0 ppb
Southport Central School	Basement Floor Kitchen Sink 3/bay	5.3 ppb
Special Services MSAD 75	10 Kitchen Sink	1.1 ppb
Special Services MSAD 75	13 Water Cooler	0 ppb
Special Services MSAD 75	19 Kitchen Sink	4.2 ppb
Special Services MSAD 75	25 Kitchen Sink	1.8 ppb
Special Services MSAD 75	27 Kitchen Sink	24 ppb
Special Services MSAD 75	28 Kitchen Sink	2 ppb
Special Services MSAD 75	30 Kitchen Sink	2.4 ppb
Special Services MSAD 75	5 Kitchen Sink	0 ppb
Spring Harbor Academy	F110 - Cafe Main Dining Rm	0 ppb
Spring Harbor Academy	F125 - Cafeteria Serving Area	0 ppb
Spring Harbor Academy	F201 - Academy Art Rm	0 ppb
Spring Harbor Academy	F208 - Gym Observation Rm	0 ppb
Spruce Mountain Adult Education	Adult Ed Kitchen Double Sink	1.4 ppb
Spruce Mountain Adult Education	Bottle Filler Station By Custodian Closet	1.5 ppb
Spruce Mountain Adult Education	Staffs Kitchen Sink	0 ppb
Spruce Mountain Elementary School	Art Room Sink	543 ppb
Spruce Mountain Elementary School	Bottle Filler Station	0 ppb
Spruce Mountain Elementary School	Kitchen Dish Washer	2 ppb
Spruce Mountain Elementary School	Kitchen Eye Wash And Sink	0 ppb
Spruce Mountain Elementary School	Kitchen Hand Wash Sink	0 ppb
Spruce Mountain Elementary School	Kitchen Rinse Sink	0 ppb
Spruce Mountain Elementary School	Kitchen Triple Basin Sink	0 ppb
Spruce Mountain Elementary School	Room 10 Sink	2 ppb
Spruce Mountain Elementary School	Room 11 Fountain And Sink	4.4 ppb
Spruce Mountain Elementary School	Room 23 Fountain And Sink	9 ppb
Spruce Mountain Elementary School	Room 24 Fountain And Sink	3.6 ppb
Spruce Mountain Elementary School	Room 26 Fountain And Sink	9.2 ppb

School Name	Sample Location	Lead Test Result
Spruce Mountain Elementary School	Room 28 Sink	5.1 ppb
Spruce Mountain Elementary School	Room 30 Fountain And Sink	6.3 ppb
Spruce Mountain Elementary School	Room 4 Nurses Office Sink	51.9 ppb
Spruce Mountain Elementary School	Room 5 Fountain And Sink	3.3 ppb
Spruce Mountain Elementary School	Room 8 Fountain And Sink	4.8 ppb
Spruce Mountain Elementary School	Room 9 Fountain And Sink	2.4 ppb
Spruce Mountain Elementary School	Room25 Fountain And Sink	8.1 ppb
Spruce Mountain Elementary School	Teachers Lounge Sink	3.3 ppb
Spruce Mountain High School	Bottle Filler Station	0 ppb
Spruce Mountain High School	Bottle Filler Station By Door # 13	0 ppb
Spruce Mountain High School	Bottle Filler Station In Cafeteria	0 ppb
Spruce Mountain High School	Bottle Foller Station On Second Floor	0 ppb
Spruce Mountain High School	Kitchen Faucet Over Mixer A	19.2 ppb
Spruce Mountain High School	Kitchen Faucet Over Mixer B	222 ppb
Spruce Mountain High School	Kitchen Ice Machine	4.2 ppb
Spruce Mountain High School	Kitchen Sink By Clock	1.4 ppb
Spruce Mountain High School	Kitchen Steamer	2.5 ppb
Spruce Mountain High School	Kitchen Triple Basin Sink A	1.2 ppb
Spruce Mountain High School	Kitchen Triple Basin Sink B	4.6 ppb
Spruce Mountain High School	Room 105 Eye Wash And Sink	1.9 ppb
Spruce Mountain High School	Room 106 Sink By Air Vent	1 ppb
Spruce Mountain High School	Room 110 Eyewash And Sink	2.1 ppb
Spruce Mountain High School	Room 111 Eyewash And Sink	2.3 ppb
Spruce Mountain High School	Room 207 Sink	3.3 ppb
Spruce Mountain High School	Room106 Sink By Dishwasher	2.6 ppb
Spruce Mountain Middle School	Bottle Filler Station	0 ppb
Spruce Mountain Middle School	Bottle Filler Station By Gym	0 ppb
Spruce Mountain Middle School	Bottle Filler Station By Room 16	0 ppb
Spruce Mountain Middle School	Ice Machine In Old Bakery	1 ppb
Spruce Mountain Middle School	Kitchen Dish Rinse Sink	3.1 ppb
Spruce Mountain Middle School	Kitchen Food Rinse Sink	1.9 ppb
Spruce Mountain Middle School	Kitchen Triple Basin Sink	5.1 ppb
Spruce Mountain Middle School	Old Bakery Sink A	0 ppb
Spruce Mountain Middle School	Old Bakery Sink B	0 ppb
Spruce Mountain Middle School	Room 145 Sink	1.6 ppb
Spruce Mountain Middle School	Room 161 Sink	1.1 ppb
Spruce Mountain Middle School	Room 162 Sink	1.5 ppb
Spruce Mountain Middle School	Room 164 Sink	3 ppb
Spruce Mountain Middle School	Room 177 Sink 1	0 ppb
Spruce Mountain Middle School	Room 177 Sink 2	0 ppb
Spruce Mountain Middle School	Room 177 Sink 3	1.3 ppb
Spruce Mountain Middle School	Room 177 Sink 4	2 ppb
Spruce Mountain Middle School	Room 177 Sink 6	2.1 ppb
Spruce Mountain Middle School	Room 177 Sink5	0 ppb
Spruce Mountain Middle School	Room 180 Sink A	0 ppb
Spruce Mountain Middle School	Room 180 Sink B	0 ppb
Spruce Mountain Middle School	Room 180 Sink C	0 ppb

School Name	Sample Location	Lead Test Result
Spruce Mountain Middle School	Room 180 Sink D	0 ppb
Spruce Mountain Middle School	Room 182 Sink F	1.6 ppb
Spruce Mountain Middle School	Room 182 Sink G	1.6 ppb
Spruce Mountain Middle School	Room 206 Sinc D Science Lab	2 ppb
Spruce Mountain Middle School	Room 206 Sink A Science Lab	0 ppb
Spruce Mountain Middle School	Room 206 Sink B Science Lab	0 ppb
Spruce Mountain Middle School	Room 206 Sink C Science Lab	1.7 ppb
Spruce Mountain Middle School	Room 206 Sink E Science Lab	0 ppb
Spruce Mountain Middle School	Room 206 Sink F Science Lab	1.3 ppb
Spruce Mountain Middle School	Room 206 Sink G Science Lab	1.4 ppb
Spruce Mountain Middle School	Room 212 Sinc 4 Science Lab	0 ppb
Spruce Mountain Middle School	Room 212 Sink 1 Science Lab	0 ppb
Spruce Mountain Middle School	Room 212 Sink 2 Science Lab	0 ppb
Spruce Mountain Middle School	Room 212 Sink 3 Science Lab	2.3 ppb
Spruce Mountain Middle School	Room 212 Sink 5 Science Lab	0 ppb
Spruce Mountain Middle School	Room 212 Sink 6 Science Lab	2 ppb
Spruce Mountain Middle School	Room 212 Sink 7 Science Lab	1.9 ppb
Spruce Mountain Middle School	Room 217 Teachers Lounge Sink	0 ppb
Spruce Mountain Middle School	Room 250 Sink In Life Skills Room	0 ppb
Spruce Mountain Middle School	Room241 Double Basin Sink In Art Room	1.1 ppb
Spruce Mountain Middle School	Safety Zone Room Sink	0 ppb
Spruce Mountain Primary School	Bottle Filler Station 2nd Floor	0 ppb
Spruce Mountain Primary School	Bottle Filler Station Across From Room 8	0 ppb
Spruce Mountain Primary School	Bottle Filler Station In Old Section	0 ppb
Spruce Mountain Primary School	Kitchen Dish Wash & Rinse	18.9 ppb
Spruce Mountain Primary School	Kitchen Eye Wash Station And Sink	1.2 ppb
Spruce Mountain Primary School	Kitchen Hand Wash	1.3 ppb
Spruce Mountain Primary School	Kitchen Triple Basin Sink	6.5 ppb
Spruce Mountain Primary School	Nurses Office Sink	0 ppb
Spruce Mountain Primary School	Room 1 Fountain And Sink	0 ppb
Spruce Mountain Primary School	Room 10 Fountain And Sink	0 ppb
Spruce Mountain Primary School	Room 2 Fountain And Sink	0 ppb
Spruce Mountain Primary School	Room 3 Fountain And Sink	0 ppb
Spruce Mountain Primary School	Room 31 Sink	0 ppb
Spruce Mountain Primary School	Room 4 Art Room Sink	1.3 ppb
Spruce Mountain Primary School	Room 5 Fountain And Sink	0 ppb
Spruce Mountain Primary School	Room 6 Fountain And Sink	0 ppb
Spruce Mountain Primary School	Room 8 Fountain And Sink	0 ppb
Spruce Mountain Primary School	Room 9 Fountain And Sink	0 ppb
Spruce Mountain Primary School	Teachers Lounge Sink	0 ppb
Spurwink Therapeutic Preschool	Lower Level Bathroom (near Classroom 5)	0 ppb
Spurwink Therapeutic Preschool	Lower Level Christian Education Office	0 ppb
Spurwink Therapeutic Preschool	Lower Level Classroom 1	0 ppb
Spurwink Therapeutic Preschool	Lower Level Classroom 2	0 ppb
Spurwink Therapeutic Preschool	Lower Level Classroom 3	0 ppb
Spurwink Therapeutic Preschool	Lower Level Classroom 4	0 ppb
Spurwink Therapeutic Preschool	Lower Level Classroom 5	0 ppb

School Name	Sample Location	Lead Test Result
Spurwink Therapeutic Preschool	Lower Level Classroom 7	0 ppb
Spurwink Therapeutic Preschool	Lower Level Classroom 8	0 ppb
Spurwink Therapeutic Preschool	Lower Level Female Bathroom A	0 ppb
Spurwink Therapeutic Preschool	Lower Level Female Bathroom B	1.2 ppb
Spurwink Therapeutic Preschool	Lower Level Male Bathroom A	0 ppb
Spurwink Therapeutic Preschool	Lower Level Male Bathroom B	0 ppb
Spurwink Therapeutic Preschool	Lower Level Nursery	0 ppb
Spurwink Therapeutic Preschool	Lower Level Youth Room	0 ppb
Spurwink-Chelsea	Mens Bathroom Near Staff Kitchen	0 ppb
Spurwink-Chelsea	Staff Kitchen- Small Kitchen	0 ppb
Spurwink-Chelsea	The Student Kitchen (large Kitchen)	0 ppb
Spurwink-Chelsea	Unit A 2nd Classroom On Fountain	0 ppb
Spurwink-Chelsea	Unit A 2nd Classroom On The Left- Sink	0 ppb
Spurwink-Chelsea	Unit A 3rd Classroom On Fountain	0 ppb
Spurwink-Chelsea	Unit A 3rd Classroom On The Left- Sink	1.4 ppb
Spurwink-Chelsea	Unit A-farthest From Driveway 1st Bathroom R Sink	0 ppb
Spurwink-Chelsea	Unit A-farthest From Driveway 2nd Bathroom R Sink	0 ppb
Spurwink-Chelsea	Unit B 2nd Bathroom On Right Sink	0 ppb
Spurwink-Chelsea	Unit B 2nd Classroom On Fountain	0 ppb
Spurwink-Chelsea	Unit B 3rd Classroom On Fountain	0 ppb
Spurwink-Chelsea	Unit B 3rd Classroom On The Left- Sink	0 ppb
Spurwink-Chelsea	Unit B-nearest Driveway 1st Bathroom R Shower	0 ppb
Spurwink-Chelsea	Unit B-nearest Driveway 1st Bathroom R Sink	0 ppb
Spurwink-Chelsea	Womens Bathroom Near Staff Kitchen	0 ppb
Spurwink-Lewiston/Auburn	1st Floor Mens Bathroom A Rm 105	1.4 ppb
Spurwink-Lewiston/Auburn	1st Floor Mens Bathroom B Rm 105	0 ppb
Spurwink-Lewiston/Auburn	1st Floor Womens Bathroom A Rm 107	0 ppb
Spurwink-Lewiston/Auburn	1st Floor Womens Bathroom B Rm 107	0 ppb
Spurwink-Lewiston/Auburn	2rd Floor Bathroom Sink- Top Of Stairs Rm Bs-2	1.4 ppb
Spurwink-Lewiston/Auburn	Basement Bathroom Sink 1	7.7 ppb
Spurwink-Lewiston/Auburn	Basement Bathroom Sink 2	8.1 ppb
Spurwink-Lewiston/Auburn	Basement Kitchen Hand Sink	4.5 ppb
Spurwink-Lewiston/Auburn	Basement Kitchen Sink	2.1 ppb
St Brigid School	Basement Art Room Laundry Sink	4.8 ppb
St Brigid School	Boys Bathroom Laundry Sink	0 ppb
St Brigid School	Boys Bathroom Sink #1	0 ppb
St Brigid School	Boys Bathroom Sink #2	0 ppb
St Brigid School	Boys Bathroom Sink #3	0 ppb
St Brigid School	Boys Bathroom Sink #4	1 ppb
St Brigid School	Frh -boys Bathroom #1 Sink	3.4 ppb
St Brigid School	Frh -boys Bathroom #2 Sink	1.3 ppb
St Brigid School	Frh -girls Bathroom #1 Sink	1.9 ppb

School Name	Sample Location	Lead Test Result
St Brigid School	Frh -girls Bathroom #2 Sink	1.1 ppb
St Brigid School	Frh -hall By Boys Bathroom #2	53.7 ppb
St Brigid School	Frh -kitchen Sink #1	20.8 ppb
St Brigid School	Frh -kitchen Sink #2	5.4 ppb
St Brigid School	Frh -lobby	0 ppb
St Brigid School	Frh -lobby Boys Bathroom Sink #1	0 ppb
St Brigid School	Frh -lobby Boys Bathroom Sink #2	1 ppb
St Brigid School	Frh -lobby Girls Bathroom Sink #2	5.6 ppb
St Brigid School	Frh -lobby Girls Bathroom Sink #1	0 ppb
St Brigid School	Girls Bathroom Sink #1	0 ppb
St Brigid School	Girls Bathroom Sink #2	0 ppb
St Brigid School	Girls Bathroom Sink #3	0 ppb
St Brigid School	Girls Bathroom Sink #4	0 ppb
St Brigid School	Girls Bathroom Sink #5	0 ppb
St Brigid School	Girls Bathroom Sink #6	0 ppb
St Brigid School	Hall Outside Boys Bathroom	0 ppb
St Brigid School	Kindergarten Hall	0 ppb
St Brigid School	Middle School Hall	0 ppb
St Brigid School	Pre -k Bathroom	4 ppb
St Brigid School	Pre -k Hall	0 ppb
St Brigid School	Staff Bathroom	0 ppb
St Croix Regional Technical Center	Bottle Fill Station	0 ppb
St Croix Regional Technical Center	Culinary Kitchen Single Bay Sink	2.6 ppb
St Croix Regional Technical Center	Drinking Water Fountain	0 ppb
St Dominic Academy-Auburn	1st Floor Academic	0 ppb
St Dominic Academy-Auburn	1st Floor Hallway - Left	0 ppb
St Dominic Academy-Auburn	1st Floor Hallway - Right	0 ppb
St Dominic Academy-Auburn	2nd Floor Academic	0 ppb
St Dominic Academy-Auburn	Gym - Left	0 ppb
St Dominic Academy-Auburn	Gym - Right	0 ppb
St Dominic Academy-Auburn	Kitchen	4.7 ppb
St Dominic Academy-Auburn	Trainer's Room	2.9 ppb
St Dominic Academy-Lewiston	1st Floor Left	2.3 ppb
St Dominic Academy-Lewiston	1st Floor Right	2.2 ppb
St Dominic Academy-Lewiston	Church - Kitchen Left	10.4 ppb
St Dominic Academy-Lewiston	Church - Kitchen Right	11.4 ppb
St Dominic Academy-Lewiston	Top Floor	0 ppb
St George School	Art Room Left Sink South Wall	11.2 ppb
St George School	Art Room Sink North Wall	2.1 ppb
St George School	Art Room Sink South Wall	3 ppb
St George School	Art Room Utility Sink	5.1 ppb
St George School	Bottle Fill Station Middle Level	0 ppb
St George School	Boys Bathroom Left Faucet Main Hall	1.4 ppb
St George School	Boys Bathroom Sink Second Floor	0 ppb
St George School	Boys Right Faucet Main Hall	1.4 ppb
St George School	Drinking Fountain Middle Level	0 ppb
St George School	Girls Bathroom Left Faucet Main Hall	0 ppb

School Name	Sample Location	Lead Test Result
St George School	Girls Bathroom Right Faucet Main Hall	1.2 ppb
St George School	Girls Bathroom Sink Second Floor	0 ppb
St George School	Health Faucet East Wall	1.5 ppb
St George School	Health Faucet South Wall	0 ppb
St George School	Health Faucet Under Window	1.8 ppb
St George School	Junior High Boys Faucet	1.5 ppb
St George School	Junior High Girls Faucet	0 ppb
St George School	Junior High Science Sink East Wall	35.7 ppb
St George School	Junior High Science Sink West Wall	5.6 ppb
St George School	Kitchen Hand Wash Sink	8.7 ppb
St George School	Kitchen Prep Sink	0 ppb
St George School	Kitchen Spray Wand	1.3 ppb
St George School	Locker Room Boys Bubbler	124 ppb
St George School	Locker Room Boys Faucet	3.3 ppb
St George School	Locker Room Girls Bathroom Sink	26.7 ppb
St George School	Locker Room Girls Bubbler	123 ppb
St George School	Mid Level Boys Bathroom Sink	0 ppb
St George School	Mid Level Girls Bathroom Sink	0 ppb
St George School	Middle Level Bottle Fill	0 ppb
St George School	Middle Level Bubbler	0 ppb
St George School	Moduler Left Bathroom Sink	6.4 ppb
St George School	Moduler Right Bathroom Sink	1 ppb
St George School	Nurses Bathroom Faucet	0 ppb
St George School	Nurses Faucet	1.9 ppb
St George School	Room 1 Bubbler	441 ppb
St George School	Room 1 Faucet	2.8 ppb
St George School	Room 17 Bubbler	1.6 ppb
St George School	Room 17 Faucet	0 ppb
St George School	Room 2 Bubbler	16 ppb
St George School	Room 2 Faucet	0 ppb
St George School	Room 25 Bubbler	175 ppb
St George School	Room 25 Faucet	0 ppb
St George School	Room 26 Bubbler	7.1 ppb
St George School	Room 26 Faucet	3 ppb
St George School	Room 27 Bubbler	0 ppb
St George School	Room 27 Faucet	4.9 ppb
St George School	Room 28 Bubbler	96.2 ppb
St George School	Room 28 Faucet	1.6 ppb
St George School	Room 3 Bubbler	96.5 ppb
St George School	Room 3 Faucet	1.9 ppb
St George School	Room 4 Bubbler	79.7 ppb
St George School	Room 4 Faucet	3.2 ppb
St George School	Room 7 Bathroom Faucet	0 ppb
St George School	Room 7 Bubbler	86.4 ppb
St George School	Room 7 Faucet	2.4 ppb
St George School	Staff Bathroom Faucet	0 ppb
St George School	Teachers Room Faucet	1.8 ppb

School Name	Sample Location	Lead Test Result
St George School	Water Dispenser 1st Floor	0 ppb
St George School	Water Dispenser 2nd Floor	0 ppb
St James School	1st Floor Bottle Fountain By Office	0 ppb
St James School	1st Floor Sink By Room 105	6.5 ppb
St James School	1st Floor Sink By Room 109	21.5 ppb
St James School	1st Floor Sink Teacher Aide	3.7 ppb
St James School	2nd Floor Sink By Room 205	6 ppb
St James School	2nd Floor Sink By Room 209	10.7 ppb
St James School	Basement Bottle Fountain	0 ppb
St James School	Basement Kitchen	10.2 ppb
St James School	Basement Pre-k	34.5 ppb
St John Valley Technology Center	Advance Tech Rr Hand Wash Sink	0 ppb
St John Valley Technology Center	Alt Education Kitchenette Sink	0 ppb
St John Valley Technology Center	Alt Education Rr Handwash Sink	0 ppb
St John Valley Technology Center	Automotive Hand Wash Sink	0 ppb
St John Valley Technology Center	Bottle Filter Above Fountain By Ct	0 ppb
St John Valley Technology Center	Construction Tr Rr Hand Wash Sink	0 ppb
St John Valley Technology Center	Drinking Fountain By Weld Classroom	7.2 ppb
St John Valley Technology Center	Early Childhood Adult Rr Handwash Sink	1.6 ppb
St John Valley Technology Center	Early Childhood Child Rr Hand Wash Sink	0 ppb
St John Valley Technology Center	Early Childhood Children's Kitchenette Sink	0 ppb
St John Valley Technology Center	Early Childhood Kitchenette Sink	0 ppb
St John Valley Technology Center	Electrical Class Hand Wash Deep Sink	0 ppb
St John Valley Technology Center	Hand Wash Basin Between Ct & Auto	4.1 ppb
St John Valley Technology Center	Handwash Basin We I / We li & Forestry	2.7 ppb
St John Valley Technology Center	Health Occ Lab Hand Wash Sink	0 ppb
St John Valley Technology Center	Health Occ Rr Hand Wash Sink	0 ppb
St John Valley Technology Center	Hose Spigot In Automotives	0 ppb
St John Valley Technology Center	Hose Spigot In Car Wash Bay	1.3 ppb
St John Valley Technology Center	Hose Spigot In Construction Trade	0 ppb
St John Valley Technology Center	Hose Spigot In Weld li & Forestry Lab	3.2 ppb
St John Valley Technology Center	Ladies Upper Public Rr Handwash Left #1	2.9 ppb
St John Valley Technology Center	Ladies Upper Public Rr Handwash Right #2	0 ppb
St John Valley Technology Center	Lower Hall Water Fountain - Bottle Filler	0 ppb
St John Valley Technology Center	Lower Hall Water Fountain Drinking Spigot	0 ppb
St John Valley Technology Center	Main Ofc- Kitchenette Sink - Hand/dish Wash	0 ppb
St John Valley Technology Center	Men's Upper Public Rr Handwash Left #1	3.8 ppb
St John Valley Technology Center	Men's Upper Public Rr Handwash Right #2	2.7 ppb
St John Valley Technology Center	Old Kitchen Double Deep Sink (cust Office)	4.8 ppb
St John Valley Technology Center	Old Kitchen Single Deep Sink (cust Office)	8.1 ppb
St John Valley Technology Center	Superintendant Office Sink - Former Cul Art	5.5 ppb
St John Valley Technology Center	Unisex Lower Public Rr Left Hand Wash Sink	0 ppb

School Name	Sample Location	Lead Test Result
St John Valley Technology Center	Unisex Lower Public Rr Right Hand Wash Sink	0 ppb
St John Valley Technology Center	Wash Bay Between Auto & Weld- Deep	0 ppb
St John Valley Technology Center	Water Fountain Between Ct & At	0 ppb
St John Valley Technology Center	Weld li/forestry Hand Wash Sink	0 ppb
St John Valley Technology Center	Welding Faucet Where Deep Sink Was	2.6 ppb
St John Valley Technology Center	Welding Rr Hand Wash Sink	3.6 ppb
St John's Catholic School-Brunswick	Gym Bottle Filler	0 ppb
St John's Catholic School-Brunswick	Hallway Bottle Filler	0 ppb
St John's Catholic School-Brunswick	Hallway Water Fountain	0 ppb
St John's Catholic School-Brunswick	Ice Machine	0 ppb
St John's Catholic School-Brunswick	Kitchen Faucet	0 ppb
St John's Catholic School-Brunswick	School Main Floor Water Fountain	20.5 ppb
St Michael School	Water Fountain In Gym	0 ppb
St Michael School	Water Fountain Near Front Office	0 ppb
St Michael School	Water Fountain On 1st Floor	0 ppb
St Michael School	Water Fountain On 2nd Floor	0 ppb
St Thomas School	Bottle Filling Station 1st Floor	0 ppb
St Thomas School	Bottle Filling Station 2nd Floor	0 ppb
St Thomas School	Kitchen Double Basin Sink	3.6 ppb
St Thomas School	Kitchen Single Basin Sink	0 ppb
Stearns Jr-Sr High School	Band Area Bottle Fill Station	8.5 ppb
Stearns Jr-Sr High School	Band Room Sink	46.7 ppb
Stearns Jr-Sr High School	Bottle Fill Station 2nd Fl Main Corridor	0 ppb
Stearns Jr-Sr High School	Bottle Fill Station Main Corridor	0 ppb
Stearns Jr-Sr High School	Bottle Fill Station Sped Wing 2nd Fl	0 ppb
Stearns Jr-Sr High School	Bottle Fill Station By Teachers Room	0 ppb
Stearns Jr-Sr High School	Boys Jacuzzi Room Sink	62.8 ppb
Stearns Jr-Sr High School	Boys Team Room Bottle Fill Station	0 ppb
Stearns Jr-Sr High School	Business Science Bottle Fill Station	0 ppb
Stearns Jr-Sr High School	Cafeteria Double Sink	4.8 ppb
Stearns Jr-Sr High School	Concessions Football Field Sink	9.7 ppb
Stearns Jr-Sr High School	Facility Managers Office Sink	3.6 ppb
Stearns Jr-Sr High School	Girls Jacuzzi Room Sink	23.3 ppb
Stearns Jr-Sr High School	Girls Locker Room Bottle Fill Station	10.3 ppb
Stearns Jr-Sr High School	Gym Lobby Bottle Fill Station	0 ppb
Stearns Jr-Sr High School	Gym Lobby Concessions Sink	261 ppb
Stearns Jr-Sr High School	Ice Machine	0 ppb
Stearns Jr-Sr High School	Kettle Fill Sink	213 ppb
Stearns Jr-Sr High School	Library Sink	1110 ppb
Stearns Jr-Sr High School	Main Office Sink	22 ppb
Stearns Jr-Sr High School	Middle School Gym Corridor Fill Station	0 ppb
Stearns Jr-Sr High School	Nurses Office Sink	52.3 ppb
Stearns Jr-Sr High School	Pantry Room Sink	218 ppb
Stearns Jr-Sr High School	Room 116 Sink #1	24.4 ppb
Stearns Jr-Sr High School	Room 116 Sink #2	13 ppb
Stearns Jr-Sr High School	Room 116 Sink #3	30.3 ppb

School Name	Sample Location	Lead Test Result
Stearns Jr-Sr High School	Room 116 Sink #4	95.2 ppb
Stearns Jr-Sr High School	Room 140	0 ppb
Stearns Jr-Sr High School	Room 142 Sink	1.8 ppb
Stearns Jr-Sr High School	Room 142a Sink	1.8 ppb
Stearns Jr-Sr High School	Room 150 Sink	427 ppb
Stearns Jr-Sr High School	Sped Room 217 2nd Fl	1.8 ppb
Stearns Jr-Sr High School	Steamer Sink	5.4 ppb
Stearns Jr-Sr High School	Teachers Room Sink	4.2 ppb
Stearns Jr-Sr High School	Wood Shop Drinking Fountain	14.6 ppb
Steep Falls Elementary School	Faucet In Clinic	14.5 ppb
Steep Falls Elementary School	Faucet Room 22	9.8 ppb
Steep Falls Elementary School	Faucet Room 23	49.4 ppb
Steep Falls Elementary School	Faucet Room 24	4.5 ppb
Steep Falls Elementary School	Faucet Room 25	9 ppb
Steep Falls Elementary School	Faucet Room 6	7.8 ppb
Steep Falls Elementary School	Faucet Room 7	7 ppb
Steep Falls Elementary School	Faucet Room 8	4.9 ppb
Steep Falls Elementary School	Faucet Room 9	18.3 ppb
Steep Falls Elementary School	Fountain In Cafeteria	11.3 ppb
Steep Falls Elementary School	Fountain Across From Cafeteria	0 ppb
Steep Falls Elementary School	Fountain Between Restrooms	1.8 ppb
Steep Falls Elementary School	Fountain Room 22	34.2 ppb
Steep Falls Elementary School	Fountain Room 23	5.4 ppb
Steep Falls Elementary School	Fountain Room 24	27 ppb
Steep Falls Elementary School	Fountain Room 25	61.4 ppb
Steep Falls Elementary School	Fountain Room 6	17.9 ppb
Steep Falls Elementary School	Fountain Room 7	9.2 ppb
Steep Falls Elementary School	Fountain Room 8	14.9 ppb
Steep Falls Elementary School	Fountain Room 9	28 ppb
Steep Falls Elementary School	Kitchen Food Prep Sink	1.5 ppb
Step by Step Child Care	Baby Room Sink	0 ppb
Step by Step Child Care	Big School Kids Room Sink	0 ppb
Step by Step Child Care	Kitchen Sink	0 ppb
Step by Step Child Care	Nursery Sink -eastside	0 ppb
Step by Step Child Care	Pre School Sink West Side	0 ppb
Step by Step Child Care	Pre-pre School Sink West Side	0 ppb
Step by Step Child Care	Toddler Room Sink East Side	0 ppb
Stepping Stones Montessori School	Main Kitchen Area	0 ppb
Stevens Brook School	Cafe- Kitchenette Sink	0 ppb
Stevens Brook School	Drinking Fountain Cafe Entrance #a	1.1 ppb
Stevens Brook School	Drinking Fountain Cafe Entrance #b	0 ppb
Stevens Brook School	Drinking Fountain Cafe Entrance Bottle Fill	0 ppb
Stevens Brook School	Hallway Bottle Fill By Rm # 178	0 ppb
Stevens Brook School	Hallway Bottle Fill Outside Rm # 134	1.6 ppb
Stevens Brook School	Hallway By Rm # 178	0 ppb
Stevens Brook School	Hallway Df Bubbler Outside Of Rm #181	0 ppb
Stevens Brook School	Hallway Df Outside Of Rm #181	0 ppb

School Name	Sample Location	Lead Test Result
Stevens Brook School	Hallway Df Outside Rm # 134 #a	0 ppb
Stevens Brook School	Hallway Df Outside Rm # 134 #b	0 ppb
Stevens Brook School	Main Kitchen 3-bay Sink	3 ppb
Stevens Brook School	Main Kitchen Dishwasher Sink	37.8 ppb
Stevens Brook School	Main Kitchen Hand Wash Sink	3.7 ppb
Stevens Brook School	Main Kitchen Singl Veggie Sink	0 ppb
Stevens Brook School	Main Kitchen Steam Kettle	2.7 ppb
Stevens Brook School	Nurse Office - Ice Maker	0 ppb
Stevens Brook School	Nurse Office - Sink	0 ppb
Stevens Brook School	Rm # 128 Art First Sink As Enter # B	1.5 ppb
Stevens Brook School	Rm # 128 Art First Sink As Enter # C	0 ppb
Stevens Brook School	Rm # 128 Art First Sink As Enter #a	0 ppb
Stevens Brook School	Rm # 131 Bubbler	0 ppb
Stevens Brook School	Rm # 131 Sink	0 ppb
Stevens Brook School	Rm # 134 Bubbler	0 ppb
Stevens Brook School	Rm # 134 Sink	0 ppb
Stevens Brook School	Rm # 138 Bubbler	0 ppb
Stevens Brook School	Rm # 138 Sink	0 ppb
Stevens Brook School	Rm # 144 Teachers Rm Sink	1.2 ppb
Stevens Brook School	Rm # 147 Bubbler	0 ppb
Stevens Brook School	Rm # 147 Sink	1.5 ppb
Stevens Brook School	Rm # 149 Bubbler	1.6 ppb
Stevens Brook School	Rm # 149 Sink	0 ppb
Stevens Brook School	Rm # 150 Bubbler	0 ppb
Stevens Brook School	Rm # 150 Sink	0 ppb
Stevens Brook School	Rm # 158 Bubbler	0 ppb
Stevens Brook School	Rm # 158 Sink	0 ppb
Stevens Brook School	Rm # 159 Bubbler	0 ppb
Stevens Brook School	Rm # 159 Sink	0 ppb
Stevens Brook School	Rm # 161 Bubbler	0 ppb
Stevens Brook School	Rm # 161 Sink	0 ppb
Stevens Brook School	Rm # 162 Bubbler	0 ppb
Stevens Brook School	Rm # 162 Sink	0 ppb
Stevens Brook School	Rm # 165 Bubbler	0 ppb
Stevens Brook School	Rm # 165 Sink	0 ppb
Stevens Brook School	Rm # 166 Bubbler	0 ppb
Stevens Brook School	Rm # 166 Sink	0 ppb
Stevens Brook School	Rm # 167 Bubbler	0 ppb
Stevens Brook School	Rm # 167 Sink	0 ppb
Stevens Brook School	Rm # 169 Bubbler	0 ppb
Stevens Brook School	Rm # 169 Sink	0 ppb
Stevens Brook School	Rm # 171 Bubbler	0 ppb
Stevens Brook School	Rm # 171 Sink	3 ppb
Stevens Brook School	Rm # 172 Bubbler	0 ppb
Stevens Brook School	Rm # 172 Sink	0 ppb
Stevens Brook School	Rm # 173 Bubbler	0 ppb
Stevens Brook School	Rm # 173 Sink	0 ppb

School Name	Sample Location	Lead Test Result
Stevens Brook School	Rm # 174 Bubblers	0 ppb
Stevens Brook School	Rm # 174 Sink	0 ppb
Stevens Brook School	Rm # 175 Bubblers	0 ppb
Stevens Brook School	Rm # 180 Bubblers	0 ppb
Stevens Brook School	Rm # 180 Sink	0 ppb
Stevens Brook School	Rm # 185 Bubblers	0 ppb
Stevens Brook School	Rm # 185 Sink	0 ppb
Stevens Brook School	Rm # 186 Bubblers	0 ppb
Stevens Brook School	Rm # 186 Sink	0 ppb
Stevens Brook School	Rm # 187 Bubblers	0 ppb
Stevens Brook School	Rm # 187 Sink	0 ppb
Stevens Brook School	Rm # 188 Bubblers	0 ppb
Stevens Brook School	Rm # 188 Sink	0 ppb
Stevens Brook School	Rm # 189 Bubblers	0 ppb
Stevens Brook School	Rm # 189 Sink	0 ppb
Stevens Brook School	Rm # 190 Bubblers	1.1 ppb
Stevens Brook School	Rm # 190 Sink	0 ppb
Stevens Brook School	Rm # 191 Bubblers	0 ppb
Stevens Brook School	Rm # 191 Sink	3.6 ppb
Stevens Brook School	Rm# 101 Sink	0 ppb
Stevens Brook School	Rm# 175 Sink	0 ppb
Stillwater Academy	Kitchen Sink	0 ppb
Stillwater Academy	Staff Bathroom-pull Out Space	0 ppb
Stillwater Academy	Student Bathroom-pull Out Space	0 ppb
Stillwater Academy	Water Cooler In Kitchen	0 ppb
Stillwater Academy	Water Fountain By Kitchen	0 ppb
Stratton Elementary School	Alice's Sink	0 ppb
Stratton Elementary School	Anna's Sink	0 ppb
Stratton Elementary School	Art Room A	0 ppb
Stratton Elementary School	Art Room B	12.7 ppb
Stratton Elementary School	Bottle Station By Hall Bathrooms	0 ppb
Stratton Elementary School	Bottle Station By Locker Rooms	0 ppb
Stratton Elementary School	Christine's Room	1.2 ppb
Stratton Elementary School	Grade 1	0 ppb
Stratton Elementary School	Grade 2 A	0 ppb
Stratton Elementary School	Grade 2 B	3 ppb
Stratton Elementary School	Kindergarten	0 ppb
Stratton Elementary School	Kitchen Island Sink	1.1 ppb
Stratton Elementary School	Nurse's Station Sink	1.7 ppb
Stratton Elementary School	Paula's Room A	0 ppb
Stratton Elementary School	Paula's Room B	0 ppb
Stratton Elementary School	Paula's Room C	1.7 ppb
Stratton Elementary School	Paula's Room D	0 ppb
Stratton Elementary School	Paula's Room E	1.9 ppb
Stratton Elementary School	Teacher's Room Sink	1.4 ppb
Strong Elementary School	Day Treatment/ Back Room	2.3 ppb
Strong Elementary School	Kitchen 3 Bay Sink/lhs	7.7 ppb

School Name	Sample Location	Lead Test Result
Strong Elementary School	Kitchen 3 Bay Sink/rhs	6.9 ppb
Strong Elementary School	Kitchen/prep Sink	4.4 ppb
Strong Elementary School	Main Hall Water Cooler	0 ppb
Strong Elementary School	Room 101a/food Service Director's Office	2.8 ppb
Strong Elementary School	Room 110	0 ppb
Strong Elementary School	Room 116	3.3 ppb
Strong Elementary School	Room 118	4.4 ppb
Strong Elementary School	Room 119	0 ppb
Strong Elementary School	Room 125/nurses Station	1.2 ppb
Strong Elementary School	Room 126	3.2 ppb
Strong Elementary School	Room 127	3.7 ppb
Strong Elementary School	Room 128/lhs	0 ppb
Strong Elementary School	Room 128/rhs	3 ppb
Strong Elementary School	Room 129	3.4 ppb
Strong Elementary School	Room 140	1.3 ppb
Strong Elementary School	Special Ed Directors Office	4.1 ppb
Strong Elementary School	Upper Wing Water Cooler	0 ppb
Summit Academy	Bathroom Sink 3rd Floor	6.1 ppb
Summit Academy	Counter Sink Room 109	11.1 ppb
Summit Academy	Kitchen Sink 1st Floor	17.3 ppb
Summit Academy	Kitchen Sink 2nd Floor	1.7 ppb
Summit Academy	Water Fountain 2nd Floor	0 ppb
Summit Academy	Water Fountain Hallway	27.6 ppb
Sumner Memorial High School	No Samples Yet Taken	
Surry Elementary School	Condo Drinking Fountain	5 ppb
Surry Elementary School	Gym Drinking Fountain	9.6 ppb
Surry Elementary School	Kindergarden Sink	0 ppb
Surry Elementary School	Kitchen Food Prep Sink	10.5 ppb
Surry Elementary School	Main Hallway Drinking Fountain	0 ppb
Surry Elementary School	Pre -k Condo Sink	1.4 ppb
Suzanne M Smith Elementary School	Gym Left	0 ppb
Suzanne M Smith Elementary School	Gym Right	0 ppb
Suzanne M Smith Elementary School	Kitchen 3 Bay	0 ppb
Suzanne M Smith Elementary School	Kitchen Prep Sink	1.1 ppb
Suzanne M Smith Elementary School	Room 108	0 ppb
Suzanne M Smith Elementary School	Room 109 Island	0 ppb
Suzanne M Smith Elementary School	Room 109 Wall	0 ppb
Suzanne M Smith Elementary School	Room 110	0 ppb
Suzanne M Smith Elementary School	Room 111	0 ppb
Suzanne M Smith Elementary School	Room 112	0 ppb
Suzanne M Smith Elementary School	Room 113	0 ppb
Suzanne M Smith Elementary School	Room 114	0 ppb
Suzanne M Smith Elementary School	Room 115	0 ppb
Suzanne M Smith Elementary School	Room 116	0 ppb
Suzanne M Smith Elementary School	Room 117	0 ppb
Suzanne M Smith Elementary School	Room 201	0 ppb
Suzanne M Smith Elementary School	Room 202	0 ppb

School Name	Sample Location	Lead Test Result
Suzanne M Smith Elementary School	Room 204	0 ppb
Suzanne M Smith Elementary School	Room 205	0 ppb
Suzanne M Smith Elementary School	Room 206	0 ppb
Suzanne M Smith Elementary School	Room 207	0 ppb
Swans Island Elementary School	3-5 Bathroom Sink Handwash Main Hallway	3.5 ppb
Swans Island Elementary School	3-5 Classroom Sink Handwash/fountain	6.1 ppb
Swans Island Elementary School	6-8 Classroom Sink Handwash/fountain	7.2 ppb
Swans Island Elementary School	Art Room - Sink - Handwashing	3.3 ppb
Swans Island Elementary School	Boy's Bathroom Gym - Sink - Handwash	3 ppb
Swans Island Elementary School	Fountain/bottle Fill Main Hallway Across Office	0 ppb
Swans Island Elementary School	Girl's Bathroom Gym - Sink - Handwash	2.9 ppb
Swans Island Elementary School	Isolation/nurse Bathroom Sink End Of Main Hallway	3.9 ppb
Swans Island Elementary School	K-2 Classroom Sink Handwash/fountain	3.8 ppb
Swans Island Elementary School	Kitchen - Handwashing Sink	1.4 ppb
Swans Island Elementary School	Kitchen - Sprayer Sink	4.3 ppb
Swans Island Elementary School	Kitchen - Triple Basin Sink	1.8 ppb
Swans Island Elementary School	Teacher's Room - Sink - Handwashing	3 ppb
Swans Island Elementary School	Water Fountain/bottle Fill Station - Gym	0 ppb
Sweatt-Winter Child Care	Childrens Bathroom Sink In Full Day Room	14.8 ppb
Sweatt-Winter Child Care	Childrens Classroom Sink In Sa Room Left	2.6 ppb
Sweatt-Winter Child Care	Childrens Classroom Sink In Sa Room Right	3.9 ppb
Sweatt-Winter Child Care	Childrens Classroom Sink Left Full Day Room	8.2 ppb
Sweatt-Winter Child Care	Childrens Classroom Sink Right Full Day Room	1.8 ppb
Sweatt-Winter Child Care	Main Kitchen Faucet	2.9 ppb
Sweatt-Winter Child Care	Teacher Sink In Full Day Preschool Room	1.6 ppb
Sweatt-Winter Child Care	Teachers Sink In School-age Room	2.4 ppb
Sylvio J Gilbert School	2 Bay Sink Kitchen	1.8 ppb
Sylvio J Gilbert School	3 Bay Sink Kitchen	0 ppb
Sylvio J Gilbert School	Bottle Fill Station By Kitchen	0 ppb
Sylvio J Gilbert School	Classroom 10	0 ppb
Sylvio J Gilbert School	Classroom 11	0 ppb
Sylvio J Gilbert School	Classroom 12	1.9 ppb
Sylvio J Gilbert School	Classroom 13	0 ppb
Sylvio J Gilbert School	Classroom 14	1.8 ppb
Sylvio J Gilbert School	Classroom 15	0 ppb
Sylvio J Gilbert School	Classroom 16	0 ppb
Sylvio J Gilbert School	Classroom 17	0 ppb
Sylvio J Gilbert School	Classroom 18	0 ppb
Sylvio J Gilbert School	Classroom 19	0 ppb
Sylvio J Gilbert School	Classroom 2	4.9 ppb
Sylvio J Gilbert School	Classroom 20	1.6 ppb
Sylvio J Gilbert School	Classroom 21	0 ppb

School Name	Sample Location	Lead Test Result
Sylvio J Gilbert School	Classroom 3	7.2 ppb
Sylvio J Gilbert School	Classroom 4	0 ppb
Sylvio J Gilbert School	Classroom 5	3.3 ppb
Sylvio J Gilbert School	Classroom 6	0 ppb
Sylvio J Gilbert School	Classroom 7	0 ppb
Sylvio J Gilbert School	Classroom 8	1.3 ppb
Sylvio J Gilbert School	Classroom 9	0 ppb
Sylvio J Gilbert School	Staff Lounge	0 ppb
T W Kelly Dirigo Middle School	Cafe Water Fountain	1.5 ppb
T W Kelly Dirigo Middle School	Gym Ice Machine	0 ppb
T W Kelly Dirigo Middle School	Kitchen Double Sink	30.9 ppb
T W Kelly Dirigo Middle School	Kitchen Kettle	19.5 ppb
T W Kelly Dirigo Middle School	Library Bottle Fill Station	0 ppb
T W Kelly Dirigo Middle School	Lobby Bottle Fill Station	0 ppb
T W Kelly Dirigo Middle School	Room 12	14.2 ppb
T W Kelly Dirigo Middle School	Room 13	18 ppb
T W Kelly Dirigo Middle School	Room 14	23.5 ppb
T W Kelly Dirigo Middle School	Room 15	22.6 ppb
T W Kelly Dirigo Middle School	Teacher Lounge	35.3 ppb
Telstar High School	Ad Ed Sink	1.4 ppb
Telstar High School	Boosters Room	8.8 ppb
Telstar High School	Bottle Fill By High School Bathrooms	0 ppb
Telstar High School	Bottle Fill Station By Kitchen	0 ppb
Telstar High School	Bottle Fill Station In Cafeteria	0 ppb
Telstar High School	Boys Locker Room-bottle Fill Station	0 ppb
Telstar High School	Boys Locker Room-ice Machine	0 ppb
Telstar High School	Girls Locker Room-bottle Fill Station	0 ppb
Telstar High School	High School Office Lunch Room	0 ppb
Telstar High School	High School Teachers Lounge	3 ppb
Telstar High School	Kitchen Kettle	11.3 ppb
Telstar High School	Kitchen-food Prep Sink	0 ppb
Telstar High School	Library Office	3.3 ppb
Telstar High School	Music Room-bathroom Sink	0 ppb
Telstar High School	Nurses's Bathroom	2.4 ppb
Telstar High School	Room 107-center Sink By Windows	3.4 ppb
Telstar High School	Room 107-left Sink By Windows	132 ppb
Telstar High School	Room 107-north Wall-center Lab	131 ppb
Telstar High School	Room 107-north Wall-near Chemical Closet	12.5 ppb
Telstar High School	Room 107-right Lab By Windows	12 ppb
Telstar High School	Room 107-right Sink By Windows	10.8 ppb
Telstar High School	Room 110-center Sink By Hall	9.3 ppb
Telstar High School	Room 110-center Sink By Windows	5.3 ppb
Telstar High School	Room 110-left Sink By Hall	11.7 ppb
Telstar High School	Room 110-left Sink By Windows	72.6 ppb
Telstar High School	Room 110-right Sink By Hall	95.8 ppb
Telstar High School	Room 110-right Sink By Windows	9.9 ppb

School Name	Sample Location	Lead Test Result
Telstar High School	Room 220-bottle Fill Station	0 ppb
Telstar High School	Room 226	1.8 ppb
Telstar High School	Room107-island Lab-front Of Room	13.6 ppb
Telstar High School	Room107-north Wall-near Closet	11 ppb
Telstar Middle School	Booster's Room	2.2 ppb
Telstar Middle School	Bottle Fill Station By Kitchen	0 ppb
Telstar Middle School	Bottle Fill Station In Cafeteria	0 ppb
Telstar Middle School	Bottle Fill Station Outside Custodial Office	0 ppb
Telstar Middle School	Bottle Fill Station Outside Room 101	0 ppb
Telstar Middle School	Boys Locker Room-bottle Fill Station	0 ppb
Telstar Middle School	Boys Locker Room-ice Machine	0 ppb
Telstar Middle School	Girls Locker Room-bottle Fill Station	0 ppb
Telstar Middle School	Kitchen Kettle	7.5 ppb
Telstar Middle School	Kitchen-food Prep Sink	0 ppb
Telstar Middle School	Library Office	2.3 ppb
Telstar Middle School	Middle School Office Bathroom	1.5 ppb
Telstar Middle School	Nurse's Bathroom-west Wall	0 ppb
Telstar Middle School	Room 101-2nd Sink From Hall	24.3 ppb
Telstar Middle School	Room 101-3rd Sink From Hall	26.2 ppb
Telstar Middle School	Room 101-by Hall Door	19 ppb
Telstar Middle School	Room 101-by Storage Closet	166 ppb
Telstar Middle School	Room 101-soutn Wall-right Hand Sink	24.1 ppb
Telstar Middle School	Room 103-east Wall-2nd From Hall	9.7 ppb
Telstar Middle School	Room 103-east Wall-3rd From Hall	7.8 ppb
Telstar Middle School	Room 103-east Wall-4th From Hall	16.2 ppb
Telstar Middle School	Room 103-east Wall-by Hall Door	48.6 ppb
Telstar Middle School	Room 103-south Wall-left Hand Sink	16.9 ppb
Telstar Middle School	Room 103-south Wall-right Hand Sink	10.1 ppb
Telstar Middle School	Room 104-east Wall	18.4 ppb
Telstar Middle School	Room 104-north Wall	10.2 ppb
Telstar Middle School	Room 105	3.4 ppb
Telstar Middle School	Room 106-island	38 ppb
Telstar Middle School	Room 106-west Wall	3.3 ppb
Telstar Middle School	Room 108-north Wall	20 ppb
Telstar Middle School	Room 217-left Sink	2.8 ppb
Telstar Middle School	Room 217-right Sink	9.7 ppb
The Community School	No Samples Yet Taken	
The Eddy Middle School	East Bathroom Sink	1 ppb
The Eddy Middle School	West Bathroom Sink	1 ppb
The Little Dolphin Sch Scarborough	After Care	0 ppb
The Little Dolphin Sch Scarborough	Guest Bath	0 ppb
The Little Dolphin Sch Scarborough	Infant 1/sink	0 ppb
The Little Dolphin Sch Scarborough	Infant 2/sink	0 ppb
The Little Dolphin Sch Scarborough	Infant 3/sink	0 ppb
The Little Dolphin Sch Scarborough	Infant 4/bath	0 ppb
The Little Dolphin Sch Scarborough	Infant 4/sink	0 ppb
The Little Dolphin Sch Scarborough	Pk Bath	0 ppb

School Name	Sample Location	Lead Test Result
The Little Dolphin Sch Scarborough	Pk Sink	0 ppb
The Little Dolphin Sch Scarborough	Ps Bath	0 ppb
The Little Dolphin Sch Scarborough	Ps Sink	0 ppb
The Little Dolphin Sch Scarborough	Ps Spout	0 ppb
The Little Dolphin Sch Scarborough	Sand Room	0 ppb
The Little Dolphin Sch Scarborough	Teach Bath	0 ppb
The Little Dolphin Sch Scarborough	Tod 1 Bath	0 ppb
The Little Dolphin Sch Scarborough	Tod 1 Sink	0 ppb
The Little Dolphin School	Bathroom 1	0 ppb
The Little Dolphin School	Bathroom 2	0 ppb
The Little Dolphin School	Bathroom 3	0 ppb
The Little Dolphin School	Big Kid Playground	0 ppb
The Little Dolphin School	Grade 1	0 ppb
The Little Dolphin School	I1	0 ppb
The Little Dolphin School	I2	0 ppb
The Little Dolphin School	I3	0 ppb
The Little Dolphin School	I4	0 ppb
The Little Dolphin School	I5	0 ppb
The Little Dolphin School	Infant Bathroom	0 ppb
The Little Dolphin School	Kindergarten	0 ppb
The Little Dolphin School	Kitchen	0 ppb
The Little Dolphin School	Modular Bathroom	0 ppb
The Little Dolphin School	Pk1	0 ppb
The Little Dolphin School	Pk2	0 ppb
The Little Dolphin School	Prek Bathroom	0 ppb
The Little Dolphin School	Preschool Bathroom	0 ppb
The Little Dolphin School	Ps1	0 ppb
The Little Dolphin School	Ps2	0 ppb
The Little Dolphin School	Sand And Water 1	3.6 ppb
The Little Dolphin School	Sand And Water 2	8.6 ppb
The Little Dolphin School	Spigot Outside Kitchen	0 ppb
The Little Dolphin School	T1	0 ppb
The Little Dolphin School	T2	0 ppb
The Little Dolphin School	Toddler Bathroom	0 ppb
The Little Dolphin School	Toddler Playground 3	5.4 ppb
The Little Dolphin School	Toddler Playground By Red Door	27.2 ppb
The Little Dolphin School	Toddler Playground By Yellow Door	0 ppb
The New School	Kitchen Sink	0 ppb
The New School	Kitchen Utility Sink	0 ppb
The New School	Large Bathroom	0 ppb
The New School	Science Room	0 ppb
The New School	Small Bathroom	0 ppb
The School at Sweetser--Saco	Art Room 5a	1.8 ppb
The School at Sweetser--Saco	Art Room 5b	20.9 ppb
The School at Sweetser--Saco	Clinic 28	0 ppb
The School at Sweetser--Saco	Clinic 28a	0 ppb
The School at Sweetser--Saco	Elementary Breakroom 2	0 ppb

School Name	Sample Location	Lead Test Result
The School at Sweetser--Saco	Hs Mens	4.1 ppb
The School at Sweetser--Saco	Hs Womens 19	0 ppb
The School at Sweetser--Saco	Kitchen 6	0 ppb
The School at Sweetser--Saco	Kitchen 6a	13 ppb
The School at Sweetser--Saco	Kitchen 6b	5.6 ppb
The School at Sweetser--Saco	Kitchen 6c	2.3 ppb
The School at Sweetser--Saco	Kitchen 6d	0 ppb
The School at Sweetser--Saco	Media Lab 7	1.6 ppb
The School at Sweetser--Saco	Mens Caf 3	0 ppb
The School at Sweetser--Saco	Room 1	131 ppb
The School at Sweetser--Saco	Room 1 16a	94.2 ppb
The School at Sweetser--Saco	Room 13 20	2.5 ppb
The School at Sweetser--Saco	Room 14	9.3 ppb
The School at Sweetser--Saco	Room 15 22	21.2 ppb
The School at Sweetser--Saco	Room 16 23	7.6 ppb
The School at Sweetser--Saco	Room 17 24	0 ppb
The School at Sweetser--Saco	Room 18	1.1 ppb
The School at Sweetser--Saco	Room 19 26	8 ppb
The School at Sweetser--Saco	Room 2 13	0 ppb
The School at Sweetser--Saco	Room 20 27	0 ppb
The School at Sweetser--Saco	Room 3	14 ppb
The School at Sweetser--Saco	Room 3 15b	0 ppb
The School at Sweetser--Saco	Room 4 12	0 ppb
The School at Sweetser--Saco	Room 4 12a	15.2 ppb
The School at Sweetser--Saco	Room 5	11 ppb
The School at Sweetser--Saco	Room 5 14	0 ppb
The School at Sweetser--Saco	Room 5 14a	28.9 ppb
The School at Sweetser--Saco	Room 6 11	0 ppb
The School at Sweetser--Saco	Room 6 11a	0 ppb
The School at Sweetser--Saco	Room 6 11b	1.6 ppb
The School at Sweetser--Saco	Room 7 10	4.3 ppb
The School at Sweetser--Saco	Room 7 10a	15.6 ppb
The School at Sweetser--Saco	Room 8 9	3.5 ppb
The School at Sweetser--Saco	Room 9 8	0 ppb
The School at Sweetser--Saco	Room3	67.4 ppb
The School at Sweetser--Saco	Staff Lounge 17	0 ppb
The School at Sweetser--Saco	Staff Lounge 17a	1.2 ppb
The School at Sweetser--Saco	Staff Lounge 17b	0 ppb
The School at Sweetser--Saco	Womens Caf 4	0 ppb
Thomas J McMahon Elementary Sch	2nd Grade Water Fountain	7.2 ppb
Thomas J McMahon Elementary Sch	Bottle Filler By Library	4.8 ppb
Thomas J McMahon Elementary Sch	Bottle Filler Near 202	0 ppb
Thomas J McMahon Elementary Sch	Cafe Bottle Filler	2.6 ppb
Thomas J McMahon Elementary Sch	Cafe Water Fountain	1.3 ppb
Thomas J McMahon Elementary Sch	Gym Bottle Filler	0 ppb
Thomas J McMahon Elementary Sch	Gym Water Fountain Lh	0 ppb
Thomas J McMahon Elementary Sch	Gym Water Fountain Rh	0 ppb

School Name	Sample Location	Lead Test Result
Thomas J McMahon Elementary Sch	Kitchen Double Sink	2.9 ppb
Thomas J McMahon Elementary Sch	Kitchen Hand Wash Sink	6.9 ppb
Thomas J McMahon Elementary Sch	Kitchen Triple Sink	0 ppb
Thomas J McMahon Elementary Sch	Rm 101 Bubbler	11.2 ppb
Thomas J McMahon Elementary Sch	Rm 101 Sink	3.9 ppb
Thomas J McMahon Elementary Sch	Rm 102 Bubbler	12.1 ppb
Thomas J McMahon Elementary Sch	Rm 102 Sink	17.9 ppb
Thomas J McMahon Elementary Sch	Rm 103 Bubbler	16.4 ppb
Thomas J McMahon Elementary Sch	Rm 103 Sink	5.2 ppb
Thomas J McMahon Elementary Sch	Rm 104 Bubbler	12.6 ppb
Thomas J McMahon Elementary Sch	Rm 104 Sink	7.8 ppb
Thomas J McMahon Elementary Sch	Rm 105 Girls Gang Bath 1st Sink	3.4 ppb
Thomas J McMahon Elementary Sch	Rm 105 Girls Gang Bath 2nd Sink	1.4 ppb
Thomas J McMahon Elementary Sch	Rm 105a Staff Bath Sink	5.1 ppb
Thomas J McMahon Elementary Sch	Rm 106 Boys Gang Bath 1st Sink	6 ppb
Thomas J McMahon Elementary Sch	Rm 106a Staff Bath Sink	7.9 ppb
Thomas J McMahon Elementary Sch	Rm 107 Bubbler	5.7 ppb
Thomas J McMahon Elementary Sch	Rm 107 Sink	12 ppb
Thomas J McMahon Elementary Sch	Rm 109 Bubbler	13.3 ppb
Thomas J McMahon Elementary Sch	Rm 109 Sink	5 ppb
Thomas J McMahon Elementary Sch	Rm 110 Bubbler	1.9 ppb
Thomas J McMahon Elementary Sch	Rm 110 Sink	4.2 ppb
Thomas J McMahon Elementary Sch	Rm 111 Bubbler	5 ppb
Thomas J McMahon Elementary Sch	Rm 111 Sink	9.5 ppb
Thomas J McMahon Elementary Sch	Rm 112 Bubbler	16.9 ppb
Thomas J McMahon Elementary Sch	Rm 112 Sink	4.9 ppb
Thomas J McMahon Elementary Sch	Rm 113 Bubbler	24.4 ppb
Thomas J McMahon Elementary Sch	Rm 113 Sink	8.1 ppb
Thomas J McMahon Elementary Sch	Rm 114 Bubbler	5.2 ppb
Thomas J McMahon Elementary Sch	Rm 114 Sink	1.8 ppb
Thomas J McMahon Elementary Sch	Rm 117 Sink	23 ppb
Thomas J McMahon Elementary Sch	Rm 118 Sink	6.4 ppb
Thomas J McMahon Elementary Sch	Rm 119 Sink	9.6 ppb
Thomas J McMahon Elementary Sch	Rm 126 Sink	49.6 ppb
Thomas J McMahon Elementary Sch	Rm 129 Teachers Lounge Sink	6.4 ppb
Thomas J McMahon Elementary Sch	Rm 131 Nurse Sink	11.4 ppb
Thomas J McMahon Elementary Sch	Rm 131a Nurse Bath Sink	31.3 ppb
Thomas J McMahon Elementary Sch	Rm 132 Counselors Sink	5.3 ppb
Thomas J McMahon Elementary Sch	Rm 132 Sink	214 ppb
Thomas J McMahon Elementary Sch	Rm 134 Counselors Sink	805 ppb
Thomas J McMahon Elementary Sch	Rm 135 Counselors Sink	253 ppb
Thomas J McMahon Elementary Sch	Rm 136 Bubbler	24 ppb
Thomas J McMahon Elementary Sch	Rm 136 Sink	51.8 ppb
Thomas J McMahon Elementary Sch	Rm 137 Bubbler	9.3 ppb
Thomas J McMahon Elementary Sch	Rm 137 Sink	19.7 ppb
Thomas J McMahon Elementary Sch	Rm 138 Bubbler	3.6 ppb
Thomas J McMahon Elementary Sch	Rm 138 Sink	11 ppb

School Name	Sample Location	Lead Test Result
Thomas J McMahon Elementary Sch	Rm 139 Bubblers	17.6 ppb
Thomas J McMahon Elementary Sch	Rm 139 Sink	24 ppb
Thomas J McMahon Elementary Sch	Rm 140 Bubblers	13.1 ppb
Thomas J McMahon Elementary Sch	Rm 143 Boys Bath 1st Sink	3.3 ppb
Thomas J McMahon Elementary Sch	Rm 143 Boys Bath 3rd Sink	4.1 ppb
Thomas J McMahon Elementary Sch	Rm 143a Staff Bath	6.5 ppb
Thomas J McMahon Elementary Sch	Rm 144 Girls Bath 1st Sink	3.7 ppb
Thomas J McMahon Elementary Sch	Rm 144 Girls Bath 3rd Sink	1.9 ppb
Thomas J McMahon Elementary Sch	Rm 144a Staff Bath	5.2 ppb
Thomas J McMahon Elementary Sch	Rm 145 Bubblers	22.6 ppb
Thomas J McMahon Elementary Sch	Rm 145 Sink	12.9 ppb
Thomas J McMahon Elementary Sch	Rm 146 Sink	16.3 ppb
Thomas J McMahon Elementary Sch	Rm 147 Bubblers	12.9 ppb
Thomas J McMahon Elementary Sch	Rm 147 Sink	10.2 ppb
Thomas J McMahon Elementary Sch	Rm 148 Bubblers	22.9 ppb
Thomas J McMahon Elementary Sch	Rm 148 Sink	200 ppb
Thomas J McMahon Elementary Sch	Rm 149 Bubblers	6.9 ppb
Thomas J McMahon Elementary Sch	Rm 149 Sink	6.3 ppb
Thomas J McMahon Elementary Sch	Rm 14o Sink	5.1 ppb
Thomas J McMahon Elementary Sch	Rm 150 Sink	9.6 ppb
Thomas J McMahon Elementary Sch	Rm 151 Sink	2.1 ppb
Thomas J McMahon Elementary Sch	Rm 152 Bubblers	7.3 ppb
Thomas J McMahon Elementary Sch	Rm 152 Sink	2.3 ppb
Thomas J McMahon Elementary Sch	Rm 153 Bubblers	4.5 ppb
Thomas J McMahon Elementary Sch	Rm 153 Sink	1.2 ppb
Thomas J McMahon Elementary Sch	Rm 154 Bubblers	3.9 ppb
Thomas J McMahon Elementary Sch	Rm 154 Sink	2.6 ppb
Thomas J McMahon Elementary Sch	Rm 155 Bubblers	6.8 ppb
Thomas J McMahon Elementary Sch	Rm 155 Sink	1.1 ppb
Thomas J McMahon Elementary Sch	Rm 162 Bubblers	0 ppb
Thomas J McMahon Elementary Sch	Rm 162 Sink	4.9 ppb
Thomas J McMahon Elementary Sch	Rm 164 Bubblers	0 ppb
Thomas J McMahon Elementary Sch	Rm 164 Sink	2.3 ppb
Thomas J McMahon Elementary Sch	Rm 165 Bubblers	0 ppb
Thomas J McMahon Elementary Sch	Rm 165 Sink	2.2 ppb
Thomas J McMahon Elementary Sch	Rm 166 Bubblers	0 ppb
Thomas J McMahon Elementary Sch	Rm 167 Bubblers	0 ppb
Thomas J McMahon Elementary Sch	Rm 167 Sink	0 ppb
Thomas J McMahon Elementary Sch	Rm 171 2nd Sink	2.4 ppb
Thomas J McMahon Elementary Sch	Rm 181 1st Faucet Art Room	4.9 ppb
Thomas J McMahon Elementary Sch	Rm 186 Concession Sink	14.2 ppb
Thomas J McMahon Elementary Sch	Soup Kettle Kitchen	1.5 ppb
Thomas J McMahon Elementary Sch	Water Fountain By Library	2 ppb
Thomas J McMahon Elementary Sch	Water Fountain Hall By Room 129	3.5 ppb
Thomas J McMahon Elementary Sch	Water Fountain Hall Lh	0 ppb
Thomas J McMahon Elementary Sch	Water Fountain Hall Rh	0 ppb
Thomas J McMahon Elementary Sch	Water Fountain Lh Near 202	0 ppb

School Name	Sample Location	Lead Test Result
Thomas J McMahon Elementary Sch	Water Fountain Near Rm 117	130 ppb
Thomas J McMahon Elementary Sch	Water Fountain Near Rm 144	35.8 ppb
Thomas J McMahon Elementary Sch	Water Fountain Rh Near 202	0 ppb
Thomaston Grammar School	Bottle Fill Staition Outside Room 25	0 ppb
Thomaston Grammar School	Bottle Fill Staition Outside Room 29	0 ppb
Thomaston Grammar School	Bottle Fill Station Outside Boys Bathroom	0 ppb
Thomaston Grammar School	Bottle Fill Station Outside Room 2	0 ppb
Thomaston Grammar School	Boys Bathroom Sink 2/3 Wing	3.1 ppb
Thomaston Grammar School	Boys Bathroom Sink 4/5 Wing	6.9 ppb
Thomaston Grammar School	Boys Bathroom Sink Art Wing	33.5 ppb
Thomaston Grammar School	Boys Bathroom Sink K Wing	2.1 ppb
Thomaston Grammar School	Boys Locker Room Sink	5.5 ppb
Thomaston Grammar School	Cook Sink Kitchen	15.2 ppb
Thomaston Grammar School	Drinking Fountain Art Room	127 ppb
Thomaston Grammar School	Drinking Fountain Room 2	121 ppb
Thomaston Grammar School	Drinking Fountain Room 22	46.6 ppb
Thomaston Grammar School	Drinking Fountain Room 23	10.6 ppb
Thomaston Grammar School	Drinking Fountain Room 24	20.4 ppb
Thomaston Grammar School	Drinking Fountain Room 25	21.3 ppb
Thomaston Grammar School	Drinking Fountain Room 27	17.4 ppb
Thomaston Grammar School	Drinking Fountain Room 28	13.4 ppb
Thomaston Grammar School	Drinking Fountain Room 29	35.6 ppb
Thomaston Grammar School	Drinking Fountain Room 4	812 ppb
Thomaston Grammar School	Drinking Fountain Room 7	60.4 ppb
Thomaston Grammar School	Drinking Fountain Room Outside Girls Lr	2.9 ppb
Thomaston Grammar School	Girls Locker Room Sink	2.6 ppb
Thomaston Grammar School	Girls Bathroom Sink 2/3 Wing	5.2 ppb
Thomaston Grammar School	Girls Bathroom Sink 4/5 Wing	4.6 ppb
Thomaston Grammar School	Girls Bathroom Sink Art Wing	10.6 ppb
Thomaston Grammar School	Girls Bathroom Sink K Wing	4.6 ppb
Thomaston Grammar School	Kitchen Dish Sink	11.7 ppb
Thomaston Grammar School	Kitchen Hand Wash Sink	37.8 ppb
Thomaston Grammar School	Lift Skills Room 20 Sink A	0 ppb
Thomaston Grammar School	Lift Skills Room 20 Sink B	162 ppb
Thomaston Grammar School	Room 15 Sink	0 ppb
Thomaston Grammar School	Room 16 Sink	3.3 ppb
Thomaston Grammar School	Room 17 Sink	1.1 ppb
Thomaston Grammar School	Room 18 Sink	10.9 ppb
Thomaston Grammar School	Room 19 Sink	32.2 ppb
Thomaston Grammar School	Room 2 Sink A	6.7 ppb
Thomaston Grammar School	Room 2 Sink B	112 ppb
Thomaston Grammar School	Room 20 Sink	7.9 ppb
Thomaston Grammar School	Room 22 Sink	109 ppb
Thomaston Grammar School	Room 23 Sink	20.3 ppb
Thomaston Grammar School	Room 24 Sink	45.4 ppb
Thomaston Grammar School	Room 25 Sink	51.9 ppb
Thomaston Grammar School	Room 26 Sink A	16 ppb

School Name	Sample Location	Lead Test Result
Thomaston Grammar School	Room 26 Sink B	28.1 ppb
Thomaston Grammar School	Room 26 Sink C	5.2 ppb
Thomaston Grammar School	Room 27 Sink	26.3 ppb
Thomaston Grammar School	Room 28 Sink	17.2 ppb
Thomaston Grammar School	Room 29 Sink	16.1 ppb
Thomaston Grammar School	Room 7 Sink	30.7 ppb
Thomaston Grammar School	Room 8 Sink	3.2 ppb
Thomaston Grammar School	Teachers Room 32 Sink	1.5 ppb
Thornton Academy	1st Fl Bathroom Left Sink Brewer Side	0 ppb
Thornton Academy	1st Fl Bathroom Left Sink Hersey Side	0 ppb
Thornton Academy	1st Fl Bathroom Left Sink Nasse Side	0 ppb
Thornton Academy	1st Fl Bathroom Left Sink Nelson Side	0 ppb
Thornton Academy	1st Fl Bathroom Middle Sink Brewer Side	0 ppb
Thornton Academy	1st Fl Bathroom Middle Sink Hersey Side	0 ppb
Thornton Academy	1st Fl Bathroom Middle Sink Nasse Side	0 ppb
Thornton Academy	1st Fl Bathroom Middle Sink Nelson Side	3.6 ppb
Thornton Academy	1st Fl Bathroom Right Sink Brewer Side	0 ppb
Thornton Academy	1st Fl Bathroom Right Sink Hersey Side	0 ppb
Thornton Academy	1st Fl Bathroom Right Sink Nasse Side	0 ppb
Thornton Academy	1st Fl Bathroom Right Sink Nelson Side	0 ppb
Thornton Academy	1st Floor Kitchen Sink By Nasse	0 ppb
Thornton Academy	2nd Fl Bathroom Left Sink Nasse Side	0 ppb
Thornton Academy	2nd Fl Bathroom Left Sink Nelson Side	0 ppb
Thornton Academy	2nd Fl Bathroom Left Sink Normand Side	0 ppb
Thornton Academy	2nd Fl Bathroom Left Sink Robert Side	0 ppb
Thornton Academy	2nd Fl Bathroom Middle Sink Nelson Side	0 ppb
Thornton Academy	2nd Fl Bathroom Middle Sink Robert Side	0 ppb
Thornton Academy	2nd Fl Bathroom Right Sink Nasse Side	0 ppb
Thornton Academy	2nd Fl Bathroom Right Sink Nelson Side	0 ppb
Thornton Academy	2nd Fl Bathroom Right Sink Normand Side	0 ppb
Thornton Academy	2nd Fl Bathroom Right Sink Robert Side	0 ppb
Thornton Academy	2nd Fl Br Left Middle Sink Nasse Side	0 ppb
Thornton Academy	2nd Fl Br Left Middle Sink Normand Side	0 ppb
Thornton Academy	2nd Fl Br Right Middle Sink Nasse Side	0 ppb
Thornton Academy	2nd Fl Br Right Middle Sink Normand Side	0 ppb
Thornton Academy	Ah Bathroom Sink First Floor	3.4 ppb
Thornton Academy	Ah Bathroom Sink Second Floor	1.5 ppb
Thornton Academy	Ah Kitchen Sink	2590 ppb
Thornton Academy	Ah Water Cooler	6.3 ppb
Thornton Academy	Annex 2nd Floor Water Fountain	0 ppb
Thornton Academy	Art Wing Bathroom Sink	0 ppb
Thornton Academy	Arts Office Bathroom Sink	0 ppb
Thornton Academy	Boys Locker Room Sink By Storage Closet	22.6 ppb
Thornton Academy	Boys Locker Room Sink By Toilet Gary's Side	2.8 ppb
Thornton Academy	Boys Locker Room Water Fountain	0 ppb
Thornton Academy	Boys Stadium Bathroom Left Sink	0 ppb

School Name	Sample Location	Lead Test Result
Thornton Academy	Boys Stadium Bathroom Right Sink	0 ppb
Thornton Academy	Brewer Bathroom Sink	0 ppb
Thornton Academy	Brewer Kitchen Sink	0 ppb
Thornton Academy	Concession Stand 3 Bay Sink	3.3 ppb
Thornton Academy	Concession Stand Hand Wash By Back Door	39.4 ppb
Thornton Academy	Davies Apartment 1st Floor Bathroom Sink	0 ppb
Thornton Academy	Davies Apartment Kitchen Sink	0 ppb
Thornton Academy	Davies Apartment Master Bathroom Sink	0 ppb
Thornton Academy	Eastern Trail Drinking Fountain	4.9 ppb
Thornton Academy	El Boys Bathroom Sink	0 ppb
Thornton Academy	El Girls Bathroom Sink	3.6 ppb
Thornton Academy	El Teachers Lounge Bathroom Sink	0 ppb
Thornton Academy	El Teachers Lounge Kitchen Sink	1.4 ppb
Thornton Academy	El Water Cooler In Hallway By Fls	7.9 ppb
Thornton Academy	El Water Fountain By Bathrooms Left	0 ppb
Thornton Academy	El Water Fountain By Bathrooms Right	0 ppb
Thornton Academy	Fa Boys Bathroom Left Sink	0 ppb
Thornton Academy	Fa Boys Bathroom Middle Sink	0 ppb
Thornton Academy	Fa Boys Bathroom Right Sink	0 ppb
Thornton Academy	Fa Girls Bathroom Left Sink	0 ppb
Thornton Academy	Fa Girls Bathroom Middle Sink	0 ppb
Thornton Academy	Fa Girls Bathroom Right Sink	0 ppb
Thornton Academy	Fa Kitchen 2 Bay Sink By Gevin Left Faucet	0 ppb
Thornton Academy	Fa Kitchen 2 Bay Sink By Gevin Right Faucet	0 ppb
Thornton Academy	Fa Kitchen Hand Wash In Cooking Area	0 ppb
Thornton Academy	Fa Kitchen Hand Washing Sink	0 ppb
Thornton Academy	Fa Kitchen Ice Machine	0 ppb
Thornton Academy	Fa Sink Attached To Grill	0 ppb
Thornton Academy	Fa Sink In Cooking Area	0 ppb
Thornton Academy	Fa114	19.7 ppb
Thornton Academy	Fa116 3 Bay Sink Left Faucet	0 ppb
Thornton Academy	Fa116 3 Bay Sink Right Faucet	1 ppb
Thornton Academy	Fa116 Left Sink	0 ppb
Thornton Academy	Fa116 Right Sink	1.2 ppb
Thornton Academy	Fa118 Left Sink	1.1 ppb
Thornton Academy	Fa118 Right Sink	0 ppb
Thornton Academy	Fa121a Left Sink	0 ppb
Thornton Academy	Fa121a Right Sink	2.3 ppb
Thornton Academy	Fd 2nd Fl Bathroom No Windows Left Sink	0 ppb
Thornton Academy	Fd 2nd Fl Bathroom No Windows Right Sink	0 ppb
Thornton Academy	Fd 2nd Fl Bathroom With Windows Left Sink	0 ppb
Thornton Academy	Fd 2nd Fl Bathroom With Windows Right Sink	0 ppb
Thornton Academy	Fd Apartment Bathroom Sink	0 ppb

School Name	Sample Location	Lead Test Result
Thornton Academy	Fd Apartment Kitchen Sink	0 ppb
Thornton Academy	Fd First Floor Kitchen Sink	0 ppb
Thornton Academy	Fd First Floor Single Bathroom	0 ppb
Thornton Academy	Fd Second Floor Kitchen Sink	1 ppb
Thornton Academy	Fd Water Cooler	1.9 ppb
Thornton Academy	Fm Office Bathroom	0 ppb
Thornton Academy	Fm Office Sink	1.2 ppb
Thornton Academy	Fm Office Water Cooler	1.7 ppb
Thornton Academy	Fm Utility Sink	0 ppb
Thornton Academy	Fm Water Cooler	1.5 ppb
Thornton Academy	Fo First Floor Bathroom Sink	0 ppb
Thornton Academy	Fo Kitchen Sink	0 ppb
Thornton Academy	Fo Second Floor Bathroom Sink	0 ppb
Thornton Academy	Girls Locker Room Sink Left	2.8 ppb
Thornton Academy	Girls Locker Room Sink Middle	5 ppb
Thornton Academy	Girls Locker Room Sink Right	2.5 ppb
Thornton Academy	Girls Locker Room Water Fountain	7.9 ppb
Thornton Academy	Girls Stadium Bathroom Left Sink	0 ppb
Thornton Academy	Girls Stadium Bathroom Right Sink	0 ppb
Thornton Academy	Gym Boys Public Bathroom Left Sink	0 ppb
Thornton Academy	Gym Boys Public Bathroom Middle Sink	2.7 ppb
Thornton Academy	Gym Boys Public Bathroom Right Sink	1.5 ppb
Thornton Academy	Gym Concession Stand Kitchen Sink	19.2 ppb
Thornton Academy	Gym Girls Public Bathroom Left Sink	33 ppb
Thornton Academy	Gym Girls Public Bathroom Middle Sink	30.2 ppb
Thornton Academy	Gym Girls Public Bathroom Right Sink	225 ppb
Thornton Academy	Gym Ice Machine	0 ppb
Thornton Academy	Gym104m Sink	9.3 ppb
Thornton Academy	Gym112d Sink	1260 ppb
Thornton Academy	Halftime Room Bathroom Sink	0 ppb
Thornton Academy	Halftime Room Ice Machine	0 ppb
Thornton Academy	Headmaster's Bathroom Sink	0 ppb
Thornton Academy	Hersey Apartment Bathroom Sink	0 ppb
Thornton Academy	Hersey Apartment Kitchen Sink	0 ppb
Thornton Academy	Hersey Apartment Master Bathroom Sink	0 ppb
Thornton Academy	Jones Apartment Bathroom Sink	0 ppb
Thornton Academy	Jones Apartment Kitchen Sink	0 ppb
Thornton Academy	Jr Trojans 2 Bay Kitchen Sink	26.8 ppb
Thornton Academy	Jr Trojans Hand Washing Sink	32 ppb
Thornton Academy	Jr Trojans Left Bathroom Sink	16.9 ppb
Thornton Academy	Jr Trojans Right Bathroom Sink	26.8 ppb
Thornton Academy	Jr Trojans Spigot	129 ppb
Thornton Academy	Lb105 Kitchen Sink	0 ppb
Thornton Academy	Lb105a Bathroom Sink	0 ppb
Thornton Academy	Library Bathroom Sink	0 ppb
Thornton Academy	Mb Basement Bathroom Sink	24.3 ppb
Thornton Academy	Mb Boys Bathroom Sink Left	0 ppb

School Name	Sample Location	Lead Test Result
Thornton Academy	Mb Boys Bathroom Sink Middle	0 ppb
Thornton Academy	Mb Boys Bathroom Sink Right	0 ppb
Thornton Academy	Mb Dwf Near Student Br With Bottle Fill	0 ppb
Thornton Academy	Mb Dwf Near Student Br Without Bottle Fill	0 ppb
Thornton Academy	Mb Girls Bathroom Sink Left	0 ppb
Thornton Academy	Mb Girls Bathroom Sink Middle	1.3 ppb
Thornton Academy	Mb Girls Bathroom Sink Right	0 ppb
Thornton Academy	Mb Mens Staff Bathroom Sink	0 ppb
Thornton Academy	Mb Nurse's Sink	0 ppb
Thornton Academy	Mb Womens Staff Bathroom Right Sink	0 ppb
Thornton Academy	Mb112 Bathroom Sink	1.5 ppb
Thornton Academy	Mb113 Bathroom Sink	15.3 ppb
Thornton Academy	Mb206 Sink #1 Closest To Classroom Door	2 ppb
Thornton Academy	Mb206 Sink #2 2nd Closest To Classroom Door	5.6 ppb
Thornton Academy	Mb206 Sink #3 3rd Closest To Classroom Door	3.4 ppb
Thornton Academy	Mb206 Sink #4 Farthest From Classroom Door	2.3 ppb
Thornton Academy	Ms Boys Bathroom Sink Left Side	0 ppb
Thornton Academy	Ms Boys Bathroom Sink Right Side	0 ppb
Thornton Academy	Ms Custodial Closet Sink	3.7 ppb
Thornton Academy	Ms Girls Bathroom Sink Left Side	0 ppb
Thornton Academy	Ms Girls Bathroom Sink Right Side	0 ppb
Thornton Academy	Ms Kitchen Hand Washing Sink	2.1 ppb
Thornton Academy	Ms Kitchen Ice Machine	0 ppb
Thornton Academy	Ms Kitchen Left Faucet	23.6 ppb
Thornton Academy	Ms Kitchen Right Faucet	1.6 ppb
Thornton Academy	Ms Nurse's Office Sink	2.8 ppb
Thornton Academy	Ms Teacher's Lounge Bathroom Sink	1.5 ppb
Thornton Academy	Ms Teacher's Lounge Kitchen Sink	0 ppb
Thornton Academy	Ms Teacher's Single Bathroom Sink Hallway	0 ppb
Thornton Academy	Ms Water Fountain With Filling Station	0 ppb
Thornton Academy	Ms104 Sink	2 ppb
Thornton Academy	Ms107 Sink	18 ppb
Thornton Academy	Ms111 Left Sink	0 ppb
Thornton Academy	Ms111 Right Sink	0 ppb
Thornton Academy	Ms112	1.4 ppb
Thornton Academy	Ms113 Left Sink	0 ppb
Thornton Academy	Ms113 Middle Sink	1.6 ppb
Thornton Academy	Ms113 Right Sink	5.6 ppb
Thornton Academy	Nasse Bathroom Sink	0 ppb
Thornton Academy	Nasse Kitchen Sink	0 ppb
Thornton Academy	Nasse Master Bathroom Sink	0 ppb
Thornton Academy	Nelson Apartment Bathroom Sink	0 ppb

School Name	Sample Location	Lead Test Result
Thornton Academy	Nelson Apartment Kitchen Sink	0 ppb
Thornton Academy	Nelson Apartment Master Bathroom Sink	0 ppb
Thornton Academy	Nh 1st Fl Bathroom Left Sink Route 1 Side	0 ppb
Thornton Academy	Nh 1st Fl Bathroom Left Sink Stadium Side	0 ppb
Thornton Academy	Nh 1st Fl Bathroom Right Sink Route 1 Side	0 ppb
Thornton Academy	Nh 1st Fl Bathroom Right Sink Stadium Side	0 ppb
Thornton Academy	Nh 2nd Fl Bathroom Left Sink Route 1 Side	0 ppb
Thornton Academy	Nh 2nd Fl Bathroom Left Sink Stadium Side	0 ppb
Thornton Academy	Nh 2nd Fl Bathroom Middle Sink Route 1 Side	0 ppb
Thornton Academy	Nh 2nd Fl Bathroom Right Sink Route 1 Side	0 ppb
Thornton Academy	Nh 2nd Fl Bathroom Right Sink Stadium Side	0 ppb
Thornton Academy	Nh First Floor Kitchen Sink	0 ppb
Thornton Academy	Nh First Floor Water Cooler Lounge	0 ppb
Thornton Academy	Nh Second Floor Kitchen Sink	0 ppb
Thornton Academy	Nh Second Floor Water Cooler	0 ppb
Thornton Academy	Normand Bathroom Sink	0 ppb
Thornton Academy	Normand Kitchen Sink	0 ppb
Thornton Academy	Paradis Apartment First Floor Bathroom	0 ppb
Thornton Academy	Paradis Apartment Kitchen Sink	0 ppb
Thornton Academy	Paradis Apartment Second Floor Bathroom	0 ppb
Thornton Academy	Parise Apartment Bathroom Sink	0 ppb
Thornton Academy	Parise Apartment Kitchen Sink	0 ppb
Thornton Academy	Robert Apartment Bathroom Sink	0 ppb
Thornton Academy	Robert Apartment Kitchen Sink	0 ppb
Thornton Academy	Robert Apartment Master Bathroom Sink	0 ppb
Thornton Academy	Roche 1st Floor Bathroom Sink	1.2 ppb
Thornton Academy	Roche 2nd Floor Bathroom Sink	0 ppb
Thornton Academy	Roche Kitchen Sink	0 ppb
Thornton Academy	Sb 111 Sink 7	3.3 ppb
Thornton Academy	Sb 2nd Floor Boys Bathroom Left Sink	1.8 ppb
Thornton Academy	Sb 2nd Floor Boys Bathroom Middle Sink	0 ppb
Thornton Academy	Sb 2nd Floor Boys Bathroom Right Sink	0 ppb
Thornton Academy	Sb 2nd Floor Girls Bathroom Left Sink	0 ppb
Thornton Academy	Sb 2nd Floor Girls Bathroom Right Sink	0 ppb
Thornton Academy	Sb 2nd Floor Girls Bathroom Solo Sink	0 ppb
Thornton Academy	Sb 2nd Floor Water Fountain	0 ppb
Thornton Academy	Sb Boys Bathroom Left Sink	1 ppb
Thornton Academy	Sb Boys Bathroom Middle Sink	0 ppb
Thornton Academy	Sb Boys Bathroom Right Sink	0 ppb
Thornton Academy	Sb Girls Bathroom Left Sink	5.3 ppb
Thornton Academy	Sb Girls Bathroom Right Sink	2.1 ppb
Thornton Academy	Sb Girls Bathroom Sink On Wall By Itself	1.6 ppb
Thornton Academy	Sb Hallway Bathroom Sink	28.9 ppb

School Name	Sample Location	Lead Test Result
Thornton Academy	Sb Water Fountain	0 ppb
Thornton Academy	Sb Water Fountain With Bottle Fill	0 ppb
Thornton Academy	Sb101 Sink 1	292 ppb
Thornton Academy	Sb101 Sink 10	100 ppb
Thornton Academy	Sb101 Sink 11	592 ppb
Thornton Academy	Sb101 Sink 12	52.3 ppb
Thornton Academy	Sb101 Sink 13	687 ppb
Thornton Academy	Sb101 Sink 2	29.6 ppb
Thornton Academy	Sb101 Sink 3	45.2 ppb
Thornton Academy	Sb101 Sink 4	39.7 ppb
Thornton Academy	Sb101 Sink 5	54.5 ppb
Thornton Academy	Sb101 Sink 6	917 ppb
Thornton Academy	Sb101 Sink 7	947 ppb
Thornton Academy	Sb101 Sink 8	2020 ppb
Thornton Academy	Sb101 Sink 9	141 ppb
Thornton Academy	Sb102 Teacher's Sink	1540 ppb
Thornton Academy	Sb111 Sink #8	430 ppb
Thornton Academy	Sb111 Sink 1	8 ppb
Thornton Academy	Sb111 Sink 2	19.6 ppb
Thornton Academy	Sb111 Sink 3	2.6 ppb
Thornton Academy	Sb111 Sink 4	2.5 ppb
Thornton Academy	Sb111 Sink 5	1.9 ppb
Thornton Academy	Sb111 Sink 6	2.2 ppb
Thornton Academy	Sb112 Sink 1	3.9 ppb
Thornton Academy	Sb112 Sink 2	6.1 ppb
Thornton Academy	Sb112 Sink 3	1.7 ppb
Thornton Academy	Sb112 Sink 4	2.8 ppb
Thornton Academy	Sb112 Sink 5	4.1 ppb
Thornton Academy	Sb112 Sink 6	1.8 ppb
Thornton Academy	Sb112 Sink 7	2.3 ppb
Thornton Academy	Sb115 Bathroom Sink	5.7 ppb
Thornton Academy	Sb117 Sink 1	9.5 ppb
Thornton Academy	Sb117 Sink 10	41 ppb
Thornton Academy	Sb117 Sink 11	167 ppb
Thornton Academy	Sb117 Sink 12	533 ppb
Thornton Academy	Sb117 Sink 13	10 ppb
Thornton Academy	Sb117 Sink 14	11.1 ppb
Thornton Academy	Sb117 Sink 2	9.2 ppb
Thornton Academy	Sb117 Sink 3	277 ppb
Thornton Academy	Sb117 Sink 4	12.5 ppb
Thornton Academy	Sb117 Sink 5	10.2 ppb
Thornton Academy	Sb117 Sink 6	39.5 ppb
Thornton Academy	Sb117 Sink 7	393 ppb
Thornton Academy	Sb117 Sink 8	49.5 ppb
Thornton Academy	Sb117 Sink 9	35.8 ppb
Thornton Academy	Sb119 Sink 1	55 ppb
Thornton Academy	Sb119 Sink 2	36.9 ppb

School Name	Sample Location	Lead Test Result
Thornton Academy	Sb119 Sink 3	23.3 ppb
Thornton Academy	Sb119 Sink 4	63.5 ppb
Thornton Academy	Sb120 Sink 1	698 ppb
Thornton Academy	Sb120 Sink 2	271 ppb
Thornton Academy	Sb120 Sink 3	111 ppb
Thornton Academy	Sb121 Sink 1	43.7 ppb
Thornton Academy	Sb121 Sink 2	585 ppb
Thornton Academy	Sb121 Sink 3	494 ppb
Thornton Academy	Sb121 Sink 4	151 ppb
Thornton Academy	Sb202	221 ppb
Thornton Academy	Sb203 Sink #1	85.3 ppb
Thornton Academy	Sb203 Sink #10	159 ppb
Thornton Academy	Sb203 Sink #11	160 ppb
Thornton Academy	Sb203 Sink #12	933 ppb
Thornton Academy	Sb203 Sink #13	230 ppb
Thornton Academy	Sb203 Sink #14	993 ppb
Thornton Academy	Sb203 Sink #15	262 ppb
Thornton Academy	Sb203 Sink #16	332 ppb
Thornton Academy	Sb203 Sink #17	477 ppb
Thornton Academy	Sb203 Sink #2	365 ppb
Thornton Academy	Sb203 Sink #3	18.2 ppb
Thornton Academy	Sb203 Sink #4	50.9 ppb
Thornton Academy	Sb203 Sink #5	29.7 ppb
Thornton Academy	Sb203 Sink #6	166 ppb
Thornton Academy	Sb203 Sink #7	132 ppb
Thornton Academy	Sb203 Sink #8	1020 ppb
Thornton Academy	Sb203 Sink #9	150 ppb
Thornton Academy	Sb211 Sink #1	1.8 ppb
Thornton Academy	Sb211 Sink #2	3.2 ppb
Thornton Academy	Sb211 Sink #3	4.3 ppb
Thornton Academy	Sb211 Sink #4	18.1 ppb
Thornton Academy	Sb211 Sink #5	5.4 ppb
Thornton Academy	Sb211 Sink #6	2.2 ppb
Thornton Academy	Sb211 Sink #7	18 ppb
Thornton Academy	Sb212 Sink #1	1.7 ppb
Thornton Academy	Sb212 Sink #2	5.6 ppb
Thornton Academy	Sb212 Sink #3	5.8 ppb
Thornton Academy	Sb212 Sink #4	3.1 ppb
Thornton Academy	Sb212 Sink #5	1.4 ppb
Thornton Academy	Sb212 Sink #6	29 ppb
Thornton Academy	Sb212 Sink #7	3.6 ppb
Thornton Academy	Sb212c Chem Closet Sink	16.2 ppb
Thornton Academy	Sb217	9.2 ppb
Thornton Academy	Sb218 Sink In Table	10.7 ppb
Thornton Academy	Sb218 Wall Sink	15.1 ppb
Thornton Academy	Sb2nd Floor Water Fountain Bottle Fill	0 ppb
Thornton Academy	Sh 1st Floor Kitchen Sink By Lounge	0 ppb

School Name	Sample Location	Lead Test Result
Thornton Academy	Sh 1st Floor Water Cooler	3 ppb
Thornton Academy	Sh Second Floor Water Cooler	2 ppb
Thornton Academy	Sink In Overlook Lounge	0 ppb
Thornton Academy	Stadium Spigot By Bathrooms	0 ppb
Thornton Academy	Td 1st Floor Kitchen Sink	0 ppb
Thornton Academy	Td 1st Floor Mens Bathroom Sink	0 ppb
Thornton Academy	Td 1st Floor Water Cooler In Lounge	0 ppb
Thornton Academy	Td 1st Floor Womens Bathroom Sink	0 ppb
Thornton Academy	Td Laundry Sink	0 ppb
Thornton Academy	Td Second Floor Kitchen Sink	0 ppb
Thornton Academy	Td Second Floor Water Cooler	0 ppb
Thornton Academy	Th Staff Bathroom Sink	0 ppb
Thornton Academy	Th Student Bathroom Sink	0 ppb
Thornton Academy	Th Water Fountain	0 ppb
Thornton Academy	Trainers Room Sink	0 ppb
Thornton Academy	Tuttle Apartment Bathroom Sink	0 ppb
Thornton Academy	Tuttle Apartment Kitchen Sink	0 ppb
Thornton Academy	Water Cooler By Gary's Office	0 ppb
Thornton Academy	Water Cooler By Lisa E	0 ppb
Thornton Academy	Water Fountain By Gary's Office	0 ppb
Thornton Academy	Water Fountain By Nurse	0 ppb
Thornton Academy	Water Fountain Near Ms4 Left Side	0 ppb
Thornton Academy	Water Fountain Near Ms4 Right Side	0 ppb
Thornton Academy	Water Supplying Soda Machine	0 ppb
Thornton Academy	Womens Staff Bathroom Left Sink	0 ppb
Tremont Consolidated School	Bottle Fill Station Grammar School Wing	0 ppb
Tremont Consolidated School	Bottle Fill Station Gym	0 ppb
Tremont Consolidated School	Kitchen Double Sink	0 ppb
Tremont Consolidated School	Kitchen Handwash Sink	0 ppb
Tremont Consolidated School	Kitchen Spray Off Sink	0 ppb
Tremont Consolidated School	Nurses Bathroom Sink	1.9 ppb
Tremont Consolidated School	Teachers Room Sink	0 ppb
Trenton Elementary School	3-5 Water Fountain	0 ppb
Trenton Elementary School	6-8 Water Fountain	0 ppb
Trenton Elementary School	Art Room Sink	1.3 ppb
Trenton Elementary School	Boy's Locker Room 1st Sink	1.3 ppb
Trenton Elementary School	Girl's Locker Room 1st Sink	2.4 ppb
Trenton Elementary School	Gym Water Fountain	0 ppb
Trenton Elementary School	K-2 Drinking Water Fountain	0 ppb
Trenton Elementary School	Kitchen Sink By Stove	5.6 ppb
Trenton Elementary School	Nurses Room	3.4 ppb
Trenton Elementary School	Pre-k Sink	1.8 ppb
Tri-County Technical Center	Kitchen 3 Bay Sink	3.5 ppb
Tri-County Technical Center	Kitchen Serving Line Sink	7.1 ppb
Tri-County Technical Center	Kitchen Veggie Sink	5.4 ppb
Tri-County Technical Center	Main Hall Fountain	0 ppb
Tri-County Technical Center	Metals Bathroom Sink	4.3 ppb

School Name	Sample Location	Lead Test Result
Tri-County Technical Center	Metals Fountain	0 ppb
Tri-County Technical Center	Staff Bathroom Sink	6.9 ppb
Tri-County Technical Center	Truckdriving Boys Bathroom	1.6 ppb
Tri-County Technical Center	Truckdriving Fountain	39 ppb
Tri-County Technical Center	Truckdriving Girls Bathroom	1.5 ppb
Tripp Middle School	Bengal Wing Bottle Fill	0 ppb
Tripp Middle School	Bengal Wing Fountain	0 ppb
Tripp Middle School	Bengal Wing Staff Bathroom Faucet	0 ppb
Tripp Middle School	Boys Bathroom Faucet Near Door 16	0 ppb
Tripp Middle School	Boys Locker Room Faucet Left	0 ppb
Tripp Middle School	Boys Locker Room Faucet Right	0 ppb
Tripp Middle School	Downstairs A. D. Office Faucet	1.4 ppb
Tripp Middle School	Downstairs Bathroom By A.d. Office Faucet	0 ppb
Tripp Middle School	Downstairs Bottle Fill	0 ppb
Tripp Middle School	Downstairs Boys Bathroom Faucet Left	0 ppb
Tripp Middle School	Downstairs Boys Bathroom Faucet Right	0 ppb
Tripp Middle School	Downstairs Fountain	0 ppb
Tripp Middle School	Downstairs Girls Bathroom Faucet Left	0 ppb
Tripp Middle School	Downstairs Girls Bathroom Faucet Right	0 ppb
Tripp Middle School	Downstairs Utility Room Faucet	3.4 ppb
Tripp Middle School	Girls Bathroom Faucet Near Door 16	0 ppb
Tripp Middle School	Girls Locker Room Faucet Left	1.4 ppb
Tripp Middle School	Girls Locker Room Faucet Right	0 ppb
Tripp Middle School	Gym Bottle Fill	0 ppb
Tripp Middle School	Gym Fountain	0 ppb
Tripp Middle School	Gym Mens Room Faucet	1.2 ppb
Tripp Middle School	Gym Womens Room Faucet	0 ppb
Tripp Middle School	Hallway Fountain Short	0 ppb
Tripp Middle School	Hallway Fountain Tall	0 ppb
Tripp Middle School	Kitchen 3 Bay Sink Left	4.2 ppb
Tripp Middle School	Kitchen 3 Bay Sink Right	1.6 ppb
Tripp Middle School	Kitchen Handwash Sink Faucet	1.3 ppb
Tripp Middle School	Kitchen Prep Sink Faucet	1.4 ppb
Tripp Middle School	Kitchen Prep Sink Spray Hose	4.2 ppb
Tripp Middle School	Library Work Room Faucet	7.1 ppb
Tripp Middle School	Office Staff Bathroom Faucet	0 ppb
Tripp Middle School	Room 101 Handwash Sink Faucet	0 ppb
Tripp Middle School	Room 101 Sink Left Faucet	4 ppb
Tripp Middle School	Room 101 Sink Middle Faucet	76.5 ppb
Tripp Middle School	Room 101 Sink Right Faucet	12.1 ppb
Tripp Middle School	Room 102 Handwash Sink By Door Faucet	0 ppb
Tripp Middle School	Room 102 Handwash Sink In Corner Faucet	1.8 ppb
Tripp Middle School	Room 102 Sink Faucet Left	5.3 ppb
Tripp Middle School	Room 102 Sink Faucet Middle	4.7 ppb
Tripp Middle School	Room 102 Sink Faucet Right	3.8 ppb
Tripp Middle School	Room 208 Faucet Left	6.5 ppb

School Name	Sample Location	Lead Test Result
Tripp Middle School	Room 208 Faucet Right	0 ppb
Tripp Middle School	Room 211 Faucet	4.5 ppb
Tripp Middle School	Room 222 Faucet	1.6 ppb
Tripp Middle School	Room 226 Faucet Left	2.4 ppb
Tripp Middle School	Room 226 Faucet Right	2.9 ppb
Tripp Middle School	Room 226 Teacher's Station Faucet	18.9 ppb
Tripp Middle School	Room 227 Faucet Left	3.5 ppb
Tripp Middle School	Room 227 Faucet Right	5.9 ppb
Tripp Middle School	Room 227 Teacher's Station Faucet	10.4 ppb
Tripp Middle School	Room 254 Inside Faucet Left	0 ppb
Tripp Middle School	Room 254 Inside Faucet Right	3.8 ppb
Tripp Middle School	Room 254 Outside Faucet Left	1.9 ppb
Tripp Middle School	Room 254 Outside Faucet Right	2.4 ppb
Tripp Middle School	Room 254 Teacher's Station Faucet	7.2 ppb
Tripp Middle School	Siberian Wing Bottle Fill	0 ppb
Tripp Middle School	Siberian Wing Boys Bathroom Faucet	0 ppb
Tripp Middle School	Siberian Wing Fountain	0 ppb
Tripp Middle School	Siberian Wing Girls Bathroom Faucet Left	1.4 ppb
Tripp Middle School	Siberian Wing Girls Bathroom Faucet Right	0 ppb
Tripp Middle School	Siberian Wing Staff Bathroom Faucet	0 ppb
Tripp Middle School	Storage Room Sink Across 102	14.8 ppb
Tripp Middle School	Unisex Bathroom Left Faucet Near Door 16	1.2 ppb
Tripp Middle School	Unisex Bathroom Right Faucet Near Door 16	0 ppb
Tripp Middle School	Wildcat Wing Bottle Fill	0 ppb
Tripp Middle School	Wildcat Wing Fountain	0 ppb
Tripp Middle School	Wildcat Wing Staff Bathroom Faucet	0 ppb
Tripp Middle School	Wildcat Wing Staff Room Faucet	0 ppb
Troy A Howard Middle School	Back Of Room 115	3.1 ppb
Troy A Howard Middle School	Back Of Room 116	13.4 ppb
Troy A Howard Middle School	Back Of Room 215	413 ppb
Troy A Howard Middle School	Back Of Room 216	24.8 ppb
Troy A Howard Middle School	Classroom 112	2.2 ppb
Troy A Howard Middle School	Classroom 113	2.4 ppb
Troy A Howard Middle School	Classroom 114	4.3 ppb
Troy A Howard Middle School	Classroom 115	11.7 ppb
Troy A Howard Middle School	Classroom 116	15.4 ppb
Troy A Howard Middle School	Classroom 210	1.1 ppb
Troy A Howard Middle School	Classroom 212	2.9 ppb
Troy A Howard Middle School	Classroom 213	0 ppb
Troy A Howard Middle School	Classroom 214	4.2 ppb
Troy A Howard Middle School	Classroom 215	7 ppb
Troy A Howard Middle School	Classroom 216	8.5 ppb
Troy A Howard Middle School	Fountain Outside Gym Door	0 ppb
Troy A Howard Middle School	Gym Fountain	0 ppb
Troy A Howard Middle School	Kitchen 1	0 ppb
Troy A Howard Middle School	Kitchen 2	0 ppb

School Name	Sample Location	Lead Test Result
Troy A Howard Middle School	Kitchen 3	3.2 ppb
Troy A Howard Middle School	Kitchen 4	0 ppb
Troy A Howard Middle School	Kitchen 5	0 ppb
Troy A Howard Middle School	Kitchen 6	0 ppb
Troy A Howard Middle School	Main Office	1.1 ppb
Troy A Howard Middle School	Old Home Ec Classroom 1	4.4 ppb
Troy A Howard Middle School	Old Home Ec Classroom 2	7.4 ppb
Troy A Howard Middle School	Old Home Ec Classroom 3	9.4 ppb
Troy A Howard Middle School	Old Home Ec Classroom 4	6 ppb
Troy Central School	Art Storage Sink	24.9 ppb
Troy Central School	Faculty Room- Bathroom Sink	2.3 ppb
Troy Central School	Faculty Room- Kitchen Sink	2 ppb
Troy Central School	First Grade Classroom- Fountain	2.4 ppb
Troy Central School	First Grade Classroom- Handwash Sink	0 ppb
Troy Central School	Gym Bathroom- Handwash Sink	1.5 ppb
Troy Central School	K Classroom- Fountain	0 ppb
Troy Central School	K Classroom- Handwash Sink	0 ppb
Troy Central School	Kitchen- Dishwasher Rinse Station Spray	21.6 ppb
Troy Central School	Kitchen- Handwash Sink	7.1 ppb
Troy Central School	Kitchen- Single Bay Prep Fixture	2.9 ppb
Troy Central School	Kitchen- Single Bay Prep Sprayer	1.9 ppb
Troy Central School	Kitchen- Three Bay Prep Fixture #1	12.5 ppb
Troy Central School	Kitchen- Three Bay Prep Fixture #2	2.4 ppb
Troy Central School	Kitchen- Three Bay Prep Sprayer	1.4 ppb
Troy Central School	Library Sink	9.1 ppb
Troy Central School	Ni-6 Wing- Bottle Fill Station	0 ppb
Troy Central School	Ni-6 Wing- Fountain	0 ppb
Troy Central School	Older Age Wing- Bottle Fill Station	0 ppb
Troy Central School	Older Age Wing- Boys Bathroom Handwash Sink A	1.8 ppb
Troy Central School	Older Age Wing- Boys Bathroom Handwash Sink B	0 ppb
Troy Central School	Older Age Wing Classroom 2- Sprayer A	97.6 ppb
Troy Central School	Older Age Wing Classroom 2- Sprayer B	1.7 ppb
Troy Central School	Older Age Wing Classroom 2-handwash Sink A	4.6 ppb
Troy Central School	Older Age Wing Classroom 2-handwash Sink B	1240 ppb
Troy Central School	Older Age Wing- Fountain	0 ppb
Troy Central School	Older Age Wing-girls Bathroom Handwash Sink A	1.2 ppb
Troy Central School	Older Age Wing-girls Bathroom Handwash Sink B	4.8 ppb
Troy Central School	Second Grade Classroom- Fountain	2.9 ppb
Troy Central School	Second Grade Classroom- Handwash Sink	0 ppb
Turner Elementary School	A Wing Boys Bathroom Faucet Left	32.7 ppb
Turner Elementary School	A Wing Boys Bathroom Faucet Right	2.9 ppb

School Name	Sample Location	Lead Test Result
Turner Elementary School	A Wing Girls Bathroom Faucet Left	2.7 ppb
Turner Elementary School	A Wing Girls Bathroom Faucet Right	9.5 ppb
Turner Elementary School	B Wing Boys Bathroom Faucet Left	5 ppb
Turner Elementary School	B Wing Boys Bathroom Faucet Right	2.4 ppb
Turner Elementary School	B Wing Girls Bathroom Faucet Left	1.4 ppb
Turner Elementary School	B Wing Girls Bathroom Faucet Right	2.8 ppb
Turner Elementary School	Bottle Fill Near Library	0 ppb
Turner Elementary School	Boys Bathroom Hallway Faucet	0 ppb
Turner Elementary School	Boys Shower Room Faucet	0 ppb
Turner Elementary School	C Wing Boys Bathroom Faucet Left	2 ppb
Turner Elementary School	C Wing Boys Bathroom Faucet Right	9 ppb
Turner Elementary School	C Wing Girls Bathroom Faucet Left	2.1 ppb
Turner Elementary School	C Wing Girls Bathroom Faucet Right	3.7 ppb
Turner Elementary School	Cafeteria Bottle Fill	0 ppb
Turner Elementary School	Cafeteria Fountain	0 ppb
Turner Elementary School	Fountain Near Library	0 ppb
Turner Elementary School	Girls Bathroom Hallway Faucet	0 ppb
Turner Elementary School	Girls Shower Room Faucet	0 ppb
Turner Elementary School	Gym Boys Bathroom Faucet	3 ppb
Turner Elementary School	Gym Girls Bathroom Faucet	3.9 ppb
Turner Elementary School	Jp Hallway Fountain	0 ppb
Turner Elementary School	Jp Wing Hallway Bottle Fill	0 ppb
Turner Elementary School	Kitchen 3 Bay Sink Faucet	9.8 ppb
Turner Elementary School	Kitchen Bathroom Sink Faucet	8.1 ppb
Turner Elementary School	Kitchen Handwash Sink Faucet	12.4 ppb
Turner Elementary School	Kitchen Prep Sink Faucet	17.1 ppb
Turner Elementary School	Kitchen Prep Sink Spray Hose	24.8 ppb
Turner Elementary School	Kitchen Tilt Skillet Faucet	28.1 ppb
Turner Elementary School	Room 010 Office Fountain	6.1 ppb
Turner Elementary School	Room 010 Staff Bathroom Faucet	6.7 ppb
Turner Elementary School	Room 010d Upstairs Bathroom Left Faucet	19.5 ppb
Turner Elementary School	Room 010d Upstairs Bathroom Right Faucet	7.2 ppb
Turner Elementary School	Room 010d Upstairs Kitchenette Faucet	19.6 ppb
Turner Elementary School	Room 010e Nurse Room Faucet	6 ppb
Turner Elementary School	Room 101 Faucet	6.1 ppb
Turner Elementary School	Room 101 Fountain	8.9 ppb
Turner Elementary School	Room 102 Faucet	19.8 ppb
Turner Elementary School	Room 102 Fountain	12.6 ppb
Turner Elementary School	Room 103 Faucet	18 ppb
Turner Elementary School	Room 103 Fountain	8.4 ppb
Turner Elementary School	Room 104 Faucet	8.2 ppb
Turner Elementary School	Room 104 Fountain	4.8 ppb
Turner Elementary School	Room 105 Faucet	4.4 ppb
Turner Elementary School	Room 105 Fountain	3.3 ppb
Turner Elementary School	Room 106 Faucet	0 ppb
Turner Elementary School	Room 106 Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Turner Elementary School	Room 201 Faucet	9.7 ppb
Turner Elementary School	Room 201 Fountain	10.7 ppb
Turner Elementary School	Room 202 Faucet	11.5 ppb
Turner Elementary School	Room 202 Fountain	4.9 ppb
Turner Elementary School	Room 203 Faucet	7.4 ppb
Turner Elementary School	Room 203 Fountain	4.8 ppb
Turner Elementary School	Room 204 Faucet	14.1 ppb
Turner Elementary School	Room 204 Fountain	10.3 ppb
Turner Elementary School	Room 205 Faucet	13.2 ppb
Turner Elementary School	Room 205 Fountain	2.8 ppb
Turner Elementary School	Room 206 Faucet	14.8 ppb
Turner Elementary School	Room 206 Fountain	9.2 ppb
Turner Elementary School	Room 301 Faucet	22.5 ppb
Turner Elementary School	Room 301 Fountain	15 ppb
Turner Elementary School	Room 302 Faucet	28.3 ppb
Turner Elementary School	Room 302 Fountain	21 ppb
Turner Elementary School	Room 303 Faucet	16.4 ppb
Turner Elementary School	Room 303 Fountain	8.5 ppb
Turner Elementary School	Room 304 Faucet	9.7 ppb
Turner Elementary School	Room 304 Fountain	5.8 ppb
Turner Elementary School	Room 305 Faucet	3.2 ppb
Turner Elementary School	Room 305 Fountain	1.6 ppb
Turner Elementary School	Room 306 Faucet	5.6 ppb
Turner Elementary School	Room 306 Fountain	2.8 ppb
Turner Elementary School	Room 402 Faucet	1.5 ppb
Turner Elementary School	Room 402 Fountain	11.6 ppb
Turner Elementary School	Room 403 Faucet	2.7 ppb
Turner Elementary School	Room 403 Fountain	22.4 ppb
Turner Elementary School	Room 404 Faucet	2 ppb
Turner Elementary School	Room 404 Fountain	2.6 ppb
Turner Elementary School	Room 406 Faucet	5.6 ppb
Turner Elementary School	Room 406 Fountain	55.2 ppb
Turner Elementary School	Room 407 Faucet	0 ppb
Turner Elementary School	Room 407 Fountain	4.6 ppb
Turner Elementary School	Staff Bathroom Sink Faucet 406/407	0 ppb
Turner Primary School	Bottle Fill Cafeteria	0 ppb
Turner Primary School	Bottle Fill Near 148	0 ppb
Turner Primary School	Boys Bathroom Faucet Left	0 ppb
Turner Primary School	Boys Bathroom Faucet Right	0 ppb
Turner Primary School	Cafeteria Dining Room Sink Faucet	1.1 ppb
Turner Primary School	Fountain Cafeteria	0 ppb
Turner Primary School	Fountain Near 148	0 ppb
Turner Primary School	Girls Bathroom Faucet Left	1.3 ppb
Turner Primary School	Girls Bathroom Faucet Right	0 ppb
Turner Primary School	Kitchen 3 Bay Sink Faucet	0 ppb
Turner Primary School	Kitchen Bathroom Sink Faucet	20.9 ppb
Turner Primary School	Kitchen Handwash Sink Faucet	3.1 ppb

School Name	Sample Location	Lead Test Result
Turner Primary School	Kitchen Prep Sink Spray Hose	2.7 ppb
Turner Primary School	Room 106 Office Faucet	0 ppb
Turner Primary School	Room 113 Faucet	0 ppb
Turner Primary School	Room 113 Fountain	6.3 ppb
Turner Primary School	Room 114 Faucet	0 ppb
Turner Primary School	Room 114 Fountain	2.6 ppb
Turner Primary School	Room 115 Faucet	0 ppb
Turner Primary School	Room 115 Fountain	2 ppb
Turner Primary School	Room 117 Faucet	0 ppb
Turner Primary School	Room 117 Fountain	3.7 ppb
Turner Primary School	Room 118 Faucet	4.6 ppb
Turner Primary School	Room 118 Fountain	0 ppb
Turner Primary School	Room 121 Faucet	1.1 ppb
Turner Primary School	Room 121 Fountain	9.7 ppb
Turner Primary School	Room 122 Faucet	0 ppb
Turner Primary School	Room 122 Fountain	2.4 ppb
Turner Primary School	Room 125 Faucet	0 ppb
Turner Primary School	Room 125 Fountain	10.1 ppb
Turner Primary School	Room 126 Faucet	6.3 ppb
Turner Primary School	Room 126 Fountain	0 ppb
Turner Primary School	Room 128 Faucet	0 ppb
Turner Primary School	Room 128 Fountain	19.8 ppb
Turner Primary School	Room 129 Faucet	3.2 ppb
Turner Primary School	Room 129 Fountain	0 ppb
Turner Primary School	Room 130 Faucet	0 ppb
Turner Primary School	Room 133 Faucet Left	1.7 ppb
Turner Primary School	Room 133 Faucet Right	2.6 ppb
Turner Primary School	Room 135 Faucet	2.2 ppb
Turner Primary School	Room 136 Faucet	0 ppb
Turner Primary School	Room 159 Faucet	35.5 ppb
Turner Primary School	Room 160 Faucet	30.2 ppb
Turner Primary School	Room 161a Faucet	0 ppb
Turner Primary School	Room 163 Faucet	12.2 ppb
Turner Primary School	Room 170 Faucet	1.1 ppb
Turner Primary School	Room 170 Fountain	7 ppb
Turner Primary School	Room 171 Faucet	0 ppb
Turner Primary School	Room 171 Fountain	2.2 ppb
Turner Primary School	Room 172 Faucet	0 ppb
Turner Primary School	Room 172 Fountain	2.6 ppb
Turner Primary School	Room 174 Faucet	0 ppb
Turner Primary School	Room 174 Fountain	1.5 ppb
Turner Primary School	Room 175 Faucet	2.2 ppb
Turner Primary School	Room 175 Fountain	4 ppb
Turner Primary School	Room 181 Faucet	0 ppb
Turner Primary School	Room 181 Fountain	3.2 ppb
Turner Primary School	Room 182 Faucet	0 ppb
Turner Primary School	Room 182 Fountain	2.8 ppb

School Name	Sample Location	Lead Test Result
Turner Primary School	Room 184 Faucet	0 ppb
Turner Primary School	Room 184 Fountain	3 ppb
Turner Primary School	Room 185 Faucet	0 ppb
Turner Primary School	Room 185 Fountain	1.7 ppb
Turner Primary School	Room 186 Faucet	0 ppb
Turner Primary School	Room 186 Fountain	6.8 ppb
UCP of Maine Sch	Classroom Bathroom	9.9 ppb
UCP of Maine Sch	Kitchen	1.6 ppb
Union Elementary	#103 Art Bubbler	1.8 ppb
Union Elementary	#103 Art Sink	2.4 ppb
Union Elementary	#107 Resource Room Bubbler	0 ppb
Union Elementary	#107 Resource Room Sink	2.4 ppb
Union Elementary	#120 5th Grade Bubbler	4.2 ppb
Union Elementary	#120 5th Grade Sink	14.8 ppb
Union Elementary	#121 4th Grade Bubbler	5 ppb
Union Elementary	#121 4th Grade Sink	3.3 ppb
Union Elementary	#125 2nd Grade Bubbler	0 ppb
Union Elementary	#125 2nd Grade Sink	3.4 ppb
Union Elementary	#126 6th Grade Bubbler	6.7 ppb
Union Elementary	#126 6th Grade Sink	3.7 ppb
Union Elementary	#127 3rd Grade Bubbler	3.9 ppb
Union Elementary	#127 3rd Grade Sink	0 ppb
Union Elementary	#131 1st Grade Bubbler	5.4 ppb
Union Elementary	#131 1st Grade Sink	3.7 ppb
Union Elementary	#133 Pre K Bubbler	51.5 ppb
Union Elementary	#133 Pre K Sink	1.5 ppb
Union Elementary	#140 Custodian Closet Sink	0 ppb
Union Elementary	#142 Office Bubbler	39 ppb
Union Elementary	#142 Office Sink	29.3 ppb
Union Elementary	#151 Kindergarten Bathroom Sink	0 ppb
Union Elementary	#151 Kindergarten Bubbler	33.6 ppb
Union Elementary	#151 Kindergarten Sink	2.3 ppb
Union Elementary	Bathroom 1 Hallway Across From Office Sink	0 ppb
Union Elementary	Bathroom 2 Hallway Across From Office Sink	0 ppb
Union Elementary	Bottle Filling Station Hallway In Lobby	0 ppb
Union Elementary	Bottle Filling Station Hallway In Lobby Bubbler	2.1 ppb
Union Elementary	Boys Bathroom Across From Resource Rm 2 Sinks	0 ppb
Union Elementary	Boy's Bathroom Hallway 2 Sinks	0 ppb
Union Elementary	Clinic Bathroom Sink	0 ppb
Union Elementary	Clinic Room Sink	1.5 ppb
Union Elementary	Girls Bathroom By Resource Room 2 Sinks	0 ppb
Union Elementary	Girls Bathroom Hallway 2 Sinks	1.1 ppb
Union Elementary	Gym Locker Boys/storage 2 Sinks	14 ppb

School Name	Sample Location	Lead Test Result
Union Elementary	Gym Locker Girls /storage 2 Sinks	1.4 ppb
Union Elementary	Kitchen 3 Bay Sink	2.7 ppb
Union Elementary	Kitchen Handwash Sink	6.2 ppb
Union Elementary	Library 2 Sinks	16.3 ppb
Union Elementary	Staff Bathroom By Kitchen	3.1 ppb
Union Elementary	Teacher Lounge Sink	1.3 ppb
United Technologies Ctr-Region 4	Bottle Filler In Cvc Hallway	0 ppb
United Technologies Ctr-Region 4	Bottle Filler In Enh Hallway	0 ppb
United Technologies Ctr-Region 4	Bottle Filler In Hoc Hallway	0 ppb
United Technologies Ctr-Region 4	Bottle Filler In Opr Hallway	0 ppb
United Technologies Ctr-Region 4	Bottle Filler In Plumbing Hallway	0 ppb
United Technologies Ctr-Region 4	Delivery Water Line Rm Behind Plumb Class Rm	7.8 ppb
United Technologies Ctr-Region 4	Food Prep Sink #1	0 ppb
United Technologies Ctr-Region 4	Food Prep Sink #2	1.9 ppb
United Technologies Ctr-Region 4	Food Prep Sink #3	24.4 ppb
United Technologies Ctr-Region 4	Food Prep Sink #4	0 ppb
United Technologies Ctr-Region 4	Large Coffee Maker At Server Window	45.7 ppb
United Technologies Ctr-Region 4	Large Coffee Maker In Book Store	21.9 ppb
United Technologies Ctr-Region 4	Server Ice Maker	0 ppb
United Technologies Ctr-Region 4	Server Prep Sink (drinking Pitcher)	2.5 ppb
United Technologies Ctr-Region 4	Sink Next To Clothes Dryer In Hoc	3.8 ppb
United Technologies Ctr-Region 4	Sink Next To Clothes Dryer In Hog	16 ppb
Unity Elementary School	Across Pre-k Classroom B- Bathroom Sink	7.4 ppb
Unity Elementary School	Across Pre-k Classroom B- Kitchen Sink- Handwash	0 ppb
Unity Elementary School	Classroom 3- Fountain	28.5 ppb
Unity Elementary School	Classroom 3- Handwash Sink	8.9 ppb
Unity Elementary School	Co Bathroom- Handwash Sink #1	0 ppb
Unity Elementary School	Co Bathroom- Handwash Sink #2	0 ppb
Unity Elementary School	Co Bathroom Nook	3 ppb
Unity Elementary School	Co- Bottle Fill Station	0 ppb
Unity Elementary School	Co Conference Room- Bathroom Handwash Sink	5.3 ppb
Unity Elementary School	Co- Fountain	0 ppb
Unity Elementary School	Pre-k Classroom A- Fountain	12 ppb
Unity Elementary School	Pre-k Classroom A- Handwash Sink	0 ppb
Unity Elementary School	Pre-k Classroom B- Fountain	13.6 ppb
Unity Elementary School	Pre-k Classroom B- Handwash Sink	6 ppb
Unity Elementary School	Pre-k Classroom C- Fountain	12.2 ppb
Unity Elementary School	Pre-k Classroom C- Handwash Sink	1.6 ppb
Unity Elementary School	School Kitchen- Dishwasher Rinse Station	22.7 ppb
Unity Elementary School	School Kitchen- Handwash Sink	2.3 ppb
Unity Elementary School	School Kitchen- Three Bay Wash	33.9 ppb
Unity Elementary School	School Kitchen- Two Bay Food Prep	17.7 ppb
Unity Elementary School	School Side- Bottle Fill Station	0 ppb
Unity Elementary School	School Side Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Unity Elementary School	School Side Mens Bathroom- Handwash Sink	2.5 ppb
Unity Elementary School	School Side Womens Bathroom-handwash Sink	1.6 ppb
Unity Elementary School	Staff Bathroom- Handwash Sink	0 ppb
Upper Kennebec Valley Middle/Senior High S	Bottle Filler - Academic Wing	0 ppb
Upper Kennebec Valley Middle/Senior High S	Bottle Filler - Admin Wing	0 ppb
Upper Kennebec Valley Middle/Senior High S	Bottle Filler - Gym	1.9 ppb
Upper Kennebec Valley Middle/Senior High S	Bottle Filler - Near Library	0 ppb
Upper Kennebec Valley Middle/Senior High S	Kitchen Sink 1	0 ppb
Upper Kennebec Valley Middle/Senior High S	Kitchen Sink 2	0 ppb
Upper Kennebec Valley Middle/Senior High S	Sink Consumer Science Room	1.6 ppb
Upper Kennebec Valley Middle/Senior High S	Sink Teachers' Room	2.4 ppb
Van Buren District School District	Bottle Fill Station 4th Floor Near Elevator	0 ppb
Van Buren District School District	Bottle Fill Station 4th Floor Near Gym	0 ppb
Van Buren District School District	Bottle Fill Station Across Nurses Rm	0 ppb
Van Buren District School District	Bottle Fill Station Gateway Across Rm 105	0 ppb
Van Buren District School District	Bottle Fill Station In Cafe	0 ppb
Van Buren District School District	Double Basin Sink Home Ec-a	18.1 ppb
Van Buren District School District	Double Basin Sink Home Ec-b	4 ppb
Van Buren District School District	Double Basin Sink Home Ec-c	2.4 ppb
Van Buren District School District	Double Basin Sink In Nurses Rm	3.5 ppb
Van Buren District School District	Double Basin Sink Kitchen Near Break Rm	3.5 ppb
Van Buren District School District	Double Basin Sink Kitchen Near Freezer	4.8 ppb
Van Buren District School District	Steamer Middle Of Kitchen	7620 ppb
Vassalboro Community School	Faucet In Sped Room #305	1.9 ppb
Vassalboro Community School	Kitchen Kettle Fill Faucet	4.4 ppb
Vassalboro Community School	Kitchen Prep Sink	6.3 ppb
Vassalboro Community School	Nurses Room Sink	7 ppb
Vassalboro Community School	Room 109	0 ppb
Vassalboro Community School	Room 119	13.9 ppb
Vassalboro Community School	Room 121	1.3 ppb
Vassalboro Community School	Room 123	2.6 ppb
Vassalboro Community School	Room 124	1.3 ppb
Vassalboro Community School	Room 125	0 ppb
Vassalboro Community School	Room 126	1.2 ppb
Vassalboro Community School	Room 127	1.8 ppb
Vassalboro Community School	Room 128	2.5 ppb
Vassalboro Community School	Room 131 Pre-k	1.2 ppb
Vassalboro Community School	Sped Lab In New Area	0 ppb
Vassalboro Community School	Teachers Lounge	2.9 ppb
Vassalboro Community School	Water Fountain 4-5 Wing	0 ppb
Vassalboro Community School	Water Fountain 7-8 Wing	0 ppb
Vassalboro Community School	Water Fountain Basement	0 ppb
Vassalboro Community School	Water Fountain By By Library	0 ppb
Vassalboro Community School	Water Fountain By Gym	0 ppb
Veazie Community School	Art Room Sink 1	1.2 ppb

School Name	Sample Location	Lead Test Result
Veazie Community School	Art Room Sink 2	1.7 ppb
Veazie Community School	Chandler Fountain	0 ppb
Veazie Community School	Chandler Sink	1.9 ppb
Veazie Community School	Cobb Fountain	2.6 ppb
Veazie Community School	Cobb Sink	1.5 ppb
Veazie Community School	Daigneau Fountain	0 ppb
Veazie Community School	Daigneau Sink	2.2 ppb
Veazie Community School	Frazier Fountain	0 ppb
Veazie Community School	Frazier Sink	4.1 ppb
Veazie Community School	Gonyar Fountain	0 ppb
Veazie Community School	Gonyar Sink	1.7 ppb
Veazie Community School	Gym Bottle Station	0 ppb
Veazie Community School	Gym Fountain	0 ppb
Veazie Community School	Hileman Fountain	0 ppb
Veazie Community School	Hileman Sink	2.4 ppb
Veazie Community School	Humphrey Fountain	0 ppb
Veazie Community School	Humphrey Sink	2 ppb
Veazie Community School	Int. Spare Fountain	1 ppb
Veazie Community School	Int. Spare Sink	4.3 ppb
Veazie Community School	Kimball Fountain	0 ppb
Veazie Community School	Kimball Sink	2.4 ppb
Veazie Community School	Kitchen Big Hw	4.8 ppb
Veazie Community School	Kitchen Big Sink	3.1 ppb
Veazie Community School	Kitchen Sm Hw	5.1 ppb
Veazie Community School	Library Sink	1.4 ppb
Veazie Community School	Lobby Bottle Station	0 ppb
Veazie Community School	Lobby Fountain	0 ppb
Veazie Community School	Middle School Bottle Station	0 ppb
Veazie Community School	Nurse Clinic	2.5 ppb
Veazie Community School	P.spare Fountain	2.2 ppb
Veazie Community School	P.spare Sink	1.8 ppb
Veazie Community School	Prek Fountain	0 ppb
Veazie Community School	Prek Sink	1.4 ppb
Veazie Community School	Primary Bottle Station	0 ppb
Veazie Community School	Resource Room Fountain	0 ppb
Veazie Community School	Resource Room Sink	2.2 ppb
Veazie Community School	Science Lab Fountain	3.4 ppb
Veazie Community School	Science Lab Sink 1	2.5 ppb
Veazie Community School	Science Lab Sink 2	2.9 ppb
Veazie Community School	Science Lab Sink 3	5.3 ppb
Veazie Community School	Science Lab Sink 4	4.4 ppb
Veazie Community School	Science Lab Sink 5	3 ppb
Veazie Community School	Teacher Lounge Sink	1.4 ppb
Vickery School	1st Portable Right Bathroom Sink	0 ppb
Vickery School	2nd Portable Left Bathroom Sink	0 ppb
Vickery School	3rd Portable Bottle Fill Station Entryway	0 ppb
Vickery School	4th Portable Bottle Fill Station Entryway	0 ppb

School Name	Sample Location	Lead Test Result
Vickery School	Bfs-across Room 16	0 ppb
Vickery School	Bottle Fill Station - Across Room 1	0 ppb
Vickery School	Bottle Fill Station - Across Room 12	0 ppb
Vickery School	Kitchen 2 Bay Sink	0 ppb
Vickery School	Kitchen Combi Oven Steamer	3.3 ppb
Vickery School	Kitchen Kettle	0 ppb
Vickery School	Kitchen Steamer	97.1 ppb
Vickery School	Main Office Sink	0 ppb
Vickery School	Nurse's Bathroom Sink	5.4 ppb
Vickery School	Teacher's Lounge Sink	1.1 ppb
Village Elementary School-Gorham	Between Gang Bathrooms By K Wing A	0 ppb
Village Elementary School-Gorham	Between Gang Bathrooms By K Wing B	0 ppb
Village Elementary School-Gorham	By Gym Across From Door 4-a	0 ppb
Village Elementary School-Gorham	By Gym Across From Door 4-b	0 ppb
Village Elementary School-Gorham	Cafe	0 ppb
Village Elementary School-Gorham	Kitchen-a	2 ppb
Village Elementary School-Gorham	Kitchen-b	2.1 ppb
Village Elementary School-Gorham	Kitchen-c	5.2 ppb
Village Elementary School-Gorham	Near 4-5 By Teacher Lounge-a	0 ppb
Village Elementary School-Gorham	Near 4-5 By Teacher Lounge-b	0 ppb
Village Elementary School-Gorham	Room 1	2.1 ppb
Village Elementary School-Gorham	Room 10	1.2 ppb
Village Elementary School-Gorham	Room 11	1 ppb
Village Elementary School-Gorham	Room 2	2.1 ppb
Village Elementary School-Gorham	Sink In Teacher Lounge	0 ppb
Village Elementary School-York	1st Grade Boys Bathroom Left Sink	1 ppb
Village Elementary School-York	1st Grade Boys Bathroom Right Sink	0 ppb
Village Elementary School-York	1st Grade Girls Bathroom Left Sink	1.6 ppb
Village Elementary School-York	1st Grade Girls Bathroom Middle Sink	0 ppb
Village Elementary School-York	1st Grade Girls Bathroom Right Sink	0 ppb
Village Elementary School-York	Art Room Sink	11.3 ppb
Village Elementary School-York	Cafe Boys Bathroom Left Sink	0 ppb
Village Elementary School-York	Cafe Boys Bathroom Right Sink	1.1 ppb
Village Elementary School-York	Cafe Girls Bathroom Left Sink	0 ppb
Village Elementary School-York	Cafe Girls Bathroom Right Sink	1.2 ppb
Village Elementary School-York	K Boys Bathroom Sink Left	6.3 ppb
Village Elementary School-York	K Boys Bathroom Sink Right	7.4 ppb
Village Elementary School-York	K Girls Bathroom Sink Left	0 ppb
Village Elementary School-York	K Girls Bathroom Sink Right	0 ppb
Village Elementary School-York	K Kitchen Sink Rm 151	0 ppb
Village Elementary School-York	Kitchen 3 Gang Sink	73.8 ppb
Village Elementary School-York	Kitchen Bathroom Sink	1.6 ppb
Village Elementary School-York	Kitchen Dishwasher Sink	8.6 ppb
Village Elementary School-York	Kitchen Handwash Sink	3 ppb
Village Elementary School-York	Kitchen Pan Sink	4 ppb
Village Elementary School-York	Rm 101 Bathroom Sink	12.8 ppb
Village Elementary School-York	Rm 104 Bathroom Sink	0 ppb

School Name	Sample Location	Lead Test Result
Village Elementary School-York	Rm 104 Ss Sink	1.7 ppb
Village Elementary School-York	Rm 106 Bathroom Sink	3.3 ppb
Village Elementary School-York	Rm 110 Class Room Sink	1.2 ppb
Village Elementary School-York	Rm 120 Sink	5.9 ppb
Village Elementary School-York	Rm 121 Sink	29.4 ppb
Village Elementary School-York	Rm 122 Sink	5.6 ppb
Village Elementary School-York	Rm 123 Sink	7.9 ppb
Village Elementary School-York	Rm 130 Sink	9 ppb
Village Elementary School-York	Rm 132 Sink	4.9 ppb
Village Elementary School-York	Rm 134 Sink	9.3 ppb
Village Elementary School-York	Rm 136 Sink	0 ppb
Village Elementary School-York	Rm 137 Sink	6.3 ppb
Village Elementary School-York	Rm 138 Sink	12.1 ppb
Village Elementary School-York	Rm 146 Sink	0 ppb
Village Elementary School-York	Rm 147 Bathroom Sink	0 ppb
Village Elementary School-York	Rm 148 Sink	1.4 ppb
Village Elementary School-York	Rm 150 Sink	1.2 ppb
Village Elementary School-York	Rm 152 Sink	1.5 ppb
Village Elementary School-York	Rm 154 Bathroom Sink	1.7 ppb
Village Elementary School-York	Rm 154 Sink	2.7 ppb
Village Elementary School-York	Rm 156 Bathroom Sink	2.4 ppb
Village Elementary School-York	Rm 156 Sink	2.8 ppb
Village Elementary School-York	Rm 158 Sink	2.8 ppb
Village Elementary School-York	Staff Bathroom Sink (left)	0 ppb
Village Elementary School-York	Staff Bathroom Sink (right)	0 ppb
Village Elementary School-York	Teachers Room Sink	0 ppb
Vinalhaven School	Dishwash Sin - Ls Room - Middle	6.8 ppb
Vinalhaven School	Dishwash Sink - Kitchen - Furthest	4 ppb
Vinalhaven School	Dishwash Sink - Kitchen - Near Door	5.2 ppb
Vinalhaven School	Dishwash Sink - Kitchen Main Prep	2.3 ppb
Vinalhaven School	Dishwash Sink - Ls Room - Furthest	3.3 ppb
Vinalhaven School	Dishwash Sink - Ls Room - Near Door	3.6 ppb
Vinalhaven School	Drinking Fountain - 1st Grade Room	0 ppb
Vinalhaven School	Drinking Fountain - 2 To 5 Wing (lower)	0 ppb
Vinalhaven School	Drinking Fountain - 2 To 5 Wing (upper)	0 ppb
Vinalhaven School	Drinking Fountain - 2nd Grade Room	1.3 ppb
Vinalhaven School	Drinking Fountain - 3rd Grade Room	1.8 ppb
Vinalhaven School	Drinking Fountain - 4th Grade Room	1.6 ppb
Vinalhaven School	Drinking Fountain - 5th Grade Room	1.2 ppb
Vinalhaven School	Drinking Fountain - Cafeteria	209 ppb
Vinalhaven School	Drinking Fountain - Gym (lower)	0 ppb
Vinalhaven School	Drinking Fountain - Gym (upper)	0 ppb
Vinalhaven School	Drinking Fountain - Hs Wing (lower)	0 ppb
Vinalhaven School	Drinking Fountain - Hs Wing (upper)	0 ppb
Vinalhaven School	Drinking Fountain - Kindergarten Room	1.3 ppb
Vinalhaven School	Drinking Fountain - Ms Wing (lower)	0 ppb
Vinalhaven School	Drinking Fountain - Ms Wing (upper)	0 ppb

School Name	Sample Location	Lead Test Result
Vinalhaven School	Drinking Fountain - Pre K Room	0 ppb
Vinalhaven School	Drinking Fountain - Teacher's Room	0 ppb
Vinalhaven School	Drinking Fountain - Voc. Ed. Shop	0 ppb
Vinalhaven School	Handwash Sink - Nurses Room	7.5 ppb
Vinalhaven School	Handwash Sink - Hs Science Lab	85.3 ppb
Vinalhaven School	Handwash Sink - Teacher's Room	4.1 ppb
Vinalhaven School	Outdoor Spigot - Front Entrance	24.3 ppb
Vinalhaven School	Outdoor Spigot - Near Baseball Field	123 ppb
Vinalhaven School	Steamer Faucet - Kitchen	181 ppb
Vine Street School	Bathroom Faucet - Room 5	3.1 ppb
Vine Street School	Bottle Fill Station - D Wing	5.4 ppb
Vine Street School	Bottle Fill Station - Hallway Near Gym	0 ppb
Vine Street School	Bottle Fill Station - Near Cafeteria	0 ppb
Vine Street School	Bottle Fill Station - Ramp Hallway	3.3 ppb
Vine Street School	Drinking Water Tap - Book Room	48.1 ppb
Vine Street School	Drinking Water Tap - Room 1	3.4 ppb
Vine Street School	Drinking Water Tap - Room 10	27.9 ppb
Vine Street School	Drinking Water Tap - Room 11	9.9 ppb
Vine Street School	Drinking Water Tap - Room 13	71.9 ppb
Vine Street School	Drinking Water Tap - Room 14	97.8 ppb
Vine Street School	Drinking Water Tap - Room 15	526 ppb
Vine Street School	Drinking Water Tap - Room 16	16.6 ppb
Vine Street School	Drinking Water Tap - Room 17	7.7 ppb
Vine Street School	Drinking Water Tap - Room 18	368 ppb
Vine Street School	Drinking Water Tap - Room 19	75.8 ppb
Vine Street School	Drinking Water Tap - Room 2	2 ppb
Vine Street School	Drinking Water Tap - Room 20	33.2 ppb
Vine Street School	Drinking Water Tap - Room 3	2.4 ppb
Vine Street School	Drinking Water Tap - Room 4	1.7 ppb
Vine Street School	Drinking Water Tap - Room 6	3.9 ppb
Vine Street School	Drinking Water Tap - Room 9	146 ppb
Vine Street School	Faucet - Library	123 ppb
Vine Street School	Faucet - Office Restroom	10 ppb
Vine Street School	Faucet - Teacher's Lounge	2.9 ppb
Vine Street School	Kitchen - Food Prep Left Faucet	7.5 ppb
Vine Street School	Kitchen - Food Prep Right Faucet	8.4 ppb
Vivian E Hussey School	100 Wing Hall Drinking Fountain	0 ppb
Vivian E Hussey School	200 Wing Hall Drinking Fountain	0 ppb
Vivian E Hussey School	300 Wing Hall Drinking Fountain	0 ppb
Vivian E Hussey School	400 Wing Hall Drinking Fountain	0 ppb
Vivian E Hussey School	Art Room Sink #1	3.6 ppb
Vivian E Hussey School	Art Room Sink #2	2.5 ppb
Vivian E Hussey School	Classroom 101 Sink/bubbler	2.8 ppb
Vivian E Hussey School	Classroom 102 Sink/bubbler	3.3 ppb
Vivian E Hussey School	Classroom 103 Sink/bubbler	6.4 ppb
Vivian E Hussey School	Classroom 104 Sink/bubbler	0 ppb
Vivian E Hussey School	Classroom 105 Sink/bubbler	549 ppb

School Name	Sample Location	Lead Test Result
Vivian E Hussey School	Classroom 106 Sink/bubbler	0 ppb
Vivian E Hussey School	Classroom 107 Sink/bubbler	2.9 ppb
Vivian E Hussey School	Classroom 201 Sink/bubbler	1.6 ppb
Vivian E Hussey School	Classroom 202 Sink/bubbler	2.1 ppb
Vivian E Hussey School	Classroom 203 Sink/bubbler	0 ppb
Vivian E Hussey School	Classroom 204 Sink/bubbler	1.2 ppb
Vivian E Hussey School	Classroom 205 Sink/bubbler	2.4 ppb
Vivian E Hussey School	Classroom 206 Sink/bubbler	0 ppb
Vivian E Hussey School	Classroom 207 Sink/bubbler	0 ppb
Vivian E Hussey School	Classroom 208 Sink/bubbler	2.7 ppb
Vivian E Hussey School	Classroom 209 Sink/bubbler	0 ppb
Vivian E Hussey School	Classroom 210 Sink/bubbler	0 ppb
Vivian E Hussey School	Classroom 301 Sink/bubbler	0 ppb
Vivian E Hussey School	Classroom 302 Sink/bubbler	2.5 ppb
Vivian E Hussey School	Classroom 303 Sink/bubbler	0 ppb
Vivian E Hussey School	Classroom 304 Sink/bubbler	4.3 ppb
Vivian E Hussey School	Classroom 305 Sink/bubbler	0 ppb
Vivian E Hussey School	Classroom 306 Sink/bubbler	0 ppb
Vivian E Hussey School	Classroom 307 Sink/bubbler	1.8 ppb
Vivian E Hussey School	Classroom 308 Sink/bubbler	0 ppb
Vivian E Hussey School	Classroom 401 Sink/bubbler	0 ppb
Vivian E Hussey School	Classroom 402 Sink/bubbler	2.9 ppb
Vivian E Hussey School	Classroom 403 Sink/bubbler	1.4 ppb
Vivian E Hussey School	Classroom 404 Sink/bubbler	2.5 ppb
Vivian E Hussey School	Classroom 405 Sink/bubbler	0 ppb
Vivian E Hussey School	Classroom 406 Sink/bubbler	0 ppb
Vivian E Hussey School	Classroom 407 Sink/bubbler	1.1 ppb
Vivian E Hussey School	Classroom 408 Sink/bubbler	1.7 ppb
Vivian E Hussey School	Classroom 409 Sink/bubbler	0 ppb
Vivian E Hussey School	Classroom 410 Sink/bubbler	0 ppb
Vivian E Hussey School	Kitchen Prep Sink #1	32.3 ppb
Vivian E Hussey School	Kitchen Prep Sink #2	83.9 ppb
Vivian E Hussey School	Kitchen Prep Sink #3	25.3 ppb
Vivian E Hussey School	Kitchen Steam Kettle	4 ppb
Vivian E Hussey School	Main Hall Lower Wing Drinking Fountain	0 ppb
Vivian E Hussey School	Main Office Lobby Drinking Fountain	0 ppb
Vivian E Hussey School	Nurse Office Sink	0 ppb
Vivian E Hussey School	Teacher Lounge Sink	2.4 ppb
W G Mallett School	Bottle Fill By Room 111	0 ppb
W G Mallett School	Bottle Fill Upstairs	0 ppb
W G Mallett School	Kitchen 3-bay Sink	21.2 ppb
W G Mallett School	Kitchen Dish Sink	23.1 ppb
W G Mallett School	Kitchen Hand Sink	4.4 ppb
W G Mallett School	Kitchen Kettle	124 ppb
W G Mallett School	Sink Nurse's Room	5.2 ppb
W G Mallett School	Sink Room 100	1.4 ppb
W G Mallett School	Sink Room 109	2.6 ppb

School Name	Sample Location	Lead Test Result
W G Mallett School	Sink Room 112	1.9 ppb
W G Mallett School	Sink Room 114	5.5 ppb
W G Mallett School	Sink Room 115	3.8 ppb
W G Mallett School	Sink Room 200	3.8 ppb
W G Mallett School	Sink Room 208	2.1 ppb
W G Mallett School	Sink Room 214	2 ppb
W G Mallett School	Sink Room 219	4.5 ppb
W G Mallett School	Sink Room 220	3 ppb
W G Mallett School	Sink Room 221	1.9 ppb
W G Mallett School	Sink Room 222	4.2 ppb
W G Mallett School	Sink Room104	3.3 ppb
W G Mallett School	Sink Teachers Lounge	4.1 ppb
Waldo County Tech Ctr-Region 7	Building Construction Restroom	2.3 ppb
Waldo County Tech Ctr-Region 7	Building Construction Tool Sharpening Sink	75.7 ppb
Waldo County Tech Ctr-Region 7	Cna Classroom Restroom Hand Washing Sink	2.5 ppb
Waldo County Tech Ctr-Region 7	Cna Classroom Sink	3.4 ppb
Waldo County Tech Ctr-Region 7	Cna/cc Kitchenette Double Sink	5.8 ppb
Waldo County Tech Ctr-Region 7	Culinary Coffee Sink	12 ppb
Waldo County Tech Ctr-Region 7	Culinary Hand Washing (by Back Door)	4.9 ppb
Waldo County Tech Ctr-Region 7	Culinary Hand Washing (by Classroom)	13.3 ppb
Waldo County Tech Ctr-Region 7	Culinary Mens Restroom	1.5 ppb
Waldo County Tech Ctr-Region 7	Culinary Pot Washing Sink	21.8 ppb
Waldo County Tech Ctr-Region 7	Culinary Prep Sink	24.5 ppb
Waldo County Tech Ctr-Region 7	Culinary Serving Bar Buffet Sink	3.1 ppb
Waldo County Tech Ctr-Region 7	Culinary Womens Restroom	0 ppb
Waldo County Tech Ctr-Region 7	Diesel Tech. Restroom	7.4 ppb
Waldo County Tech Ctr-Region 7	Drinking Fountain By Cna/et/cc/overflow	0 ppb
Waldo County Tech Ctr-Region 7	Drinking Fountain By Dt	0 ppb
Waldo County Tech Ctr-Region 7	Drinking Fountain By Strive/ac/at	0 ppb
Waldo County Tech Ctr-Region 7	Literacy Classroom Sink	10.3 ppb
Waldo County Tech Ctr-Region 7	Mens Restroom By Overflow Classroom	0 ppb
Waldo County Tech Ctr-Region 7	Mens Restroomby Strive/ac/at (2 Sinks)	2.6 ppb
Waldo County Tech Ctr-Region 7	Outdoor Leadership (bucket Fill Sink)	16.9 ppb
Waldo County Tech Ctr-Region 7	Outdoor Leadership Restroom (not Currently Used)	2.5 ppb
Waldo County Tech Ctr-Region 7	Restroom By Literacy Classroom	0 ppb
Waldo County Tech Ctr-Region 7	Restroom Hall By Electrical/alarm Rm.	2.8 ppb
Waldo County Tech Ctr-Region 7	Restroom Hall By Main Office	5.5 ppb
Waldo County Tech Ctr-Region 7	Student Center Restroom	7.7 ppb
Waldo County Tech Ctr-Region 7	Welding Tech. Restroom	0 ppb
Waldo County Tech Ctr-Region 7	Womens Restroom By Overflow Classroom	14.3 ppb
Waldo T Skillin Elementary School	1st ..bottle Fill Near Main Office	0 ppb
Waldo T Skillin Elementary School	1st ..bottle Fill Near Main Office	0 ppb
Waldo T Skillin Elementary School	1st...bottle Fill Near Gym	0 ppb

School Name	Sample Location	Lead Test Result
Waldo T Skillin Elementary School	1st...bottle Fill Near Stairs No.1	0 ppb
Waldo T Skillin Elementary School	1st...bottle Fill Near Stairs No.2	0 ppb
Waldo T Skillin Elementary School	1stàbottle Fill Near Gym	0 ppb
Waldo T Skillin Elementary School	1stàbottle Fill Near Stairs No.1	0 ppb
Waldo T Skillin Elementary School	1stàbottle Fill Near Stairs No.2	0 ppb
Waldo T Skillin Elementary School	2nd Fl..room 208	0 ppb
Waldo T Skillin Elementary School	2nd Fl....bottle Fill Near Restrooms	0 ppb
Waldo T Skillin Elementary School	2nd Fl...room 201	0 ppb
Waldo T Skillin Elementary School	2nd Fl...room 202	0 ppb
Waldo T Skillin Elementary School	2nd Fl...room 203	0 ppb
Waldo T Skillin Elementary School	2nd Fl...room 204	0 ppb
Waldo T Skillin Elementary School	2nd Fl...room 205	0 ppb
Waldo T Skillin Elementary School	2nd Fl...room 206	0 ppb
Waldo T Skillin Elementary School	2nd Fl...room 207	0 ppb
Waldo T Skillin Elementary School	2nd Flà.bottle Fill Near Restrooms	0 ppb
Waldo T Skillin Elementary School	2nd Floor Room 209	0 ppb
Waldo T Skillin Elementary School	Kitchen...prep Sink	0 ppb
Waldo T Skillin Elementary School	Nurses Office	0 ppb
Waldo T Skillin Elementary School	Room 101	0 ppb
Waldo T Skillin Elementary School	Room 102	0 ppb
Waldo T Skillin Elementary School	Room 103	0 ppb
Waldo T Skillin Elementary School	Room 104	0 ppb
Waldo T Skillin Elementary School	Room 105	0 ppb
Waldo T Skillin Elementary School	Room 106	0 ppb
Waldo T Skillin Elementary School	Room 107	0 ppb
Waldo T Skillin Elementary School	Room 108	0 ppb
Waldo T Skillin Elementary School	Room 109	0 ppb
Waldo T Skillin Elementary School	Room 110	0 ppb
Waldo T Skillin Elementary School	Room 111	0 ppb
Waldo T Skillin Elementary School	Room 112	4.6 ppb
Waldo T Skillin Elementary School	Room 113	0 ppb
Waldo T Skillin Elementary School	Teacher Break Room	0 ppb
Warren Community School	219220217215 218 216 214 212 208 9 Sinks	0 ppb
Warren Community School	22823122922622723221 1 Sink Each 7 Total	1.3 ppb
Warren Community School	2nd Grade E Bathroom Sink	0 ppb
Warren Community School	4th & 5th #105 & #107 Bathroom Sink	0 ppb
Warren Community School	Art Room 2 Sinks 204 2 Dual Sinks	1.4 ppb
Warren Community School	Bathroom 200 1 Sink	0 ppb
Warren Community School	Bathroom A 1 Sink B 1 Sink C 1 Sink D 1 Sink	0 ppb
Warren Community School	Bathroom Across From 227 Sink	0 ppb
Warren Community School	Bathroom Next To #103 Sink	0 ppb
Warren Community School	Bathroom Next To #105 Sink	0 ppb
Warren Community School	Bathroom Next To #114 4th Grade Sink	0 ppb
Warren Community School	Bathroom Staff Downstairs Sink	0 ppb
Warren Community School	Boiler Room Water Source	0 ppb
Warren Community School	Boys Bathroom Downstairs - Gang - 2 Sinks	0 ppb
Warren Community School	Boys Bathroom Next To 228 Sink	0 ppb

School Name	Sample Location	Lead Test Result
Warren Community School	Custodial Cloest Upstairs 1 Sink	0 ppb
Warren Community School	Custodial Closet Downstairs 1 Sink	0 ppb
Warren Community School	Custodial Closet Downstairs Faucet 2	0 ppb
Warren Community School	Fill Station By Cafe	0 ppb
Warren Community School	Fill Station Downstairs By Rm 108	0 ppb
Warren Community School	Fill Station Upstairs Across From 219	0 ppb
Warren Community School	Girls Bathroom Next To 228 Sink	0 ppb
Warren Community School	Grils Bathroom Downstairs - Gang - Sinks	0 ppb
Warren Community School	Gym Boys Locker Room 2 Sinks	1.2 ppb
Warren Community School	Gym Girls Locker Room 2 Sinks	0 ppb
Warren Community School	Gym Office Sink	0 ppb
Warren Community School	Kitchen 2 Bay Sink Wash Stations	0 ppb
Warren Community School	Kitchen 3 Bay Sink Wash Stations	0 ppb
Warren Community School	Kitchen Bathroom 1 Sink	0 ppb
Warren Community School	Kitchen Single Sink Handwash	0 ppb
Warren Community School	Library 1 Sink	0 ppb
Warren Community School	Nurse Sink 1 Bathroom & 1 Office	0 ppb
Warren Community School	Rm 102 2 Sinks 1 Bath & 1 Classrom	0 ppb
Warren Community School	Rm 103 105 107 109114 111 116 113 8 Sinks	11.8 ppb
Warren Community School	Rm 108 Bath Sink Classroom Sink	0 ppb
Warren Community School	Rm 205 Pre K 2 Sinks	0 ppb
Warren Community School	Staff Bathroom Upstairs 1 Sink	0 ppb
Warsaw Middle School	Bottle Fill Station - Across Room 103	0 ppb
Warsaw Middle School	Bottle Fill Station - Across Room 117	0 ppb
Warsaw Middle School	Bottle Fill Station - Cafeteria	0 ppb
Warsaw Middle School	Bottle Fill Station - Outside Room 211	0 ppb
Warsaw Middle School	Bottle Fill Station Outside Room 203	0 ppb
Warsaw Middle School	Boy's Locker Room Custodian Faucet By Door	3.4 ppb
Warsaw Middle School	Girl's Locker Room Custodian Faucet By Door	6.1 ppb
Warsaw Middle School	Nurse's Office Bathroom Sink	4.7 ppb
Warsaw Middle School	Nurse's Office Main Sink	1.7 ppb
Warsaw Middle School	Teacher's Lounge Sink	1.1 ppb
Washburn District Elem School	Bottle Fill Station 2nd Floor By Elevator	0 ppb
Washburn District Elem School	Bottle Fill Station Main Foyer	0 ppb
Washburn District Elem School	Kitchen Kettle	4.2 ppb
Washburn District Elem School	Kitchen Single Basin Sink	3.3 ppb
Washburn District Elem School	Kitchen Triple Basin Sink	1.7 ppb
Washburn District High School	Bottle Fill Station By Principal Office	0 ppb
Washburn District High School	Drinking Fountain English Wing By Rm 8	2.8 ppb
Washburn District High School	Drinking Fountain In Shop Wing	6.6 ppb
Washburn School	Bathroom By Cafeteria Faucet	0 ppb
Washburn School	Bathroom By Room 103 Faucet	0 ppb
Washburn School	Bathroom Next To Room 101 Faucet	0 ppb
Washburn School	Boys Bathroom By Room 108 L Faucet	2.3 ppb
Washburn School	Boys Bathroom By Room 108 R Faucet	0 ppb

School Name	Sample Location	Lead Test Result
Washburn School	Cafeteria Bubbler	0 ppb
Washburn School	Cafeteria Hand/eyewash Faucet	2.5 ppb
Washburn School	Cafeteria Left Faucet	0 ppb
Washburn School	Cafeteria Right Faucet	14.3 ppb
Washburn School	Cafeteria Water Bottle Filling Station	0 ppb
Washburn School	Girls Bathroom By Room 108 L Faucet	61.6 ppb
Washburn School	Girls Bathroom By Room 108 R Faucet	1.7 ppb
Washburn School	Hallway Bathroom By Main Entrance Faucet	0 ppb
Washburn School	Left Bubbler Across From 108	0 ppb
Washburn School	Modular Ramp Entry On L Bathroom Faucet	0 ppb
Washburn School	Modular Ramp Entry On L Slop Sink Faucet	0 ppb
Washburn School	Modular Ramp Entry On R Bathroom Faucet	0 ppb
Washburn School	Nurses Office Bubbler	0 ppb
Washburn School	Nurses Office Faucet	0 ppb
Washburn School	Right Bubbler Across From 108	0 ppb
Washburn School	Room 101 Bathroom Faucet	4.2 ppb
Washburn School	Room 101 Bubbler	78.9 ppb
Washburn School	Room 101 Faucet	0 ppb
Washburn School	Room 103 Bathroom Faucet	0 ppb
Washburn School	Room 103 Bubbler	0 ppb
Washburn School	Room 103 Faucet	1.2 ppb
Washburn School	Room 104 Bathroom Faucet	1.3 ppb
Washburn School	Room 104 Bubbler	153 ppb
Washburn School	Room 104 Faucet	0 ppb
Washburn School	Room 105 Bathroom Faucet	0 ppb
Washburn School	Room 105 Bubbler	83.7 ppb
Washburn School	Room 105 Faucet	0 ppb
Washburn School	Room 106 Bathroom Faucet	2.8 ppb
Washburn School	Room 106 Bubbler	306 ppb
Washburn School	Room 106 Faucet	0 ppb
Washburn School	Room 107 Bubbler	224 ppb
Washburn School	Room 107 Faucet	0 ppb
Washburn School	Room 108 Bubbler	220 ppb
Washburn School	Room 108 Faucet	0 ppb
Washburn School	Room 110 Bubbler	106 ppb
Washburn School	Room 110 Faucet	0 ppb
Washburn School	Room 112 Bubbler	412 ppb
Washburn School	Room 112 Faucet	0 ppb
Washburn School	Room 117 Bathroom Faucet	1.7 ppb
Washburn School	Room 117 Bubbler	227 ppb
Washburn School	Room 117 Faucet	0 ppb
Washburn School	Room 118 Bathroom Faucet	1.2 ppb
Washburn School	Room 118 Bubbler	96.7 ppb
Washburn School	Room 118 Faucet	0 ppb
Washburn School	Room 119 Bathroom Faucet	1.2 ppb

School Name	Sample Location	Lead Test Result
Washburn School	Room 119 Bubblers	98.3 ppb
Washburn School	Room 119 Faucet	0 ppb
Washburn School	Room 120 Bathroom Faucet	2.3 ppb
Washburn School	Room 120 Bubblers	200 ppb
Washburn School	Room 120 Faucet	0 ppb
Washburn School	Room Across From Library Bubblers	4.8 ppb
Washburn School	Room Across From Library Faucet	1 ppb
Washburn School	Teachers Room Faucet	0 ppb
Washburn School	Water Bottle Filler Across From 108	0 ppb
Washington Academy	Alumni Building Dwf Across Headmasters Office	4.6 ppb
Washington Academy	Alumni Building Dwf By Science Bathrooms	2.3 ppb
Washington Academy	Alumni Building Kitchen 3 Bay Sink	0 ppb
Washington Academy	Alumni Building Kitchen Sink By Dish Washer	2.3 ppb
Washington Academy	Alumni Building Teachers Room	0 ppb
Washington Academy	Alumni Building White Sink By Coffee Maker Kitchen	3.5 ppb
Washington Academy	Alumni-boys Bathroom By Rm 13 Sink Near Door	0 ppb
Washington Academy	Alumni-boys Bathroom By Rm 13 Sink Near Urinal	0 ppb
Washington Academy	Alumni-drinking Fountain By Rm 13 Bathrooms	29.7 ppb
Washington Academy	Alumni-girls Bathroom By Rm 13 Sink Near Door 1	0 ppb
Washington Academy	Alumni-girls Bathroom By Rm 13 Sink Near Door 2	0 ppb
Washington Academy	Alumni-maine Office Mail Room Sink	3.1 ppb
Washington Academy	Alumni-mens Teachers Bathroom	0 ppb
Washington Academy	Alumni-outside Spicket By Main Office	161 ppb
Washington Academy	Alumni-rm 9 Sink 3	10.7 ppb
Washington Academy	Alumni-rm 10 Alcove Sink	2.8 ppb
Washington Academy	Alumni-rm 11 Alcove Sink	0 ppb
Washington Academy	Alumni-rm 17 Station 3 Sink Three	11.1 ppb
Washington Academy	Alumni-rm 7 Station 3 Sink Four	8 ppb
Washington Academy	Alumni-rm 7 Station 3 Sink One	13.6 ppb
Washington Academy	Alumni-rm 7 Station 3 Sink Two	25.1 ppb
Washington Academy	Alumni-rm 8 Main Sink	43.1 ppb
Washington Academy	Alumni-rm 8 Station 1 Sink One	20.1 ppb
Washington Academy	Alumni-rm 8 Station 1 Sink Two	13.1 ppb
Washington Academy	Alumni-rm 8 Station 2 Sink One	18.1 ppb
Washington Academy	Alumni-rm 8 Station 2 Sink Two	17.4 ppb
Washington Academy	Alumni-rm 8 Station 3 Sink One	32.9 ppb
Washington Academy	Alumni-rm 8 Station 3 Sink Two	29.4 ppb
Washington Academy	Alumni-rm 9 Main Sink	5.6 ppb

School Name	Sample Location	Lead Test Result
Washington Academy	Alumni-rm 9 Sink 1	4.3 ppb
Washington Academy	Alumni-rm 9 Sink 2	6.1 ppb
Washington Academy	Alumni-rm 9 Sink 4	5.8 ppb
Washington Academy	Alumni-room 7 Station 1 Sink One	32.1 ppb
Washington Academy	Alumni-room 7 Station 1 Sink Two	37.7 ppb
Washington Academy	Alumni-room 7 Station 2 Sink Four	29.3 ppb
Washington Academy	Alumni-room 7 Station 2 Sink One	21.9 ppb
Washington Academy	Alumni-room 7 Station 2 Sink Three	11.7 ppb
Washington Academy	Alumni-room 7 Station 2 Sink Two	24.6 ppb
Washington Academy	Alumni-science Boys Bathroom Sink Near Door	25.8 ppb
Washington Academy	Alumni-science Boys Bathroom Sink Near Stalls	0 ppb
Washington Academy	Alumni-science Girls Bathroom Sink Near Door	7.2 ppb
Washington Academy	Alumni-science Girls Bathroom Sink Near Stalls	0 ppb
Washington Academy	Alumni-womens Teachers Bathroom	0 ppb
Washington Academy	Cafeteria Ice Machine	0 ppb
Washington Academy	Cates Apartment O	3.2 ppb
Washington Academy	Cates-down Stairs Apartment Bathroom Sink	2.4 ppb
Washington Academy	Clifford House-2nd Floor Bathroom Sink	13.6 ppb
Washington Academy	Clifford House-basement Sink Near Shower	17 ppb
Washington Academy	Clifford House-basement Sink Near Toilet	15.8 ppb
Washington Academy	Clifford House-bathroom Sink By Living Room	24.1 ppb
Washington Academy	Clifford House-kitchen Sink	21.9 ppb
Washington Academy	Fine Arts Art Room Sink	0 ppb
Washington Academy	Fine Arts Fountain By Door To Baseball Feild	0 ppb
Washington Academy	Fine Arts Fountain By Gym Entrance	0 ppb
Washington Academy	Fine Arts Fountain By Weight Room	0 ppb
Washington Academy	Fine Arts Sink In Room 3	1.9 ppb
Washington Academy	Fine Arts-bathroom Sink Officals Room	12.3 ppb
Washington Academy	Fine Arts-boys Bathroom Near Music Room	0 ppb
Washington Academy	Fine Arts-boys Locker Room Sink	3.8 ppb
Washington Academy	Fine Arts-concession Sink	5.8 ppb
Washington Academy	Fine Arts-girls Bathroom By Music Room	0 ppb
Washington Academy	Fine Arts-girls Locker Room Sink	2 ppb
Washington Academy	Fine Arts-lower Boys Br Sink Near Door	0 ppb
Washington Academy	Fine Arts-lower Boys Br Sink Near Toilets	0 ppb
Washington Academy	Fine Arts-lower Girls Br Sink By Wall	0 ppb
Washington Academy	Fine Arts-lower Girls Br Sink Fourth From Wall	0 ppb

School Name	Sample Location	Lead Test Result
Washington Academy	Fine Arts-lower Girls Br Sink Second From Wall	0 ppb
Washington Academy	Fine Arts-lower Girls Br Sink Third From Wall	0 ppb
Washington Academy	Fine Arts-outside Spicket Wall Weight Rm	57.2 ppb
Washington Academy	Fine Arts-outside Spicket By Baseball Field	145 ppb
Washington Academy	Fine Arts-outside Spicket Rear Building	26.8 ppb
Washington Academy	Fine Arts-training Room Sink	9 ppb
Washington Academy	Gaddis - Bathroom Sink By Back Stairs	0 ppb
Washington Academy	Gaddis - Kitchen Sink	0 ppb
Washington Academy	Gaddis-bathroom Downstairs By Washer And Dryer	0 ppb
Washington Academy	Girls Locker Room Sink Near Toilet	1.4 ppb
Washington Academy	Guidance Bathroom	0 ppb
Washington Academy	Larson-apartment Old Part Alcove Sink	10.5 ppb
Washington Academy	Larson-apartment Old Part Bathroom Sink	10.1 ppb
Washington Academy	Larson-apartment Old Part Kithchen Sink	0 ppb
Washington Academy	Old Academy Dwf Between Bathrooms	1.6 ppb
Washington Academy	Old Academy Kirby Room Sink	22.2 ppb
Washington Academy	Old Academy Nurses Sink Bathroom	24 ppb
Washington Academy	Room 7 Main Sink	7.3 ppb
Washington Academy	Talbot - Boys Bathroom Sink 1	0 ppb
Washington Academy	Talbot - Boys Bathroom Sink 2	0 ppb
Washington Academy	Talbot - Boys Bathroom Sink 3	0 ppb
Washington Academy	Talbot - Boys Bathroom Sink 4	0 ppb
Washington Academy	Talbot - Boys Bathroom Sink 5	0 ppb
Washington Academy	Talbot - Apartment 1 Bathroom	0 ppb
Washington Academy	Talbot - Apartment 2 Bathroom	1.9 ppb
Washington Academy	Talbot - Apartment 3 Bathroom	0 ppb
Washington Academy	Talbot - Apartment 4 Bathroom	2.6 ppb
Washington Academy	Talbot - Boys Laundry Sink	0 ppb
Washington Academy	Talbot - Girls Bathroom Sink 1	0 ppb
Washington Academy	Talbot - Girls Bathroom Sink 2	6.9 ppb
Washington Academy	Talbot - Girls Bathroom Sink 3	0 ppb
Washington Academy	Talbot - Girls Bathroom Sink 4	0 ppb
Washington Academy	Talbot - Girls Bathroom Sink 5	0 ppb
Washington Academy	Talbot - Girls Laundry Sink	0 ppb
Washington Academy	Talbot Dorm Bw Kitchen	0 ppb
Washington Academy	Talbot Dorm Jh Kitchen	0 ppb
Washington Academy	Talbot Dorm Jm Kitchen	0 ppb
Washington Academy	Talbot Dorm Mcbrine Kitchen	1.8 ppb
Washington Academy	Talbot Maine Kitchen Sink	0 ppb
Washington Academy	Talbot-common Room Bathroom Sink	2.7 ppb
Washington Academy	Talbot-outside Spicket Boys Front Of Building	8.2 ppb
Washington Academy	Talbot-outside Spicket Boys Rear Building	34.7 ppb
Washington Academy	Talbot-outside Spicket By Apartment 1	11.9 ppb

School Name	Sample Location	Lead Test Result
Washington Academy	Talbot-outside Spicket By Apartment 2	19.2 ppb
Washington Academy	Talbot-outside Spicket Girls Front Of Building	11.9 ppb
Washington Academy	Talbot-outside Spicket Girls Rear Building	29 ppb
Waterboro Elementary School	Drinking Fountain-cafe (l)	0 ppb
Waterboro Elementary School	Drinking Fountain-cafe (r)	0 ppb
Waterboro Elementary School	Drinking Fountain-gym	0 ppb
Waterboro Elementary School	Drinking Fountain-modular	0 ppb
Waterboro Elementary School	Drinking Fountain-near Room 10	0 ppb
Waterboro Elementary School	Drinking Fountain-near Room 11	0 ppb
Waterboro Elementary School	Kitchen-3 Bay Sink (l)	0 ppb
Waterboro Elementary School	Kitchen-3 Bay Sink (r)	0 ppb
Waterboro Elementary School	Kitchen-combi Oven	0 ppb
Waterboro Elementary School	Kitchen-dish Wash Sink	1.3 ppb
Waterboro Elementary School	Kitchen-tilt Skillet	2.3 ppb
Waterboro Elementary School	Kitchen-vegetable Sink	0 ppb
Waterboro Elementary School	Nurse Office-sink	0 ppb
Waterboro Elementary School	Refridgerator-teacher's Room	0 ppb
Waterboro Elementary School	Room 10-drinking Fountain	0 ppb
Waterboro Elementary School	Room 10-sink	1.1 ppb
Waterboro Elementary School	Room 11-drinking Fountain	1.2 ppb
Waterboro Elementary School	Room 11-sink	0 ppb
Waterboro Elementary School	Room 12-drinking Fountain	0 ppb
Waterboro Elementary School	Room 12-sink	0 ppb
Waterboro Elementary School	Room 13-drinking Fountain	0 ppb
Waterboro Elementary School	Room 13-sink	0 ppb
Waterboro Elementary School	Room 14-drinking Fountain	0 ppb
Waterboro Elementary School	Room 14-sink	0 ppb
Waterboro Elementary School	Room 15-drinking Fountain	0 ppb
Waterboro Elementary School	Room 15-sink	0 ppb
Waterboro Elementary School	Room 16-drinking Fountain	0 ppb
Waterboro Elementary School	Room 16-sink	1.4 ppb
Waterboro Elementary School	Room 17-drinking Fountain	2.6 ppb
Waterboro Elementary School	Room 17-sink	0 ppb
Waterboro Elementary School	Room 18 Drinking Fountain	0 ppb
Waterboro Elementary School	Room 18-sink	0 ppb
Waterboro Elementary School	Room 32-drinking Fountain	3.8 ppb
Waterboro Elementary School	Room 32-sink	0 ppb
Waterboro Elementary School	Room 33-drinking Fountain	5.3 ppb
Waterboro Elementary School	Room 33-sink	1.3 ppb
Waterboro Elementary School	Room 34-drinking Fountain	3 ppb
Waterboro Elementary School	Room 34-sink	0 ppb
Waterboro Elementary School	Room 36-drinking Fountain	2.9 ppb
Waterboro Elementary School	Room 36-sink	0 ppb
Waterboro Elementary School	Room 37-drinking Fountain	26.7 ppb
Waterboro Elementary School	Room 37-sink	0 ppb
Waterboro Elementary School	Room 38-drinking Fountain	2 ppb

School Name	Sample Location	Lead Test Result
Waterboro Elementary School	Room 38-sink	0 ppb
Waterboro Elementary School	Room 39-drinking Fountain	4.3 ppb
Waterboro Elementary School	Room 39-sink	0 ppb
Waterboro Elementary School	Room 3-drinking Fountain	0 ppb
Waterboro Elementary School	Room 3-sink	0 ppb
Waterboro Elementary School	Room 40-drinking Fountain	4.7 ppb
Waterboro Elementary School	Room 40-sink	3.7 ppb
Waterboro Elementary School	Room 41-drinking Fountain	2.5 ppb
Waterboro Elementary School	Room 41-sink	1.8 ppb
Waterboro Elementary School	Room 43-drinking Fountain	144 ppb
Waterboro Elementary School	Room 43-sink	0 ppb
Waterboro Elementary School	Room 4-drinking Fountain	0 ppb
Waterboro Elementary School	Room 4-sink	0 ppb
Waterboro Elementary School	Room 5-drinking Fountain	0 ppb
Waterboro Elementary School	Room 5-sink	0 ppb
Waterboro Elementary School	Room 6-drinking Fountain	0 ppb
Waterboro Elementary School	Room 6-sink	0 ppb
Waterboro Elementary School	Room 7-drinking Fountain	0 ppb
Waterboro Elementary School	Room 7-sink	0 ppb
Waterboro Elementary School	Room 8-drinking Fountain	0 ppb
Waterboro Elementary School	Room 8-sink	0 ppb
Waterboro Elementary School	Room 9-drinking Fountain	0 ppb
Waterboro Elementary School	Room 9-sink	0 ppb
Waterboro Elementary School	Social Worker's Office-sink	0 ppb
Waterboro Elementary School	Teacher's Room-sink	4 ppb
Waterford Memorial School	First Floor Hall	2.5 ppb
Waterford Memorial School	G10 Spec Ed Suite	2.7 ppb
Waterford Memorial School	Gym Outside Spigot	458 ppb
Waterford Memorial School	Library	2.3 ppb
Waterford Memorial School	Pre K	6.3 ppb
Waterford Memorial School	Room 105	0 ppb
Waterford Memorial School	Room 118	0 ppb
Waterford Memorial School	Room 130	0 ppb
Waterford Memorial School	Room 134	0 ppb
Waterford Memorial School	Room 139	0 ppb
Waterford Memorial School	Room 141	0 ppb
Waterford Memorial School	Stairwell Outside Spigot	82.3 ppb
Watershed School	Large Kitchen Sink	7.5 ppb
Watershed School	Main Room Kitchen Sink	0 ppb
Watershed School	Small Sink	0 ppb
Waterville Alternative School	Basement Student Bathroom Sink	0 ppb
Waterville Alternative School	Basement Teachers Bathroom Sink	1.7 ppb
Waterville Alternative School	Main Floor Teachers Kitchen Double Sink	3 ppb
Waterville Alternative School	Main Floor Teachers Kitchen Small Sink	24.7 ppb
Waterville Alternative School	Main Floor Unisex Bathroom Sink	2.9 ppb
Waterville Alternative School	Main Floor Water Fountain	0 ppb
Waterville Alternative School	Main Floor Womens Bath Left Sink	2.4 ppb

School Name	Sample Location	Lead Test Result
Waterville Alternative School	Main Floor Womens Bath Right Sink	17 ppb
Waterville Junior High School	35 Cafe Bathroom Sink	3 ppb
Waterville Junior High School	36 Cafe Kitchen Sink	2 ppb
Waterville Junior High School	38 Lab Sink M	108 ppb
Waterville Junior High School	38 Lab Sink R	21 ppb
Waterville Junior High School	42 Lab Sink	7 ppb
Waterville Junior High School	46 Lab Sink	2 ppb
Waterville Junior High School	62 Kitchen Sink	2 ppb
Waterville Junior High School	66 Sink	16 ppb
Waterville Junior High School	73 Girls Locker Room Sink L	0 ppb
Waterville Junior High School	75c Broom Sink	0 ppb
Waterville Junior High School	75c Kitchen Sink	0 ppb
Waterville Junior High School	75c Left Sink	1 ppb
Waterville Junior High School	75c Middle Sink	2 ppb
Waterville Junior High School	75c Right Sink	2 ppb
Waterville Junior High School	75d Left Sink	0 ppb
Waterville Junior High School	75d Right Sink	4 ppb
Waterville Junior High School	Boys Bathroom L Sink 37a	1 ppb
Waterville Junior High School	Boys Bathroom M Sink 37a	0 ppb
Waterville Junior High School	Boys Bathroom R Sink 37a	0 ppb
Waterville Junior High School	Boys Locker Room Sink	2 ppb
Waterville Junior High School	Drinking Fountain Outside Locker Rm	1 ppb
Waterville Junior High School	Drinking Water Fountain Outside Gym	0 ppb
Waterville Junior High School	Drinking Water Fountain Outside Lounge	0 ppb
Waterville Junior High School	Drinking Water Fountain Outside Rm 46	0 ppb
Waterville Junior High School	Fountain Outside 37b	0 ppb
Waterville Junior High School	Girls Bathroom L Sink 37a	3 ppb
Waterville Junior High School	Girls Bathroom M Sink 37a	0 ppb
Waterville Junior High School	Girls Bathroom R Sink 37a	0 ppb
Waterville Junior High School	Gym Pe Office L Sink	3 ppb
Waterville Junior High School	Gym Pe Office R Sink	2 ppb
Waterville Junior High School	Hall Fountain Outside Rm 6	0 ppb
Waterville Junior High School	Kitchen Bathroom	0 ppb
Waterville Junior High School	Kitchen Dish Room Hand Sink	0 ppb
Waterville Junior High School	Kitchen Sink L	1 ppb
Waterville Junior High School	Kitchen Sink R	0 ppb
Waterville Junior High School	Library Sink	4960 ppb
Waterville Junior High School	Lobby Boys Bathroom L Sink	1 ppb
Waterville Junior High School	Lobby Boys Bathroom R Sink	1 ppb
Waterville Junior High School	Lobby Drinking Water Fountain	0 ppb
Waterville Junior High School	Lobby Girls Bathroom L Sink	0 ppb
Waterville Junior High School	Lobby Girls Bathroom R Sink	1 ppb
Waterville Junior High School	Lounge Bathroom L	0 ppb
Waterville Junior High School	Lounge Bathroom R	0 ppb
Waterville Junior High School	Lounge Kitchen Sink	0 ppb
Waterville Junior High School	Nurses Sink	4 ppb
Waterville Senior High School	122 & 123 Teachers Room Kitchen Sink	9 ppb

School Name	Sample Location	Lead Test Result
Waterville Senior High School	221 & 223 Teachers Room Kitchen Sink	5 ppb
Waterville Senior High School	222 - 224 Teachers Room Sink	1 ppb
Waterville Senior High School	Adult Ed Office Bathroom	0 ppb
Waterville Senior High School	Adult Ed Office Kitchen	0 ppb
Waterville Senior High School	Ae/t Bathroom Area Custodial	0 ppb
Waterville Senior High School	Ae/t Boys L Sink	0 ppb
Waterville Senior High School	Ae/t Boys R Sink	0 ppb
Waterville Senior High School	Ae/t Drinking Fountain L	0 ppb
Waterville Senior High School	Ae/t Drinking Fountain R	0 ppb
Waterville Senior High School	Ae/t Girls L Sink	0 ppb
Waterville Senior High School	Ae/t Girls R Sink	0 ppb
Waterville Senior High School	Art 101 Panther Cafe Bathroom	0 ppb
Waterville Senior High School	Art 101 Panther Cafe Kitchen Sink	0 ppb
Waterville Senior High School	Art 105 Left Bathroom Sink	0 ppb
Waterville Senior High School	Art 105 Right Bathroom Sink	0 ppb
Waterville Senior High School	Art 105 Teachers Lounge Kitchen Sink	0 ppb
Waterville Senior High School	Art Fountain L	0 ppb
Waterville Senior High School	Art Fountain R	0 ppb
Waterville Senior High School	Art/boys L Sink	0 ppb
Waterville Senior High School	Art/boys R Sink	0 ppb
Waterville Senior High School	Art/g 113 Handwashing Sink 1	3 ppb
Waterville Senior High School	Art/g 113 Handwashing Sink 2	2 ppb
Waterville Senior High School	Art/g 113 Handwashing Sink 3	2 ppb
Waterville Senior High School	Art/g Bathroom Custodial Closet	0 ppb
Waterville Senior High School	Art/girls L Sink	0 ppb
Waterville Senior High School	Art/girls R Sink	0 ppb
Waterville Senior High School	Boys Locker Room Left Sink	0 ppb
Waterville Senior High School	Boys Locker Room Right Sink	0 ppb
Waterville Senior High School	Boys Locker Room Water Fountain	0 ppb
Waterville Senior High School	Cafeteria Bathroom Sink	1 ppb
Waterville Senior High School	Cafeteria Kitchen Sink 1	1 ppb
Waterville Senior High School	Cafeteria Kitchen Sink 2	0 ppb
Waterville Senior High School	Cafeteria Kitchen Sink 3	5 ppb
Waterville Senior High School	Cafeteria Kitchen Sink 4	1 ppb
Waterville Senior High School	Cafeteria Kitchen Sink 5	0 ppb
Waterville Senior High School	Cafeteria Kitchen Sink 6	6 ppb
Waterville Senior High School	English Boys Bathroom L Sink	0 ppb
Waterville Senior High School	English Boys Bathroom R Sink	0 ppb
Waterville Senior High School	English Custodial Closet	0 ppb
Waterville Senior High School	English Fountain L	0 ppb
Waterville Senior High School	English Fountain R	0 ppb
Waterville Senior High School	English Girls Bathroom L Sink	0 ppb
Waterville Senior High School	English Girls Bathroom R Sink	0 ppb
Waterville Senior High School	English Teachers Room Kitchen Sink	0 ppb
Waterville Senior High School	Girls Locker Room Middle Sink	1 ppb
Waterville Senior High School	Girls Locker Room Right Sink	4 ppb
Waterville Senior High School	Girls Locker Room Water Fountain	1 ppb

School Name	Sample Location	Lead Test Result
Waterville Senior High School	Gym Hall Hydration Station	0 ppb
Waterville Senior High School	Gym Hall Water Fountain	0 ppb
Waterville Senior High School	Left Sink Girls Locker Room	15 ppb
Waterville Senior High School	Main Office Br #1 Sink	3 ppb
Waterville Senior High School	Main Office Br #2 Sink	2 ppb
Waterville Senior High School	Main Office Br #3 Sink	36 ppb
Waterville Senior High School	Main Office Kitchen Sink	0 ppb
Waterville Senior High School	Math Wing Bathroom #1 L Sink	0 ppb
Waterville Senior High School	Math Wing Bathroom #2 L Sink	0 ppb
Waterville Senior High School	Math Wing Staff Room Kitchen Sink	0 ppb
Waterville Senior High School	Media Ctr Sink	0 ppb
Waterville Senior High School	Rotunda Brr Left Sink	0 ppb
Waterville Senior High School	Rotunda Brr Right Sink	0 ppb
Waterville Senior High School	Rotunda Custodial Closet	1 ppb
Waterville Senior High School	Rotunda Fountain #1	0 ppb
Waterville Senior High School	Rotunda Fountain #2	0 ppb
Waterville Senior High School	Rotunda Gbr Left Sink	0 ppb
Waterville Senior High School	Rotunda Gbr Right Sink	0 ppb
Waterville Senior High School	Rotunda Hydration Station	0 ppb
Waterville Senior High School	Science 121 Lab Sink 1	18 ppb
Waterville Senior High School	Science 121 Lab Sink 2	2 ppb
Waterville Senior High School	Science 121 Lab Sink 3	10 ppb
Waterville Senior High School	Science 122 Lab Sink 1	102 ppb
Waterville Senior High School	Science 122 Lab Sink 2	5 ppb
Waterville Senior High School	Science 122 Lab Sink 3	13 ppb
Waterville Senior High School	Science 122 Lab Sink 4	34 ppb
Waterville Senior High School	Science 122 Lab Sink 5	12 ppb
Waterville Senior High School	Science 122 Lab Sink 6	7 ppb
Waterville Senior High School	Science 122 Lab Sink 7	0 ppb
Waterville Senior High School	Science 123 Lab Sink 1	35 ppb
Waterville Senior High School	Science 123 Lab Sink 2	1 ppb
Waterville Senior High School	Science 123 Lab Sink 3	2 ppb
Waterville Senior High School	Science 124 Lab Sink 1	2 ppb
Waterville Senior High School	Science 124 Lab Sink 2	7 ppb
Waterville Senior High School	Science 221 Lab Sink 1	0 ppb
Waterville Senior High School	Science 221 Lab Sink 2	12 ppb
Waterville Senior High School	Science 221 Lab Sink 3	6 ppb
Waterville Senior High School	Science 221 Lab Sink 4	12 ppb
Waterville Senior High School	Science 221 Lab Sink 5	13 ppb
Waterville Senior High School	Science 221 Lab Sink 6	35 ppb
Waterville Senior High School	Science 221 Lab Sink 7	16 ppb
Waterville Senior High School	Science 221 Lab Sink 8	172 ppb
Waterville Senior High School	Science 222 Lab Sink 1	4 ppb
Waterville Senior High School	Science 222 Lab Sink 2	2 ppb
Waterville Senior High School	Science 222 Lab Sink 3	1 ppb
Waterville Senior High School	Science 222 Lab Sink 4	14 ppb
Waterville Senior High School	Science 222 Lab Sink 5	18 ppb

School Name	Sample Location	Lead Test Result
Waterville Senior High School	Science 222 Lab Sink 6	15 ppb
Waterville Senior High School	Science 222 Lab Sink 7	5 ppb
Waterville Senior High School	Science 223 Lab Sink 1	0 ppb
Waterville Senior High School	Science 223 Lab Sink 2	7 ppb
Waterville Senior High School	Science 223 Lab Sink 3	3 ppb
Waterville Senior High School	Science 223 Lab Sink 4	10 ppb
Waterville Senior High School	Science 223 Lab Sink 5	12 ppb
Waterville Senior High School	Science 223 Lab Sink 6	9 ppb
Waterville Senior High School	Science 223 Lab Sink 7	20 ppb
Waterville Senior High School	Science 223 Lab Sink 8	167 ppb
Waterville Senior High School	Science 224 Lab Sink 1	3 ppb
Waterville Senior High School	Science 224 Lab Sink 2	10 ppb
Waterville Senior High School	Science 224 Lab Sink 3	6 ppb
Waterville Senior High School	Science 224 Lab Sink 4	112 ppb
Waterville Senior High School	Science 224 Lab Sink 5	5 ppb
Waterville Senior High School	Science 224 Lab Sink 6	2 ppb
Waterville Senior High School	Science 224 Lab Sink 7	1 ppb
Waterville Senior High School	Science 224 Lab Sink 8	43 ppb
Waterville Senior High School	Se Bathroom Sink	0 ppb
Waterville Senior High School	Se Ice maker	0 ppb
Waterville Senior High School	Se Kitchen Sink	0 ppb
Waterville Senior High School	Ss Boys Bathroom L Sink	6 ppb
Waterville Senior High School	Ss Boys Bathroom R Sink	0 ppb
Waterville Senior High School	Ss Custodial Closet	0 ppb
Waterville Senior High School	Ss Fountain L	0 ppb
Waterville Senior High School	Ss Fountain R	0 ppb
Waterville Senior High School	Ss Girls Bathroom L Sink	0 ppb
Waterville Senior High School	Ss Girls Bathroom R Sink	0 ppb
Waterville Senior High School	Ss Hydration Station 1	0 ppb
Waterville Senior High School	Staff Locker Room Ice Machine	0 ppb
Waterville Senior High School	Staff Locker Room Right Sink	4 ppb
Waterville Senior High School	Staff Locker Room Utility Sink	0 ppb
Waterville Senior High School	Teachers Room Bathroom Sink	0 ppb
Wayfinder Schools at Camden	Kitchen Double Basin Sink	0 ppb
Wayne Elementary School	1st Grade Rm	1.1 ppb
Wayne Elementary School	2nd Grade Rm	0 ppb
Wayne Elementary School	3rd Grade Rm	0 ppb
Wayne Elementary School	4th Grade Sink #1	0 ppb
Wayne Elementary School	5th Grade Rm	0 ppb
Wayne Elementary School	Kindergarten Rm	1.1 ppb
Wayne Elementary School	Kitchen Sink #1	3.1 ppb
Wayne Elementary School	Kitchen Sink #2	1.4 ppb
Wayne Elementary School	Kitchen Sink #3	22.6 ppb
Wayne Elementary School	Math Invervention Rm #1	10.8 ppb
Wayne Elementary School	Nurses Station	0 ppb
Wayne Elementary School	Speech Rm	2.8 ppb
Wayne Elementary School	Staff Room	0 ppb

School Name	Sample Location	Lead Test Result
Wayne Elementary School	Stage	17.4 ppb
Wayne Elementary School	Upper Wing Water Fountain (bottle)	0 ppb
Wayne Elementary School	Water Fountain Near Gym	0 ppb
Waynflete School	Arts A-204 Sink C	0 ppb
Waynflete School	Arts A-204 Sink L	0 ppb
Waynflete School	Arts A-204 Sink R	1.4 ppb
Waynflete School	Arts A-205 Sink C	1.8 ppb
Waynflete School	Arts A-205 Sink L	2.4 ppb
Waynflete School	Arts A-205 Sink R	2.9 ppb
Waynflete School	Arts A-206 Sink L	0 ppb
Waynflete School	Arts A-206 Sink R	0 ppb
Waynflete School	Arts Ceramics Restroom Sink	4.1 ppb
Waynflete School	Arts Ceramics Studio Sink C	12.4 ppb
Waynflete School	Arts Ceramics Studio Sink L	3.4 ppb
Waynflete School	Arts Ceramics Studio Sink R	9.2 ppb
Waynflete School	Arts Level 1 Band Room Sink	8.3 ppb
Waynflete School	Arts Level 1 Storer St. Water Fountain	62.1 ppb
Waynflete School	Arts Lower Level A-017 Water Bubbler	0 ppb
Waynflete School	Arts Lower Level Dance Restroom Sink L	0 ppb
Waynflete School	Arts Lower Level Dance Restroom Sink R	0 ppb
Waynflete School	Arts Lower Level Theater Restroom Sink	4 ppb
Waynflete School	Arts Lower Level Theater Workshop Sink	12.4 ppb
Waynflete School	Arts Theater Restroom Womens Sink C	2.5 ppb
Waynflete School	Arts Theater Restroom Mens Sink C	2.5 ppb
Waynflete School	Arts Theater Restroom Mens Sink L	1.9 ppb
Waynflete School	Arts Theater Restroom Mens Sink R	5.2 ppb
Waynflete School	Arts Theater Restroom Womens Sink L	1.7 ppb
Waynflete School	Arts Theater Restroom Womens Sink R	1.1 ppb
Waynflete School	Ch Level 1 Restroom Sink L	0 ppb
Waynflete School	Ch Level 1 Restroom Sink R	0 ppb
Waynflete School	Ch Level 1 Water Fountain	0 ppb
Waynflete School	Ch Level 2 Restroom Sink	0 ppb
Waynflete School	Ch Level 3 Restroom	0 ppb
Waynflete School	Chm 24-classroom Sink Window	0 ppb
Waynflete School	Chm-11 Sink	0 ppb
Waynflete School	Chm-24 Classroom Sink Corner	4.9 ppb
Waynflete School	E-00 Classroom Fish Tank Sink	0 ppb
Waynflete School	E-00 Classroom Island Sink	1.6 ppb
Waynflete School	E-00 Classroom Sink Pod #1	5.3 ppb
Waynflete School	E-00 Classroom Sink Pod #2	36.1 ppb
Waynflete School	E-00 Classroom Sink Pod #3	4.1 ppb
Waynflete School	E-00 Classroom Sink Pod #4	8.7 ppb
Waynflete School	E-00 Classroom Student Ctr Sink	0 ppb
Waynflete School	E-00 Office Sink	1.2 ppb
Waynflete School	E-10 Classroom Island Sink	0 ppb
Waynflete School	E-10 Classroom Sink L Back	1.2 ppb
Waynflete School	E-10 Classroom Sink L Front	1.1 ppb

School Name	Sample Location	Lead Test Result
Waynflete School	E-10 Classroom Sink Pod #1	0 ppb
Waynflete School	E-10 Classroom Sink Pod #2	12 ppb
Waynflete School	E-10 Classroom Sink Pod #3	1.7 ppb
Waynflete School	E-10 Classroom Sink Pod #4	1.1 ppb
Waynflete School	E-10 Classroom Sink R Back	0 ppb
Waynflete School	E-10 Office Sink	0 ppb
Waynflete School	E-11 Classroom Sink Pod #1	8.8 ppb
Waynflete School	E-11 Classroom Sink Pod #2	12.6 ppb
Waynflete School	E-11 Classroom Sink Pod #3	8.1 ppb
Waynflete School	E-11 Classroom Sink Pod #4	15.7 ppb
Waynflete School	E-11 Classroom Utility Sink	1.2 ppb
Waynflete School	E-20 Classroom Sink L	0 ppb
Waynflete School	E-20 Classroom Sink R	0 ppb
Waynflete School	E-20 Office Sink	3.5 ppb
Waynflete School	E-21 Classroom Sink Island	19.4 ppb
Waynflete School	E-21 Classroom Sink Peninsula #1	9.3 ppb
Waynflete School	E-21 Classroom Sink Peninsula #2	76 ppb
Waynflete School	E-21 Classroom Sink Peninsula #3	30.4 ppb
Waynflete School	E-21 Classroom Sink Peninsula #4	4.7 ppb
Waynflete School	E-21 Classroom Utility Sink	2.8 ppb
Waynflete School	E-24 Classroom Kitchen Sink	3.4 ppb
Waynflete School	Emery Atrium Restroom Sink L	0 ppb
Waynflete School	Emery Atrium Water Bubbler	0 ppb
Waynflete School	Emery Atrium Water Fountain	133 ppb
Waynflete School	Emery Atrium Restroom Sink R	0 ppb
Waynflete School	Emery Bunker Sink	3.6 ppb
Waynflete School	Emery Cafe Sink By Stove	2.2 ppb
Waynflete School	Emery Cafe Sink Dish Washing Station	0 ppb
Waynflete School	Emery Hallway Bunker Sink	1.6 ppb
Waynflete School	Emery Ice Machine	0 ppb
Waynflete School	Emery Level 1 Restroom L	0 ppb
Waynflete School	Emery Level 1 Restroom R	0 ppb
Waynflete School	Emery Level 1 Water Fountain	0 ppb
Waynflete School	Emery Level 2 Restroom Sink L	0 ppb
Waynflete School	Emery Level 2 Restroom Sink R	1.1 ppb
Waynflete School	Emery Level 2 Water Fountain	0 ppb
Waynflete School	Emery Level 3 Restroom Sink L	0 ppb
Waynflete School	Emery Level 3 Restroom Sink R	0 ppb
Waynflete School	Emery Level 3 Water Fountain	8.8 ppb
Waynflete School	Emery Library Hall Restroom Sink	0 ppb
Waynflete School	Emery Library Office Sink	1.6 ppb
Waynflete School	Frc Baseball Field Spigot	3 ppb
Waynflete School	Frc Boys Locker Room Sink	6.7 ppb
Waynflete School	Frc Cage Water Spigot	4.5 ppb
Waynflete School	Frc Fieldhouse Ice Machine	5 ppb
Waynflete School	Frc Girls Locker Room Sink	1.4 ppb
Waynflete School	Frc Girls Locker Room Water Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Waynflete School	Frc Tennis Pavilion Outside Spigot	0 ppb
Waynflete School	Frc Tennis Pavilion Restroom Sink	0 ppb
Waynflete School	Frc Tennis Pavilion Water Fountain	2.5 ppb
Waynflete School	Gym Boys Restroom Sink L	0 ppb
Waynflete School	Gym Boys Restroom Sink R	1.1 ppb
Waynflete School	Gym Girls Restroom Sink L	0 ppb
Waynflete School	Gym Girls Restroom Sink R	0 ppb
Waynflete School	Gym Water Fountain	0 ppb
Waynflete School	Hurd As Restroom Sink	0 ppb
Waynflete School	Hurd As Water Bubbler	0 ppb
Waynflete School	Hurd Level 1 Restroom Sink L	0 ppb
Waynflete School	Hurd Level 1 Restroom Sink R	3.1 ppb
Waynflete School	Hurd Level 1 Water Fountain	11.8 ppb
Waynflete School	Hurd Level 2 Restroom Sink	6 ppb
Waynflete School	Ls 2-3 Kitchen Sink	0 ppb
Waynflete School	Ls 2-3 Restroom Sink L	0 ppb
Waynflete School	Ls 2-3 Restroom Sink R	0 ppb
Waynflete School	Ls 2-3 Sink/fountain L	0 ppb
Waynflete School	Ls 2-3 Sink/fountain R	0 ppb
Waynflete School	Ls 4-5 Classroom Sink L Front	0 ppb
Waynflete School	Ls 4-5 Classroom Sink L Middle	0 ppb
Waynflete School	Ls 4-5 Classroom Sink R Back	0 ppb
Waynflete School	Ls 4-5 Classroom Sink R Front	0 ppb
Waynflete School	Ls 4-5 Kitchen Sink	0 ppb
Waynflete School	Ls 4-5 Restroom Sink L	0 ppb
Waynflete School	Ls 4-5 Restroom Sink R	0 ppb
Waynflete School	Ls Art Room Sink #1	1.1 ppb
Waynflete School	Ls Art Room Sink #2	0 ppb
Waynflete School	Ls Art Room Sink #3	0 ppb
Waynflete School	Ls Art Room Sink #4	0 ppb
Waynflete School	Ls Founders Ec Classroom Sink L Back	0 ppb
Waynflete School	Ls Founders Ec Classroom Sink R Back	0 ppb
Waynflete School	Ls Founders Ec Classroom Sink R Front	0 ppb
Waynflete School	Ls Founders Ec Restroom Sink L	0 ppb
Waynflete School	Ls Founders Ec Restroom Sink R	0 ppb
Waynflete School	Ls Innovation Lab Sink	0 ppb
Waynflete School	Ls K-1 Classroom Sink L	0 ppb
Waynflete School	Ls K-1 Classroom Sink R & Fountain	0 ppb
Waynflete School	Ls K-1 Restroom Sink C	0 ppb
Waynflete School	Ls K-1 Restroom Sink L	0 ppb
Waynflete School	Ls K-1 Restroom Sink R	0 ppb
Waynflete School	Ls Level 1 Library Restroom Sink	0 ppb
Waynflete School	Ls Level 1 Teaching Kitchen Sink	2 ppb
Waynflete School	Ls Level 2 Water Fountain	0 ppb
Waynflete School	Ls Lower Level Laundry Sink	13.6 ppb
Waynflete School	Ls Lower Level Restroom Sink L Back	0 ppb
Waynflete School	Ls Lower Level Restroom Sink L Front	0 ppb

School Name	Sample Location	Lead Test Result
Waynflete School	Ls Lower Level Restroom Sink R Back	0 ppb
Waynflete School	Ls Lower Level Restroom Sink R Front	0 ppb
Waynflete School	Ls Lower Level Water Fountain	0 ppb
Waynflete School	Ls Main Lobby Water Fountain	0 ppb
Waynflete School	M Level 1 Rn Office Sink	0 ppb
Waynflete School	M Level 1 Rn Office Water Bubbler	0 ppb
Waynflete School	M Level 2 Restroom Sink	0 ppb
Waynflete School	M Level 2 Water Fountain	30 ppb
Waynflete School	M Level 3 Kitchen Sink	0 ppb
Waynflete School	M Level 3 Restroom Sink	0 ppb
Waynflete School	Sills Restroom Sink	5.5 ppb
Waynflete School	Sills Water Fountain L	13.9 ppb
Waynflete School	Sills Water Fountain R	25 ppb
Waynflete School	Th Level 1 Restroom Sink	3.1 ppb
Waynflete School	Th Level 2 Kitchen Sink	1.6 ppb
Waynflete School	Th Level 2 Restroom Sink	1.6 ppb
Waynflete School	Th Level 2 Water Bubbler	0 ppb
Waynflete School	Th Mailroom Restroom Sink	0 ppb
Waynflete School	Th Mailroom Water Bubbler	0 ppb
Wells Elementary School	Cafeteria Drinking Fountain	0 ppb
Wells Elementary School	C-wing Hall Bottle Fill Station	0 ppb
Wells Elementary School	C-wing Hall Fountain	0 ppb
Wells Elementary School	First Floor East Wing Water Fountain	0 ppb
Wells Elementary School	First Floor West Wing Water Fountain	0 ppb
Wells Elementary School	Kitchen Ice Machine	0 ppb
Wells Elementary School	Kitchen Kettle	1.5 ppb
Wells Elementary School	Kitchen Single Sink Faucet 1	0 ppb
Wells Elementary School	Kitchen Single Sink Faucet 2	1 ppb
Wells Elementary School	Kitchen Single Sink Faucet 3	0 ppb
Wells Elementary School	Kitchen Tilt Skillet	13.1 ppb
Wells Elementary School	Room 116 Refridgerator	0 ppb
Wells Elementary School	Room 116 Staff Lunch Double Sink	0 ppb
Wells Elementary School	Room 125 Double Basin Sink	0 ppb
Wells Elementary School	Room 125 Refridgerator	0 ppb
Wells Elementary School	Second Floor East Wing Water Fountain	0 ppb
Wells Elementary School	Second Floor West Wing Water Fountain	0 ppb
Wells High School	Bridges Room Sink	0 ppb
Wells High School	First Floor Bottle Filler	0 ppb
Wells High School	Fitness Room Bottle Filler	0 ppb
Wells High School	Football Concession Stand	0 ppb
Wells High School	Ice Machine Kitchen	0 ppb
Wells High School	Ice Machine Trainers Room	0 ppb
Wells High School	Kitchen Single Sink	0 ppb
Wells High School	Kitchen Steamer	0 ppb
Wells High School	Kitchen Tri Sink	0 ppb
Wells High School	Pe Gym Bottle Filler	0 ppb
Wells High School	Second Floor Bottle Filler	0 ppb

School Name	Sample Location	Lead Test Result
Wells High School	Second Floor Teachers Room	0 ppb
Wells High School	Third Floor Bottle Filler	0 ppb
Wells High School	Track Concession Stand	0 ppb
Wells Junior High School	5th Grade Wing Bottle Fill Station	0 ppb
Wells Junior High School	7th Grade Wing Bottle Fill Station	0 ppb
Wells Junior High School	8th Grade Wing Bottle Fill Station	0 ppb
Wells Junior High School	Bridges Room Sink	0 ppb
Wells Junior High School	Health Room Sink Next To Stove	0 ppb
Wells Junior High School	Ice Maching Pe Office	0 ppb
Wells Junior High School	Kitchen 2 Bay Sink For Cooking	0 ppb
Wells Junior High School	Pe Office Bottle Fill Station	0 ppb
Wentworth School	A117 Staff Break Room Sink	0 ppb
Wentworth School	A125 Exam Sink	1.6 ppb
Wentworth School	A127 Clinic Sink	0 ppb
Wentworth School	A127 Culligan Dispenser	0 ppb
Wentworth School	A136 Work Room Sink	0 ppb
Wentworth School	A147 Conference Rm Sink	0 ppb
Wentworth School	A151 Vol Ctr Sink	0 ppb
Wentworth School	A153 Gym Bottle Filler	0 ppb
Wentworth School	A153 Gym Fountain High	0 ppb
Wentworth School	A153 Gym Fountain Low	0 ppb
Wentworth School	A159 Custodial Break Sink	0 ppb
Wentworth School	A185 Caf Kitchen Sink	0 ppb
Wentworth School	B100 Hall Bottle Filler	0 ppb
Wentworth School	B100 Hall Filler High	0 ppb
Wentworth School	B100 Hall Filler Low	0 ppb
Wentworth School	B102 Stem Large Sink	1.4 ppb
Wentworth School	B102 Stem Sink Left	0 ppb
Wentworth School	B102 Stem Sink W/eyewash	0 ppb
Wentworth School	B103 Fountain	1.8 ppb
Wentworth School	B103 Sink	1.2 ppb
Wentworth School	B104 Fountain	2.6 ppb
Wentworth School	B104 Sink	0 ppb
Wentworth School	B105 Fountain	1.6 ppb
Wentworth School	B105 Sink	0 ppb
Wentworth School	B108 Fountain	2.9 ppb
Wentworth School	B108 Sink	0 ppb
Wentworth School	B109 Fountain	4.1 ppb
Wentworth School	B109 Sink	0 ppb
Wentworth School	B110 Fountain	3.7 ppb
Wentworth School	B110 Sink	0 ppb
Wentworth School	B113 Fountain	2.7 ppb
Wentworth School	B113 Sink	0 ppb
Wentworth School	B114 Fountain	3.2 ppb
Wentworth School	B114 Sink	0 ppb
Wentworth School	B122 Sink	0 ppb
Wentworth School	B123 Fountain	17.9 ppb

School Name	Sample Location	Lead Test Result
Wentworth School	B123 Sink	1.4 ppb
Wentworth School	B125 Break Room Sink	0 ppb
Wentworth School	B128 Fountain	8.6 ppb
Wentworth School	B128 Sink	0 ppb
Wentworth School	B130 Fountain	9.3 ppb
Wentworth School	B130 Sink	3.1 ppb
Wentworth School	B131 Fountain	5.6 ppb
Wentworth School	B131 Sink	1.3 ppb
Wentworth School	B132 Fountain	3.2 ppb
Wentworth School	B132 Sink	0 ppb
Wentworth School	B140a Counter Sink	0 ppb
Wentworth School	B140a Island Sink	0 ppb
Wentworth School	B145 Fountain	2.5 ppb
Wentworth School	B145 Sink	0 ppb
Wentworth School	B146 Fountain	2.4 ppb
Wentworth School	B146 Sink	0 ppb
Wentworth School	B147 Fountain	17.8 ppb
Wentworth School	B147 Sink	2.4 ppb
Wentworth School	B148 Sink	0 ppb
Wentworth School	B200 Hall Bottle Filler	0 ppb
Wentworth School	B200 Hall Fountain High	0 ppb
Wentworth School	B200 Hall Fountain Low	0 ppb
Wentworth School	B201 Corner Sink	0 ppb
Wentworth School	B201 South Sink	0 ppb
Wentworth School	B201 Stem Double Sink	0 ppb
Wentworth School	B203 Fountain	2.4 ppb
Wentworth School	B203 Sink	1 ppb
Wentworth School	B204 Fountain	2.8 ppb
Wentworth School	B204 Sink	0 ppb
Wentworth School	B205 Fountain	1.8 ppb
Wentworth School	B205 Sink	0 ppb
Wentworth School	B208 Fountain	3.3 ppb
Wentworth School	B208 Sink	1.2 ppb
Wentworth School	B209 Fountain	4 ppb
Wentworth School	B209 Sink	0 ppb
Wentworth School	B210 Fountain	1.6 ppb
Wentworth School	B210 Sink	0 ppb
Wentworth School	B213 Fountain	3 ppb
Wentworth School	B213 Sink	0 ppb
Wentworth School	B214 Fountain	2.8 ppb
Wentworth School	B214 Sink	1.3 ppb
Wentworth School	B222 Sink	0 ppb
Wentworth School	B223 Fountain	2.7 ppb
Wentworth School	B223 Sink	1.1 ppb
Wentworth School	B225 Break Room Sink	0 ppb
Wentworth School	B228 Fountain	5.6 ppb
Wentworth School	B228 Sink	1.4 ppb

School Name	Sample Location	Lead Test Result
Wentworth School	B230 Fountain	7.9 ppb
Wentworth School	B230 Sink	2.2 ppb
Wentworth School	B231 Fountain	1.3 ppb
Wentworth School	B231 Sink	0 ppb
Wentworth School	B235 Fountain	31.5 ppb
Wentworth School	B235 Sink	1.5 ppb
Wentworth School	B237 Sink	0 ppb
Wentworth School	B238 Fountain	2.6 ppb
Wentworth School	B238 Sink	1 ppb
Wentworth School	B245 Fountain	1.5 ppb
Wentworth School	B245 Sink	0 ppb
Wentworth School	B246 Fountain	2.6 ppb
Wentworth School	B246 Sink	0 ppb
Wentworth School	B247 Fountain	9.2 ppb
Wentworth School	B247 Sink	0 ppb
Wentworth School	B248 Sink	1.3 ppb
Wentworth School	C100 Hall Bottle Filler	0 ppb
Wentworth School	C100 Hall Fountain High	0 ppb
Wentworth School	C100 Hall Fountain Low	0 ppb
Wentworth School	C101 Sink	0 ppb
Wentworth School	C103 Fountain	7.5 ppb
Wentworth School	C103 Sink	0 ppb
Wentworth School	C104 Fountain	1.5 ppb
Wentworth School	C104 Sink	0 ppb
Wentworth School	C105 Fountain	4.1 ppb
Wentworth School	C105 Sink	1 ppb
Wentworth School	C115 Fountain	3.3 ppb
Wentworth School	C115 Sink	0 ppb
Wentworth School	C116 Fountain	0 ppb
Wentworth School	C116 Sink	0 ppb
Wentworth School	C119 Fountain	1.4 ppb
Wentworth School	C119 Sink	0 ppb
Wentworth School	C120 Fountain	1.2 ppb
Wentworth School	C120 Sink	1.8 ppb
Wentworth School	C121 Fountain	2 ppb
Wentworth School	C121 Sink	0 ppb
Wentworth School	C124 Fountain	1.3 ppb
Wentworth School	C124 Sink	0 ppb
Wentworth School	C125 Fountain	4.9 ppb
Wentworth School	C125 Sink	0 ppb
Wentworth School	C126 Fountain	1.7 ppb
Wentworth School	C126 Sink	0 ppb
Wentworth School	C127 Fountain	7.8 ppb
Wentworth School	C127 Sink	2.8 ppb
Wentworth School	C200 Hall Bottle Filler	0 ppb
Wentworth School	C200 Hall Fountain High	0 ppb
Wentworth School	C200 Hall Fountain Low	0 ppb

School Name	Sample Location	Lead Test Result
Wentworth School	C201 Sink	1.2 ppb
Wentworth School	C203 Fountain	5.7 ppb
Wentworth School	C203 Sink	0 ppb
Wentworth School	C204 Fountain	1.7 ppb
Wentworth School	C204 Sink	0 ppb
Wentworth School	C205 Fountain	1.6 ppb
Wentworth School	C205 Sink	1.4 ppb
Wentworth School	C215 Fountain	3.7 ppb
Wentworth School	C215 Sink	0 ppb
Wentworth School	C216 Fountain	3.2 ppb
Wentworth School	C216 Sink	0 ppb
Wentworth School	C219 Fountain	2.4 ppb
Wentworth School	C219 Sink	1.2 ppb
Wentworth School	C220 Fountain	2.4 ppb
Wentworth School	C220 Sink	0 ppb
Wentworth School	C221 Fountain	2.4 ppb
Wentworth School	C221 Sink	0 ppb
Wentworth School	C224 Fountain	1.7 ppb
Wentworth School	C224 Sink	0 ppb
Wentworth School	C225 Fountain	2.6 ppb
Wentworth School	C225 Sink	1.5 ppb
Wentworth School	C226 Fountain	2 ppb
Wentworth School	C226 Sink	0 ppb
Wentworth School	C227 Fountain	2.1 ppb
Wentworth School	C227 Sink	2.6 ppb
Wentworth School	C227 Stem Big Sink	0 ppb
Wentworth School	Caf Bottle Filler L	0 ppb
Wentworth School	Caf Bottle Filler R	0 ppb
Wentworth School	Caf L Fountain High	0 ppb
Wentworth School	Caf L Fountain Low	0 ppb
Wentworth School	Caf R Fountain High	0 ppb
Wentworth School	Caf R Fountain Low	0 ppb
Wentworth School	Coffee Maker	0 ppb
Wentworth School	D105 Work Room Sink	0 ppb
Wentworth School	D106 Sink	0 ppb
Wentworth School	D108 Art Large Sink	0 ppb
Wentworth School	D111 Art Large Sink	0 ppb
Wentworth School	D114 Chorus Fountain	6 ppb
Wentworth School	D114 Chorus Sink	0 ppb
Wentworth School	D120 Band Fountain	4.3 ppb
Wentworth School	D120 Band Sink	0 ppb
Wentworth School	D120 Solo Sink	2.2 ppb
Wentworth School	D123 Fountain	5.4 ppb
Wentworth School	D123 Sink	1 ppb
Wentworth School	D124 Fountain	17.1 ppb
Wentworth School	D124 Sink	0 ppb
Wentworth School	D125 Fountain	3.1 ppb

School Name	Sample Location	Lead Test Result
Wentworth School	D125 Sink	1.2 ppb
Wentworth School	D127 Big Sink	0 ppb
Wentworth School	D127 Fountain	12.7 ppb
Wentworth School	D127 Sink	2.3 ppb
Wentworth School	Kitchen Ice Maker	0 ppb
Wentworth School	Lc Maker Space Sink	0 ppb
Wentworth School	Learning Commons Fountain At Sink	6.9 ppb
Wentworth School	Learning Commons Sink #1	0 ppb
Wentworth School	Main Hall Bottle Filler	0 ppb
Wentworth School	Main Hall Fountain High	0 ppb
Wentworth School	Main Hall Fountain Low	0 ppb
Wentworth School	Produce 2-bay Sink	0 ppb
Wentworth School	Produce Sink Near Stove	0 ppb
Wentworth School	Produce Sink Nsk	0 ppb
Wentworth School	Steam Kettle L	1.5 ppb
Wentworth School	Steam Kettle R	1.7 ppb
Wentworth School	Wash Sink By Coffee Maker	0 ppb
Wesley Elementary School	Drinking Fountain In Hall Way	0 ppb
Wesley Elementary School	Kitchen Food Prep Sink	2.3 ppb
West Bath School	1b	9 ppb
West Bath School	1h	17.6 ppb
West Bath School	2b	12.3 ppb
West Bath School	3m	15.5 ppb
West Bath School	4j	14.7 ppb
West Bath School	4s	23.9 ppb
West Bath School	5g	5.2 ppb
West Bath School	Art	6.2 ppb
West Bath School	Fountain	0 ppb
West Bath School	Kitchen	21.7 ppb
West Bath School	Kt	3.6 ppb
West Bath School	Nurse	5.3 ppb
West Bath School	Office	2.7 ppb
West Bath School	Teachers' Room	15.4 ppb
Westbrook High School	206	13.8 ppb
Westbrook High School	319	0 ppb
Westbrook High School	Co Kitchen 1	2.1 ppb
Westbrook High School	Co Kitchen 2	1.6 ppb
Westbrook High School	Gym Fountain Lobby Rear	0 ppb
Westbrook High School	Hall Fountain Audi Lobby	0 ppb
Westbrook High School	Hall Fountain Main	0 ppb
Westbrook High School	Hall Fountain Main South	2.3 ppb
Westbrook High School	Hall Fountain Sub	0 ppb
Westbrook High School	Hall Fountain Top	3.3 ppb
Westbrook High School	Hall Fountain Top South	2.4 ppb
Westbrook High School	Library Prep	2.9 ppb
Westbrook High School	Lockerroom Boys	0 ppb
Westbrook High School	Lockerroom Girls	1.4 ppb

School Name	Sample Location	Lead Test Result
Westbrook High School	Music Upper Fountain	0 ppb
Westbrook High School	Teachers Lounge	7.7 ppb
Westbrook Middle School	A108 Fountain	0 ppb
Westbrook Middle School	A110 Fountain	0 ppb
Westbrook Middle School	A111 Fountain	0 ppb
Westbrook Middle School	A112 Fountain	0 ppb
Westbrook Middle School	A113 Fountain	0 ppb
Westbrook Middle School	A114 Fountain	0 ppb
Westbrook Middle School	A200 Office Fountain	0 ppb
Westbrook Middle School	A205 Fountain	0 ppb
Westbrook Middle School	C101 Fountain	0 ppb
Westbrook Middle School	C103 Fountain	0 ppb
Westbrook Middle School	C105 Fountain	0 ppb
Westbrook Middle School	C106 Sink East	0 ppb
Westbrook Middle School	C106 Sink West	0 ppb
Westbrook Middle School	C108 Fountain	0 ppb
Westbrook Middle School	C109 Fountain	1.2 ppb
Westbrook Middle School	C114 Fountain	0 ppb
Westbrook Middle School	C116 Fountain	0 ppb
Westbrook Middle School	C117 Fountain	0 ppb
Westbrook Middle School	C118 Fountain	0 ppb
Westbrook Middle School	C119 Fountain	0 ppb
Westbrook Middle School	C120 Fountain	0 ppb
Westbrook Middle School	C121 Fountain	0 ppb
Westbrook Middle School	C122 Fountain	0 ppb
Westbrook Middle School	C123 Fountain	0 ppb
Westbrook Middle School	C125 Fountain	0 ppb
Westbrook Middle School	C129 Fountain	0 ppb
Westbrook Middle School	C200 Fountain	0 ppb
Westbrook Middle School	C201 Fountain	0 ppb
Westbrook Middle School	C202 Fountain	0 ppb
Westbrook Middle School	C203 Fountain	0 ppb
Westbrook Middle School	C204 Fountain	0 ppb
Westbrook Middle School	C212 Fountain	0 ppb
Westbrook Middle School	C214 Fountain	0 ppb
Westbrook Middle School	C216 Fountain	0 ppb
Westbrook Middle School	C218 Fountain	0 ppb
Westbrook Middle School	C220 Fountain	0 ppb
Westbrook Middle School	C221 Fountain	0 ppb
Westbrook Middle School	C223 Fountain	0 ppb
Westbrook Middle School	C225 Fountain	0 ppb
Westbrook Middle School	C227 Fountain	0 ppb
Westbrook Middle School	C229 Fountain	0 ppb
Westbrook Middle School	C233 Fountain	0 ppb
Westbrook Middle School	C300 Fountain	2.3 ppb
Westbrook Middle School	C301 Fountain	0 ppb
Westbrook Middle School	C302 Fountain	4.8 ppb

School Name	Sample Location	Lead Test Result
Westbrook Middle School	C303 Fountain	0 ppb
Westbrook Middle School	C304 Fountain	0 ppb
Westbrook Middle School	C305 Fountain	0 ppb
Westbrook Middle School	C306 Fountain	0 ppb
Westbrook Middle School	C308a Fountain	0 ppb
Westbrook Middle School	C309 Fountain	0 ppb
Westbrook Middle School	C312 Fountain	3.8 ppb
Westbrook Middle School	C313 Fountain	0 ppb
Westbrook Middle School	C314 Fountain	8.9 ppb
Westbrook Middle School	C315 Fountain	0 ppb
Westbrook Middle School	C316 Fountain	2.1 ppb
Westbrook Middle School	C317 Fountain	0 ppb
Westbrook Middle School	C318 Fountain	2.6 ppb
Westbrook Middle School	C319 Fountain	0 ppb
Westbrook Middle School	C320 Fountain	2.5 ppb
Westbrook Middle School	C321 Fountain	0 ppb
Westbrook Middle School	C325 Fountain	0 ppb
Westbrook Middle School	Common 1 Fountain	1.6 ppb
Westbrook Middle School	Common 2 Fountain	1.9 ppb
Westbrook Middle School	Common 3 Fountain	2.9 ppb
Westbrook Middle School	Hall Band Fountain	1.8 ppb
Westbrook Middle School	Hall Gym Fountain	1.6 ppb
Westbrook Middle School	Hall Pac Fountain	2 ppb
Westbrook Middle School	Kitchen Prep Sink	2.2 ppb
Westbrook Regional Technology Ctr	Kitchen Prep 1	0 ppb
Westbrook Regional Technology Ctr	Kitchen Prep 2	1.1 ppb
Westbrook Regional Technology Ctr	V1 Office	0 ppb
Westbrook Regional Technology Ctr	V2 Sink	0 ppb
Westbrook Regional Technology Ctr	V24 Sink	0 ppb
Westbrook Regional Technology Ctr	V3 Sink	0 ppb
Westbrook Regional Technology Ctr	V4 Prep 1	0 ppb
Westbrook Regional Technology Ctr	V4 Prep 2	0 ppb
Westbrook Regional Technology Ctr	Vhall Fountain East	0 ppb
Westbrook Regional Technology Ctr	Vhall Fountain Mid	0 ppb
Western Foothills Regional Program	2110 Ms Laundry- Sink	1.5 ppb
Western Foothills Regional Program	2203 Hs Classroom- Sink	2.6 ppb
Western Foothills Regional Program	2204 Classroom	2 ppb
Western Foothills Regional Program	2207 Classroom- Bathroom Sink	0 ppb
Western Foothills Regional Program	2208 Main Office Bath Room 1	2.1 ppb
Western Foothills Regional Program	2209 Kitchen Hand Sink 1- (k1)	0 ppb
Western Foothills Regional Program	2209 Kitchen Hnd Sink 2 (k2)	1.7 ppb
Western Foothills Regional Program	2216 Classroom	1.7 ppb
Western Foothills Regional Program	Art Room Sink- (ar)	5.8 ppb
Western Foothills Regional Program	Boiler Room Sink- (bor 1)	0 ppb
Western Foothills Regional Program	Custodians Room	0 ppb
Western Foothills Regional Program	Elementary Bathroom 2- (ebr2)	7.8 ppb
Western Foothills Regional Program	Elementary Bathroom 1- (ebr1)	16.4 ppb

School Name	Sample Location	Lead Test Result
Western Foothills Regional Program	Elementary Bathroom 3- (ebr3)	3 ppb
Western Foothills Regional Program	Elementary Water Fountain- (ewf)	0 ppb
Western Foothills Regional Program	Hs Bathroom- (hsbr)	6.8 ppb
Western Foothills Regional Program	Hs Water Fountain- (hswf)	0 ppb
Western Foothills Regional Program	Main Entrance Bathroom (mebr)	7 ppb
Western Foothills Regional Program	Main Entrance Fountain (mef1)	0 ppb
Western Foothills Regional Program	Shop/fitness Center Bathroom Sink- Sfbr	7.3 ppb
Western Foothills Regional Program	Teachers Bathroom- (tbr)	5.7 ppb
Western Foothills Regional Program	Teachers Room- (tr)	4.6 ppb
WFS Pineland	1st Floor Ladies Room	0 ppb
WFS Pineland	1st Floor Mens Room	1.9 ppb
WFS Pineland	2nd Floor Ladies Room	1.6 ppb
WFS Pineland	Kitchen Water Cooler	0 ppb
WFS Pineland	Moon Bathroom	0 ppb
WFS Pineland	Moon Room	0 ppb
WFS Pineland	Ocean Bathroom	1.5 ppb
WFS Pineland	Purple	2.8 ppb
WFS Pineland	Staff Kitchen	0 ppb
WFS Pineland	Sun Bathroom	0 ppb
WFS Pineland	Sun Room	0 ppb
WFS Pineland	Yellow Bathroom	0 ppb
WFS Waterville	Forest Bathroom	0 ppb
WFS Waterville	Forest Room	0 ppb
WFS Waterville	Guest Bathroom	0 ppb
WFS Waterville	Ocean Bathroom	0 ppb
WFS Waterville	Ocean Room	0 ppb
WFS Waterville	Space Bathroom	0 ppb
WFS Waterville	Space Room	0 ppb
WFS Waterville	Staff Bathroom	0 ppb
WFS Waterville	Staff Kitchen	0 ppb
WFS Waterville	Water Cooler	0 ppb
WFS Westbrook	Belugas Classroom	0 ppb
WFS Westbrook	Children's Bathroom Sink 1	1.3 ppb
WFS Westbrook	Children's Bathroom Sink 2	2 ppb
WFS Westbrook	Hallway Sink	1 ppb
WFS Westbrook	Ladies Bathroom Sink 1	2.2 ppb
WFS Westbrook	Ladies Bathroom Sink 2	2.2 ppb
WFS Westbrook	Ladies Bathroom Sink 3	1.1 ppb
WFS Westbrook	Main Kitchen	1.4 ppb
WFS Westbrook	Mens Bathroom	0 ppb
WFS Westbrook	Mens Bathroom Sink 2	1.2 ppb
WFS Westbrook	Motor Room	18.8 ppb
WFS Westbrook	Narwals Classroom	0 ppb
WFS Westbrook	Staff Kitchen	2.3 ppb
WFS Westbrook	Starfish Classroom	1.5 ppb
WFS Westbrook	Turtles Bathroom Sink 1	1.1 ppb
WFS Westbrook	Turtles Bathroom Sink 2	0 ppb

School Name	Sample Location	Lead Test Result
WFS Westbrook	Turtles Sink	1.2 ppb
WFS Westbrook	Water Cooler	0 ppb
Whitefield Elementary School	Bottle Fill Near Boys Restroom (el. Wing)	0 ppb
Whitefield Elementary School	Bottle Filler Across From Rm #3	0 ppb
Whitefield Elementary School	Gym Between Boys And Girls Restrooms	0 ppb
Whitefield Elementary School	Kitchen #1	1.8 ppb
Whitefield Elementary School	Kitchen #2	0 ppb
Whitefield Elementary School	Nurses Rm	1.1 ppb
Whitefield Elementary School	Pre-k Sink Faucet #1	0 ppb
Whitefield Elementary School	Pre-k Sink Faucet #2	0 ppb
Whitefield Elementary School	Rm #14 Teachers Rm	0 ppb
Whitefield Elementary School	Sink Across From Rm #25	0 ppb
Whiting Village School	Drinking Fountain	3.7 ppb
Whiting Village School	Kitchen Prep Sink	0 ppb
Willard School	A-floor Wtr Fountain Boys Rm	2 ppb
Willard School	A-floor Wtr Fountain Girls Rm	17.1 ppb
Willard School	B-floor Teachers Room	13.9 ppb
Willard School	B-floor Wtr Fountain Boys Rm	1.4 ppb
Willard School	B-floor Wtr Fountain Girls Rm	3.9 ppb
Willard School	C-floor Wtr Fountain Boys Rm	3.3 ppb
Willard School	C-floor Wtr Fountain Girls Rm	14.7 ppb
Willard School	Nurse Office Sink	24.4 ppb
William H Rowe School	Gym Fountain	3.8 ppb
William H Rowe School	Kitchen Sink	1.1 ppb
William H Rowe School	Kitchen Steamer	12.3 ppb
William H Rowe School	Main Lobby Outside Office Fountain	2.6 ppb
William H Rowe School	Nurse Room Sink	8.4 ppb
William H Rowe School	Room B126 Fountain	5.7 ppb
William H Rowe School	Room B127 Fountain	3.4 ppb
William H Rowe School	Room B128 Fountain	7.8 ppb
William H Rowe School	Room B129 Fountain	7.9 ppb
William H Rowe School	Room B130 Fountain	6.4 ppb
William H Rowe School	Room B131 Fountain	6.1 ppb
William H Rowe School	Room B132 Fountain	7.7 ppb
William H Rowe School	Room B133 Fountain	9.4 ppb
William H Rowe School	Room B134 Fountain	11.3 ppb
William H Rowe School	Room B135 Fountain	6.3 ppb
William H Rowe School	Room B136 Fountain	6.9 ppb
William H Rowe School	Room B137 Fountain	6.6 ppb
William H Rowe School	Room B138 Fountain	3.6 ppb
William H Rowe School	Room B140 Break Room	2.4 ppb
William H Rowe School	Room B143 Fountain	3.6 ppb
William H Rowe School	Room B145 Fountain	4.9 ppb
William H Rowe School	Room B146 Fountain	3.6 ppb
William H Rowe School	Room B147 Fountain	2.6 ppb
William H Rowe School	Room B148 Fountain	3.2 ppb
William H Rowe School	Room B149 Fountain	1.9 ppb

School Name	Sample Location	Lead Test Result
William S. Cohen School	Bottle Fill Station - Auditorium	0 ppb
William S. Cohen School	Bottle Fill Station - Gym	0 ppb
William S. Cohen School	Bottle Fill Station - Library	0 ppb
William S. Cohen School	Bottle Fill Station - Near Head End Room	0 ppb
William S. Cohen School	Bottle Fill Station - Outside Cafeteria	0 ppb
William S. Cohen School	Bottle Fill Station - Outside Gym	0 ppb
William S. Cohen School	Bottle Fill Station - Outside Room 207	0 ppb
William S. Cohen School	Bottle Fill Station - Outside Room 220	0 ppb
William S. Cohen School	Faucet - Room 125	1.4 ppb
William S. Cohen School	Faucet - Room 213	0 ppb
William S. Cohen School	Faucet - Teacher's Lounge	0 ppb
William S. Cohen School	Kitchen - Double Basin Sink Faucet	1.1 ppb
William S. Cohen School	Kitchen - Kettle	16.4 ppb
Williams Elementary School	105 Girls Locker Room - Sink A	0 ppb
Williams Elementary School	105 Girls Locker Room - Sink B	0 ppb
Williams Elementary School	105 Girls Locker Room - Sink C	0 ppb
Williams Elementary School	107 Boys Bath Room - Sink A	0 ppb
Williams Elementary School	107 Boys Bath Room - Sink C	0 ppb
Williams Elementary School	107 Boys Bath Room - Sink B	0 ppb
Williams Elementary School	200 Staff Lounge - Sink	1.1 ppb
Williams Elementary School	200 Staff Lounge - Water Cooler	0 ppb
Williams Elementary School	200 Staff Lounge Bathroom - Sink A	1.1 ppb
Williams Elementary School	200 Staff Lounge Bathroom -sink -b	0 ppb
Williams Elementary School	253-255-a -bottle Fill Station	0 ppb
Williams Elementary School	Cafateria - Dish Wash Sink	1.7 ppb
Williams Elementary School	Cafateria - Sanatize Sink	1 ppb
Williams Elementary School	Cafateria Hand Wash - Sink B	1.2 ppb
Williams Elementary School	Cafateria Hand Wash - Sink A	12.2 ppb
Williams Elementary School	Extension Of Room 003 Sink B	1.4 ppb
Williams Elementary School	Main Office - Bathroom Sink	0 ppb
Williams Elementary School	Mens Locker Room - Sink	4.5 ppb
Williams Elementary School	Next To 253-255 A Drinking Water Fountain	0 ppb
Williams Elementary School	Next To 255 Bottle Fill Station 208	0 ppb
Williams Elementary School	Next To 255 Drinking Water Fountain 208	0 ppb
Williams Elementary School	Next To 308 Drinking Water Fountain	0 ppb
Williams Elementary School	Next To 308 Bottle Fill Station	0 ppb
Williams Elementary School	Next To Library Bot. Fill Station	0 ppb
Williams Elementary School	Next To Library Drinking Water Fountain	0 ppb
Williams Elementary School	Next To Mens Locker Room - Bottle Fill	0 ppb
Williams Elementary School	Next To Mens Locker Room - Dwf	0 ppb
Williams Elementary School	Nurses Station	1.2 ppb
Williams Elementary School	Room 005 -drinking Water Fountain	2.4 ppb
Williams Elementary School	Room 109-e Library -sink	8.1 ppb
Williams Elementary School	Room 251 Girls Bathroom Sink A	0 ppb
Williams Elementary School	Room 251 Girls Bathroom Sink B	4.8 ppb
Williams Elementary School	Room 253 Boys Bathroom Sink	2.7 ppb

School Name	Sample Location	Lead Test Result
Williams Elementary School	Room 259 - Sink A	15.7 ppb
Williams Elementary School	Room 259 - Sink B	50.4 ppb
Williams Elementary School	Room 261-sink A	4.9 ppb
Williams Elementary School	Room 263-sink	14.4 ppb
Williams Elementary School	Room 300 Girls Bathroom - Sink A	0 ppb
Williams Elementary School	Room 300 Girls Bathroom - Sink B	0 ppb
Williams Elementary School	Room 308 Boys Bathroom -sink A	0 ppb
Williams Elementary School	Room 308 Boys Bathroom -sink B	0 ppb
Williams Elementary School	Womens Locker Room - Sink	2.5 ppb
Williams-Cone School	1 Room 1 Water Fountain	2 ppb
Williams-Cone School	10 Room 5 Kitchen Faucet	0 ppb
Williams-Cone School	11 Room 6 Water Fountain	1.7 ppb
Williams-Cone School	12 Room 6 Kitchen Faucet	0 ppb
Williams-Cone School	13 Room 7 Water Fountain	2.5 ppb
Williams-Cone School	14 Room 7 Kitchen Faucet	0 ppb
Williams-Cone School	15 Room 8 Water Fountain	1.3 ppb
Williams-Cone School	16 Room 8 Kitchen Faucet	0 ppb
Williams-Cone School	2 Room 1 Kitchen Faucet	0 ppb
Williams-Cone School	25 Water Fountain	0 ppb
Williams-Cone School	28 Room 20 Kitchen Faucet	0 ppb
Williams-Cone School	3 Room 2 Water Fountain	1.6 ppb
Williams-Cone School	31 Water Fountain	0 ppb
Williams-Cone School	32 Water Fountain	0 ppb
Williams-Cone School	33 Kitchen Sprayer	4.2 ppb
Williams-Cone School	34 Kitchen Faucet Prep	1.1 ppb
Williams-Cone School	35 Kitchen Faucet Prep	0 ppb
Williams-Cone School	36 Hand Wash Sink	16.8 ppb
Williams-Cone School	37 Kitchen Faucet Prep	0 ppb
Williams-Cone School	4 Room 2 Kitchen Faucet	0 ppb
Williams-Cone School	41 Room 27 Kitchen Sink	0 ppb
Williams-Cone School	42 Room 27 Kitchen Sink	0 ppb
Williams-Cone School	47 Nurse Sink	0 ppb
Williams-Cone School	48 Water Fountain	1.3 ppb
Williams-Cone School	49 Water Fountain	0 ppb
Williams-Cone School	5 Room 3 Water Fountain	6.5 ppb
Williams-Cone School	55 Water Cooler	0 ppb
Williams-Cone School	56 Kitchen Faucet Prep	1.1 ppb
Williams-Cone School	58 Water Fountain	1.2 ppb
Williams-Cone School	6 Room 3 Kitchen Faucet	0 ppb
Williams-Cone School	65 Spigot	2.5 ppb
Williams-Cone School	7 Room 4 Water Fountain	4.5 ppb
Williams-Cone School	8 Room 4 Kitchen Faucet	0 ppb
Williams-Cone School	9 Room 5 Water Fountain	20.1 ppb
Windham High School	Athletic Lobby Water Fountain- Bottle Fill	0 ppb
Windham High School	Athletic Lobby Water Fountain- High Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Windham High School	Athletic Lobby Water Fountain- Low Fountain	0 ppb
Windham High School	Concession Stand- Sink Faucet	0 ppb
Windham High School	Eagles Nest Water Fountain- Bottle Fill	0 ppb
Windham High School	Eagles Nest Water Fountain- High Fountain	0 ppb
Windham High School	Eagles Nest Water Fountain- Low Fountain	0 ppb
Windham High School	Faculty Office K- Sink Faucet	0 ppb
Windham High School	Faculty Office M-sink Faucet	0 ppb
Windham High School	Gym Lobby Wf By Concession Stand- Bottle Fill	0 ppb
Windham High School	Gym Lobby Wf By Concession Stand-high Fountain	0 ppb
Windham High School	Gym Lobby Wf By Concession Stand-low Fountain	0 ppb
Windham High School	Katahdin- Bottle Fill	0 ppb
Windham High School	Katahdin-small Classroom Sink Faucet	0 ppb
Windham High School	Kitchen- Cleavland Kettle Sink	0 ppb
Windham High School	Kitchen- Dishwashing Sink #1 On Left	0 ppb
Windham High School	Kitchen- Dishwashing Sink #2 On Left	1.1 ppb
Windham High School	Kitchen- Dishwashing Sink #3 On Right	1.5 ppb
Windham High School	Kitchen- Prep Sink On Island Back Of Kitchen	0 ppb
Windham High School	Kitchen- Prep Sink On Island Front Of Kitchen	1 ppb
Windham High School	Kitchen- Steam Table Fill Faucet	0 ppb
Windham High School	Main Office-water Cooler & Heater	0 ppb
Windham High School	Prep Room 1c- Sink Faucet	8.6 ppb
Windham High School	Prep Room 1l- Sink Faucet	1 ppb
Windham High School	Prep Room 2c- Sink Faucet	19.8 ppb
Windham High School	Prep Room 3l- Sink Faucet	4.4 ppb
Windham High School	Room 113b- 3rd Island Back Faucet	10.8 ppb
Windham High School	Room 113b- 3rd Island Front Faucet	5 ppb
Windham High School	Room 113b- Demonstration Table Faucet	17.3 ppb
Windham High School	Room 113b- Faucet On Left Bench	4.7 ppb
Windham High School	Room 113b Prep Room- Sink Faucet	143 ppb
Windham High School	Room 113b-1st Island Back Faucet	4.5 ppb
Windham High School	Room 113b-1st Island Front Faucet	3.8 ppb
Windham High School	Room 113b-2nd Island Back Faucet	12.4 ppb
Windham High School	Room 113b-2nd Island Front Faucet	6.4 ppb
Windham High School	Room 114 C- Back Left Counter Sink Faucet	0 ppb
Windham High School	Room 114c- Demonstration Table Faucet	23.7 ppb
Windham High School	Room 114c-1st Island From Left Back Sink	89.3 ppb
Windham High School	Room 114c-1st Island From Left Front Sink	19.4 ppb
Windham High School	Room 114c-1st Island From Left Middle Sink	23.2 ppb
Windham High School	Room 114c-2nd Island From Left Back Sink	56.3 ppb

School Name	Sample Location	Lead Test Result
Windham High School	Room 114c-2nd Island From Left Front Sink	45.6 ppb
Windham High School	Room 114c-2nd Island From Left Middle Sink	38.5 ppb
Windham High School	Room 115c- Back Island Left Faucet	6.6 ppb
Windham High School	Room 115c- Back Island Right Faucet	6.3 ppb
Windham High School	Room 115c- Demonstration Table Faucet	29.2 ppb
Windham High School	Room 115c- Front Island Left Faucet	4.3 ppb
Windham High School	Room 115c- Front Island Right Faucet	1.3 ppb
Windham High School	Room 115c- Left Bench Faucet	0 ppb
Windham High School	Room 115c- Middle Island Left Faucet	3.6 ppb
Windham High School	Room 115c- Middle Island Right Faucet	4 ppb
Windham High School	Room 116c- Demonstration Table Faucet	67.2 ppb
Windham High School	Room 116c- Right Bench Sink Faucet	1.8 ppb
Windham High School	Room 116c-1st Island From Left Back Sink	5.1 ppb
Windham High School	Room 116c-1st Island From Left Front Sink	4.3 ppb
Windham High School	Room 116c-1st Island From Left Middle Sink	5.7 ppb
Windham High School	Room 116c-2nd Island From Left Back Sink	4.8 ppb
Windham High School	Room 116c-2nd Island From Left Front Sink	3.3 ppb
Windham High School	Room 116c-2nd Island From Left Middle Sink	5.6 ppb
Windham High School	Room 117c- Back Island Left Faucet	11.7 ppb
Windham High School	Room 117c- Back Island Right Faucet	6.3 ppb
Windham High School	Room 117c- Demonstration Table Faucet	29.2 ppb
Windham High School	Room 117c- Front Island Left Faucet	1.6 ppb
Windham High School	Room 117c- Middle Island Left Faucet	5.8 ppb
Windham High School	Room 117c- Middle Island Right Faucet	6.5 ppb
Windham High School	Room 117c- Right Bench Sink Faucet	3.4 ppb
Windham High School	Room 117c-front Island Right Faucet	1.7 ppb
Windham High School	Room 118c- Back Right Sink Faucet	11.1 ppb
Windham High School	Room 118c-back Left Sink Faucet	5.7 ppb
Windham High School	Room 118c-demonstration Table	101 ppb
Windham High School	Room 119c- Back Left Sink Faucet	3.2 ppb
Windham High School	Room 119c- Back Right Sink Faucet	4.1 ppb
Windham High School	Room 119c- Demonstration Table	20.4 ppb
Windham High School	Room 131e- Sink Faucet	0 ppb
Windham High School	Room 214l- Back Middle Sink Faucet	5 ppb
Windham High School	Room 214l- Back Right Sink Faucet	12.1 ppb
Windham High School	Room 214l-demonstration Table	44.8 ppb
Windham High School	Room 215l- Demonstration Table	5.3 ppb
Windham High School	Room 215l- Left Island 2nd Sink	4.6 ppb
Windham High School	Room 215l- Left Island 3rd Sink	5.6 ppb
Windham High School	Room 215l- Right Island 1st Sink From Front	5.2 ppb
Windham High School	Room 215l- Right Island 3rd Sink	5 ppb
Windham High School	Room 215l-left Island 1st Sink From Front	1.6 ppb

School Name	Sample Location	Lead Test Result
Windham High School	Room 215I-left Side Bench Faucet #2 After Hood	16.8 ppb
Windham High School	Room 215I-right Island 2nd Sink	4.6 ppb
Windham High School	Room 216I- Back Left Sink Faucet	20.9 ppb
Windham High School	Room 216I- Back Middle Sink Faucet	11.7 ppb
Windham High School	Room 216I- Back Right Sink Faucet	3.4 ppb
Windham High School	Room 216I- Demonstration Table	13.1 ppb
Windham High School	Room 217I- Demonstration Table	6.3 ppb
Windham High School	Room 217I- Right Bench 1st Sink Faucet	2.2 ppb
Windham High School	Room 217I-1st Island From Left Back Sink	21.2 ppb
Windham High School	Room 217I-1st Island From Left Front Sink	6.1 ppb
Windham High School	Room 217I-1st Island From Left Middle Sink	11.5 ppb
Windham High School	Room 217I-2nd Island From Left Back Sink	5.5 ppb
Windham High School	Room 217I-2nd Island From Left Front Sink	1.6 ppb
Windham High School	Room 217I-2nd Island From Left Middle Sink	1.8 ppb
Windham High School	Room 217I-right Bench 2nd Sink Faucet(by Shower)	8.3 ppb
Windham High School	Room 218I- Back Left Sink Faucet	6.9 ppb
Windham High School	Room 218I- Back Right Sink Faucet	5.1 ppb
Windham High School	Room 218I- Demonstration Table	14.8 ppb
Windham High School	Room 219I- Back Left Sink Faucet	5.6 ppb
Windham High School	Room 219I- Back Right Sink Faucet	6 ppb
Windham High School	Room 219I-demonstration Table	7.2 ppb
Windham High School	Room 300 H- Sink Faucet	0 ppb
Windham High School	Room 302 H- Sink Faucet #2- Lab 2	1.4 ppb
Windham High School	Room 302 H- Sink Faucet #3- Lab 3	1.2 ppb
Windham High School	Room 302 H- Sink Faucet #4- Lab 4	1.6 ppb
Windham High School	Room 302 H- Sink Faucet #5- Lab 5	2.1 ppb
Windham High School	Room 302 H-sink Faucet #1 By Door Lab 1	1.4 ppb
Windham High School	Room 303 I- Back Wall Sink #1 By Hall	1.4 ppb
Windham High School	Room 303 I- Back Wall Sink #2	1.2 ppb
Windham High School	Room 303 I- Back Wall Sink #3 By Outside Wall	2.5 ppb
Windham High School	Room 304 I- Side Wall Sink #1 By Hall	1.5 ppb
Windham High School	Room 304 I- Side Wall Sink #2	0 ppb
Windham High School	Room 304 I- Side Wall Sink #3 By Outside Wall	0 ppb
Windham High School	Room 305 I- Deep Sink	0 ppb
Windham High School	Room 305 I-side Wall Sink #1 By Hall	26.2 ppb
Windham High School	Room 305 I-side Wall Sink #2	0 ppb
Windham High School	Room 305 I-side Wall Sink #3 By Outside Wall	0 ppb
Windham High School	Room 312 I- Deep Sink	0 ppb
Windham High School	Room 214I- Back Left Sink Faucet	5.5 ppb

School Name	Sample Location	Lead Test Result
Windham High School	Room215I-left Side Bench Faucet #1 Before Hood	1.2 ppb
Windham High School	Trainers Office- Ice Maker	0 ppb
Windham High School	Trainers Office- Sink Faucet	3.7 ppb
Windham High School	Water Fountain By 112b- High Fountain	0 ppb
Windham High School	Water Fountain By 112b- Low Fountain	0 ppb
Windham High School	Water Fountain By 112b-bottle Fill	0 ppb
Windham High School	Water Fountain By Rm 120- Bottle Fill	0 ppb
Windham High School	Water Fountain By Rm 120- High Fountain	0 ppb
Windham High School	Water Fountain By Rm 120- Low Fountain	0 ppb
Windham High School	Water Fountain By Rm 212- Bottle Fill	0 ppb
Windham High School	Water Fountain By Rm 212- High Fountain	0 ppb
Windham High School	Water Fountain By Rm 212- Low Fountain	0 ppb
Windham High School	Water Fountain By Rm 216I- High Fountain	0 ppb
Windham High School	Water Fountain By Rm 216I- Low Fountain	0 ppb
Windham High School	Water Fountain By Rm 216I-bottle Fill	0 ppb
Windham High School	Wf By Mezzanie Access Door- Bottle Fill	0 ppb
Windham High School	Wf By Mezzanie Access Door- High Fountain	0 ppb
Windham High School	Wf By Mezzanie Access Door- Low Fountain	0 ppb
Windham High School	Youth Football Concession Stand	5.8 ppb
Windham Middle School	Adult3- Kitchen- Water Cooler/heater	0 ppb
Windham Middle School	Adult4- Kitchen-kitchen Sink	0 ppb
Windham Middle School	Do3- Kitchenet 112- Sink Faucet	0 ppb
Windham Middle School	Do4- Kitchenet 112- Hot/cold Water Cooler	0 ppb
Windham Middle School	Do5- Colonial Kitchenet- Sink Faucet	0 ppb
Windham Middle School	Do6- Colonial Kitchenet- Hot/cold Water Cooler	0 ppb
Windham Middle School	Fa13-room 22- Sink Faucet	1.7 ppb
Windham Middle School	Fa3-fountain By Rr- Bottle Fill	1.8 ppb
Windham Middle School	Fa4-fountain By Rr-high Level	0 ppb
Windham Middle School	Fa5-fountain By Rr- Low Level	0 ppb
Windham Middle School	Fa8-teachers Break Room- Kitchen Faucet	0 ppb
Windham Middle School	Maint2-shop Area- Bottle Fill	0 ppb
Windham Middle School	Stadium1- Concession Stand- Sink Faucet	0 ppb
Windham Middle School	Stadium2- Concession Stand- Bottle Fill	0 ppb
Windham Middle School	Treatment1- Lab Bench- Sink Faucet	0 ppb
Windham Middle School	Wms20-stem 321- Left Cleaning Sink Faucet	2.3 ppb
Windham Middle School	Wms21-stem321-right Cleaning Sink Faucet	3.1 ppb
Windham Middle School	Wms22-stem322-left Cleaning Sink Faucet	2.9 ppb
Windham Middle School	Wms23-stem322-right Cleaning Sink Faucet	1.7 ppb
Windham Middle School	Wms24-stem- Water Fountain	6.8 ppb

School Name	Sample Location	Lead Test Result
Windham Middle School	Wms25-hallway Outside Of Stem-bottle Fill	0 ppb
Windham Middle School	Wms26-hallway Outside Stem- Oasis High Fountain	0 ppb
Windham Middle School	Wms27-hallway Outside Stem- Oasis Low Fountain	0 ppb
Windham Middle School	Wms28-caft Wall By Office-bottle Fill	0 ppb
Windham Middle School	Wms29-caft Wall By Office- Fountain	0 ppb
Windham Middle School	Wms2-gym- Water Fountain	0 ppb
Windham Middle School	Wms30-caft By 304-bottle Fill	0 ppb
Windham Middle School	Wms31-caft By 304- High Fountain	0 ppb
Windham Middle School	Wms32-caft By 304- Low Fountain	1.1 ppb
Windham Middle School	Wms33-room 304- Kitchen Faucet	1.4 ppb
Windham Middle School	Wms35-room 301 Art- Sink #1 Left On Far Wall	1.2 ppb
Windham Middle School	Wms36-room 301 Art-sink #2 Right On Far Wall	1.2 ppb
Windham Middle School	Wms3-mens Pe Teacher Rr- Bathroom Sink	33.3 ppb
Windham Middle School	Wms42-nurse Office Sink- Kitchen Faucet	2.8 ppb
Windham Middle School	Wms43-kitchen Faucet #1-1st On Left From Hall	4.5 ppb
Windham Middle School	Wms44-kitchen Faucet #2-second On Left From Hall	2 ppb
Windham Middle School	Wms45-kitchen Faucet #3-on Back Wall By Storage	73.4 ppb
Windham Middle School	Wms46-kitchen Faucet#4-in Island	4.4 ppb
Windham Middle School	Wms47-kitchen Faucet #5- By Dishwasher	2.3 ppb
Windham Middle School	Wms4-womens Pe Teacher Rr- Bathroom Sink	4 ppb
Windham Middle School	Wms51-rm209 Lab Sink #1- Left From Doorway	15.6 ppb
Windham Middle School	Wms52-rm209 Lab Sink #2-left From Doorway	25.7 ppb
Windham Middle School	Wms53-rm209 Lab Sink #3-left From Doorway	43.1 ppb
Windham Middle School	Wms54-rm209 Lab Sink #4-left From Doorway	25.4 ppb
Windham Middle School	Wms55-rm209 Lab Sink- Demonstration Table	12.3 ppb
Windham Middle School	Wms56-rm209 Lab Sink #1-right From Doorway	14.9 ppb
Windham Middle School	Wms57-rm209 Lab Sink #2- Right From Doorway	13.8 ppb
Windham Middle School	Wms58-rm209 Lab Sink #3- Right From Doorway	46.6 ppb
Windham Middle School	Wms59-rm207 Lab Sink #1- Demonstration Table	9.7 ppb

School Name	Sample Location	Lead Test Result
Windham Middle School	Wms5-gym Entrance- Oasis Bottle Filler	4.1 ppb
Windham Middle School	Wms60-rm205 Lab Sink #2- Demonstration Table	3 ppb
Windham Middle School	Wms61-rm203 Lab Sink#1- Left From Doorway	5.1 ppb
Windham Middle School	Wms62-rm203 Lab Sink #2-left From Doorway	14.7 ppb
Windham Middle School	Wms63-rm203 Lab Sink #3-left From Doorway	6.9 ppb
Windham Middle School	Wms64-rm203 Lab Sink #4-left From Doorway	47 ppb
Windham Middle School	Wms65-rm203 Lab Sink- Demonstration Table	18.2 ppb
Windham Middle School	Wms66-rm203 Lab Sink #1- Right From Doorway	4.6 ppb
Windham Middle School	Wms67-rm203 Lab Sink #2- Right From Doorway	7 ppb
Windham Middle School	Wms68-rm203 Lab Sink #3- Right From Doorway	6.6 ppb
Windham Middle School	Wms6-gym Entrance- Oasis Fountain	1 ppb
Windham Middle School	Wms72-bottle Fill By Upper Restrooms	0 ppb
Windham Middle School	Wms73- High Level Fountain By Upper Restrooms	0 ppb
Windham Middle School	Wms74-low Level Fountain By Upper Restrooms	0 ppb
Windham Middle School	Wms77-rm213 Lab Sink #1-left From Door To 213a	29.4 ppb
Windham Middle School	Wms78-rm213 Lab Sink #2-left From Door To 213a	14 ppb
Windham Middle School	Wms79-rm213 Lab Sink #3-left From Door To 213a	9.9 ppb
Windham Middle School	Wms80-rm213 Lab Sink #4-left From Door To 213a	16.3 ppb
Windham Middle School	Wms81-rm213 Lab Sink- Demonstration Table	140 ppb
Windham Middle School	Wms82-rm213 Lab Sink #1-right From Door To 213a	16 ppb
Windham Middle School	Wms83-rm213 Lab Sink #2-right From Door To 213a	24.7 ppb
Windham Middle School	Wms84-rm213 Lab Sink #3-right From Door To 213a	12.5 ppb
Windham Middle School	Wms85- Teacher Work Room Sink Off Teachers Rm	10.6 ppb
Windham Middle School	Wms86- Teachers Room Sink	4.6 ppb
Windham Middle School	Wms92-lower Restrooms- Bottle Fill	0 ppb
Windham Middle School	Wms93-lower Restrooms- High Level Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Windham Middle School	Wms94-lower Restrooms- Low Level Fountain	0 ppb
Windham Primary School	A 1st Floor Hall- Bottle Fill	0 ppb
Windham Primary School	A 2nd Floor Hall- Bottle Fill	0 ppb
Windham Primary School	Art Rm 1- Sink #1 Faucet By Door	0 ppb
Windham Primary School	Art Rm 2- Sink #1 Faucet By Door	0 ppb
Windham Primary School	B 1st Floor Hall- Bottle Fill	0 ppb
Windham Primary School	B 2nd Floor Hall- Bottle Fill	0 ppb
Windham Primary School	C 1st Floor Hall- Bottle Fill	0 ppb
Windham Primary School	C 2nd Floor Hall- Bottle Fill	0 ppb
Windham Primary School	Caft Hall Water Cooler- Bottle Fill	0 ppb
Windham Primary School	Caft Hall Water Cooler- High Drinking Fountain	0 ppb
Windham Primary School	Caft Hall Water Cooler- Low Drinking Fountain	0 ppb
Windham Primary School	Gym Pe Office Br- Sink Faucet	1.1 ppb
Windham Primary School	Hallway Fountain Near Art Rm	0 ppb
Windham Primary School	Kitchen Bathroom- Bathroom Sink	0 ppb
Windham Primary School	Kitchen- Dish Washer Sink Faucet	2.9 ppb
Windham Primary School	Kitchen- Prep Sink 1- Closest To Cafe	1.2 ppb
Windham Primary School	Kitchen- Prep Sink 2- Furthest From Caft	1.2 ppb
Windham Primary School	Kitchen-cleavland Kettle Faucet	10.1 ppb
Windham Primary School	Mothers Rm- Sink Faucet	3.3 ppb
Windham Primary School	Nurse Office Front- Sink Faucet	0 ppb
Windham Primary School	Rm A106- Bubbler Faucet	0 ppb
Windham Primary School	Rm A108- Bubbler Faucet	0 ppb
Windham Primary School	Rm A110- Bubbler Faucet	1.2 ppb
Windham Primary School	Rm A112- Bubbler Faucet	0 ppb
Windham Primary School	Rm A120- Bubbler Faucet	1.7 ppb
Windham Primary School	Rm A122- Bubbler Faucet	0 ppb
Windham Primary School	Rm A202- Bubbler Faucet	0 ppb
Windham Primary School	Rm A204- Bubbler Faucet	2.1 ppb
Windham Primary School	Rm A206- Bubbler Faucet	1.5 ppb
Windham Primary School	Rm A208- Bubbler Faucet	0 ppb
Windham Primary School	Rm A210- Bubbler Faucet	0 ppb
Windham Primary School	Rm A217- Bubbler Faucet	0 ppb
Windham Primary School	Rm A219- Bubbler Faucet	0 ppb
Windham Primary School	Rm B106- Bubbler Faucet	0 ppb
Windham Primary School	Rm B108- Bubbler Faucet	2 ppb
Windham Primary School	Rm B110- Bubbler Faucet	0 ppb
Windham Primary School	Rm B112- Bubbler Faucet	0 ppb
Windham Primary School	Rm B115- Bubbler Faucet	0 ppb
Windham Primary School	Rm B120- Bubbler Faucet	20.9 ppb
Windham Primary School	Rm B122- Bubbler Faucet	1.1 ppb
Windham Primary School	Rm B202- Bubbler Faucet	1.5 ppb
Windham Primary School	Rm B204- Bubbler Faucet	0 ppb
Windham Primary School	Rm B206- Bubbler Faucet	0 ppb

School Name	Sample Location	Lead Test Result
Windham Primary School	Rm B208- Bubbler Faucet	0 ppb
Windham Primary School	Rm B210- Bubbler Faucet	0 ppb
Windham Primary School	Rm B217- Bubbler Faucet	1.1 ppb
Windham Primary School	Rm B219- Bottle Fill	2 ppb
Windham Primary School	Rm C106- Bubbler Faucet	1.4 ppb
Windham Primary School	Rm C108- Bubbler Faucet	0 ppb
Windham Primary School	Rm C110- Bubbler Faucet	0 ppb
Windham Primary School	Rm C112- Bubbler Faucet	0 ppb
Windham Primary School	Rm C115- Bubbler Faucet	0 ppb
Windham Primary School	Rm C120- Bubbler Faucet	0 ppb
Windham Primary School	Rm C122-bubbler Faucet	0 ppb
Windham Primary School	Rm C202- Bubbler Faucet	0 ppb
Windham Primary School	Rm C204- Bubbler Faucet	1.5 ppb
Windham Primary School	Rm C206- Bubbler Faucet	0 ppb
Windham Primary School	Rm C208- Bubbler Facuet	0 ppb
Windham Primary School	Rm C210- Bubbler Faucet	0 ppb
Windham Primary School	Rm C217- Bubbler Faucet	3.9 ppb
Windham Primary School	Rm C219- Bubbler Faucet	0 ppb
Windham Primary School	Rm C54- Bubbler Faucet	0 ppb
Windham Primary School	Teachers Break Room- Sink Faucet	1 ppb
Windsor Elementary School	3-5 Wing Rm #204	0 ppb
Windsor Elementary School	3-5 Wing Rm #205	0 ppb
Windsor Elementary School	3-5 Wing Rm #211	0 ppb
Windsor Elementary School	3-5 Wing Rm #213	0 ppb
Windsor Elementary School	3-5 Wing Rm #214	0 ppb
Windsor Elementary School	3-5 Wing Rm #215	0 ppb
Windsor Elementary School	3-5 Wing Rm #217	0 ppb
Windsor Elementary School	3-5 Wing Rm #222	0 ppb
Windsor Elementary School	Cafeteria	0 ppb
Windsor Elementary School	Gym Lobby	0 ppb
Windsor Elementary School	Jr High Wing (beside Rm #312)	0 ppb
Windsor Elementary School	Jr. High Wing	0 ppb
Windsor Elementary School	K-2 Wing Rm #101	0 ppb
Windsor Elementary School	K-2 Wing Rm #102	0 ppb
Windsor Elementary School	K-2 Wing Rm #104	0 ppb
Windsor Elementary School	K-2 Wing Rm #105	0 ppb
Windsor Elementary School	K-2 Wing Rm #107	0 ppb
Windsor Elementary School	K-2 Wing Rm #110	0 ppb
Windsor Elementary School	Kitchen (3 Bay Sink) #1	1.4 ppb
Windsor Elementary School	Kitchen (3 Bay Sink) #2	3 ppb
Windsor Elementary School	Kitchen (tilt Steamer)	9.5 ppb
Windsor Elementary School	Music Rm #311	2.1 ppb
Windsor Elementary School	Nurses Rm #113	1.1 ppb
Windsor Elementary School	Pre-k Rm#116	0 ppb
Windsor Elementary School	Science Rm #321 #1	0 ppb
Windsor Elementary School	Science Rm #321 #2	0 ppb
Windsor Elementary School	Teachers Rm #301	0 ppb

School Name	Sample Location	Lead Test Result
Winfield Children's House	Antique Building Lobby Bathroom	1.3 ppb
Winfield Children's House	Casa Aria Bathroom	0 ppb
Winfield Children's House	Casa Aria Kitchen	0 ppb
Winfield Children's House	Casa Fiore Kitchen	0 ppb
Winfield Children's House	Casa Luce Bathroom	0 ppb
Winfield Children's House	Casa Luce Kitchen	0 ppb
Winfield Children's House	Casa Mare Bathroom (left)	0 ppb
Winfield Children's House	Casa Mare Bathroom (right)	0 ppb
Winfield Children's House	Casa Mare Kitchen	0 ppb
Winfield Children's House	Casa Pace Kitchen	0 ppb
Winfield Children's House	Casa Pace/fiore Classroom Bathroom	0 ppb
Winfield Children's House	Casa Terra Bathroom	0 ppb
Winfield Children's House	Casa Terra Kitchen	1.2 ppb
Winfield Children's House	Millennium Building Kitchen	2.7 ppb
Winfield Children's House	Millennium Building Lobby Bathroom	1.8 ppb
Winfield Children's House	Toddler House Admin Bathroom	3 ppb
Winfield Children's House	Toddler House Lobby Bathroom	1.6 ppb
Winfield Children's House	Toddler House Upstairs Kitchen	0 ppb
Winslow Elementary School	1st Floor Fountain By Gym	0 ppb
Winslow Elementary School	1st Floor Fountain By Teachers Room	0 ppb
Winslow Elementary School	2nd Floor Fountain By Elevator	0 ppb
Winslow Elementary School	2nd Floor Fountain By Mechanical Room	0 ppb
Winslow Elementary School	First Floor Fountain By Main Office	0 ppb
Winslow Elementary School	Kitchen Food Prep Sink	1.1 ppb
Winslow Elementary School	Kitchen Kettel Faucet	3.4 ppb
Winslow Elementary School	Lg. Teachers Room Upstairs	2 ppb
Winslow Elementary School	Nurses Exam Room	1.3 ppb
Winslow Elementary School	Room 107	0 ppb
Winslow Elementary School	Room 107	7.8 ppb
Winslow Elementary School	Room 108	0 ppb
Winslow Elementary School	Room 108	8.9 ppb
Winslow Elementary School	Room 109	16.3 ppb
Winslow Elementary School	Room 109	1.5 ppb
Winslow Elementary School	Room 111	4.4 ppb
Winslow Elementary School	Room 111	3.5 ppb
Winslow Elementary School	Room 112	7.3 ppb
Winslow Elementary School	Room 112	0 ppb
Winslow Elementary School	Room 113	1.3 ppb
Winslow Elementary School	Room 113	4.8 ppb
Winslow Elementary School	Room 114	3.4 ppb
Winslow Elementary School	Room 114	7 ppb
Winslow Elementary School	Room 127	3.7 ppb
Winslow Elementary School	Room 128	0 ppb
Winslow Elementary School	Room 128	8.8 ppb
Winslow Elementary School	Room 129	0 ppb
Winslow Elementary School	Room 131	0 ppb
Winslow Elementary School	Room 131	20.1 ppb

School Name	Sample Location	Lead Test Result
Winslow Elementary School	Room 132	1.8 ppb
Winslow Elementary School	Room 133	1.2 ppb
Winslow Elementary School	Room 133	6.8 ppb
Winslow Elementary School	Room 134	2 ppb
Winslow Elementary School	Room 134	4.5 ppb
Winslow Elementary School	Room 162	1.5 ppb
Winslow Elementary School	Room 163	0 ppb
Winslow Elementary School	Room 163	13 ppb
Winslow Elementary School	Room 164	1.7 ppb
Winslow Elementary School	Room 164	7.1 ppb
Winslow Elementary School	Room 165	1.5 ppb
Winslow Elementary School	Room 165	11.5 ppb
Winslow Elementary School	Room 167	1.4 ppb
Winslow Elementary School	Room 167	4.3 ppb
Winslow Elementary School	Room 168	0 ppb
Winslow Elementary School	Room 168	9.5 ppb
Winslow Elementary School	Room 169	3.2 ppb
Winslow Elementary School	Room 169	9 ppb
Winslow Elementary School	Room 170	2.1 ppb
Winslow Elementary School	Room 170	17 ppb
Winslow Elementary School	Room 180	1.7 ppb
Winslow Elementary School	Room 180	6.6 ppb
Winslow Elementary School	Room 204	7.1 ppb
Winslow Elementary School	Room 204	5.9 ppb
Winslow Elementary School	Room 204 A	1.7 ppb
Winslow Elementary School	Room 204 B	0 ppb
Winslow Elementary School	Room 205	3.7 ppb
Winslow Elementary School	Room 207	0 ppb
Winslow Elementary School	Room 207	5.9 ppb
Winslow Elementary School	Room 208	2.8 ppb
Winslow Elementary School	Room 210	4.4 ppb
Winslow Elementary School	Room 210	17.2 ppb
Winslow Elementary School	Room 212	0 ppb
Winslow Elementary School	Room 212	7.1 ppb
Winslow Elementary School	Room 213	3.3 ppb
Winslow Elementary School	Room 213	5.6 ppb
Winslow Elementary School	Room 214	3.8 ppb
Winslow Elementary School	Room 220	9.3 ppb
Winslow Elementary School	Room 220	5.5 ppb
Winslow Elementary School	Room 222	6.2 ppb
Winslow Elementary School	Room 222	22.5 ppb
Winslow Elementary School	Room 223	2.8 ppb
Winslow Elementary School	Room 223	4.3 ppb
Winslow Elementary School	Room 224	2.2 ppb
Winslow Elementary School	Room 224	5 ppb
Winslow Elementary School	Room 226	12.6 ppb
Winslow Elementary School	Room 226	29.9 ppb

School Name	Sample Location	Lead Test Result
Winslow Elementary School	Room 227	0 ppb
Winslow Elementary School	Room 227	4.1 ppb
Winslow Elementary School	Room 229	0 ppb
Winslow Elementary School	Room 229	5.7 ppb
Winslow Elementary School	Room 230	1.3 ppb
Winslow Elementary School	Room 230	4.4 ppb
Winslow Elementary School	Room 247	2.1 ppb
Winslow Elementary School	Room 247	9.6 ppb
Winslow Elementary School	Room 248	2.5 ppb
Winslow Elementary School	Room 248	6.5 ppb
Winslow Elementary School	Room 250	2.4 ppb
Winslow Elementary School	Room 252	2.1 ppb
Winslow Elementary School	Room 252	10.2 ppb
Winslow Elementary School	Room 253	3.2 ppb
Winslow Elementary School	Room 254	3.6 ppb
Winslow Elementary School	Room 254	9.7 ppb
Winslow Elementary School	Room 256	2.3 ppb
Winslow Elementary School	Room 256	5.9 ppb
Winslow Elementary School	Room 257	0 ppb
Winslow Elementary School	Teachers Room 2nd Gr. Hallway	2 ppb
Winslow Elementary School	Teachers Room By Main Office	0 ppb
Winslow High School	Commons Food Prep Faucet	1.1 ppb
Winslow High School	Faucet In Life Skills Room #122	1.7 ppb
Winslow High School	Faucet In Life Skills Room #127	1.4 ppb
Winslow High School	Fountain Athletic Wing	0 ppb
Winslow High School	Fountain By Back Custodial Closet	0 ppb
Winslow High School	Fountain Fine Arts Wing	0 ppb
Winslow High School	Fountain Front/main Hallway	0 ppb
Winslow High School	Fountain Math/science Wing	0 ppb
Winslow High School	Front Teachers Lounge	1.9 ppb
Winslow High School	Ice Machine Boys Locker Room	1 ppb
Winslow High School	Ice Machine Girls Locker Room	0 ppb
Winslow High School	Kitchen Food Prep Sink	4.6 ppb
Winslow High School	Library Work Room	1.4 ppb
Winslow High School	Main Office Faucet	1.6 ppb
Winslow High School	Nurses Exam Room	2.2 ppb
Winslow High School	Room 134	1.4 ppb
Winslow High School	Trainers Room Room 28	2.4 ppb
Winslow Junior High School	Fountain In Main Hallway	0 ppb
Winslow Junior High School	Nurses Exam Room	1.2 ppb
Winslow Junior High School	Room 411	0 ppb
Winslow Junior High School	Room 413	0 ppb
Winslow Junior High School	Room 422	0 ppb
Winslow Junior High School	Room 424	1.5 ppb
Winthrop Grade School	All Purpose Kitchen /fountain	19.1 ppb
Winthrop Grade School	Boys Locker Room Faucet	4.8 ppb
Winthrop Grade School	Cafeteria Fountain	0 ppb

School Name	Sample Location	Lead Test Result
Winthrop Grade School	Cafeteria Kitchen Faucet	0 ppb
Winthrop Grade School	Daycare Bathroom	1.2 ppb
Winthrop Grade School	Daycare Kitchen	1.8 ppb
Winthrop Grade School	Fountain/sw/downstairs/near Cafeteria	0 ppb
Winthrop Grade School	Gym Lobby Drinking Fountain 1	0 ppb
Winthrop Grade School	Gym Lobby Drinking Fountain W	0 ppb
Winthrop Grade School	K Faucet 1	3.3 ppb
Winthrop Grade School	K Faucet 2	2.4 ppb
Winthrop Grade School	North Wing Fountain By 1st Grade	0 ppb
Winthrop Grade School	North Wing Fountain By 2nd Grade	0 ppb
Winthrop Grade School	North Wing Fountain By Prek	0 ppb
Winthrop Grade School	Nurse Office Faucet	2.9 ppb
Winthrop Grade School	Ot/pt Faucet	10.2 ppb
Winthrop Grade School	Prek Faucet 1	3.7 ppb
Winthrop Grade School	Prek Faucet 2	5.8 ppb
Winthrop Grade School	South Wing/breakrm/faucet	1.9 ppb
Winthrop Grade School	Town/super. Office Breakroom	0 ppb
Winthrop Grade School	Upstairs Southwing Faucet	0 ppb
Winthrop Grade School	Visitors Locker Room Fountain	365 ppb
Winthrop High School	Drinking Fountain By Gym	0 ppb
Winthrop High School	Kitchen Cafe Sink	0 ppb
Winthrop High School	Lobby Drinking Fountain	0 ppb
Winthrop High School	Nurse's Room	0 ppb
Winthrop High School	Self Contained Room	0 ppb
Winthrop High School	Teachers Room	0 ppb
Winthrop High School	Upstairs Drinking Fountain	0 ppb
Winthrop High School	Water Dispenser In Cafe	0 ppb
Winthrop Middle School	Cafe Kitchen Sink	2.4 ppb
Winthrop Middle School	Drinking Fountain In Cafe	0 ppb
Winthrop Middle School	Drinking Fountain In Hall By Office	0 ppb
Winthrop Middle School	Gym Drinking Fountain	1.8 ppb
Winthrop Middle School	Teachers Room	3.7 ppb
Wiscasset Elementary School	Bottle Fill Station - 1st Grade Wing	1.4 ppb
Wiscasset Elementary School	Bottle Fill Station - Cafeteria	2.6 ppb
Wiscasset Elementary School	Bottle Fill Station - Outside Room 201	0 ppb
Wiscasset Elementary School	Bottle Fill Station - Outside Teach Lounge	25.5 ppb
Wiscasset Elementary School	Center Island Sink - Kitchen	11 ppb
Wiscasset Elementary School	Corridor - Drinking Fountain #1	71.1 ppb
Wiscasset Elementary School	Facucet - Teacher's Lounge	65.6 ppb
Wiscasset Elementary School	Fountain - Outside Room 205	3.7 ppb
Wiscasset Elementary School	Gym Corridor - Drinking Fountain	9.4 ppb
Wiscasset Elementary School	Main Corridor - Drinking Fountain	32.1 ppb
Wiscasset Elementary School	Nurses Station 111c - Sink	20 ppb
Wiscasset Elementary School	Prep Sink Left - Kitchen	12.8 ppb
Wiscasset Elementary School	Prep Sink Right - Kitchen	17.1 ppb
Wiscasset Elementary School	Room 101 - Sink	3.5 ppb
Wiscasset Elementary School	Room 102 - Sink	5.8 ppb

School Name	Sample Location	Lead Test Result
Wiscasset Elementary School	Room 103 - Sink	2.1 ppb
Wiscasset Elementary School	Room 104 - Sink	5.6 ppb
Wiscasset Elementary School	Room 106 - Sink	2.4 ppb
Wiscasset Elementary School	Room 107 - Sink	5.4 ppb
Wiscasset Elementary School	Room 109c Behind Stage - Sink	22.8 ppb
Wiscasset Elementary School	Room 122 - Sink	64.5 ppb
Wiscasset Elementary School	Room 123 - Sink	24.4 ppb
Wiscasset Elementary School	Room 124 - Sink	13.7 ppb
Wiscasset Elementary School	Room 125 - Sink	989 ppb
Wiscasset Elementary School	Room 129 - Sink	44.3 ppb
Wiscasset Elementary School	Room 130 - Sink	329 ppb
Wiscasset Elementary School	Room 131 - Sink	90.6 ppb
Wiscasset Elementary School	Room 201 - Left Sink	173 ppb
Wiscasset Elementary School	Room 205 - Left Sink	11.8 ppb
Wiscasset Elementary School	Room 205 - Right Sink	687 ppb
Wiscasset Elementary School	Room 5 - Sink	32.3 ppb
Wiscasset Elementary School	Room 7 - Sink	60.5 ppb
Wiscasset Middle/High School	Artland - Sink	10.5 ppb
Wiscasset Middle/High School	Bottle Fill Station - Cafeteria	2.8 ppb
Wiscasset Middle/High School	Bottle Fill Station - Main Lobby	1.9 ppb
Wiscasset Middle/High School	Bottle Fill Station - Middle School Wing	6.2 ppb
Wiscasset Middle/High School	Bottle Fill Station - Outside Nurse Office	1.8 ppb
Wiscasset Middle/High School	Bottle Fill Station - Room 203	6.2 ppb
Wiscasset Middle/High School	Break Room Sink - Room 104b	69.7 ppb
Wiscasset Middle/High School	Breakroom Sink - Secretary	453 ppb
Wiscasset Middle/High School	Closet Between Rms - 10 & 12 - Sink	293 ppb
Wiscasset Middle/High School	Dishwash Sink - Kitchen	24.1 ppb
Wiscasset Middle/High School	Gymnasium - Left Drinking Fountain	8.9 ppb
Wiscasset Middle/High School	Gymnasium - Right Drinking Fountain	19.8 ppb
Wiscasset Middle/High School	Handwash Sink - Kitchen	9 ppb
Wiscasset Middle/High School	Ice Machine - Gym	1660 ppb
Wiscasset Middle/High School	Kitchen Sink - Life Skills Room	23.5 ppb
Wiscasset Middle/High School	Kitchen Sink - Staff Breakroom	122 ppb
Wiscasset Middle/High School	Prep Station Sink - Kitchen	301 ppb
Wiscasset Middle/High School	Room 12a - Sink	18.1 ppb
Wiscasset Middle/High School	Sink - Nurses Office	74.5 ppb
Wiscasset Middle/High School	Sink - Room 111	219 ppb
Wiscasset Middle/High School	Sink Left - Room 102c	20.6 ppb
Wiscasset Middle/High School	Sink Right - Room 102c	438 ppb
Wiscasset Middle/High School	Staff Bathroom - Sink	5.1 ppb
Wisdom Middle High School/Dr Levesque Ele	3 Tub Deep Sink Garage Hallway	3 ppb
Wisdom Middle High School/Dr Levesque Ele	Boys Rr Handwash Sink	0 ppb
Wisdom Middle High School/Dr Levesque Ele	Dble Sink Accross From Stove In Home Ec	5.3 ppb
Wisdom Middle High School/Dr Levesque Ele	Dble Sink Across From Other Dbl Sink - Home Ec	15.6 ppb
Wisdom Middle High School/Dr Levesque Ele	Double Sink By Washing Machine - Home Ec	6.9 ppb

School Name	Sample Location	Lead Test Result
Wisdom Middle High School/Dr Levesque Ele	Dr. Levesque Wing Rm #24 Double Handwash Sink	22.3 ppb
Wisdom Middle High School/Dr Levesque Ele	Garage 3 Tub Deep Sink	3.9 ppb
Wisdom Middle High School/Dr Levesque Ele	Garage Hallway Restroom Handwash Sink	3.1 ppb
Wisdom Middle High School/Dr Levesque Ele	Gym Center Hand Wash Sink In Restroom	9 ppb
Wisdom Middle High School/Dr Levesque Ele	Gym Leftside Hand Wash Sink Restroom	14.3 ppb
Wisdom Middle High School/Dr Levesque Ele	Gym Lobby Area Left Girls Hand Sink	14 ppb
Wisdom Middle High School/Dr Levesque Ele	Gym Lobby Left Boys Room Hand Sink	13.7 ppb
Wisdom Middle High School/Dr Levesque Ele	Gym Lobby Right Girls Room Hand Sink	21 ppb
Wisdom Middle High School/Dr Levesque Ele	Gym Lobby Water Bottle Filler	3 ppb
Wisdom Middle High School/Dr Levesque Ele	Gym Lobby Water Fountain Left	3.4 ppb
Wisdom Middle High School/Dr Levesque Ele	Gym Lobby Water Fountain Right	3.4 ppb
Wisdom Middle High School/Dr Levesque Ele	Gym Right Side Handwash Sink In Rr	12.6 ppb
Wisdom Middle High School/Dr Levesque Ele	Hallway Drinking Fountain Bottle Filler	0 ppb
Wisdom Middle High School/Dr Levesque Ele	Hallway Drinking Fountain Spigot	0 ppb
Wisdom Middle High School/Dr Levesque Ele	Hallway Fountain Bottle Filler Dr Levesque Wing	0 ppb
Wisdom Middle High School/Dr Levesque Ele	Hallway Fountain Spigot Dr Levesque Wing	0 ppb
Wisdom Middle High School/Dr Levesque Ele	Home Ecomonics Sink By Elec Stove	10.1 ppb
Wisdom Middle High School/Dr Levesque Ele	Inside Garage - Hose Spigot	4.1 ppb
Wisdom Middle High School/Dr Levesque Ele	Kitchen 3 Deep Sink	1.8 ppb
Wisdom Middle High School/Dr Levesque Ele	Kitchen Dishes Sprayer Sink	0 ppb
Wisdom Middle High School/Dr Levesque Ele	Kitchen Single Deep Sink	1.2 ppb
Wisdom Middle High School/Dr Levesque Ele	Kitchen Sprayer Head To Clean Fryer	0 ppb
Wisdom Middle High School/Dr Levesque Ele	Men's Bathroom Handwash Sink	0 ppb
Wisdom Middle High School/Dr Levesque Ele	Outside Spigot Front Of Bldg Dr Levesque Side	8.8 ppb
Wisdom Middle High School/Dr Levesque Ele	Outside Spigot Wisdom Wing-back Side Toward Gym	3.7 ppb
Wisdom Middle High School/Dr Levesque Ele	Pre-k Building Left Side Sink	1.6 ppb
Wisdom Middle High School/Dr Levesque Ele	Pre-k Building Right Side Sink	3.1 ppb
Wisdom Middle High School/Dr Levesque Ele	Teacher Rr Handwash Sink	3.4 ppb
Wisdom Middle High School/Dr Levesque Ele	Teacher Work Area Room Handwash Sink	19.8 ppb
Wisdom Middle High School/Dr Levesque Ele	Teacher's Rr Handwash Sink Dr Levesque Wing	3.1 ppb
Wisdom Middle High School/Dr Levesque Ele	Women Rr Left Handwash Sink (teacher Area)	4.8 ppb
Wisdom Middle High School/Dr Levesque Ele	Women Rr Right Handwash Sink (teacher Area)	0 ppb
Wisdom Middle High School/Dr Levesque Ele	Women's Rr Handwash Sink Dr Levesque Wing	1.3 ppb
WMRPCE - Oxford Annex	Kitchen Sink	1.9 ppb
WMRPCE - Oxford Annex	Water Fountain In Hall	2.2 ppb
Woodland Consolidated Sch	Grade Pre-k Sink Fountain	5.4 ppb
Woodland Consolidated Sch	Hallway Drinking Fountain By Office	0 ppb
Woodland Consolidated Sch	Hallway Drinking Fountain Handicap	0 ppb
Woodland Consolidated Sch	Kindergarten Sink Fountain	2.7 ppb

School Name	Sample Location	Lead Test Result
Woodland Consolidated Sch	Left Side Tap Of Kitchen 2 Bay Sink	3.7 ppb
Woodland Elementary School	Cafeteria	3.3 ppb
Woodland Elementary School	Nurse Office	3.2 ppb
Woodland Elementary School	Room #15	1.1 ppb
Woodland Elementary School	Room 10a	3.1 ppb
Woodland Elementary School	Room 10b	2.3 ppb
Woodland Elementary School	Room 12	13.6 ppb
Woodland Elementary School	Room 14	6.2 ppb
Woodland Elementary School	Room 4	2 ppb
Woodland Elementary School	Room 5	4.8 ppb
Woodland Elementary School	Room 6	58.3 ppb
Woodland Elementary School	Room 8a	3.9 ppb
Woodland Elementary School	Room 8b	0 ppb
Woodland Elementary School	Room 9a	5.8 ppb
Woodland Elementary School	Room 9b	7.9 ppb
Woodland Elementary School	Teachers Lounge	1.8 ppb
Woodland Elementary School	Water Bottle Fill Station	0 ppb
Woodland Jr-Sr High School	Cafeteria Tilting Skillet Faucet	2.6 ppb
Woodland Jr-Sr High School	Cafeteria Vegetable Sink	0 ppb
Woodland Jr-Sr High School	Hs Bottle Fill Station	0 ppb
Woodland Jr-Sr High School	Hs Nurse Office	3.8 ppb
Woodland Jr-Sr High School	Jh Bottle Fill Station	2.1 ppb
Woodland Jr-Sr High School	Life Skills	5.1 ppb
Woodland Jr-Sr High School	Teacher Lounge	0 ppb
Woodside Elementary School	1 Water Fountain	0 ppb
Woodside Elementary School	100 Room 211 Water Fountain	0 ppb
Woodside Elementary School	102 Room 210 Kitchen Faucet	2.9 ppb
Woodside Elementary School	103 Room 210 Water Fountain	0 ppb
Woodside Elementary School	105 Water Fountain	0 ppb
Woodside Elementary School	107 Room 212 Kitchen Faucet	2.9 ppb
Woodside Elementary School	108 Room 212 Water Fountain	1.4 ppb
Woodside Elementary School	11 Room 102 Kitchen Faucet	2.2 ppb
Woodside Elementary School	111 Room 213 Kitchen Faucet	1.3 ppb
Woodside Elementary School	112 Room 213 Water Fountain	2.5 ppb
Woodside Elementary School	113 Room 216 Kitchen Faucet	1.8 ppb
Woodside Elementary School	114 Room 216 Water Fountain	0 ppb
Woodside Elementary School	117 Room 217 Kitchen Faucet	2.4 ppb
Woodside Elementary School	118 Room 217 Water Fountain	12.8 ppb
Woodside Elementary School	119 Room 218 Kitchen Faucet	2.2 ppb
Woodside Elementary School	12 Room 102 Water Fountain	1.6 ppb
Woodside Elementary School	120 Room 218 Water Fountain	0 ppb
Woodside Elementary School	123 Room 219 Kitchen Faucet	4.5 ppb
Woodside Elementary School	124 Room 219 Water Fountain	1 ppb
Woodside Elementary School	125 Room 214 Kitchen Faucet	2.3 ppb
Woodside Elementary School	126 Room 214 Water Fountain	1.2 ppb
Woodside Elementary School	129 Room 215 Kitchen Faucet	2 ppb
Woodside Elementary School	13 Room 103 Kitchen Fuacet	1.2 ppb

School Name	Sample Location	Lead Test Result
Woodside Elementary School	130 Room 215 Water Fountain	1.3 ppb
Woodside Elementary School	132 Kitchen Faucet	2.6 ppb
Woodside Elementary School	133 Water Fountain	4.5 ppb
Woodside Elementary School	134 Kitchen Faucet	12.9 ppb
Woodside Elementary School	135 Water Fountain	14.7 ppb
Woodside Elementary School	17 Room 104 Kitchen Faucet	2.1 ppb
Woodside Elementary School	18 Room 104 Water Fountain	3.7 ppb
Woodside Elementary School	20 Library Office Kitchen Faucet	4.6 ppb
Woodside Elementary School	21 Library Office Water Fountain	13.1 ppb
Woodside Elementary School	22 Water Fountain	1.1 ppb
Woodside Elementary School	23 Room 110 Kitchen Faucet	1.6 ppb
Woodside Elementary School	24 Room 110 Water Fountain	0 ppb
Woodside Elementary School	27 Room 111 Kitchen Faucet	2.3 ppb
Woodside Elementary School	28 Room 111 Water Fountain	3 ppb
Woodside Elementary School	30 Room 113 Kitchen Faucet	1.9 ppb
Woodside Elementary School	31 Room 113 Water Fountain	5.3 ppb
Woodside Elementary School	33 Room 112 Kitchen Faucet	2.6 ppb
Woodside Elementary School	34 Room 112 Water Fountain	0 ppb
Woodside Elementary School	35 Room 115 Kitchen Faucet	2.9 ppb
Woodside Elementary School	36 Room 115 Water Fountain	3.5 ppb
Woodside Elementary School	38 Room 116 Kitchen Faucet	3.7 ppb
Woodside Elementary School	39 Room 116 Water Fountain	0 ppb
Woodside Elementary School	42 Room 117 Kitchen Faucet	2.4 ppb
Woodside Elementary School	43 Room 117 Water Fountain	3 ppb
Woodside Elementary School	44 Room 120 Kitchen Faucet	1.5 ppb
Woodside Elementary School	45 Room 120 Water Fountain	0 ppb
Woodside Elementary School	48 Room 121 Kitchen Faucet	2 ppb
Woodside Elementary School	49 Room 121 Water Fountain	1.9 ppb
Woodside Elementary School	5 Room 100 Kitchen Faucet	2.2 ppb
Woodside Elementary School	50 Room 122 Kitchen Faucet	2.1 ppb
Woodside Elementary School	51 Room 122 Water Fountain	1.5 ppb
Woodside Elementary School	54 Room 123 Kitchen Faucet	1.7 ppb
Woodside Elementary School	56 Room 118 Kitchen Faucet	3.2 ppb
Woodside Elementary School	57 Room 118 Water Fountain	5 ppb
Woodside Elementary School	6 Room 100 Water Fountain	4.7 ppb
Woodside Elementary School	60 Room 119 Kitchen Faucet	1.8 ppb
Woodside Elementary School	61 Room 119 Water Fountain	0 ppb
Woodside Elementary School	62 Art Kitchen Faucet	5.2 ppb
Woodside Elementary School	63 Art Kitchen Faucet	2.7 ppb
Woodside Elementary School	64 Art Water Fountain	4.8 ppb
Woodside Elementary School	65 Art Kitchen Faucet	2.8 ppb
Woodside Elementary School	67 Nurse Sink	0 ppb
Woodside Elementary School	7 Room 101 Kitchen Faucet	1.7 ppb
Woodside Elementary School	70 Office Staff Room Kitchen Faucet	2.5 ppb
Woodside Elementary School	71 Office Staff Room Water Fountain	10.5 ppb
Woodside Elementary School	72 Gym Water Fountain	0 ppb
Woodside Elementary School	78 Kitchen Faucet	6.3 ppb

School Name	Sample Location	Lead Test Result
Woodside Elementary School	8 Room 101 Water Fountain	2.3 ppb
Woodside Elementary School	80 Kettle	5.6 ppb
Woodside Elementary School	82 Kitchen Faucet	0 ppb
Woodside Elementary School	83 Room 205 Kitchen Faucet	40.6 ppb
Woodside Elementary School	84 Room 205 Water Fountain	5.1 ppb
Woodside Elementary School	85 Room 207 Kitchen Faucet	3.6 ppb
Woodside Elementary School	86 Room 207 Water Fountain	3 ppb
Woodside Elementary School	87 Room 206 Kitchen Faucet	4.4 ppb
Woodside Elementary School	88 Room 206 Water Fountain	9.4 ppb
Woodside Elementary School	89 Room 207a Kitchen Faucet	2.3 ppb
Woodside Elementary School	90 Room 207a Water Fountain	8.3 ppb
Woodside Elementary School	92 Room 208 Kitchen Faucet	2.2 ppb
Woodside Elementary School	93 Room 208 Water Fountain	0 ppb
Woodside Elementary School	95 Room 209 Kitchen Faucet	2.1 ppb
Woodside Elementary School	96 Room 209 Water Fountain	1.8 ppb
Woodside Elementary School	99 Room 211 Kitchen Faucet	2.6 ppb
Woodstock School	Boyaes Bathroom Left	5.6 ppb
Woodstock School	Boyaes Bathroom Right	4.5 ppb
Woodstock School	Girlaes Bathroom Left	6.8 ppb
Woodstock School	Girlaes Bathroom Right	5 ppb
Woodstock School	Grade 1 Sink	14 ppb
Woodstock School	Grade 2 Sink	15.5 ppb
Woodstock School	Grade 3 Sink	19.2 ppb
Woodstock School	Grade 4 Sink	9.3 ppb
Woodstock School	Grade 5 Sink	14.2 ppb
Woodstock School	Grade K Sink	19.7 ppb
Woodstock School	Janitoraes Closet Faucet	9 ppb
Woodstock School	K/1 Bathroom Sink	4.9 ppb
Woodstock School	Kitchen Dish Sink Left	23.4 ppb
Woodstock School	Kitchen Dish Sink Right	11.5 ppb
Woodstock School	Kitchen Handwashing Sink	8.6 ppb
Woodstock School	Library Sink	63.2 ppb
Woodstock School	Mka/art Sink	7.1 ppb
Woodstock School	Old Nurseaes Office Sink	33.7 ppb
Woodstock School	Teacheraes Bathroom	50.7 ppb
Woodstock School	Teacher's Room Sink	13.5 ppb
Woolwich Central School	Cafeteria Water Fountain Spicket	0 ppb
Woolwich Central School	First Floor Near Pk-2 Bottle Filling Spicket	0 ppb
Woolwich Central School	First Floor Near Pk-2 Water Fountain	0 ppb
Woolwich Central School	Gym Bottle Filling Station	0 ppb
Woolwich Central School	Kitchen Island Sink	0 ppb
Woolwich Central School	Main Kitchen Sink With Three Bays	0 ppb
Woolwich Central School	Second Floor Bottle Filling Spicket	0 ppb
Woolwich Central School	Second Floor Water Fountain	0 ppb
Woolwich Central School	Third Floor Water Bottle Filling Station	0 ppb
Woolwich Central School	Third Floor Water Fountain	0 ppb
Yarmouth Elementary School	Area D 2nd Floor Class 1 Fountain D211	0 ppb

School Name	Sample Location	Lead Test Result
Yarmouth Elementary School	Area D 2nd Floor Class 2 Fountain D210	0 ppb
Yarmouth Elementary School	Area D 2nd Floor Class 3 Fountain D209	1.2 ppb
Yarmouth Elementary School	Area D 2nd Floor Class 4 Fountain D208	1.8 ppb
Yarmouth Elementary School	Area D 2nd Floor Class 5 Fountain D206	1.7 ppb
Yarmouth Elementary School	Area D 2nd Floor Class 6 Fountain D204	0 ppb
Yarmouth Elementary School	Area D 2nd Floor Class 7 Fountain D203	0 ppb
Yarmouth Elementary School	Area D 2nd Floor Class 8 Fountain D202	0 ppb
Yarmouth Elementary School	Area D 2nd Floor Class 9 Fountain D201	1.1 ppb
Yarmouth Elementary School	Area D 2nd Floor Fountain 1 Bathroom Left To Right	0 ppb
Yarmouth Elementary School	Area D 2nd Floor Fountain 2 Bathroom Middle	0 ppb
Yarmouth Elementary School	Area D 2nd Floor Fountain 3 Bathroom Right	0 ppb
Yarmouth Elementary School	Area D Class 1 Fountain D177	0 ppb
Yarmouth Elementary School	Area D Class 10 Fountain D161	1.1 ppb
Yarmouth Elementary School	Area D Class 2 Fountain D178	1.7 ppb
Yarmouth Elementary School	Area D Class 3 Fountain D176	0 ppb
Yarmouth Elementary School	Area D Class 4 Fountain D175	2.2 ppb
Yarmouth Elementary School	Area D Class 5 Fountain D174	1.6 ppb
Yarmouth Elementary School	Area D Class 6 Fountain D165	1.9 ppb
Yarmouth Elementary School	Area D Class 7 Fountain D166	1.2 ppb
Yarmouth Elementary School	Area D Class 8 Fountain D172	1.2 ppb
Yarmouth Elementary School	Area D Class 9 Fountain D162	1.2 ppb
Yarmouth Elementary School	Area D Fountain 1 Second Bathroom Across 168	0 ppb
Yarmouth Elementary School	Area D Fountain 2 Second Bathroom Middle	0 ppb
Yarmouth Elementary School	Area D Fountain 3 Second Bathroom Right	0 ppb
Yarmouth Elementary School	Area D Near Fountain 1 Near Bathroom Across D179	0 ppb
Yarmouth Elementary School	Area D Near Fountain 2 Near Bathroom Middle	0 ppb
Yarmouth Elementary School	Area D Near Fountain 3 Near Bathroom Right	0 ppb
Yarmouth Elementary School	Area D Teacher's Workshop D170	3.6 ppb
Yarmouth Elementary School	Area E Class 1 Fountain E 192	0 ppb
Yarmouth Elementary School	Area E Class 2 Fountain E 193	0 ppb
Yarmouth Elementary School	Area E Class 3 Fountain E 190	0 ppb
Yarmouth Elementary School	Area E Class 4 Fountain E 191	0 ppb
Yarmouth Elementary School	Area E Class 5 Fountain E 188	0 ppb
Yarmouth Elementary School	Area E Class 6 Fountain E 189	1 ppb
Yarmouth Elementary School	Art Room Room Next Door Fountain	2.2 ppb
Yarmouth Elementary School	Gym Fountain 1 Left To Right Entrance	0 ppb
Yarmouth Elementary School	Gym Fountain 2 Middle	0 ppb
Yarmouth Elementary School	Gym Fountain 3 Right	0 ppb
Yarmouth Elementary School	Gym Fountain 4 Left To Right In Gym	0 ppb

School Name	Sample Location	Lead Test Result
Yarmouth Elementary School	Gym Fountain 5 Middle	0 ppb
Yarmouth Elementary School	Gym Fountain 6 Right	0 ppb
Yarmouth Elementary School	Kitchen Food Prep	2.8 ppb
Yarmouth Elementary School	Kitchen Steamer Sink	41.5 ppb
Yarmouth Elementary School	New Cafeteria Fountain 1 Next To Storage	0 ppb
Yarmouth Elementary School	New Cafeteria Fountain 2 Middle	0 ppb
Yarmouth Elementary School	New Cafeteria Fountain 3 Right	0 ppb
Yarmouth Elementary School	New Cafeteria Fountain 4 Left To Right	0 ppb
Yarmouth Elementary School	New Cafeteria Fountain 5 Middle	0 ppb
Yarmouth Elementary School	New Cafeteria Fountain 6 Right Side	0 ppb
Yarmouth Elementary School	Room A102e Nurse Station	12.4 ppb
Yarmouth Elementary School	Room A103 Art Room Fountain	2.1 ppb
Yarmouth Elementary School	Room D207 Facility Room D207	3.6 ppb
Yarmouth High School	Across D161 Bathroom Fountain 2	2.6 ppb
Yarmouth High School	Across D161 Bathrrom Fountain 1	1.5 ppb
Yarmouth High School	Back Of Gym In Hall Fountain 1	4.4 ppb
Yarmouth High School	Back Of Gym In Hall Fountain 2	2 ppb
Yarmouth High School	Kitchen Steam Kettle 1	1.4 ppb
Yarmouth High School	Kitchen Steam Kettle 2	29.2 ppb
Yarmouth High School	Main Office Break Room Sink	6.3 ppb
Yarmouth High School	Near Room B133 Bathroom Bottle Fill	0 ppb
Yarmouth High School	Near Room C147 Bathroom Bottle Fill	0 ppb
Yarmouth High School	Near Room C147 Bathroom Fountain	0 ppb
Yarmouth High School	Near Room E184 Bathroom Fountain 1	9.1 ppb
Yarmouth High School	Near Room E184 Bathroom Fountain 2	1.9 ppb
Yarmouth High School	Next To D205 Bottle Fill	0 ppb
Yarmouth High School	Next To D205 Fountain	0 ppb
Yarmouth High School	Next To E196 Bottle Fill	0 ppb
Yarmouth High School	Next To E196 Drinking Fountain	0 ppb
Yarmouth High School	Right Side Back Kitchen Sink	1.5 ppb
Yarmouth High School	Room D168 Faucet	0 ppb
Yarmouth High School	Room D171 Fountain	1.4 ppb
Yarmouth High School	Room D215 Kitchen Sink	1.1 ppb
Yarmouth High School	Salad Bar Area Bottle Fill	22.1 ppb
York High School	"c 156 ""alonso"" Sink"	15.9 ppb
York High School	1st Floor English Teachers Sink	0 ppb
York High School	1st Floor English Womans Br Left Sink	0 ppb
York High School	1st Floor English Womans Br Right Sink	0 ppb
York High School	2nd Floor Elevator Bottle Fill	0 ppb
York High School	Alt Ed Deep Sink	0 ppb
York High School	Alt Ed Hand Sink	5.2 ppb
York High School	Art Br Left Sink	0 ppb
York High School	Art Br Right Sink	0 ppb
York High School	Art Comp Room Left Sink	1.7 ppb
York High School	Art Comp Roomright Sink	2.2 ppb
York High School	Aud Bottle Fill	0 ppb
York High School	Aud Mens Br Front To Back Sink 1	1.1 ppb

School Name	Sample Location	Lead Test Result
York High School	Aud Mens Br Front To Back Sink 2	0 ppb
York High School	Aud Mens Br Front To Back Sink 3	1.2 ppb
York High School	Aud Snack Bar Sink	0 ppb
York High School	Aud Womans Br Front To Back Sink 1	1.4 ppb
York High School	Aud Womans Br Front To Back Sink 2	1.1 ppb
York High School	Aud Womans Br Front To Back Sink 3	0 ppb
York High School	Aud Womans Br Front To Back Sink 4	2.4 ppb
York High School	Aud Womans Br Front To Back Sink 5	0 ppb
York High School	Aud Womans Br Front To Back Sink 6	2.6 ppb
York High School	B 109 Lab Station Sink 1	1.1 ppb
York High School	B 109 Lab Station Sink 2	4.6 ppb
York High School	B 109 Lab Station Sink 3	2 ppb
York High School	B 109 Lab Station Sink 4	4.3 ppb
York High School	B 109 Lab Station Sink 5	5.6 ppb
York High School	B 109 Lab Station Sink 6	5.2 ppb
York High School	B 112 Lab Sink	2.9 ppb
York High School	B 112 Lab Station Sink 1	4.5 ppb
York High School	B 112 Lab Station Sink 2	3 ppb
York High School	B 112 Lab Station Sink 3	0 ppb
York High School	B 112 Lab Station Sink 4	3.4 ppb
York High School	B 112 Lab Station Sink 6	3 ppb
York High School	B 112 Prep Sink	0 ppb
York High School	B 118 Lab Sink	2.4 ppb
York High School	B 118 Prep Sink	0 ppb
York High School	B 118 Sci. Station Sink 1	14.6 ppb
York High School	B 118 Sci. Station Sink 2	24.9 ppb
York High School	B 118 Sci. Station Sink 3	54 ppb
York High School	B 118 Sci. Station Sink 4	153 ppb
York High School	B 118 Sci. Station Sink 5	42 ppb
York High School	B 118 Sci. Station Sink 6	1.6 ppb
York High School	B 205 Lab Station Sink	3.1 ppb
York High School	B 205 Prep Room Sink	0 ppb
York High School	B 212 Lab Sink	6.8 ppb
York High School	B 212 Prep Sink	8.7 ppb
York High School	B 212corner Sink	11.4 ppb
York High School	B 215 Corner Sink	3.3 ppb
York High School	B 215 Lab Sink	3.2 ppb
York High School	B205 Sci. Station Sink 1	20.8 ppb
York High School	B205 Sci. Station Sink 2	5.4 ppb
York High School	B205 Sci. Station Sink 3	0 ppb
York High School	B205 Sci. Station Sink 4	9.1 ppb
York High School	B205 Sci. Station Sink 5	3.8 ppb
York High School	B205 Sci. Station Sink 6	9.4 ppb
York High School	B211 Sci. Station Sink 1	4.1 ppb
York High School	B211 Sci. Station Sink 2	2.5 ppb
York High School	B211 Sci. Station Sink 3	5.3 ppb
York High School	B211 Sci. Station Sink 4	2.4 ppb

School Name	Sample Location	Lead Test Result
York High School	B211 Sci. Station Sink 5	3.6 ppb
York High School	B211 Sci. Station Sink 6	3.1 ppb
York High School	Balanos Bottle Fill	0 ppb
York High School	Band Left Br Sink	0 ppb
York High School	Band Right Br Sink	0 ppb
York High School	Band Room Sink	0 ppb
York High School	Boys Locker Room Back Shower	3.3 ppb
York High School	Boys Locker Room Front Right Shower	4 ppb
York High School	Boys Locker Room Left Shower	2.4 ppb
York High School	Boys Locker Room Left Sink	3.6 ppb
York High School	Boys Locker Room Right Sink	1.6 ppb
York High School	Cleary Mens Br Sink Left	0 ppb
York High School	Cleary Mens Br Sink Right	0 ppb
York High School	Cleary Teacher Br Sink	0 ppb
York High School	Cleary Womans Br Sink Left	7.8 ppb
York High School	Cleary Womans Br Sink Right	26 ppb
York High School	Coachs Room Deep Sink	128 ppb
York High School	Coachs Room Shower	116 ppb
York High School	Coachs Room Sink	20.8 ppb
York High School	Commons Bottle Fill	0 ppb
York High School	Commons Mens Br Sink	11.1 ppb
York High School	Commons Womans Br Sink	6.5 ppb
York High School	Damiano Office Sink	0 ppb
York High School	F 125 Deep Sink	0 ppb
York High School	F 125 Shallow Sink Grant	0 ppb
York High School	F 136 Deep Sink Shennett	0 ppb
York High School	F 136 Shallow Sink	0 ppb
York High School	Faculty Br Ramp	9.8 ppb
York High School	Fl Hall Bottle Fill	0 ppb
York High School	Fl Mens Sink Right	17.9 ppb
York High School	Fl Womans Sink Left	3.1 ppb
York High School	Fl Womans Sink Right	28.7 ppb
York High School	Foreign Language Mens Sink Left	12.5 ppb
York High School	Gym Basketball Womans Sink	4.1 ppb
York High School	Gym Womans Team Room	4.6 ppb
York High School	Gym Womans Team Room Left Shower	9.1 ppb
York High School	Gym Womans Team Room Right Shower	39.1 ppb
York High School	Hocker Locker Room Left Shower	1.8 ppb
York High School	Hocker Locker Room Left Sink	0 ppb
York High School	Hocker Locker Room Right Shower	0 ppb
York High School	Hocker Locker Room Right Sink	2.4 ppb
York High School	Home Ec Br	2.3 ppb
York High School	Home Ec Deep Sink	3.9 ppb
York High School	Home Ec Island Sink	2.3 ppb
York High School	Home Ec Station 1 Sink	6.5 ppb
York High School	Home Ec Station 2 Sink	12.9 ppb
York High School	Home Ec Station 3 Sink	2.5 ppb

School Name	Sample Location	Lead Test Result
York High School	Ice Macine	2.3 ppb
York High School	Jiminez Faculty Br Sink	0 ppb
York High School	Jiminez Mens Br Sink Left	1.1 ppb
York High School	Jiminez Mens Br Sink Right	5.8 ppb
York High School	Kitchen Bakers Sink	2.7 ppb
York High School	Kitchen Br Sink	7.6 ppb
York High School	Kitchen Dish Sink Left	3.9 ppb
York High School	Kitchen Dish Sink Right	7.4 ppb
York High School	Kitchen Elec. Fry Pan Fill	43.8 ppb
York High School	Kitchen Hand Sink	3.3 ppb
York High School	Kitchen Prep Sink	1.1 ppb
York High School	Kitchen Snack Bar Sink	18.2 ppb
York High School	Kitchen Steam Kettles Left	1100 ppb
York High School	Kitchen Steam Kettles Right	1080 ppb
York High School	Library Office Sink	8.7 ppb
York High School	Life Skills Br Sink	0 ppb
York High School	Life Skills Sink	0 ppb
York High School	Mens Dressing Room Sink	0 ppb
York High School	Nurses Br Sink	68.7 ppb
York High School	Nurses Office Sink	0 ppb
York High School	Outside Gym Drinking Fountain	73.1 ppb
York High School	Science Lab Sink	53.2 ppb
York High School	Single Gym Br Sink	0 ppb
York High School	Sro Office Sink	31.6 ppb
York High School	Ss Prep Sink	0 ppb
York High School	Teachers Rm Bottle Fill Station	0 ppb
York High School	Teachers Rm Br Sink	0 ppb
York High School	Womans Dressing Room Sink	0 ppb
York High School	Womans Locker Room Back Left Shower	4320 ppb
York High School	Womans Locker Room Back Right Shower	1140 ppb
York High School	Womans Locker Room Front Left Shower	516 ppb
York High School	Womans Locker Room Front Right Shower	1470 ppb
York High School	Womans Locker Room Sink Left	33.4 ppb
York High School	Womans Locker Room Sink Right	4.6 ppb
York High School	Wyett F101 Sink	0 ppb
York Middle School	1202 Art 1st Sink Left Side	0 ppb
York Middle School	1202 Art 2nd Sink Left Side	0 ppb
York Middle School	1202 Art 3rd Sink Left Side	0 ppb
York Middle School	1202 Art 4th Sink Left Side	0 ppb
York Middle School	1204 Art 1st Sink Right Side	0 ppb
York Middle School	1204 Art 2nd Sink Right Side	0 ppb
York Middle School	1204 Art 3rd Sink Right Side	0 ppb
York Middle School	1204 Art 4th Sink Right Side	0 ppb
York Middle School	1205 Faculty Bath 1 Sink	0 ppb
York Middle School	1208 Shop Class 1 Sink Front Of Room	0 ppb
York Middle School	1209 Music Room 1 Sink Front Of Room	1.1 ppb
York Middle School	1212 Art 1st Sink Right Side	0 ppb

School Name	Sample Location	Lead Test Result
York Middle School	1212 Art 2nd Sink Right Side	0 ppb
York Middle School	1212 Art 3rd Sink Right Side	0 ppb
York Middle School	1212 Art 4th Sink Right Side	0 ppb
York Middle School	1301 Home Ec 1st Sink Center Of Room	0 ppb
York Middle School	1301 Home Ec 2nd Sink Right Side	0 ppb
York Middle School	1301 Home Ec 3rd Sink Right Side	0 ppb
York Middle School	1301 Home Ec 4th Sink Right Side	0 ppb
York Middle School	1301 Home Ec 5th Sink Right Side	0 ppb
York Middle School	1301 Home Ec 6th Sink Right Side	0 ppb
York Middle School	1301 Home Ec 7th Sink Right Side	0 ppb
York Middle School	1302 Upper Cafe 1 Sink	1.6 ppb
York Middle School	1303 Kitchen Bathroom 1 Sink	0 ppb
York Middle School	1303 Kitchen Double Basin Sink	0 ppb
York Middle School	1303 Kitchen Double Basin Sink #2	0 ppb
York Middle School	1303 Kitchen Ice Machine	0 ppb
York Middle School	1303 Kitchen Kettle	1.4 ppb
York Middle School	1303 Kitchen Small Bar Sink	0 ppb
York Middle School	1303 Kitchen Small Bar Sink By Snack Bar	1.1 ppb
York Middle School	1303 Kitchen Tilting Skillet	92 ppb
York Middle School	1304 Teachers Room 1 Sink Off Of Upper Cafe	1.2 ppb
York Middle School	1305 Bathroom 1 Sink Upper Cafe	0 ppb
York Middle School	1308 Boys Bath 1st Sink Left Side	0 ppb
York Middle School	1308 Boys Bath 2nd Sink Left Side	0 ppb
York Middle School	1308 Boys Bath 3rd Sink Left Side	0 ppb
York Middle School	1308 Boys Bath 4th Sink Left Side	0 ppb
York Middle School	1309 Girls Bath 1st Sink Right Side	0 ppb
York Middle School	1309 Girls Bath 2nd Sink Right Side	0 ppb
York Middle School	1309 Girls Bath 3rd Sink Right Side	0 ppb
York Middle School	1309 Girls Bath 4th Sink Right Side	0 ppb
York Middle School	2106 Nurses Station 1 Sink Center	0 ppb
York Middle School	2106b Nurses Bath 1 Sink	0 ppb
York Middle School	2301 Classroom 1 Sink Left Side	1.4 ppb
York Middle School	2302 Classroom 1 Sink Right Side	4.9 ppb
York Middle School	2305 1st Sink Center Of Room	0 ppb
York Middle School	2305 2nd Sink Right Side	1.2 ppb
York Middle School	2305- 3rd Sink Right Side	0 ppb
York Middle School	2305-4th Sink Right Side	0 ppb
York Middle School	2305-5th Sink Left Side	0 ppb
York Middle School	2305-6th Sink Left Side	0 ppb
York Middle School	2305-7th Sink Left Side	0 ppb
York Middle School	2307 Classroom 1 Sink Right Side	0 ppb
York Middle School	2308 Classroom 1 Sink Left Side	0 ppb
York Middle School	2309- 3rd Sink Left Side	0 ppb
York Middle School	2309-1st Sink Center Of Room	1.9 ppb
York Middle School	2309-2nd Sink Left Side	1.9 ppb
York Middle School	2309-4th Sink Left Side	1.5 ppb

School Name	Sample Location	Lead Test Result
York Middle School	2309-5th Sink Left Side	0 ppb
York Middle School	2309-6th Sink Right Side	0 ppb
York Middle School	2309-7th Sink Right Side	0 ppb
York Middle School	2312 Classroom 1 Sink Left Side	1.1 ppb
York Middle School	2313 Classroom 1 Sink Right Side	0 ppb
York Middle School	2314 Classroom 1 Sink Left Side	0 ppb
York Middle School	2315 Classroom 1 Sink Right Side	0 ppb
York Middle School	2316 Classroom 1 Sink Left Side	1.5 ppb
York Middle School	2320 Boys Bath 1st Sink Left Side	0 ppb
York Middle School	2320 Boys Bath 2nd Sink Left Side	0 ppb
York Middle School	2320 Boys Bath 3rd Sink Left Side	0 ppb
York Middle School	2320 Boys Bath 4th Sink Left Side	0 ppb
York Middle School	2321 Girls Bath 1 Sink Right Side	0 ppb
York Middle School	2321 Girls Bath 2nd Sink Right Side	0 ppb
York Middle School	2321 Girls Bath 3rd Sink Right Side	0 ppb
York Middle School	2321 Girls Bath 4th Sink Right Side	0 ppb
York Middle School	2325 Faculty Closet 1 Sink	2.7 ppb
York Middle School	2328-girls Gym Bath 1st Sink Left Side	0 ppb
York Middle School	2328-girls Gym Bath 2nd Sink Left Side	0 ppb
York Middle School	2328-girls Gym Bath 3rd Sink Left Side	0 ppb
York Middle School	2329-boys Gym Bath 1 Sink Right	0 ppb
York Middle School	2329-boys Gym Bath 2nd Sink Right	0 ppb
York Middle School	2329-boys Gym Bath 3rd Sink Right	0 ppb
York Middle School	2330 Boys Locker Room Sink 1 Right Side	0 ppb
York Middle School	2330 Boys Locker Room Sink 2 Right Side	0 ppb
York Middle School	2331 Girls Locker Room Sink 1 Left Side	0 ppb
York Middle School	2331 Girls Locker Room Sink 2 Left Side	0 ppb
York Middle School	3205 1st Sink Center	1.6 ppb
York Middle School	3205 2nd Sink Right Side	1.4 ppb
York Middle School	3205 3rd Sink Right Side	0 ppb
York Middle School	3205 4th Sink Left Side	2.9 ppb
York Middle School	3205 5th Sink Left Side	1.3 ppb
York Middle School	3205 6th Sink Left Side	0 ppb
York Middle School	3205 7th Sink Left Side	9.8 ppb
York Middle School	3209 1st Sink Center	2.3 ppb
York Middle School	3209 2nd Sink Left Side	1.3 ppb
York Middle School	3209 3rd Sink Left Side	0 ppb
York Middle School	3209 4th Sink Left Side	0 ppb
York Middle School	3209 5th Sink Left Side	2.4 ppb
York Middle School	3209 6th Sink Right Side	0 ppb
York Middle School	3209 7th Sink Right Side	1 ppb
York Middle School	3308-science Lab 1st Sink Center Of Room	50.3 ppb
York Middle School	3308-science Lab 2nd Sink Left Side	9.1 ppb
York Middle School	3308-science Lab 3rd Sink Left Side	1.5 ppb
York Middle School	3308-science Lab 4th Sink Left Side	0 ppb
York Middle School	3308-science Lab 5th Sink Left Side	0 ppb
York Middle School	3308-science Lab 6th Sink Right Side	1.1 ppb

School Name	Sample Location	Lead Test Result
York Middle School	3308-science Lab 7th Sink Right Side	0 ppb
York Middle School	3312- Science Lab 1st Sink Center Of Room	1.6 ppb
York Middle School	3312-science Lab 2nd Sink Left Side	1.8 ppb
York Middle School	3312-science Lab 3rd Sink Left Side	0 ppb
York Middle School	3312-science Lab 4th Sink Left Side	2.8 ppb
York Middle School	3312-science Lab 5th Sink Left Side	1.8 ppb
York Middle School	3312-science Lab 6th Sink Right Side	0 ppb
York Middle School	3312-science Lab 7th Sink Right Side	3.7 ppb
York Middle School	3321 8th Boys 2nd Sink Left Side	0 ppb
York Middle School	3321 8th Boys 3rd Sink Left Side	0 ppb
York Middle School	3321 8th Boys 4th Sink Left Side	0 ppb
York Middle School	3321 8th Grade Boys 1st Sink	0 ppb
York Middle School	3322 8th Girls 1st Sink Right Side	0 ppb
York Middle School	3322 8th Girls 2nd Sink Right Side	0 ppb
York Middle School	3322 8th Girls 3rd Sink Right Side	0 ppb
York Middle School	3322 8th Girls 4th Sink Right Side	0 ppb
York Middle School	3322-b Library Office 1 Sink Left	3.3 ppb
York Middle School	All Gender Left - 1 Sink Left	0 ppb
York Middle School	All Gender Left 1 Sink Left Side	0 ppb
York Middle School	All Gender Left 1 Sink Right Side	0 ppb
York Middle School	All Gender Right 1 Sink Right	0 ppb
York Middle School	Bath Between 2323+2324 1 Sink	0 ppb
York Middle School	Bottle Fill Station Between Baths 2320-2321	0 ppb
York Middle School	Bottle Fill Station Outside Room 1301	0 ppb
York Middle School	Bottle Fill Station Outside Room 2302	0 ppb
York Middle School	Drinking Water Fountain 2 Locker Rooms	0 ppb
York Middle School	Faculty Bath 1 Sink - 2108	0 ppb
York Middle School	Faculty Bath 1 Sink - 3107	0 ppb
York Middle School	Faculty Bath-3304-1 Sink	0 ppb
York Middle School	Pantherian Class 1st Sink Classroom	0 ppb
York Middle School	Pantherian Class 2nd Sink Bath	0 ppb
York Middle School	Water Fountain Outside Of Room 3312	0 ppb
Young School	Dwf Obck Br	0 ppb
Young School	Dwf Ofrnt-off	0 ppb
Young School	Dwf Orm11	18 ppb
Young School	Dwf Orm14	0 ppb
Young School	Dwf Orm29	0 ppb
Young School	Dwf Orm4	0 ppb