

- 1 Heat Flux
- 2 Emissivity
- 3 Blast Wave Energy
- 4 TNT Mass Equivalent
- 5 BLEVE
- 6 Fireball
- 7 Pool Fires Mass Loss Rate
- 8 Total Heat Generated
- 9 Energy Absorbed
- 10 Heat Release Time growth
- 11 Lower Flammable Limit
- 12 Exit sign visibility
- 13 Compartment Fires
- 14 McCaffrey Flashover Heat Release Equations
- 14A Pre-Flashover Compartment Temps – Natural Ventilation
- 14B Pre-Flashover Compartment Temps – Natural Ventilation @ STP
- 14C Pre-Flashover Compartment Temps – Forced Ventilation
- 14D Flashover Reference
- 15 Virtual Origin of Pool Fire
- 15A Virtual Origin of Other Fire Types
- 16 Peak Heat Release Rate
- 17 Pipe Schedule Correction Factor
- 18 Hydrant Flow Test
- 19 Sprinkler System K-Factor to balance pressures (NOT additive – use highest pressure of any single branch line)
- 20 Sprinkler Head flow using Sprinkler K-Factor
- 21 Sprinkler Flow Normal Pressure
- 22 Sprinkler Flow Velocity Pressure
- 23 Conservation Equation/Bernoulli Equation
- 24 Darcy-Weisbach Equation (foam concentrate, antifreeze >40 gal, & water mist)
- 25 Piping Loops
- 26 Pump Cavitation
- 27 Water Hammer
- 28 Pump Affinity Laws
- 29 Fire Pump Total Head
- 30 Pump Brake Horsepower) Remember, typical psi is 65% @ 150% capacity or 55% @ 160% capacity.
- 31 Velocity Head
- 31A Net Positive Suction Head (NPSH_r)
- 31B Diesel Fuel Tank Capacity
- 32 Fire Pump Controller Operation
- 33 Sprinkler Flow Pressure Loss Hazen-Williams
- 33A Pressure Due to Elevation
- 34 ISO Water Supply Equation
- 35 ISU (Iowa State) Water Supply Equation
- 36 IIU (Illinois Institute) Water Supply Equation
- 37 Door Opening Forces
- 38 Thrust Blocks
- 39 Reaction Forces in Nozzles
- 40 Rate of Heat Release
- 41 Heat Detector RTI
- 42 Furnace Test Correction Factor
- 43 Tied Fire Walls
- 44 Equivalent Thickness of Wall Material with Voids
- 45 Wind Pressure
- 46 Stairwell Pressurization
- 47 Stairwell Pressurization Height Limitation
- 48 Liquid Fuel Flame Height
- 49 Plume Centerline Temperature Rise
- 49A Temperature of Smoke in a Plume
- 50 Plume Radius to point where temperature rise has declined to $0.5\Delta T_o$
- 51 Plume Centerline Velocity
- 52 Weak Plume Driven Temperature of Ceiling Jet
- 52A Weak Plume Driven Velocity of Ceiling Jet
- 53 Height of 1st Indication of Smoke for Steady Fires
- 54 Height of First Indication of Smoke for Unsteady (or Growing) Fires
- 55 Height of Flame Tip
- 56 Mass Flow Rate if $H > z_l$
- 57 Volumetric Flow Rate
- 58 Density of Smoke
- 59 Average Temperature of Fire Plume
- 60 Average Mass Flow Rate of Fire Plume
- 61 Maximum Flow Rate to Avoid Plugholing
- 62 Required Opposed Airflow for Smoke Control
- 63 Limiting Average Velocity through Communicating Space
- 64 Vented Fire Smoke Layer Temperature Change
- 65 Atrium ASET
- 66 Smoke Flow Across an Opening /Pressurization
- 67 Stack Effect/Bouyancy
- 68 Critical Airflow Velocity for Smoke Control
- 69 Minimum Recommended Vent Area for Venting of Low-strength Enclosures from Gases, Gas Mixtures and Mists
- 70 Beam or Column Substitution
- 71 Venting One End of Elongated Enclosure
- 72 Minimum P_{red} for Non-Relieving Wall Construction
- 73 Vent Area for High-Strength Enclosures
- 74 Effects of Vent Ducts (Non-cubical Vessels)
- 75 Effects of Vent Ducts (Cubical Vessels)
- 76 Venting of Deflagrations of Dusts and Hybrid Mixtures

77 Partial Volume Deflagrations

78 Column Resistive Rating

79 Vent Area Threshold Mass

80 Time Value of Money

1 Heat Flux

(FPH 3-156; HFPE 3-279)

$$\dot{q}_r'' = \dot{Q}_R / (4\pi r^2)$$

\dot{q}_r'' ≡ Heat flux on target perpendicular to radius from point source

\dot{Q}_R ≡ Radiative heat release from fire (20 to 30% of \dot{Q}_C)

r ≡ R ≡ Distance from plume center at h/2 to target

NEED TO LOOK AT HFPE 1-4 FOR CONFIGURATION (SHAPE) FACTORS Table 1-4.1 pg 1-77 & Appendix pg A-45

2 Emissivity

(HFPE 3-307; FPH 2-11)

$$\dot{q}'' = \varepsilon \sigma T^4$$

\dot{q}'' ≡ flame emissive power kW/m²

ε = 1.0 for a blackbody

σ = 5.67 x 10⁻¹² (kW/m²K⁴ - Stefan-Boltzman Constant)

T is in Kelvin

3 Blast Wave Energy

(FPH 2-95)

$$E = \alpha \Delta H_c m_F$$

E ≡ Blast wave energy (kJ)

α ≡ A ≡ Yield (Fraction of available combustion energy participating in blast wave generation. **Conservative value is 0.5**)

ΔH_c ≡ C ≡ Theoretical net heat of combustion (kJ/kg)

m_F ≡ M ≡ Mass of flammable vapor released (kg)

4 TNT Mass Equivalent

(FPH 2-94)

$$W_{TNT} = E / 4500$$

W_{TNT} ≡ Equivalent weight of TNT in kg

E ≡ Blast wave energy in kJ

5 BLEVE

(FPH 6-171)

$$E = m(u_r - u_a)$$

E ≡ Blast wave energy

m ≡ Mass of liquid in vessel

u_r ≡ Internal energy (per unit mass) of liquid at rupture

u_a ≡ Internal energy (per unit mass) of vapor after expansion

6 Fireball

(FPH 18-86; HFPE 3-311)

$$D_{max} = 5.25 m_{fluid}^{1/3}$$

$$Z_p = 12.73 V_{va}^{1/3}$$

$$\dot{q}_{max}'' = 828 m_{fuel}^{0.771} / R^2$$

D_{max} ≡ Maximum diameter of fireball (m)

m_{fluid} ≡ Mass of fluid (kg)

Z_p ≡ Rise of **center** of fireball above tank (m)

V_{va} ≡ Fuel vapor volume (m³)

\dot{q}_{max}'' ≡ Peak thermal radiation from fireball (kW/m²)

m_{fuel} ≡ mass of fuel (kg)

R ≡ Distance of center of fireball to target (m)

7 Pool Fires Mass Loss Rate

(NFPA 92.B.5.1; HFPE 3-37)

$$\dot{m}'' = \dot{m}_{\infty}'' (1 - e^{-k\beta D})$$

\dot{m}'' ≡ large pool burning rate

\dot{m}_{∞}'' ≡ Mass loss rate for an infinite pool diameter

$k\beta$ ≡ Extinction absorption coefficient (HFPE pg 3-37 or NFPA 92 Table B.5.1)

8 Total Heat Generated

(HFPE 1-96)

$$\dot{Q}_T = \chi_r * \dot{m}' * \Delta H_c$$

\dot{Q}_T ≡ Total Heat Generated

χ_r ≡ Radiative fraction of combustion energy (calculated from HFPE pg 3-142 $\chi_r = H_R / H_T = (1 - \chi_{Convective})$)

\dot{m}' ≡ Mass burning rate of fuel

ΔH_c ≡ Heat of combustion (HFPE 1-94)

$$\dot{q}'' = \dot{Q}_T / 4\pi r^2$$

\dot{q}'' ≡ heat flux, r meters from point source

9 Energy Absorbed

$$E = \varepsilon * \dot{q}'' * A * t$$

E ≡ Energy absorbed

ε ≡ Emissivity

\dot{q}'' ≡ Heat flux

A ≡ Exposed area

t ≡ time

10 Heat Release Time growth

(NFPA 92.5.2.4.2.1 & Table B.5.2(b); HFPE 4-13; FPH 18-62)

$$Q(t) = \left(\frac{1055}{t_g^2} \right) * t^2$$

$Q(t)$ ≡ Total heat release rate at time t (kW)

t ≡ Time in seconds

t_g ≡ Time for a fire to grow from first appearance of flame to 1,055 kW (1,000 Btu/s) (NFPA 92 Table B.4.2(b); HFPE 4-13; FPH 18-62)

Common t_g = 75 for ultrafast fires, 150 for fast fires, 300 for medium fires, and 600 for slow fires

11 Lower Flammable Limit

(HFPE 2-197; FPH 3-126)

$$LFL = V_{LFL} / 0.147$$

LFL ≡ lower flammable limit

V_{LFL} ≡ Vapor pressure of liquid @ its LFL, psia

$$LFL = V_{LFL} / 1.01$$

LFL ≡ lower flammable limit

V_{LFL} ≡ Vapor pressure of liquid @ its LFL, kPa

$$LFL = 100V/P$$

LFL ≡ lower flammable limit

V ≡ Vapor pressure of liquid @ its LFL @ ambient pressure

P ≡ Ambient pressure

Generally as T↑ LFL↓ UFL↑ and as p↑ LFL ≈ const UFL↑

12 Exit sign visibility

(HFPE 2-53)

$C_s V V = 8$ for light emitting exit sign

$C_s V = 3$ for light reflecting exit sign

C_s ≡ extinction coefficient (m^{-1}) (HFPE 2-64)

V ≡ visibility (m)

$$\frac{I}{I_0} = e^{-C_s L} \quad \text{Bouguer's Law}$$

$$\frac{I}{I_0} = 10^{-DL}$$

$$D = C_s / 2.303$$

$$D_s = D V_c / A$$

$$D_m = D V_c / \Delta M$$

$$C_s = C_m m$$

I ≡ Intensity of Light through Pathlength (L) of Smoke

I_0 ≡ Intensity of Incident Monochromatic Light

D ≡ Optical Density per Meter

D_s ≡ Specific Optical Density (dimensionless)

D_m ≡ Mass Optical Density (m^2/g) **HFPE 2-264 Table 2-13.5**

V_c ≡ Volume of space being filled with smoke (m^3)

A ≡ Area of Sample being burned (m^2)

C_s ≡ extinction coefficient (m^{-1})

C_{mm} ≡ extinction coefficient per unit mass ~ 7.6 m^2/g
(flaming fire of wood and plastics – use unless
other info given) OR ~ 4.4 m^2/g (pyrolysis fire)

ΔM ≡ amount of material that burns (**grams**)

m ≡ mass concentration of smoke aerosol

13 Compartment Fires

(HFPE 3-195)

Use Law's formula to calculate post-flashover
compartment fire temperatures (HFPE pg 3-216)

14 McCaffrey Flashover Heat Release Equations

(HFPE 3-219)

$$\dot{Q}_{fl} = 610(h_k A_T A_O \sqrt{H_O})^{1/2}$$

\dot{Q}_{fl} ≡ Heat Release rate required for flashover (kW)

h_k ≡ Effective heat transfer coefficient ((kW/m)/K)

A_T ≡ Total area of compartment surfaces (m^2)

A_O ≡ Area of opening (m^2)

H_O ≡ Height of opening (m)

$h_k = \frac{k}{\delta}$ where time of exposure (t) > thermal penetration
time (t_p)

$h_k = (krc/t)^{1/2}$ where $t \leq t_p$

k ≡ Thermal conductivity of wall material **HFPE A-28-33**

δ ≡ Thickness

$$t_p = (rc/k)(\delta/2)^2$$

r ≡ density of compartment surface (kg/m^3)

c ≡ specific heat of compartment surface material ($kJ/m-K$)

k ≡ thermal conductivity of compartment surface ($kW/m-K$)

δ ≡ thickness of compartment surface (m)

14A Pre-Flashover Compartment Temps – Natural Ventilation

(FPH 3-151; HFPE 3-209)

$$\Delta T_g = 480 \left(\frac{\dot{Q}}{\sqrt{g}(c_p \rho_\infty T_\infty A_O) \sqrt{H_O}} \right)^{2/3} \left(\frac{h_k A_T}{\sqrt{g}(c_p \rho_\infty A_O) \sqrt{H_O}} \right)^{-1/3}$$

$$\Delta T_g = T_g - T_\infty$$

ΔT_g ≡ Upper gas temperature rise above ambient (Kelvin)

T_g ≡ Upper gas temperature (Kelvin)

T_∞ ≡ Ambient gas temperature (Kelvin)

\dot{Q} ≡ **Total** Heat Release Rate (kW)

h_k ≡ Effective heat transfer coefficient (**thermal inertia**)

$h_k = (krc/t)^{1/2}$ (Note: c, r may not be same ↓) ($kW/m^*Kelvin$)

A_T ≡ Total area of compartment enclosing surfaces (m^2)

A_O ≡ Area of opening (m^2)

H_O ≡ Height of opening (m)

$g = 9.8 m/s^2$

$c_p = 1.05 kJ/kg*K$ (specific heat)

$r_\infty = 1.2 kg/m^3$ (density)

$T_\infty = 295 K$ (Kelvin)

14B Pre-Flashover Compartment Temps – Natural Ventilation @ STP

(FPH 3-151; HFPE 3-209)

$$\Delta T_g = 6.85 \left(\frac{\dot{Q}^2}{h_k A_T A_O \sqrt{H_O}} \right)^{1/3}$$

$$\Delta T_g = T_g - T_\infty$$

ΔT_g ≡ Upper gas temperature rise above ambient (Kelvin)

T_g ≡ Upper gas temperature (Kelvin)

T_∞ ≡ Ambient gas temperature (Kelvin)

\dot{Q} ≡ **Total** Heat Release Rate (kW)

h_k ≡ Effective heat transfer coefficient ((kW/m)/Kelvin)

A_T ≡ Total area of compartment enclosing surfaces (m^2)

A_O ≡ Area of opening (m^2)

H_O ≡ Height of opening (m)

14C Pre-Flashover Compartment Temps – Forced Ventilation

(HFPE pg 3-210)

$$\frac{\Delta T_g}{T_\infty} = 0.63 \left(\frac{\dot{Q}}{m_g T_\infty c_p} \right)^{0.72} \left(\frac{h_k A_T}{m_g c_p} \right)$$

$$\Delta T_g = T_g - T_\infty$$

ΔT_g ≡ Upper gas temperature rise above ambient (Kelvin)

T_g ≡ Upper gas temperature (Kelvin)

T_∞ ≡ Ambient gas temperature (Kelvin)

\dot{Q} ≡ **Total** Heat Release Rate (kW)

h_k ≡ Effective heat transfer coefficient ((kW/m)/Kelvin)
 A_T ≡ Total area of compartment enclosing surfaces (m²)
 c_p ≡ specific heat of gas (kJ/kg-K)
 m_g ≡ compartment mass ventilation rate (kg/s)
 m_g is (m³/s)(1.18 kg/m³) {5000 cfm ~ 2.4 m³/s}

14D Predicting Flashover Reference

(HFPE 3-217; FPH 2-56, 3-128, & 3-150)
 Solve equations above for $T_g \approx 600^\circ\text{C}$
 Flashover occurs, $T_g \approx 600^\circ\text{C}$ and $\dot{q}_r'' \approx 20\text{kW/m}^2$

15 Virtual Origin of Pool Fire

(HFPE 2-10; FPH 3-155)
 $z_o = -1.02D + 0.083\dot{Q}^{2/5}$
 z_o ≡ Virtual Origin
 D ≡ diameter of fire source(m)
 \dot{Q} ≡ **Total** heat release rate (kW)

15A Virtual Origin of Other Fire Types

(HFPE pg 2-11; FPH pg 3-155)
 $z_o = L - 0.175\dot{Q}_c^{2/5}$
 z_o ≡ Virtual Origin
 L ≡ Flame Height (m) = $0.533 \dot{Q}_c^{2/5}$ (NFPA 92 5.5.1.1)
 Or
 L ≡ Flame Height (m) = $0.235\dot{Q}_T^{2/5} - 1.02D$ (HFPE 2 - 4)
 \dot{Q} ≡ **Total** heat release rate (kW)

16 Peak Heat Release Rate

(HFPE 2-11; NFPA 92B Annex B)
 $\dot{Q} = \dot{m}'' A * \Delta H_C$
 \dot{Q} ≡ Peak Heat Release Rate (kW)
 \dot{m}'' ≡ mass loss rate per unit area of fuel from HFPE 3-134 or HFPE 3-37 (kg/s)
 A ≡ Area (m²)
 ΔH_C ≡ Heat of Combustion (kJ/kg)

17 Pipe Schedule Correction Factor

(NFPA 13 11.2.2 & 23.4.3.1.13.1)

$$\text{Correction factor} = \left(\frac{d_{\text{actual}}}{d_{\text{sched 40}}} \right)^{4.87}$$
 d_{actual} ≡ Pipe diameter for schedule pipe being used (in)
 $d_{\text{sched 40}}$ ≡ Pipe diameter for schedule 40 pipe (in)

18 Hydrant Flow Test

(NFPA 24 C.4.10.1.2)

$$Q_{\text{desired}} = Q_{\text{actual}} \frac{(p_s - p_{R,\text{desired}})^{0.54}}{(p_s - p_{R,\text{actual}})^{0.54}}$$

$$= Q_{\text{actual}} \frac{(\Delta p_{R,\text{desired}})^{0.54}}{(\Delta p_{R,\text{actual}})^{0.54}}$$
 Q ≡ Flow (gpm) = Equation 20 (FPH 15-46; HFPE 4-75)
 p_s ≡ Static pressure (psi)
 p_R ≡ Residual pressure (psi)

(FPH pgs 15-40 through 15-45)

$$Q = 29.84cd^2\sqrt{\text{pitot}}$$

c ≡ constant based upon hydrant outlet (FPH 15-45 Table 15.3.2)

d ≡ diameter of opening (inches)

pitot ≡ velocity pressure of water exiting hydrant (psi)

19 Sprinkler System K-Factor to balance pressures

(FPH 15-48; HFPE 4-75; NFPA 13.23.4.2.5)

$$K_{\text{total}} = \frac{Q_{\text{total}}}{\sqrt{p_{\text{required}}}}$$

$$K_{\text{total}} = K_{\text{branch1}} + K_{\text{branch2}} + \dots + K_{\text{branchn}} K_{\text{total}} \equiv$$

Sprinkler System K-factor

Q_{total} ≡ Total System Flow (gpm)

p_{required} ≡ Required System Pressure (psi) (**NOT additive – use highest pressure of any single branch line**)

20 Flow Through Nozzles K-Factor

(FPH 15-46; HFPE 4-75)

$$\dot{Q} = K\sqrt{p}$$

$$K = 29.84cd^2$$

d ≡ nominal diameter of opening (inches)

c ≡ coefficient of friction (FPH 15-45) (NOT the Hazen-Williams Coefficient)

\dot{Q} ≡ System Flow (gpm)

p ≡ System Pressure (psi)

21 Sprinkler Flow Normal Pressure

(NFPA 13 23.4.2.3)

$$P_n = P_t - P_v$$

P_n ≡ Normal pressure

P_t ≡ Total pressure

P_v ≡ Velocity pressure

22 Sprinkler Flow Velocity Pressure

(NFPA 13 23.4.2.2)

$$P_v = 0.001123Q^2/d^4$$

P_v ≡ Velocity pressure (psi)

\dot{Q} ≡ Flow prior to orifice (gpm)

d_{actual} ≡ Actual Pipe inside diameter prior to orifice (inches) (HFPE A-48; NFPA 13 Table A.6.3.2 & Table A.6.3.5; NFPA 24 Table A.10.1.6)

23 Conservation Equation/Bernoulli Equation

(FPH 15-38; HFPE 4-48)

$$\frac{p_1}{\rho g} + \frac{V_1^2}{2g} + z_1 + H_A - H_L - H_E = \frac{p_2}{\rho g} + \frac{V_2^2}{2g} + z_2$$

Total Energy 1st loc. + & - = Total Energy 2nd loc.

$$p_T = p + \frac{\rho V^2}{2} + \rho gz$$

p_T ≡ Total pressure (psi)
 p ≡ Normal pressure (psi)
 ρ ≡ Fluid density in mass per unit volume
 V ≡ Fluid velocity (ft/s)
 g ≡ Gravitational constant
 z ≡ Vertical distance from an arbitrary elevation
 H ≡ Pluses & Minuses due to pumps, elevation changes, flowing heads, etc.

24 Darcy-Weisbach Equation (foam concentrate, antifreeze >40 gal, & water mist)

(FPH 15-51; HFPE 4-57)

$$h = \left(\frac{f}{D}\right) \left(\frac{v^2}{2g}\right) = \left(\frac{f}{D}\right) \left(\frac{1}{2g}\right) \left(\frac{16}{\pi^2}\right) \left(\frac{\dot{Q}^2}{D^4}\right)$$

$$h_L = \frac{fLv^2}{2Dg}$$

h ≡ Friction loss over a unit length of pipe
 h_L ≡ Friction loss over a entire length of pipe
 L ≡ Length of pipe
 f ≡ Friction factor
 D ≡ Pipe diameter
 v ≡ Fluid velocity
 g ≡ Gravitational constant
 \dot{Q} ≡ Flow rate
 $h = \frac{0.0135fl\dot{Q}^2}{D^5}$
 f ≡ comes from Moody Diagram = $64/Re$
 Need to know pipe roughness, ϵ , -(FPH 15-52)
 Reynolds Number, $Re = \frac{vD}{\nu}$
 ν ≡ Kinematic viscosity

25 Piping Loops

(HFPE 4-78)

$$A = \sum_{i=1}^x \left[\frac{L_i}{c_i^{1.85} d_{actual,i}^{4.87}} \right] \text{ for Leg 1 of the loop}$$

$$B = \sum_{j=1}^y \left[\frac{L_j}{c_j^{1.85} d_{actual,j}^{4.87}} \right] \text{ for Leg 2 of the loop}$$

$$\dot{Q}_1 = \dot{Q}_3 \left[\frac{B^{0.54}}{(A^{0.54} + B^{0.54})} \right]$$

$$\dot{Q}_2 = \dot{Q}_3 - \dot{Q}_1$$

L ≡ Length of pipe (ft)

d_{actual} ≡ Actual Pipe diameter (in) (HFPE A-48; NFPA 13 Table A.6.3.2 & Table A.6.3.5; NFPA 24 Table A.10.1.6)
 c ≡ Pipe Hazen-Williams C-factor (HFPE 4-55; FPH 15-56; NFPA 13 Table 23.4.4.7.1)
 \dot{Q} ≡ Pipe flow (gpm)

Equivalent Pipe: (HFPE 4-79)

Series: $FLC_e = FLC_1 + FLC_2 + FLC_3 + \dots$

$$\text{Parallel: } (1/FLC_e)^{0.54} = (1/FLC_1)^{0.54} + (1/FLC_2)^{0.54} + (1/FLC_3)^{0.54} + \dots$$

$$FLC_e = 4.52L_e / (C_e^{1.85} D_e^{4.87})$$

L_e ≡ Equivalent Length of pipe (ft)
 D_e ≡ Equivalent Pipe diameter (in)
 C_e ≡ Equivalent Pipe C-factor
 FLC_e ≡ Equivalent Pipe flow (gpm)

26 Pump Cavitation

(FPH 15-91)

Cavitation occurs when normal water pressure in pipe drops below water vapor pressure

27 Water Hammer

(FPH 15-59 & 15-60)

28 Pump Affinity Laws

(FPH 15-91 & 15-92)

Law 1 – Constant Speed

$$\frac{\dot{Q}_1}{\dot{Q}_2} = \frac{N_1}{N_2}, \frac{H_1}{H_2} = \frac{N_1^2}{N_2^2}, \frac{bhp_1}{bhp_2} = \frac{N_1^3}{N_2^3}$$

Law 2 – Constant Diameter

$$\frac{\dot{Q}_1}{\dot{Q}_2} = \frac{D_1}{D_2}, \frac{H_1}{H_2} = \frac{D_1^2}{D_2^2}, \frac{bhp_1}{bhp_2} = \frac{D_1^3}{D_2^3} \text{ or } \frac{D_1^5}{D_2^5} \text{ if trimmed}$$

\dot{Q} ≡ Capacity (gpm)

N ≡ Specific speed number

H ≡ Head (ft)

bhp ≡ Brake horsepower

D ≡ Impeller diameter

29 Fire Pump Total Head

(FPH pg 15-89)

$$H = h_d + h_{vd} - h_s - h_{vs}$$

H ≡ Total head (ft)

h_d ≡ Discharge head (ft)

h_{vd} ≡ Discharge velocity head (ft)

$$h_{vd} = \frac{V_d^2}{2g}$$

h_s ≡ Total suction head (ft)

$$h_{vs} = \frac{V_s^2}{2g}$$

V ≡ Velocity (ft/sec) discharge or suction velocity

g ≡ Acceleration due to gravity (32.2 ft/s² or 9.81 m/s²)

30 Pump Brake Horsepower

(FPH 15-97-98)

$$bhp = \frac{\dot{Q}P}{1710E}$$

bhp ≡ Brake Horsepower

hp ≡ Hydraulic Horsepower = $\dot{Q}P/1710$

\dot{Q} ≡ Flow (gpm)

P ≡ Total pressure (psi) = (Total head)(0.433)

E \equiv Pump efficiency (decimal); Usually 60 to 75% (typically assume 65% @ 160% capacity) **Remember, typical psi is 65% @ 150% capacity or 55% @ 160% capacity.**

Deratings for Altitude and Temperature:

Altitude: 3% for every 1000 ft. above 300 ft. (NFPA 20 11.2.2.4)

Temperature: 1% for every 10°F above 77°F (NFPA 20 11.2.2.5)

$$bhp_{\text{before derating}} = bhp_{\text{after derating}} / (1 - (A+T))$$

Max Pump Churn = 1.4(rated psi) + city psi if using booster

Max Flow = 1.5(rated gpm) @ 0.65 (rated psi)

$$bhp_{\text{max flow}} = (\text{max flow})[(0.65)(\text{rated psi})]/1710E$$

See FPH for SI units.

31 Velocity Head

(FPH 15-36)

$$h_v =$$

h_v \equiv Velocity head (psi)

\dot{Q} \equiv Flow rate (gpm)

d \equiv Pipe inside diameter (in)

31A Net Positive Suction Head (NPSH)

(FPH 15-91)

$$NPSHA = P_{atm} + P_{static} - f - P_{vapor}$$

NPSH \equiv Net Positive Suction Head (psi)

P_{atm} \equiv Atmospheric Pressure (14.7 psia)

P_{static} \equiv pressure tank pressure - height*0.433 (psi)

f \equiv friction loss in line (psi)

P_{vapor} \equiv Vapor Pressure (psig) adjust for Temp and Altitude

31B Diesel Fuel Tank Capacity

(NFPA 20 11.4.2)

1 gallon/bhp + 5% for expansion + 5% for sump, so effectively, 1.1 gallons/bhp

32 Fire Pump Controller Operation

(NFPA 20 A.14.2.6.4(7)(f))

Jockey pump stop = Fire pump churn + minimum static suction

Jockey pump start \leq Jockey pump stop - 10 psi

Fire pump #1 start = Jockey pump start - 5 psi

Fire pump #2 start = Fire pump #1 start - 10 psi

Fire pump stop = Fire pump + minimum static suction

33 Sprinkler Flow Pressure Loss Hazen-Williams

(FPH 15-53; NFPA 13 23.4.2.1.1; HFPE 4-76)

$$\Delta p = \frac{4.52 \dot{Q}^{1.85}}{(C^{1.85} d_{actual}^{4.87})}$$

Δp \equiv Pressure lost per foot of pipe in psi

\dot{Q} \equiv Flow rate (gpm)

C \equiv Hazen-Williams coefficient (HFPE 4-55; FPH 15-56; NFPA 13 Table 23.4.4.7.1)

d_{actual} \equiv Actual internal pipe diameter (inches) (HFPE A-48; NFPA 13 Table A.6.3.2 & Table A.6.3.5; NFPA 24 Table A.10.1.6)

33A Pressure Due to Elevation

$$P = 0.433H$$

P = psi

H = Height (ft)

34 ISO Water Supply Equation

(FPH pgs 15-24)

$$NFF_i = (C_i)(O_i)(1 + (X_i + P_i))$$

NFF \equiv Needed Fire Flow

C_i \equiv Construction Factor (FPH pg 15-25)

O \equiv Occupancy Factor (FPH pg 15-25 Table 15.2.1)

$1 + (X + P)$ \equiv Exposure factor (FPH pg 15-27 Table 15.2.3) with a maximum value of 1.6. Note exceptions where X or P is equal to 0 due to building construction or occupancy classification.

$$C_i = 18f\sqrt{A}$$

f \equiv Coefficient related to class of construction (FPH pgs 15-25)

A \equiv Effective building area

For wood roofs of building or exposure building, add 500 gpm to total.

Round C_i to nearest 250 gpm **before** calculating NFF

Round final calc to **nearest** 250 gpm if under 2500 gpm and to **nearest** 500 gpm if over 2500 gpm

35 ISU (Iowa State) Water Supply Equation

(FPH pg15-25)

$$RFF = \sqrt[3]{V/100}$$

RFF \equiv Required Fire Flow

V \equiv Enclosed volume (ft³)

36 IIU (Illinois Institute) Water Supply Equation

(FPH pg 15-26)

Residential Occupancies

$$Flow = 9 \times 10^{-5} A^2 + 50 \times 10^{-2} A$$

Non-residential Occupancies

$$Flow = -1.3 \times 10^{-5} A^2 + 42 \times 10^{-2} A$$

A \equiv Area of the fire (ft²)

37 Door Opening Forces

(HFPE 4-374; NFPA 101.7.2.1.4.5; NPFA 92 A.4.4.2.2)

$$F = F_{DC} + \frac{k_d W A \Delta P}{2(W - d)}$$

F \equiv Total door opening force (lb) [N]

F_{DC} \equiv Force to overcome the door closer (lb) [N]

W \equiv Door width (ft) [m]

A \equiv Door area (ft²) [m²]

ΔP \equiv Pressure difference across door (in H₂O) [Pa]

d \equiv Distance from doorknob to the edge of the knob side of the door (ft) [m]

$k_d \equiv$ Coefficient (5.20) [1.00]

38 Thrust Blocks

(NFPA A.10.8.2)

The required block area (A_b) is as follows:

$$A_b = (h)(b) = \frac{T(S_f)}{S_b}$$

where:

A_b = required block area (ft²)

h = block height(ft)

b = calculated block width (ft)

T = Thrust Force (lbf)

S_f = safety factor (usually 1.5)

S_b = bearing strength (lb/ft²)

Then for horizontal bend, the following formula is used:

$$b = \frac{2(S_f)(P)(A)\sin\frac{\theta}{2}}{(h)(S_b)}$$

where:

b = calculated block width (ft)

S_f = safety factor (usually 1.5 for thrust block design)

P = water pressure (lb/in.²)

A = cross-sectional area of the pipe based on outside diameter

h = block height (ft)


S_b = horizontal bearing strength of the soil (lb/ft²) (in.²)

Horizontal Bearing Strengths

Soil	Bearing Strength, S_b	
	lb/ft ²	kN/m ²
Muck	0	0
Soft clay	1000	47.9
Silt	1500	71.8
Sandy silt	3000	143.6
Sand	4000	191.5
Sandy clay	6000	287.3
Hard clay	9000	430.9

Note: Although the bearing strength values in this table have been used successfully in the design of thrust blocks and are considered to be conservative, their accuracy is totally dependent on accurate soil identification and evaluation. The ultimate responsibility for selecting the proper bearing strength of a particular soil type must rest with the design engineer.

Thrust Force Acting on a Bend



T = Thrust force resulting from change in direction of flow (lbf)

T_x = Component of the thrust force acting parallel to the original direction of flow (lbf)

T_y = Component of the thrust force acting perpendicular to the original direction of flow (lbf)

P = Water pressure (psi²)

A = Cross-sectional area of the pipe based on outside diameter (in.²)

V = Velocity in direction of flow

It can be easily shown that $T_y = PA \sin\theta$. The required volume of the block is as follows:

$$V_g = \frac{S_f PA \sin\theta}{W_m}$$

where:

V_g = block volume (ft³)

S_f = safety factor

P = water pressure (psi)

A = cross-sectional area of the pipe interior

W_m = density of the block material (lb/ft³)

In a case such as the one shown, the horizontal component of thrust force is calculated as follows:

$$T_x = PA(1 - \cos\theta)$$

where:

T_x = horizontal component of the thrust force

P = water pressure (psi)

A = cross-sectional area of the pipe interior

39 Reaction Forces in Nozzles

(FPH 13-33)

$$F = 1.57c^2 d_2^2 p_2 (1 - \beta^2)$$

$F \equiv$ Reaction force (lbf)

$c \equiv$ Nozzle C-factor

$d_2 \equiv$ Pipe diameter at point 2 (in)

$p_2 \equiv$ Discharge velocity pressure (psi)

$$\beta = \frac{d_2}{d_1}$$

Simplified

$$F = 1.57p_1 d_2^2 \text{ or } NF = 1.5d^2 NP$$

$NF \equiv$ Nozzle force (lbf)

$NP \equiv$ Nozzle pressure (psi)

40 Rate of Heat Release

(FPH 3-127; HFPE 2-355)

$$\dot{Q} = \alpha t^2$$

\dot{Q} ≡ Rate of heat release (Btu/s) [kW]

α ≡ Fire intensity coefficient (Btu/s³) [kW/s²] (HFPE 4-13; FPH 3-150)

t ≡ Time after burning occurs (sec)

41 Heat Detector RTI

(HFPE 4-15)

$$RTI = \tau_0 \sqrt{u_0}$$

RTI ≡ Response Time Index

τ_0 ≡ Detector time constant (secs) (HFPE 4-14)

u_0 ≡ Gas velocity (ft/sec) [m/sec]

42 Furnace Test Correction Factor

(NFPA 251 Table B.1)

$$C = \frac{2I(A - A_S)}{3(A_S + L)}$$

C ≡ Correction Factor

I ≡ Indicated fire resistance period

A ≡ Area under the curve of indicated average furnace temperature for the first three-fourths of the indicated period

A_S ≡ Area under the standard furnace curve for the same part of the indicated period. **Found in NFPA 251 Table B.1**

L ≡ Lag Correction (54°F-h or 3240°F-min)

Add C to A for final answer

43 Tied Fire Walls

()

$$H = \frac{wBL^2}{8S}$$

H ≡ Horizontal pull per tie (lb)

w ≡ Dead load plus 25% of the live load of the roof (lb/ft²)

B ≡ Distance between ties (ft)

L ≡ Span of the structural member running perpendicular to the wall (ft)

S ≡ Sag in ft that may be assumed as:

0.07L for open web steel trusses

0.09L for solid web steel beams

0.06L for wood trusses

44 Equivalent Thickness of Wall Material with Voids

()

$$T_E = V/L(H)$$

T_E ≡ Equivalent thickness (in)

V ≡ Net volume (gross volume less volume of voids) (in³)

L ≡ Length of block (in)

H ≡ Height of block (in)

45 Wind Pressure

(HFPE 4-370)

$$P_W = C_W K_W V^2$$

P_W ≡ Wind pressure (in. H₂O)

C_W ≡ Dimensionless pressure coefficient ranging from -0.8 to 0.8, with positive values for windward walls and negative values for leeward walls

K_W ≡ Coefficient, 4.82x10⁻⁴

V ≡ Wind velocity (mph)

46 Stairwell Pressurization

(FPE pg 4-380; NFPA 92 A.4.4.2.1.1)

$$\Delta P_{SB} = \Delta P_{SBb} + \frac{by}{1 + \left(\frac{A_{SB}}{A_{BO}}\right)^2}$$

ΔP_{SB} ≡ Pressure difference between stairwell and building (inches of H₂O)

ΔP_{SBb} ≡ Pressure difference between stairwell and building at the bottom of stairwell (inches H₂O)

A_{SB} ≡ Flow area between stairwell and building (ft²)

A_{BO} ≡ Flow area between building and outside (ft²)

y ≡ Distance above stairwell bottom

$$b = K_s \left(\frac{1}{T_o} - \frac{1}{T_s} \right)$$

b ≡ Temperature factor (in. H₂O/ft)

K_s ≡ 7.64

T_o ≡ Absolute temperature of outside air (°R)

T_s ≡ Absolute temperature of stairwell air (°R)

$$\dot{Q} = K_q \frac{NA_{SB}}{\sqrt{\rho}} \left(\frac{\Delta P_{SBt}^{3/2} - \Delta P_{SBb}^{3/2}}{\Delta P_{SBt} - \Delta P_{SBb}} \right)$$

\dot{Q} ≡ Flow rate of pressurization air (ft³/min)

N ≡ Number of floors

A_{SB} ≡ Flow area between the stairwell and building (ft²)

ρ ≡ Density of air (0.075 lb/ft³)

ΔP_{SBb} ≡ Pressure difference at the bottom of the stairwell (inches of H₂O)

ΔP_{SBt} ≡ Pressure difference at top of stairwell (in. H₂O)

K_q ≡ 475

47 Stairwell Pressurization Height Limitation

$$H_m = K_m \frac{\Delta p_{max} - \Delta p_{min}}{\left(\frac{1}{T_o} - \frac{1}{T_B}\right)} \left[1 + \left(\frac{A_{SB}}{A_{SO}}\right)^2 \right]$$

H_m ≡ Height limit (ft)

Δp_{max} ≡ Maximum allowable pressure difference between the stairwell and the building (in. H₂O)

Δp_{min} ≡ Minimum allowable pressure difference between the stairwell and the building (in. H₂O)

T_O ≡ Absolute temperature of outside air (°R)
 T_B ≡ Absolute temperature of building air (°R)
 A_{SB} ≡ Flow area between the stairwell and the building (ft²)
 A_{SO} ≡ Flow area between the building and outside (ft²)
 K_m ≡ 0.131

48 Liquid Fuel Flame Height

(HFPE 2-353 & 3-279; FPH 3-153 & 3-155)
 $h = 0.235 Q_T^{2/5} - 1.02D$
 h ≡ Flame height
 Q_T ≡ **Total** heat release rate of fire
 D ≡ Diameter of fire

Note: 0.235 is an average. See HFPE pg 2-4 for values of materials. (e.g. gasoline is 0.200)

Note: Equivalent diameter for non-circular shapes: $D = \sqrt{4A/\pi}$ if $L/W \sim 1$.

49 Plume Centerline Temperature Rise

(HFPE 2-7; NFPA 92 A.5.5.5a)

$$\Delta T_O = 9.1 \left(\frac{T_\infty}{g * c_p^2 \rho_\infty^2} \right)^{1/3} \dot{Q}_c^{2/3} (z - z_o)^{5/3}$$

$$\Delta T_O = T_O - T_\infty$$

ΔT_O ≡ Temperature rise on centerline (K)

T_O ≡ Centerline Temperature (K)

T_∞ ≡ Ambient temperature (K) ≡ 273.16 K

g ≡ Gravity ≡ 9.81 m/s²

c_p ≡ Specific heat of air at constant pressure ≡ 1 kJ/kg K

ρ_∞ ≡ Ambient density ≡ 1.2 kg/m³

Factor to 9.1 ()^{1/3} = 25.0 K m^{5/3} kW^{-2/3}

\dot{Q}_c ≡ Convective heat release rate (kW)

z ≡ Elevation of Interest

z_o ≡ Virtual Origin = $-1.02D + 0.083 \dot{Q}_T^{2/5}$

D ≡ Effective Diameter (m)

\dot{Q}_T ≡ **Total** Heat Release Rate (kW)

49A Temperature of Smoke in a Plume

(NFPA 92 A.5.5.5.b)

$$T = T_\infty + \dot{Q}_c^{0.6} / \dot{m} c_p$$

T ≡ Temperature of Smoke in Plume (F)

T_∞ ≡ Ambient temperature (F)

\dot{Q}_c ≡ Convective heat release rate (kW or Btu/s)

\dot{m} ≡ Mass Flow Rate of Plume (kW/s or lb/s)

c_p ≡ Specific heat of air at constant pressure (1 kJ/kg-K or 0.24 Btu/lb-°F)

50 Plume Radius to point where temperature rise has declined to 0.5ΔT_O

(HFPE 2-7)

$$b_{\Delta T} = 0.12 \left(\frac{T_O}{T_\infty} \right)^{1/2} (z - z_o)$$

$b_{\Delta T}$ ≡ Plume radius (m)

T_O ≡ Centerline Temperature (K)

T_∞ ≡ Ambient temperature (K) ≡ 293 K

z ≡ Elevation above fire source

z_o ≡ Elevation of virtual origin (m)

51 Plume Centerline Velocity

(HFPE 2-7)

$$u_o = 3.4 \left(\frac{g}{c_p \rho_\infty T_\infty} \right)^{1/3} \dot{Q}_c^{1/3} (z - z_o)^{-1/3}$$

u_o ≡ Mean Axial Velocity

Factor to 3.4 ()^{1/3} = 1.03 m^{4/3} s⁻¹ kW^{-1/3}

\dot{Q}_c ≡ Convective heat release rate (kW)

g ≡ Gravity ≡ 9.81 m/s²

T_∞ ≡ Ambient temperature (K) ≡ 273.16 K

c_p ≡ Specific heat of air at constant pressure ≡ 1 kJ/kg K

ρ_∞ ≡ Ambient density ≡ 1.18 kg/m³

z_o ≡ Virtual Origin

z ≡ Elevation of Interest

52 Weak Plume Driven Temperature of Ceiling Jet

(HFPE 2-22; FPH 3-129 & 3-160)

$$T_{max} - T_\infty = 16.9 \frac{\dot{Q}_c^{2/3}}{H^{5/3}} \text{ for } r/H \leq 0.18$$

$$T_{max} - T_\infty = 5.38 \frac{(\dot{Q}_c/r)^{2/3}}{H} \text{ for } r/H > 0.18$$

T_{max} ≡ Maximum temperature (°C)

T_∞ ≡ Ambient temperature (°C)

\dot{Q}_c ≡ Either convective or total heat release rate (kW)

r ≡ Radial distance from plume centerline (m)

52A Weak Plume Driven Velocity of Ceiling Jet

(HFPE 2-22; FPH 3-129 & 3-160)

$$U_{plume} = 0.96 \left(\frac{\dot{Q}_c}{H} \right)^{1/3} \text{ for } r/H \leq 0.15$$

$$U_{jet} = 0.195 \frac{(\dot{Q}_c/H)^{1/3}}{(r/H)^{5/6}} \text{ for } r/H > 0.15$$

U_{plume} ≡ Maximum ceiling jet gas velocity near the plume impingement point (m/s)

U_{jet} ≡ Maximum ceiling jet gas velocity (m/s)

\dot{Q}_c ≡ Either convective or total heat release rate (kW)

H ≡ Distance from fire source to the ceiling (m)

r ≡ Radial distance from plume centerline (m)

53 Height of 1st Indication of Smoke for Steady Fires

(HFPE 4-392; NFPA 92 5.4.2.1)

$$\frac{z}{H} = 0.67 - 0.28 \ln \left(\frac{t \dot{Q}^{1/3} / H^{4/3}}{A / H^2} \right)$$

Note: For SI Units, use 1.11 instead of 0.67

z ≡ Height of first indication of smoke above the base of the fire (ft)
 H ≡ Ceiling height above the fire surface (ft)
 t ≡ Time (sec)
 \dot{Q} ≡ Heat release rate from steady fire (Btu/s)
 A ≡ Cross-sectional area (length*width) of the space being filled with smoke (ft²) and A / H^2 is the aspect ratio

54 Height of First Indication of Smoke for Unsteady (or Growing) Fires
(HFPE 4-392; NFPA 92 5.4.2.2)

$$\frac{z}{H} = 0.23 \left(\frac{t}{t_g^{2/5} H^{4/5} \left(\frac{A}{H^2}\right)^{3/5}} \right)^{-1.45}$$

OR


$$t = t_g^{2/5} H^{4/5} \left(\frac{A}{H^2}\right)^{3/5} 1.45 \sqrt{\frac{0.23H}{z}}$$

Note: For SI Units, use 0.91 instead of 0.23
 z ≡ Height of first indication of smoke above fire surface (ft)
 H ≡ Ceiling height above the surface (ft)
 t ≡ Time (sec)
 t_g ≡ Growth Time (sec) (time for fire to reach 1000 Btu/s or 1055 kW) (NFPA 92 Table B.4.2(b); HFPE 4-13; FPH 18-62)
 A ≡ Cross-sectional area of smoke filled space (ft²)


55 Height of Flame Tip
(NFPA 92 5.5.1.1)

$z_l = 0.533 \dot{Q}_c^{2/5}$
 z_l ≡ Limiting elevation (ft)
 \dot{Q}_c ≡ Convection portion of heat release rate (Btu/sec)

56 Mass Flow Rate if $H > z_l$
(NFPA 91 5.5.1.1; FPH 18-65)

$$\dot{m} = \left[0.022 \dot{Q}_c^{1/3} z^{5/3} \right] + 0.0042 \dot{Q}_c \text{ for: } $$

\dot{m} ≡ Mass flow rate of plume at height z (lb/sec)
 \dot{Q}_c ≡ Convection portion of heat release rate (Btu/sec)
 z ≡ Height **above** the fuel (ft)



Use FPH 18-65(13) for:

57 Volumetric Flow Rate
(NFPA 92 5.7)

$\dot{V} = 60 \dot{m} / \rho$
 \dot{V} ≡ Volumetric flow rate (ft³/min)

\dot{m} ≡ Mass flow rate of plume at height z (lb/sec)
 ρ ≡ Density of air (0.075 lb/ft³)

58 Density of Smoke
(NFPA 92.5.8)

$$\frac{\rho_{smoke}}{\rho_o} = \frac{528}{460 + T}$$

ρ_o ≡ Density of air (0.075 lb/ft³)
 ρ_{smoke} ≡ Density of smoke at Temperature T (lb/ft³)
 T ≡ Temperature of smoke (°F)

59 Average Temperature of Fire Plume
(FPH 18-45; NFPA 92 5.5.5 & A.5.5.5)

$$T_p = T_o + \frac{\dot{Q}_c}{\dot{m} C_p}$$

T_p ≡ Average plume temperature at elevation z (°F)
 T_o ≡ Ambient temperature (°F)
 \dot{Q}_c ≡ Convection portion of heat release rate (Btu/sec)
 \dot{m} ≡ Mass flow rate of plume at height z (lb/sec)
 C_p ≡ Specific heat of plume gases (0.24 Btu/lb-°F)

60 Average Mass Flow Rate of Fire Plume
(FPH 18-65)

$$\dot{m}_p = \left(\frac{\rho_o^2 g}{2} \right)^{1/2} A_v d^{1/2}$$

\dot{m}_p ≡ Mass flow rate of the plume (lb/sec)
 ρ_o ≡ Density of air (0.075 lb/ft³)
 g ≡ Acceleration of gravity (32.2 ft/sec²)
 A_v ≡ Aerodynamic vent area (ft²)
 d ≡ Depth of the smoke layer (ft)

61 Maximum Flow Rate to Avoid Plugholing
(FPH 18-65; NFPA 92 5.6.9)

$$\dot{m}_{max} = 0.354 \beta d^{5/2} \left[\frac{T_s - T_o}{T_s} \right]^{1/2} \left[\frac{T_o}{T_s} \right]^{1/2}$$

\dot{m}_{max} ≡ Maximum mass rate of exhaust without plugholing (lb/sec)
 β ≡ Exhaust location (Dimensionless)
 d ≡ Depth of smoke layer below the exhaust inlet (ft)
 T_s ≡ Absolute temperature of smoke layer (°R)
 T_o ≡ Absolute temperature of ambient layer (°R)

This equation is no longer in NFPA 92B. NFPA 92B now gives equation for volumetric flow rate

$$\dot{V}_{max} = 452 \gamma d^{5/2} \left(\frac{T_s - T_o}{T_o} \right)^{1/2} \text{ (NFPA 92.5.6.3)}$$

\dot{V}_{max} ≡ Maximum volumetric flow rate without plugholing at T_s (ft³/min)

γ ≡ Exhaust location factor (Per NFPA 92 5.6.4 thru 5.6.6 γ is: 1 for exhaust inlets centered no closer than twice the diameter from the nearest wall; 0.5 for exhaust inlets centered less than twice the diameter from the nearest wall; 0.5 for exhaust inlets on a wall)

d ≡ Depth of smoke layer below the lowest point of the exhaust inlet (ft)

T_s ≡ Absolute temperature of smoke layer (R)

T_o ≡ Absolute temperature of ambient layer (R)

62 Required Opposed Airflow for Smoke Control (NFPA 92 5.10)

$$v_e = 38 \left(gH \frac{\{T_f + 460\} - \{T_o + 460\}}{\{T_f + 460\}} \right)^{1/2}$$

v_e ≡ Limiting air velocity (ft/min)

g ≡ Acceleration of gravity (32.2 ft/sec²)

H ≡ Height of the opening as measured from the bottom of the opening (ft)

T_f ≡ Temperature of heated smoke (°F) (Converted to R)

T_o ≡ Temperature of ambient air (°F) (Converted to R)

63 Limiting Average Velocity through Communicating Space

(NFPA 92 5.10.2; HFPE 4-372)

$$v_e = 17 \left(\frac{\dot{Q}}{z} \right)^{1/3}$$

v_e ≡ Limiting air velocity (ft/min)

\dot{Q} ≡ Heat release rate of fire (Btu/sec)

z ≡ Distance above the base of the fire to the bottom of the opening (ft)

64 Vented Fire Smoke Layer Temperature Change

$$\Delta T = [60(1 - x_1)\dot{Q}_c] / (\rho_o c_p \dot{V})$$

ΔT ≡ Temperature rise in smoke layer (°F)

x_1 ≡ Total heat loss factor from smoke layer to atrium boundaries (assume maximum temperature rise will occur ∴ $x_1 = 0$)

$\dot{Q}_c = 0.7\dot{Q}_T$ ≡ Convective heat release rate (Btu/sec)

ρ_o ≡ Density of ambient air (0.075 lb/ft³)

c_p ≡ Specific heat of ambient air (0.241 Btu/lb-°F)

\dot{V} ≡ Volumetric vent rate (ft³/min)

65 Atrium ASET

(NFPA 92 5.4.2.2b)

$$z/H = 0.91 \left[t * t_g^{-2/5} * H^{-4/5} * \left(\frac{A}{H^2} \right)^{-3/5} \right]^{-1.45}$$

t ≡ time (s)

t_g ≡ time growth (s) NFPA 92 Table B.5.2(b)

H ≡ Atrium Height (m)

A ≡ Atrium Area (m²)

z ≡ Critical layer height (m)

66 Smoke Flow Across an Opening /Pressurization (HFPE 4-373)

$$\dot{V} = CA \sqrt{\frac{2\Delta P}{\rho}}$$

\dot{V} ≡ Volumetric Airflow Rate (CFM)

C ≡ Flow coefficient (0.65)

A ≡ Flow area (also leakage area) (ft²)

ΔP ≡ Pressure difference across flow path (in H₂O)

ρ ≡ Density of air entering the flow path (lb/ft³)

$$\dot{V} = K_f A \sqrt{\Delta P}$$

\dot{V} ≡ Volumetric Airflow Rate (CFM)

K_f ≡ Flow coefficient (2610)

A ≡ Flow area (ft²)

ΔP ≡ Pressure difference across flow path (in H₂O)

67 Stack Effect/Bouyancy

(HFPE 3-369; FPH 18-48)

$$\Delta P = K_S \left(\frac{1}{T_o} - \frac{1}{T_i} \right) h$$

ΔP ≡ Pressure difference (in H₂O)

K_S ≡ Coefficient (7.64) [3460]

T_o ≡ **Absolute** temperature of outside air (R) [K]

T_i ≡ **Absolute** temperature of inside air (R) [K]

h ≡ Distance above neutral plane (ft) [m]

68 Critical Airflow Velocity for Smoke Control

(HFPE pg 4-372)

$$v_k = K_v \left(\frac{\dot{Q}}{W} \right)^{1/3}$$

v_k ≡ Critical air velocity to prevent smoke backflow (fpm) [m/s]

\dot{Q} ≡ Heat release rate into corridor (Btu/s) [kW]

W ≡ Corridor width (ft) [m]

K_v ≡ Coefficient (86.9) [0.292]

69 Minimum Recommended Vent Area for Venting of Low-strength Enclosures from Gases, Gas Mixtures and Mists

(FPH pg 18-84)

$$A_v = \frac{C(A_s)}{(P_{red})^{1/2}}$$

A_v ≡ Minimum recommended vent area (sq ft)

C ≡ Fuel constant or venting parameter (psi^{1/2}) (NFPA 68 7.2.2.1)

A_s ≡ Internal surface area of enclosure including floor, roof and all walls (sq ft)

P_{red} ≡ Maximum pressure to be attained during vented deflagration (psi)

For $PSI^{1/2}$

$$C = (6.1 \times 10^{-5})(S_u^2) + (6.1 \times 10^{-4})(S_u) + 0.0416$$

For $\text{bar}^{1/2}$

$$C = (1.57 \times 10^{-5})(S_u^2) + (1.57 \times 10^{-4})(S_u + 0.0109)$$

$C \equiv$ Fuel constant or venting parameter ($\text{psi}^{1/2}$) (NFPA 68 7.2.2.1)

$S_u \equiv$ Fuel fundamental burning velocity (cm/s) [Has to be less than 60 cm/s. Can be found in NFPA 68 Table D.1(a) pg 68-61 or FPH Table 18.6.3 pg 18-82]

70 Column Substitution

(HFPE 4-308)

$$h_1 = \left(\frac{W_2/D_2 + 0.6}{W_1/D_1 + 0.6} \right) h_2$$

$h \equiv$ Thickness of spray-applied fire protection (in)

$W \equiv$ Weight of steel beam (lb/ft)

$D \equiv$ Heated perimeter of steel beam (see Fig. 4-11.11 HFPE 4-308)

1 \equiv Substitute beam and required protection thickness

2 \equiv The beam and protection thickness specified in the referenced tested design or tested assembly

71 Venting One End of Elongated Enclosure

$$L_3 \leq 12 A/p$$

$L_3 \equiv$ Longest dimension of the enclosure (ft)

$A \equiv$ Cross-sectional area through which the burning mixture must vent (ft^2)

$p \equiv$ Perimeter of that cross section (ft)

For highly turbulent gas mixtures, the length to diameter ratio should not exceed 2:

$$L_3 \leq 8 A/p \text{ (NFPA 68 7.2.3.4)}$$

72 Minimum P_{red} for Non-Relieving Wall Construction

$$\text{Minimum } P_{red} = P_{stat} + 0.024 \text{ bar (or 50 psf or 0.35 psig)}$$

73 Vent Area for High-Strength Enclosures

(FPH 18-85)

$$D = 2 \left(\frac{A^*}{\pi} \right)^{1/2}$$

$D \equiv$ Equivalent diameter (ft)

$A^* \equiv$ Cross-sectional area normal to the longest dimension (ft^2)

For $L/D \leq 2$ and volume $\leq 1000 \text{ m}^3$, then

$$A_v = [(0.127 \log_{10} K_G - 0.0567) P_{red}^{-0.582} + 0.175 P_{red}^{-0.572} (P_{stat} - 0.1)] V^{2/3}$$

$A_v \equiv$ Vent area (m^2)

$K_G \equiv$ Deflagration index of gas (bar-m/sec) ≤ 550

$P_{red} \equiv 2 \text{ bar}$ and at least 0.05 bar greater than P_{stat}

$P_{stat} \equiv \leq 0.5 \text{ bar}$

$V \equiv$ Enclosure volume (m^3)

If L/D between 2 and 5 and P_{red} is no greater than 2.0 bar, additional vent area must be added to A_v

$$\Delta A = \frac{A_v K_G [(L/D) - 2]^2}{750}$$

Final $A_v = \Delta A + A_v$

74 Effects of Vent Ducts (Non-cubical Vessels)

$$\text{If } L < 3 \text{ m} \therefore P'_{red} = 0.779 (P_{red})^{1.161}$$

$$\text{If } L > 3 \text{ m} \therefore P'_{red} = 0.172 (P_{red})^{1.963}$$

75 Effects of Vent Ducts (Cubical Vessels)

$$\frac{P_{red}''}{P_{red}'} = 1 + \left[17.3 \left(\frac{A_v}{V^{0.753}} \right)^{1.6} \frac{L}{D} \right]$$

P_{red}'' ≡ Pressure during a vented deflagration with the vent duct in place (bar)

P_{red}' ≡ Pressure during a vented deflagration without the vent duct (bar)

A_v ≡ Vent area (m²)

V ≡ Enclosure volume (m³)

L ≡ Duct length (m)

D ≡ Equivalent diameter of the vent duct (m)

76 Venting of Deflagrations of Dusts and Hybrid Mixtures

(FPH pg 18-86)

$$A_{v0} = .0001 \left(1 + 1.54 P_{stat}^{\frac{4}{3}} \right) K_{st} V^{\frac{3}{4}} \sqrt{\frac{P_{max}}{P_{red}}} - 1$$

A_{v0} ≡ Vent area (m²)

P_{stat} ≡ Nominal static burst pressure of vent (bar)

K_{st} ≡ Deflagration index (bar-m/sec)

V ≡ Enclosure volume (m³)

P_{max} ≡ Maximum pressure of deflagration (bar)

P_{red} ≡ Reduced pressure after deflagration (bar)

Equation is valid for the following:

- 1) 5 bar ≤ P_{max} ≤ 12 bar
- 2) 10 bar-m/sec ≤ K_{st} ≤ 800 bar-m/sec
- 3) 0.1 m³ ≤ V ≤ 10,000 m³
- 4) P_{stat} ≤ 0.75 bar

When L/D is ≤ 2, A_{v1} shall be set equal to A_{v0}

For $2 \leq L/D \leq 6$, A_{v1} shall be calculated as:

$$A_{v1} = A_{v0} \left[1 + 0.6 \left(\frac{L}{D} - 2 \right)^{0.75} \exp(-0.95 P_{red}^2) \right]$$

77 Partial Volume Deflagrations

$$A_{vpp} = A_{v0} X_r^{-1/3} \left[\frac{\left(X_r - \frac{P_{red}}{P_{max}} \right)}{\left(1 - \frac{P_{red}}{P_{max}} \right)} \right]^{1/2}$$

A_{vpp} ≡ Required vent area for the PVD (m²)

A_{v0} ≡ Required vent area for the entire enclosure if filled with an ignitable mixture (m²)

X_r ≡ Fill fraction at the time of the PVD

P_{max} ≡ Maximum pressure of deflagration (bar)

P_{red} ≡ Reduced pressure after deflagration (bar)

Π ≡ P_{red}/P_{max}

78 Column Resistive Rating

(FPH 19-38; HFPE 4-306)

$$R = [C_1(W/D) + C_2]h$$

R ≡ Fire resistance period (min)

C_1 and C_2 ≡ Material dependent constants determined by ASTM E119 test

W ≡ Mass of steel shape (lbs/ft)

D ≡ Heated perimeter of column (in) from Green book pg 494 (remember to use 3 sides for beam and 4 sides for column)

h ≡ Thickness of the coating (in)

79 Vent Area Threshold Mass

(FPH 18-85)

$$m_T = \left[6.67(P_{red}^2)(n^{0.3}) \left(\frac{V}{K_{St}^{0.5}} \right) \right]^{1.67}$$

m_T ≡ Threshold mass (kg/m²)

P_{red} ≡ Reduced pressure after deflagration (bar)

n ≡ Number of panels

V ≡ Enclosure volume (m³)

K_{St} ≡ Deflagration index (bar-m/sec)

80 Time Value of Money

$$P \left(\frac{1 - (1 + I/100)^{-N}}{I/100} \right) + F_v(1 + I/100)^{-N} + P_v = 0$$

P ≡ Payment

F_v ≡ Future Value

P_v ≡ Present Value

I ≡ Interest Rate (%)

Note: This will yield negative numbers for at least one result due to that number being a value that is paid.

Heat Release Rates FPH 3-148

- Also NFPA 92 Table B.5.2.(b) and NFPA 72 Table B.2.3.2/6.2(a-e)
- 5 kW/ m² for a person to get burned in 13 sec on bare skin, 40 sec for 2nd degree burn (HFPE pg 3-310 & 3-309)
- Skin Burns (HFPE pg 2-146 & 3-314)
 - 1st Degree 1.33-1.667 kW/m² (41.8 kJ/m²)
 - 2nd Degree 4-12.17 kW/m² (83.6 kJ/m²)
 - 3rd Degree 16.67 kW/ m² (162.2 kJ/m²)
- NFPA 92 Table B.5.2.(b) for T² fire growth rates
 - Ultra Fast t_g = 75
 - Fast t_g = 150
 - Medium t_g = 300
 - Slow t_g = 600

Flashover is at 20 kW/m² or 500 - 600°C (FPH 3-150)

ASET ≡ Available Safe Egress Time

RSET ≡ Required Safe Evacuation (Egress) Time

Fire Extinguisher Ratings (FPH 17-72):

- **Class A** – Fires in ordinary combustibles, such as wood, cloth, paper, rubber and many plastics.
- **Class B** – Fires in flammable liquids, combustible liquids, petroleum greases, tars, oils, oil-based paints, solvents, lacquers, alcohols and flammable gases.
- **Class C** – Fires that involve energized electrical equipment.
- **Class D** – Fires in combustible metals, such as magnesium, titanium, zirconium, sodium, lithium, and potassium.
- **Class K** – Fires in cooking appliances that involve combustible cooking media (vegetable or animal oils and fats).

Fire Pumps:

- Can be rated at 150% of flow capacity @ 65% of rated head (NFPA 20 4.8.1 & 6.2; FPH 15-96)
 -
- NFPA 20 A.14.2.6.4 for fire pump controller operation
- NFPA 20 A.11.4.2 fuel for 8 hrs operation
- NFPA 20 11.4.2 for diesel fuel tank capacity
- NFPA 24 for Thrust Blocks 10.8.1.; 10.8.2; A.10.8.2
- Fire Hydrant Marking is found in NFPA 24 Annex D

Sprinkler Systems:

1. Determine sprinkler density per occupancy hazard classification
2. Add hose demand

3. If dry pipe system, add 30% to required area (NFPA 13 11.2.3.2.5)
4. Make adjustment for storage height
5. Make adjustments if high temperature heads are used (NFPA 13 11.2.3.2.6)
6. From type of sprinkler, determine maximum area of sprinkler head and spacing
7. Use NFPA 30 for special occupancies
8. Number of sprinklers on a branch =
$$\frac{1.2\sqrt{\text{Sprinkler Area}}}{\text{Distance between heads}}$$
9. Make adjustments for QR heads (NFPA 13 11.2.3.2.3)

Fire Alarm (NFPA 72):

- A. Supervisory Signals – NFPA 72 10.14
- B. Trouble Signals – NFPA 72 10.15
- C. Off-Premises Monitoring – NFPA 72 10.19

Circuit Classification (NFPA 72 12.3)

- Class A circuits are more reliable since it remains operational during a single open or single ground fault.
- Class B circuits are less reliable since it remains only operational up to the location of the open fault.

NFPA 72 17.7.3 for Spacing Requirements

Venting Deflagrations:

- FPH 18-85 recommends vent mass no greater than 12.2 kb/m² (2.5 lb/ft²)

1 W = 1J/s 1 kW = 1 kJ/s 1 MW = 1 MJ/s

Conversions:

- Rankin: $t_R = t_F + 459.69$
- Kelvin: $t_K = t_C + 273.16$
- Feet: 1 ft = 0.3048 m = 30.48 cm
- Meter: 1 m = 3.28084 ft
- Gallon: 1 Gallon = 3.785412 Liters
- Square Feet: $1 \text{ ft}^2 = 0.092903 \text{ m}^2$
- Kilogram: 1 kg = 2.204623 lbs
- Kilowatts: 1 kW = 1055.87 Btu/s
- Psi: 1 psi = 2.317 feet of head
- Feet of Head: 1 ft of hd = 0.433 psi

Water Density (ρ):

Egress/Behavior in Smoke

(HFPE 3-321-478; FPH Chapter 4)

Evacuation Time Predictions

(HFPE 3-381; FPH 4-60)

Evacuation Speed of Disabled Persons

(HFPE 3-369; FPH 4-38 & 4-56)

8.34 lbs/gal

7.48 gal/ft³

62.4 lbs/ft³

Volume of a pipe: $V = 0.25\pi D^2 L$

1 Pa (Pascal) = 1 N/m² = 1 J/m³ = 1 kg/(m*s²)

Sound Pressure \equiv Pa; Sound Intensity \equiv W/m²

Threshold of hearing \equiv 0 dB \equiv 0.00002 Pa \equiv 1×10^{-12} W/m²

120dB = 20 Pa = 1 W/m²